



Energy+Environmental Economics

Contextualizing Need in + Step 2 of the CAISO's LTPP Analysis

February 10, 2012

Arne Olson, Partner
Nick Schlag, Consultant



Agenda

1. Context for “Need” Resulting from CAISO Analysis
2. Drill down into need result from All-Gas Case
3. Lessons learned from “Deep Dive” analysis



Context for Need Results of Step 2 Analysis



Framework of Integration Analysis

- + **The “Vintage” (2009) cases from the CAISO Integration Analysis were built to the 15-17% planning reserve margin before being simulated in PLEXOS to determine integration need**
 - All need for new capacity above PRM was described as “integration need” — need above a threshold that has served as an adequate margin in traditional capacity planning
- + **The adaptation of the CAISO Integration Analysis for use in the CPUC LTPP process relaxed the assumption that the simulated system was built to meet PRM exactly**
 - Instead, the CPUC cases modeled the large capacity surplus expected with the achievement of the 33% RPS
- + **In order to rationalize the seemingly counterintuitive results of the All Gas case (1,400 MW need) and the renewable cases (no need), the results need to be reframed:**
 - What are the main drivers of need in the CPUC cases?
 - What does “need” actually mean in the All-Gas case?



Methodology

- + This analysis uses a “constrained hour” approach to focus on system operations during the hours when the system is pushing its limits
- + Constrained hours are identified as the 50 hours in the year in which the system’s use of flexible resources is the highest
 - These are meant to capture the hours most likely to drive need

Net Load Approach to Flexibility Requirement	
	Load
-	Baseload & RPS generation
+	Upward A/S requirements
+	Load following up requirement
=	System Flexibility Requirement

=

Flexibility Requirement Based on Supply Side Resources	
	Generation by flexible resources
+	Imports
+	Upward A/S provision
+	Load following up provision
=	System Flexibility Requirement




Methodology

- + **One important caveat: this analysis are based on the results from the production cost runs—data already available from the LTPP analysis**
- + **Two important differences between the “need” and “cost” runs of PLEXOS under current methodology**
 - Need run uses monthly max LF and Reg requirements for each hour; cost run uses daily requirements
 - Cost run includes the generic gas CTs that are needed to resolve violations in the need run
- + **Additionally, this approach classifies resources as they are used—not as available—to meet peak period requirements**
- + **Because of these differences, we cannot pinpoint the exact causes of need in the hours in which they occur, but the constrained hour approach is still useful to reconcile PLEXOS results with the PRM calculation and to understand drivers of need**




CAISO Renewable Resource Capacity by Scenario






Effect of Solar on Daily Load Shape





CAISO Resource Utilization in Peak Load Hour




Load is identical in each of the cases, but the utilization of flexible resources used to serve load varies dramatically as a result of RPS generation

	Trajectory	Environmental	Cost	Time	AllGas
Total	56,328	56,479	56,489	56,432	55,077
RegUp	655	646	644	634	545
NonSpin	1,555	1,555	1,555	1,555	1,525
Spin	1,555	1,555	1,555	1,555	1,525
LFU	1,700	1,859	1,871	1,825	1,635
Imports	9,499	7,630	8,885	9,118	9,048
Flex Gen	24,934	23,468	26,357	26,470	28,646
RPS Gen	8,212	11,549	7,405	7,058	3,937
Baseload Gen	8,217	8,217	8,217	8,217	8,217




CAISO Resource Utilization in Constrained Hours





CAISO Flexible Resource Utilization in Constrained Hours



Largest difference between cases is the amount of flexible capacity use to serve load—not the change in A/S requirements



Breakdown of Differences – Environmental vs. All-Gas

Component	Environmental Case	All-Gas Case	Difference
Load	46,430	48,141	1,711
- Baseload Generation	(9,018)	(9,012)	6
- RPS/CSI Generation	(7,853)	(3,687)	4,166
+ Contingency Reserves	2,786	2,888	103
+ Regulation Up	672	619	(53)
+ Load Following Up	1,967	1,616	(351)
= Flexibility Requirement	34,984	40,565	5,581

High solar penetration pushes constrained hours off the peak period in the environmental case

Low RPS penetration in the All-Gas case results in much less RPS generation during constraints

Regulation and load following requirements are slightly higher in the Environmental case, driven by the higher penetration of intermittent resources

Table shows average requirements and resource performance over the top 50 constrained hours



System Need for New Resources

- + **The resulting need in the All-Gas case is better described as “system need”**
 - The primary distinction between the All-Gas case and the other four is its net load—**not** its ancillary services requirements
- + **The variations in net load are substantially larger than the variations in ancillary services requirements—which suggests that two questions are key to forward-looking capacity planning:**
 1. How high are loads expected to be?
 2. How much renewable generation can be counted on to offset peak loads?
- + **Both of these questions lend themselves to more robust analysis through a probabilistic, LOLP-type analysis**

Summary of Flexible Resource Use during Constrained Hours


Scenario	Net Load ¹ [MW]	Total A/S Requirement ² [MW]
Trajectory	31,146	5,585
Environmental	29,559	5,425
Cost	32,115	5,506
Time	32,233	5,475
All Gas	35,442	5,123

¹ Sum of CAISO flexible generation and imports

² Sum of load following up, regulation up, and spinning & non-spinning reserves




RPS Resources: Assumptions vs. Performance



PLEXOS: actual average resource performance during 50 constrained hours of simulation
CPUC PRM: deemed (or assumed) NOC value of resources used in PRM calculation



Timing of Constraints



Adding solar resources to the system *expands* the range of hours over which the system is constrained




Drill-Down into All Gas Case Need Results



Conflicting Results from the All-Gas Case

- + Using assumptions specified by the CPUC, the All-Gas case showed a reserve margin of **39%** before the PLEXOS need analysis
- + When modeled in PLEXOS, the All-Gas case required **1,400MW** of additional capacity to resolve operational violations, bringing its reserve margin to **41%**
- + With a low penetration of RPS resources, there should not be such a large gap between the two methodologies for resource adequacy



Based on LTPP assumptions



Constrained Hours in the All Gas Case

- + Because of the low penetration of renewables in the All Gas case, constraints within the CAISO are almost entirely load-driven**
 - The 50 most constrained hours all occur within the 75 hours of highest load
 - The upward load following violations occur as a result of the commitment of the system's flexible units to meet high loads in these hours
- + Focusing on the most constrained hour—the hour most likely driving need and in this case also the peak load hour—can help provide insight into the drivers of need**



Approximate PRM Based on Simulation Results

- + The PRM is a measure of the amount of capacity available at the time of system peak (without accounting for maintenance and outages)
- + Within this formulation, there are effectively two classes of resources:
 1. Resources whose capacity during peak is a known, fixed quantity (e.g. nuclear, natural gas)
 2. Resources whose capacity during peak is uncertain and varies based on external conditions (e.g. wind, solar, hydro, cogeneration)
- + The CPUC's methodology for the second category involves the calculation of a Net Qualifying Capacity by evaluating historical resource performance during a set window of hours
- + In order to approximate the PRM as modeled in these cases, the capacity of these resources to meet peak is calculated based on the performance of these resources during the most constrained hour of the year



PRM Summary – Resource Availability in the All-Gas Case

- + Accounting for all discrepancies between loads and resources as modeled in the All-Gas case in PLEXOS, the reserve margin of this case is slightly higher than 17%—though the surplus is not as large as calculated in the CPUC LTPP analysis
- + Load and imports represent the largest contributors to the disconnect between the two methodologies

	CAISO/ PLEXOS	CPUC Assumed NOC	Difference
Generation			
Nuclear ¹	4,486	4,486	-
Cogeneration ¹	4,282	4,274	(8)
Natural Gas ^{1,2}	24,541	24,552	11
Hydro/Pumped Storage ³	9,244	8,421	(823)
RPS ³	2,864	2,363	(357)
Other ³	123	822	699
Imports ³	9,610	16,955	6,806
Total Capacity	55,150	61,872	6,587
Load			
Peak Load	49,749	48,464	(1,285)
Demand Response ³	(4,287)	(4,818)	(531)
Net Peak	45,463	43,647	(1,815)
Reserve Margin			
Implied Reserve Margin	21.3%	41.8%	

¹ Based on rated capacity in PLEXOS

² Includes 1,400 MW of generic CTs added to resolve violations

³ Based on performance during the top constrained hour


* Numbers may not add due to rounding



Utilization of Resources during Peak Hour

+ During the peak load hour, **maintenance & outages** total nearly 3,900 MW

- 9% of peak load
- 12% of CAISO thermal generating capacity





Reframing Need in the All Gas Case

- + **As modeled in PLEXOS, the All-Gas case has a reserve margin much closer to the 17% requirement than suggested by the PRM calculation using CPUC assumptions**
- + **Given the input assumptions and methodology, a reserve margin requirement of 121% is not a surprising result**
 - The load-following requirement adds approximately 4% to the traditional reserves requirement during the All-Gas peak period
 - Maintenance & outages account for nine percentage points of the traditional 17% PRM requirement and are likely overstated during the peak in this study



Lessons Learned



Load

	Trajectory	High Load Case	Difference
Load during most constrained hour	51,619	55,697	4,088
Flexibility resources used	33,137	35,203	2,066

+ Conclusion: Need to consider the effect of alternative load growth assumptions and weather uncertainty



Imports

	Environment	All-Gas	Difference
Imports during most constrained hour	9,610	9,555	(55)
Assumed value in LTPP Case	16,955	16,955	-
Difference	7,345	7,400	

+ Conclusion: Need to consider the effect of imports on in-state need



Hydro Performance on Peak

	Environment	All-Gas	Difference
Hydro MW during most constrained hours	7,459	7,459	-
NQC MW	6,524	6,524	-
Difference	(935)	(935)	

+ Conclusion: Need to consider the effect of hydro availability on need for new resources



Renewable Performance on Peak

	Environment	All-Gas	Difference
RPS MW during peak load hour	10,476	2,864	(7,612)
NQC MW	5,578	2,363	(3,215)
Difference	(4,898)	(501)	

+ Conclusion: Need a robust estimate of the dependable production of renewable resources during peak load hours



Timing of Renewable Production

	Environment	All-Gas	Difference
Peak load	51,838	50,823	(1,015)
Load during most constrained hour	51,619	50,823	(796)
Difference	(219)	-	

+ Conclusion: Need to consider the timing effect of renewable production on need for new resources



Shifting the Focus to Stochastic Analysis

+ Need in CAISO's methodology is sensitive to many factors besides variable energy resource (VER) integration requirements

- Load
- Imports
- Hydro production levels
- Renewable resource production during critical hours

All of these factors are bigger drivers of need than flexibility requirements

+ These factors are traditionally addressed through a different type of analysis

- Reliability analysis focused on the potential for loss of load

+ Need to calibrate California's fleet based on these other factors before evaluating whether it has enough flexibility to accommodate VER



Energy+Environmental Economics

Thank You!

Energy and Environmental Economics, Inc. (E3)

101 Montgomery Street, Suite 1600

San Francisco, CA 94104

Tel 415-391-5100

Web <http://www.ethree.com>

Arne Olson, Partner (arne@ethree.com)

Nick Schlag, Consultant (nick@ethree.com)