

Subject: Comments on Draft 2010 ISO Transmission Plan and Draft Study Plan for 2011 ISO Transmission Plan

Submitted by

(name and phone number) Company or Entity Date Submitted

Ann Finley, 213-217-7136

Metropolitan Water District

March 2, 2010

Metropolitan Water District ("MWD") appreciates the opportunity to provide comments to the ISO on their Draft 2010 Transmission Plan and the Draft Study Plan for 2011 ISO Transmission Plan.

Draft Study Plan for 2011 ISO Transmission Plan

- MWD requests ISO add SCE's Eagle Mtn 230 and J. Hinds SCE 230 kV buses to the voltage stability and reactive power margin analyses listed on p. 18.
- MWD requests ISO correct the representation of the Blythe SPS on page 16 and in the contingency files on ISO's secure transmission planning website. The description on page 16 is incorrect for the 2011 timeframe and several of the contingency files are tripping three Blythe I units instead of one CT, which will mask potential overloads that may occur on SCE or MWD's transmission systems if not properly analyzed. Please contact David Franklin at SCE to obtain the proper representation of the Blythe SPS and contingency responses. Below is a listing of some of the contingency files that will need to be corrected:

<https://www.caiso.com/TPStudy/NonMktr/241f/241fc4952b870.con>

```
CONTINGENCY 19) line_2081      "DEVERS 230.00 -  
MIRAGE 230.00 1, J.HINDS 230.00 - MIRAGE 230.00 1"  
/* File SCEEasternBulk_v5.otg Line # 78
```

```
CONTINGENCY 24) line_2209      "Devers-Mirage 230 kV  
line & J.HINDS - Mirage 230 kV line "  
/* File SCEEasternBulk_v5.otg Line # 98
```

```
CONTINGENCY 26) line_2211      "Ramon-Mirage 230 kV
```

line & Julian Hinds-Mirage 230 kV line (summer)"
/* File SCEEasternBulk_v5.otg Line # 106
This outage actually commented out the tripping of the
Blythe Units.....please verify

CONTINGENCY 75) line_0025 "line J.HINDS to
MIRAGE 230 ck 1"
/* File SCEEasternBulk_v5.otg Line # 260
END

CONTINGENCY 76) line_0026 "line J.HINDS to
EAGLEMTN 230 ck 1"
/* File SCEEasternBulk_v5.otg Line # 263

If you have any questions, please contact me.

Regards,

Ann T. Finley

Program Manager

Metropolitan Water District of Southern California

Phone: 213-217-7136

Fax: 213-830-4550

afinley@mwdh2o.com