

A	B	C	D	E	F	G	H	I	J	K	L
DG Node		DG in Base Portfolio/ POU forecast	WDAT/Rule 21 non-NEM DG		Existing non-NEM DG		2023 Unassigned PDGD	Total Additional DG Modeled	Total DG Deliverable	2023-2024 PDGD	Notes
Substation Name	Transmission Level kV		EO	FC	EO	FC					
Alpaugh	115	3							0	0	12C1593-Midway 230kV area constraint fully allocated.
Arco	230	5							0	0	12C1593-Midway 230kV and Morro Bay 230kV area constraints are fully allocated
Bellevue	115	1							0	0	Delevan-500 kV and Contra Costa-Delta Pump (Windmaster-Delta Pump) 230 kV line (Bay Area Constraint) area constraints are fully allocated.
Carquinez	115	5							0	0	Delevan-500 kV and Contra Costa-Delta Pump (Windmaster-Delta Pump) 230 kV line (Bay Area Constraint) area constraints are fully allocated.
Contra Costa	230	1							0	0	Delevan-500 kV and Contra Costa-Delta Pump (Windmaster-Delta Pump) 230 kV line (Bay Area Constraint) area constraints are fully allocated.
Delta Switching Yard	230	8							0	0	Delevan-500 kV and Contra Costa-Delta Pump (Windmaster-Delta Pump) 230 kV line (Bay Area Constraint) area constraints are fully allocated.
Elk Hills	230	2							0	0	12C1593-Midway 230kV area constraint fully allocated.
Humboldt	115	2							0	0	Delevan 500kV area constraint fully allocated
Kearney	230	10							0	0	12C1593-Midway 230kV area constraint fully allocated.
Lamont	115	2							0	0	12C1593-Midway 230kV area constraint fully allocated.
Le Grand	115	3							0	0	12C1593-Midway 230kV area constraint fully allocated.
Lone Tree	230	1							0	0	Delevan-500 kV and Contra Costa-Delta Pump (Windmaster-Delta Pump) 230 kV line (Bay Area Constraint) area constraints are fully allocated.
Los Banos	230	1							0	0	Panoche-Gates 230 kV, 12C1593-Midway 230 kV area constraints fully allocated.
Los Esteros	115	5							0	0	Contra Costa-Delta Pump (Windmaster-Delta Pump) 230 kV line Area Constraint (Bay Area Constraint) fully are allocated.
Martin (San Francisco H)	115	8							0	0	Contra Costa-Delta Pump (Windmaster-Delta Pump) 230 kV line Area Constraint (Bay Area Constraint) fully are allocated
McCall	115	2							0	0	12C1593-Midway 230kV area constraint fully allocated
Merced	115	6							0	0	12C1593-Midway 230kV area constraint fully allocated
Metcalf	230	4							0	0	Contra Costa-Delta Pump (Windmaster-Delta Pump) 230 kV line (Bay Area Constraint) area constraint fully allocated.
Semitropic	115	10							0	0	12C1593-Midway 230kV area constraint fully allocated.
Shafter	115	3							0	0	12C1593-Midway 230kV area constraint fully allocated.
Table Mountain	115	3							0	0	Delevan 500kV area constraint fully allocated
Taft	115	3							0	0	12C1593-Midway 230kV area constraint fully allocated.
Tulucay	230	2							0	0	Contra Costa-Delta Pump (Windmaster-Delta Pump) 230 kV line (Bay Area Constraint) area constraint fully allocated.
Wheeler Ridge	115	2							0	0	12C1593-Midway 230kV area constraint fully allocated.