

Flexible Capacity Requirements for 2019 through 2021

Clyde Loutan - Principal, Renewable energy Integration

Amber Motley - Manager, Short Term Forecasting

Stakeholder Conference Call

January 29th, 2018

What's the purpose of this call?

- Discuss the criteria, methodology, and assumptions used in calculating monthly flexible capacity requirement.
- Calculate system requirements within the ISO footprint for RA compliance year 2019 and advisory flexible capacity requirements for compliance years 2020 and 2021
- Discuss the input assumptions and methodology of the annual CAISO's Availability Assessment Hour (AAH).

Agenda / Overview

- Background
- Process review
 - Expected build out from all LSEs (CPUC jurisdictional and non-Jurisdictional)
 - Load wind and solar profiles
 - Calculate 3-hour net-load ramps
 - Calculate monthly Flexible Capacity requirement
 - Add contingency reserves
 - Next steps

Flexible capacity requirements

CPUC decision on flexible capacity

2015 – The flexible capacity framework became mandatory starting with RA compliance year 2015. The adopted framework will be in effect through RA compliance year 2017

The CPUC's Decision (13-06-024 June 27, 2013) defines

“Flexible capacity need” as the quantity of resources needed by the California ISO to manage grid reliability during the greatest three-hour continuous ramp in each month.

Each LSE SC shall make a year-ahead and month-ahead showing of flexible capacity for each month of the compliance year

Resource Adequacy (RA)

- Ensure LSEs contract for adequate capacity to meet expected flexible needs
- Year ahead timeframe: LSEs need to secure a minimum of 90% of the next years monthly needs
- Month ahead timeframe: LSEs need to secure adequate net qualified capacity to serve their peak load including a planning reserve margin and flexible capacity to address largest three hour net load ramps plus contingency reserves
- All resources participating in the ISO markets under an RA contract will have an RA must-offer-obligation
- Required to submit economic bids into the ISO's real-time market consistent with the category of flexible capacity for which it is shown

The ISO flexibility capacity assessment is based on current LSE's RPS build-out data

- Uses the most current data available for renewable build-out obtained from all LSE SCs
- For new renewable installation scale 2017 actual production data based on installed capacity in subsequent years
- For new BTM use NEXANT production data located in close geographic proximity
- Generate net-load profiles for 2019 through 2021
 - Generate load profiles for 2019 through 2021
 - Generate solar profiles for 2019 through 2021
 - Generate wind profiles for 2019 through 2021

The ISO will use the CEC's 1-in-2 monthly peak load forecast to develop the load forecast

- Used 2017 actual 1-minute load data to build 1-minute load profiles for subsequent years
- Scaled the actual 1-minute load value of each month of 2017 using a load growth factor of monthly peak forecast divided by actual 2017 monthly peak

2018 Load Growth Assumptions

- Scale each 1-minute load data point of 2018 by the fraction $(\text{Monthly}_{2018_Peak_Load_Forecast} / \text{Monthly}_{2017_Actual_Peak_Load})$

2019 Load Growth Assumptions

- Scale the actual 1-minute load value of each month of 2017 by the fraction $(\text{Monthly}_{2019_Peak_Load_Forecast} / \text{Monthly}_{2018_Peak_Load_Forecast})$

*If provided by CEC; apply hourly AAEE to load growth

1-minute wind and solar data for all new CREZs would be developed using the methodology outlined below

TRACK I DIRECT TESTIMONY OF MARK ROTHLEDER ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR CORPORATION (Rulemaking 10-05-006)

Located at:

http://www.caiso.com/Documents/2011-08-10_ErrataLTPPTestimony_R10-05-006.pdf

Wind growth assumptions

- Use actual 1-minute wind production data for the most recent year
e.g. 2018 wind forecast uses actual production data from 2017
- Projects installed in 2017 would be modeled in 2018 for the months the projects were not yet in-service (e.g. projects installed in May 2017 would be included in January through April of 2018)
- Scale 1-minute data using expected capacity for the new plants scheduled to be operational in 2018
- Repeat the above steps for 2016

$$2018 W_{\text{Mth_Sim_1-min}} = 2017W_{\text{Act_1-min}} * 2018W_{\text{Mth Capacity}} / 2017W_{\text{Mth Capacity}}$$

$$2019 W_{\text{Mth_Sim_1-min}} = 2017W_{\text{Act_1-min}} * 2019W_{\text{Mth Capacity}} / 2017W_{\text{Mth Capacity}}$$

*Note: Maintain the load/wind correlation

Solar growth assumptions

Existing solar

- Use the actual solar 1-minute production data for the most recent year
e.g. 2018 forecast uses 2017 actual 1-minute data (**2017_{Act_1-min}**)

New solar installation

- Develop 1-minute solar production profiles by scaling actual 2017 1-minute data by the expected monthly installed capacity in 2018 divided by the monthly installed capacity in 2017
- Projects installed in 2017 will be modeled in 2018 for the months the projects were not yet in-service in 2017

$$\text{Total solar } 2018_{1\text{-min}} = 2017_{\text{Act_1-min}} * 2018_{\text{Monthly_Cap}} / 2017_{\text{Installed_Capacity}}$$


Net-load is a NERC accepted metric¹ for evaluating additional flexibility needs to accommodate VERs

- Net load is the aggregate of customer demand reduced by variable generation power output
- Net-load is more variable than load itself and it increases as VER production increases
- The monthly three-hour flexible capacity need equates to the largest up-ward change in net-load when looking across a rolling three-hour evaluation window
- The ISO dispatches flexible resources to meet net-load

1 NERC Special Report


Flexibility Report Requirements and metrics for Variable Generation: Implications for System Planning Studies, August 2010 . http://www.nerc.com/files/IVGTF_Task_1_4_Final.pdf

Net Load varies from one day to the next --- One week in March 2017




The monthly 3-hour ramping need is calculated using the largest ramp in each 180 minute period

- The maximum monthly three-hour net load ramp within a three-hour period is the highest MW value reached within any three-hour moving window
- The maximum net-load change in three-hours can occur in less than three hours



Upward Ramp = $\text{Average}(t+4 \text{ min}) \geq \text{Average}(t-4\text{min})$
Down Ramp = $\text{Average}(t+4\text{min}) < \text{Average}(t-4\text{min})$

Expected 3-hour ramps increase through 2020 with build out of renewables and addition of behind-the-meter resources



Note: 2017 actuals are still being analyzed, final number will be based on 2017 actuals.

Contingency reserves is a NERC/WECC requirement all BAs must have available in real-time

- Each Balancing Authority and each Reserve Sharing Group shall maintain a minimum amount of Contingency Reserve, except within the first sixty minutes following an event requiring the activation of Contingency Reserve
- To meet WECC and NERC reliability criteria, the ISO must have contingency reserves equal to the greater of:
 - 1) the most severe single contingency (“MSSC”)
 - 2) the sum of 3% of hourly integrated load plus 3% percent of hourly integrated generation
- 50% of the contingency reserve must be spinning reserve
- Contingencies can occur during the three hour ramps and the ISO must be prepared to dispatch contingency reserve to recover its Area Control Error (ACE) within 15-minutes following a disturbance
- Contingency reserves are held for contingency events and cannot be dispatched to meet day-to-day net-load ramps

For more information please refer to: WECC Standard BAL-002-WECC-2---Contingency Reserve

The proposed interim flexible capacity methodology should provide the ISO with sufficient flexible capacity

Methodology

$$\text{Flexible Req}_{MTH_y} = \text{Max}[(3RR_{HR_x})_{MTH_y}] + \text{Max}(\text{MSSC}, 3.5\% * E(\text{PL}_{MTH_y})) + \epsilon$$

Where:

$\text{Max}[(3RR_{HR_x})_{MTH_y}]$ = Largest three hour contiguous ramp starting in hour x for month y

$E(\text{PL})$ = Expected peak load

MTH_y = Month y

MSSC = Most Severe Single Contingency

ϵ = Annually adjustable error term to account for load forecast errors and variability. ϵ is currently set at zero

What data does the ISO need?

- CEC's monthly demand forecast (e.g. 2018 – 2021 demand forecast by Feb 19, 2018)
- LSE SCs to update renewable build-out for 2017 through 2022 by CREZ by February 19, 2018 (Beyond 2022 if data is available)
- The data should include:
 - Installed capacity by technology and expected operating date (e.g. Solar thermal, solar PV tracking, solar PV non-tracking, estimate of behind-the-meter solar PV etc.) for all variable energy resources under contract
 - Operational date or expected on-line date
 - Location of CREZ preferably latitude and longitude coordinates
 - Interconnecting substation or closes substation or switching station
 - Resources located outside ISO's BAA must indicate if the resources are dynamically scheduled or not
- All LSE SCs have already provided this data
 - LSE SCs must submit data for all LSE for which they are the SC
 - ISO is in the process of reviewing the submittal

ANNUAL REVIEW OF AVAILABILITY ASSESSMENT HOURS

Methodology Overview of System/Local Availability Assessment Hours

- Used data described in previous slides to obtain:
 - Hourly Average Load
 - By Hour
 - By Month
 - Years 2017-2021
- Calculated:
 - Top 5% of Load Hours within each month using an hourly load distribution
 - Years 2017 through 2021

Next steps

- ISO published a market notice for data December, 2017
- ISO assumptions phone call by January 29th, 2018
- Stakeholder comments on ISO study assumptions due by February 9th, 2018
- Finalize methodology, criteria, and assumptions for 2019 flexible requirements by February 15th, 2018
- Complete data collection from LSE SC's and CEC by **March 15th, 2018**
- Publish draft flexible capacity requirement for 2019, 2020 & 2021 by **April 13th, 2018**
- Stakeholder comments on draft flexible capacity requirements due by **April 19th, 2018**
- Issue final Flexible Capacity requirement for 2019, 2020 & 2021 by **approximately May 15th, 2018**
- CPUC proposed and final annual RA decision incorporating FCR obligations **June 2018**

Note: Dates in red approximate due to ISO receiving load data from CEC no later than March 15th, 2018.

Questions?

Please submit comments on the assumptions to

initiativecomments@caiso.com

by February 9th, 2018

Thank you for your participation!



Questions