

Lockeford-Lodi Area 230 kV Development Project (2/2)

Revised Scope:

- Current need: P 1 voltage and P6 thermal
- Loop-in the Brighton – Bellota 230 kV line into Lockeford substation.
- Approximately 6 miles of double-circuit 230 kV line from Lockeford to a new Industrial 230 kV substation.
- 2017-2018 TPP estimated cost: \$95 million
- In-service Date: 2023

