

that result from utilizing a clustered SIS or risking noncompliance with its existing LGIP tariff authority.

The Commission has granted requests for waiver of tariff provisions in cases where the moving party has shown: (1) the waiver was of limited scope; (2) a concrete problem needed to be remedied; (3) the waiver did not have undesirable consequences, such as harming third parties; and (4) where there was error, the underlying error was made in good faith.² While the fourth element is inapposite, the CAISO's waiver request satisfies each of the other three factors, and therefore should be approved.

In support of this request, the CAISO states as follows:

I. COMMUNICATIONS AND CORRESPONDENCE

Communications regarding this filing should be addressed to the following individuals whose names should be placed on the official service list established by the Secretary with respect to this submittal:

Grant Rosenblum
Senior Counsel
California Independent System
Operator Corporation
151 Blue Ravine Road
Folsom, CA 95630
Tel: (916) 351-4400
Fax: (916) 608-7296

Sean A. Atkins
Michael Kunselman
Alston & Bird
950 F Street, N.W.
Washington, D.C. 20004
Tel: (202) 756-3300
Fax: (202) 756-3333

² See *ISO New England Inc.*, 117 FERC ¶ 61,171 at P 21 (2006); see also *Gulf South Pipeline Company, LP*, 112 FERC ¶ 61,294 (2005); *Great Lakes Gas Transmission Co.*, 102 FERC ¶ 61,331 (2003); *TransColorado Gas Transmission Co.*, 102 FERC ¶ 61,330 (2003); *Wisvest-Connecticut, LLC v. ISO-New England, Inc.*, 101 FERC ¶ 61,372 (2002); *Northern Border Pipeline Co.*, 76 FERC ¶ 61,141 (1996).

II. SERVICE

The CAISO has served copies of this filing on the California Public Utilities Commission, the California Energy Commission, the California Electricity Oversight Board, and all parties with effective Scheduling Coordinator Service Agreements under the ISO Tariff. In addition, the CAISO is posting this filing on the ISO Home Page.

III. BACKGROUND

A. The Tehachapi Wind Resource Area

The TWRA lies at the southern end of the San Joaquin Valley in the mountainous region between Bakersfield and Mohave, within the service territory of Southern California Edison Company ("SCE"). The TWRA has been identified as California's largest wind resource area, with an undeveloped potential of about 14,000 gigawatt hours per year (about 4,500 MW of peak capacity).³ Because of this potential, development of wind generation in the TWRA will significantly contribute to meeting California's renewable energy goals,⁴ which were codified in 2004 as the California Renewables Portfolio Standard ("RPS"). California's RPS requires retail sellers of electricity to purchase a specified minimum percentage of electricity generated by renewable energy resources, such as wind generators.⁵ However, it has been recognized that because of the remoteness of the TWRA from the ISO Controlled Grid and insufficient existing

³ California Energy Commission, "Renewable Resources Development Report," CEC Publication Number 500-03-080F, November 2003.

⁴ CPUC Decision 04-06-010 (2004), at pp. 5-6, Finding of Fact No. 3 at p. 39 (2004).

⁵ Cal. Pub. Util. Code § 399.11 *et seq.* (2004).

transfer capability, in order to successfully develop renewable generation in the TWRA and allow energy from such resources to be deliverable to California consumers, significant transmission infrastructure upgrades must be constructed.

In June of 2004, the California Public Utilities Commission ("CPUC") issued an order addressing transmission expansion in the TWRA.⁶ In that order, the CPUC found that planning transmission upgrades for the TWRA based solely on the transmission needs of generation projects that had, at that time, submitted Interconnection Requests to interconnect in the TWRA, was unlikely to achieve the most cost-effective size, configuration, or timing of necessary transmission upgrades. The CPUC ordered the establishment of a collaborative study group to develop a comprehensive plan for transmission expansion in the TWRA. The CPUC also ordered SCE to pursue CAISO review of the Tehachapi transmission upgrades and file for certificates of public convenience and necessity seeking CPUC permission to build the "first phase" of the Tehachapi transmission upgrades no later than six months from the date of the CPUC's order.

In March of 2005, SCE filed with the Commission a petition for declaratory order seeking rolled-in rate treatment for the initial three segments that collectively formed the first phase of the transmission upgrades to the TWRA. SCE stated that it was concerned that if it provided the up-front funding for all of the upgrades, that the Commission might deny cost recovery after the facilities were constructed by finding that all or some of the projects are not "Network

⁶ *Interim Opinion on Transmission Needs in the Tehachapi Wind Resource Area*, CPUC Decision 04-06-010 (2004).

Upgrades” and, as a result, should have been paid for by the developers of the generation (direct assignment).

In its order on SCE’s petition, the Commission agreed with SCE that the first two transmission segments were appropriately characterized as Network Upgrades, and granted SCE’s request to allow it to recover 100 percent of the cost of these upgrades even if these facilities are abandoned or cancelled.⁷ The Commission found, however, that the third segment of the project, as originally configured, was not a Network Upgrade, and therefore not eligible for rolled-in rate treatment.⁸ Several Commissioners indicated that they would be receptive to an alternative cost allocation mechanism proposed by the CAISO.⁹

Contemporaneously with SCE’s efforts on the first phase of the Tehachapi transmission infrastructure, the Tehachapi Collaborative Study Group (“TCSG”), as directed by the CPUC, worked to develop a comprehensive transmission plan for the phased expansion of transmission capabilities to allow renewable generation to interconnect in the TWRA to reach California consumers. The TCSG issued two study reports to the CPUC in March 2005 and in April 2006. The outcome of the collaborative study group process was the identification of a

⁷ *Southern California Edison Company*, 112 FERC ¶ 61,014 at P 58 (2005) (“July 1 Order”)

⁸ *Id.* at P 42.

⁹ The CAISO has developed such a proposal with stakeholder input and anticipates filing with the Commission a Petition for a Declaratory Order on this proposal in the near future. The present plan of service for the TWRA contemplates that the facilities will be built over time. One or more facilities may be bulk-transfer gen-tie lines for an interim period until additional lines and interconnections are built. SCE has proposed that if some of the facilities are temporarily or permanently bulk-transfer gen-ties, those generators connected to such a gen-tie will be charged a FERC-approved rate for transmission service during the period that the facility is a bulk-transfer gen-tie. If, in the future, a bulk transfer gen-tie is converted to a Network facility as the remainder of the plan of service is constructed, the charge will be terminated. Likewise, under the proposal the CAISO anticipates it will file in the near future, a generator will be charged its proportionate share of the costs of the gen-tie it uses, but will not be assessed any further costs for that line once it becomes a Network facility.

number of general alternatives for the transmission infrastructure and recommended further study of these alternative schemes by the CAISO.

Consistent with the recommendation of the TCSG, the CAISO studied the Tehachapi Transmission Project (“TTP”) as part of its CAISO South – Regional Transmission Plan 2006 (CSRTP-2006) process in collaboration with SCE and other CSRTP-2006 participants.¹⁰ Through the CSRTP – 2006 process, the CAISO developed a new transmission upgrade configuration. This configuration satisfies two objectives.

First, the TTP represents a least-cost solution to reliably interconnect the 4,350 MW of TWRA-generation in the CAISO’s Interconnection Queue up to the start date of the CSRTP 2006 (May 24, 2006). This solution will also allow low-cost renewable generation interconnection in the TWRA for other projects that joined the Interconnection Queue after the CSRTP 2006 start date.

Second, the CAISO’s TTP configuration for the most part avoids the facility “characterization” issue addressed in the Commission’s July 1 Order.¹¹ All of the major upgrades necessary to interconnect and accommodate energy and capacity from TWRA generation projects have been designed by the CAISO as Network Upgrades, rather than Interconnection Facilities. The description and

¹⁰ The CSRTP-2006 team included the CAISO, impacted Participating Transmission Owners (PG&E, SCE and SDG&E), technical representatives from all Project Sponsors (Nevada Hydro Company, Citizens Energy, Imperial Irrigation District, Oak Creek Energy System/Tehachapi Holdings), and technical representatives from the California Energy Commission (“CEC”) and the California Electricity Oversight Board (“EOB”). This team has provided and will continue to provide the CAISO with necessary technical data and advice needed to conduct its analyses.

¹¹ As discussed in footnote 9, *supra*, the facilities are generally planned to be Network. However, because the full plan of service will be developed in phases, one or more facilities may not actually operate as part of the Network for a period of time.

support for the TTP was set forth in a report issued by the CAISO on December 29, 2006.¹²

B. The Clustering Provisions of the LGIP

Section 4.2 of the LGIP provides that the CAISO, in coordination with the applicable Participating TO(s), may study Interconnection Requests in clusters for purposes of the SIS. If the CAISO elects to study Interconnection Requests using Clustering, all Interconnection Requests received within a period not to exceed 180 Calendar Days (the "Queue Cluster Window") shall be studied together without regard to the nature of the underlying Interconnection Service. However, the CAISO may agree to conduct the study of an Interconnection Request falling within the Queue Cluster Window separately "to the extent warranted by Good Utility Practice based upon the electrical remoteness of the proposed Large Generating Facility." Under Section 4.2, Clustered SISs shall be conducted in a manner so as to "ensure the efficient implementation of the applicable regional transmission expansion plan in light of the transmission system's capabilities at the time of each study." Finally, Section 4.2 provides that the Queue Cluster Window will have a fixed time interval based on annual opening and closing dates, and that any changes to these dates must be accounted by a posting on the ISO Home Page at least 180 Calendar Days prior to the change going into effect.

C. The CAISO's Intended Approach

If the Commission grants the CAISO's requested waiver, the CAISO will define a TWRA cluster both temporally and by location (electrical influence) with

¹² A copy of this report is included with this filing as Attachment A.

the Queue Cluster Window extending from September 4, 2003 - the date of the first "active" application in the TWRA – through May 24, 2006 – the date the CAISO's LGIP became effective. This latter date was selected for two reasons. First, the CAISO must have authority to cluster.¹³ Second, the date corresponds with the approximate date of commencement of the CSRTP-2006 process, which will form the underlying basis of the clustered SIS. A list of the projects that will comprise the cluster can be found in Attachment A on page 25.¹⁴

The CAISO will apply a bifurcated SIS approach, with the clustered SIS focusing exclusively on identifying Network Upgrades necessary to interconnect the TWRA in an integrated fashion. A separate, more traditional serial SIS will still be performed for each Interconnection Request to evaluate needed Interconnection Facilities for the specific generating facilities and identify any needed Participating Transmission Owner Interconnection Facilities, both of which constitute "sole use" facilities.

Serial and clustered approaches are implemented on the basis of Queue Position. The clustered SIS therefore will not have any effect on a generating facility's Queue Position. Furthermore, SCE has committed to provide "up-front"

¹³ The May 24, 2006 date corresponds to the effective date of Section 4.2 under the CAISO's centralized LGIP study process. *California Independent System Operator Corporation*, 116 FERC ¶ 61,030 (2006). Clustered SISs were authorized as part of the "interim" LGIP study process in effect prior to implementation of the current centralized LGIP study process. *California Independent System Operator Corporation*, 115 FERC ¶ 61,237 (2006). However, under the interim LGIP Section 4.2, the applicable Participating Transmission Owner performed the clustered SIS. Given that the CSRTP – 2006 is a CAISO driven-process, the CAISO believes it is more appropriate to rely on the currently-effective Section 4.2, which incorporates the central role of the CAISO in the LGIP study process.

¹⁴ Those Interconnection Customers that have entered into Interconnection Study agreements prior to the effective date of the LGIP would normally have the option of electing either to proceed under the LGIP or continue under the interconnection procedures in place prior to the LGIP (*i.e.* the "Amendment 39 Procedures"). For purposes of conducting a clustered, integrated SIS to identify Network Upgrades necessary to interconnect facilities locating in the TWRA, the CAISO intends to rely solely on the procedures set forth in the LGIP.

financing for Network Upgrades identified through the clustered SIS, subject to the CPUC's authorization of backstop cost recovery of the transmission upgrade costs pursuant to Section 399.25 of the California Public Utilities Code.

IV. BASIS FOR WAIVER

The CAISO requests that the Commission grant it a one-time waiver of the requirements of Section 4.2 of the LGIP. Specifically, the CAISO requests waiver of the requirements that the Queue Cluster Window not exceed 180 day and that the CAISO provide advance notice of the opening and closing dates of the Window, in order to establish a retroactive Queue Cluster Window between September 4, 2003 and May 24, 2006 for the limited purpose of conducting a comprehensive SIS to identify Network Upgrades necessary to interconnect renewable resources locating in the TWRA. As explained below, the requested waiver meets the criteria for waiver established by Commission precedent, and is therefore just and reasonable, and should be approved.

A. The Requested Waiver is of Limited Scope

One of the criteria that the Commission uses to assess requests for waiver of tariff provisions is whether the waiver is of "limited scope." The CAISO's instant request satisfies this criterion. The CAISO is asking for a single waiver of the Queue Clustering Window provisions of Section 4.2 of the CAISO's LGIP to allow the CAISO to retroactively establish a Queue Cluster Window in order to identify Network Upgrades necessary to interconnect resources in the TWRA. The CAISO does not intend that this Window would set any precedent with

respect to future Queue Cluster Windows. Also, pursuant to Section 4.2, which allows the CAISO to study other projects in the Queue Cluster Window separately based on the electrical remoteness of such facilities, the CAISO will not include as part of the clustered SIS those projects that fall within the requested Queue Cluster Window, but do not plan to interconnect in the TWRA. Therefore, the CAISO's request is of limited scope both in terms of the frequency of application, in that it will only be applied once, and in geographic impact, in that it will only be applied to generation interconnecting in the TWRA with queue positions between September 4, 2003 and May 24, 2006. For these reasons, the CAISO submits that the instant request satisfies the "limited scope" requirement the Commission applies to tariff waiver requests.

B. The Requested Waiver Will Solve a Concrete Problem That Needs to be Remedied

As noted above, there already exists in the CAISO's Interconnection Queue over 4,500 MW of generating capacity that intends to interconnect in the TWRA. Under the CAISO Tariff, these facilities have the right to receive open and non-discriminatory access to the ISO Controlled Grid. Moreover, interconnecting these facilities will constitute a major step towards enhancing the amount of capacity from renewable resources in California, and allowing electricity providers in California to better meet their obligations under California's RPS. In short, interconnecting these facilities will benefit both developers and California consumers.

Under the serial study approach set forth in the LGIP, the CAISO conducts SISs separately for each generating facility in the queue on a sequential basis. The assumptions used in conducting sequential SISs are based on the queue positions of the generating facilities – generating facilities that are lower in the queue (*i.e.*, entered the queue more recently) are analyzed assuming the interconnection of higher queued projects. The result is construction of incremental transmission Network Upgrades based on the needs of individual interconnecting generating facilities, with the costs of these Network Upgrades assigned based on the Queue Position of the generating facilities.

Given the proximate geographic location of the multiple projects that plan to interconnect in the TWRA, incremental study and transmission expansion would be inefficient in the design of the necessary upgrades and the use of the CAISO's planning resources. There are currently a large number of generating facilities in the CAISO Interconnection Queue than intend to interconnect in the TWRA – the approximately 4,350 MW of capacity in the Queue that plans to interconnect in the TWRA during the date range that the CAISO requests to use as the Queue Clustering Window will come from nearly 20 individual facilities. Given the electrical remoteness of the TWRA from the California transmission grid, the most substantial portion of the necessary transmission upgrades, in terms of cost and scope, consists of the initial upgrades necessary to provide sufficient transmission capacity to allow delivery of capacity from the TWRA to the rest of the ISO Controlled Grid. Identifying the necessary transmission upgrades under a sequential approach would mean that the initial SISs would

recommend construction of upgrades that the CAISO already knows to be insufficient to handle all of the generating capacity planning to interconnect in the TWRA. The result would be a series of studies recommending incremental and ever-more costly transmission upgrades in order to meet the threshold level of transmission upgrades necessary to interconnect and deliver the energy from the projects that plan to interconnect in the TWRA.

This approach would also be very inefficient in terms of time and human resources commitments. The Tehachapi Collaborative Study Group and the CAISO, as part of its regional transmission planning process, have conducted extensive studies of the TWRA and the transmission infrastructure that would be needed in order to interconnect the facilities that plan to build in that area. It would make no sense to expend the significant time and effort necessary for the CAISO, applicable Participating TOs, and project developers to conduct and complete numerous Interconnection Studies in order to identify network transmission facilities that would inevitably need to be upgraded upon completion of the next study in sequence.

Incorporating the efforts of the CS RTP-2006 study into a clustered SIS through a modified application of the CAISO's LGIP provisions constitutes the most efficient and appropriate solution to this problem. In Order No. 2003, the Commission expressed strong support for clustering.¹⁵ The Commission explained the benefits of clustering as follows:

¹⁵ Order No. 2003, *Standardization of Generator Interconnection Agreements and Procedures*, 104 FERC ¶ 61,103 at P 155 (2003) ("Clustering is strongly encouraged in queue management and the Interconnection Study Process for all Transmission Providers.").

Clustering (by queue position and electrical location) ensures that the regional expansion plan considers all uses of the Transmission System and enables expansion of the system to be accomplished in the most efficient manner reasonably achievable. However, projects that are electrically isolated can still be studied independently. Additionally, allocation of cost responsibility for system upgrades and jointly used facilities is more readily managed by studying requests in clusters. Absent the ability to cluster interconnection requests, it is difficult to distinguish the Transmission Provider's cost responsibility for baseline reliability upgrades from the responsibility of Interconnection Customers and other developers for the costs of upgrades required to accommodate their Interconnection Requests since each request would have to be studied serially. Equally important, Interconnection Studies for smaller generators can be more easily expedited. These efficiencies are best obtained using clustered queue windows, not through the sequential processing of Interconnection Requests

In Order No. 2003-A, the Commission again emphasized its support for the clustered approach stating:

The principal benefit of studying Interconnection Requests in clusters is that it allows the Transmission Provider to better coordinate Interconnection Requests with its overall transmission planning process, and, as a result, achieve greater efficiency in both the design of needed Network Upgrades and in the use of its planning resources.¹⁶

This reasoning is highly applicable to the circumstances at issue in the instant request, which involves the interconnection of multiple projects in a proximate geographic location such that incremental study and transmission expansion would be inefficient in the design of the necessary upgrades and the use of the CAISO's planning resources. Because clustering leads to an optimized construction plan for Network Upgrades necessary to interconnect generation

¹⁶ Order No. 2003-A, *Standardization of Generator Interconnection Agreements and Procedures*, 106 FERC ¶ 61,220 at P 120 (2004).

locating in the Tehachapi area, permitting such an approach will result in substantial overall cost savings for all parties involved – the CAISO, Participating TOs, project developers, and transmission customers. A clustered SIS is also more efficient from a planning and design perspective and will allow the CAISO to coordinate Interconnection Requests within the framework of its overall transmission planning process. For these reasons, the CAISO submits that the requested waiver of Section 4.2 of the LGIP, in order to allow the CAISO to establish a retroactive Queue Cluster Window between September 4, 2003 and May 24, 2006 for purposes of identifying Network Upgrades for the TWRA, satisfies the second prong of the Commission's waiver test.

C. Granting the Requested Waiver Will Not Have Undesirable Consequences, Such as Harming Third Parties

Granting the CAISO's requested waiver of Section 4.2 of the LGIP in order to allow the CAISO to conduct a clustered SIS study to determine Network Upgrades necessary to interconnect projects locating in the TWRA with a Queue Position between September 4, 2003 and May 24, 2006 will not have undesirable consequences, such as harming third parties. The CAISO recognizes that the Commission's rationale in adopting a 180-day limit on Queue Cluster Windows, and the requirement that Queue Cluster Windows have fixed opening and closing dates, was to balance the need for a comprehensive study approach that clustering allows, while at the same time ensuring that the Interconnection

process is conducted in an orderly and fair manner.¹⁷ The CAISO agrees with the Commission's rationale, and submits that the instant request for waiver, although it would result in a retroactive cluster exceeding the 180-day time span, is consistent with, and in fact promotes, an orderly and fair interconnection process.

As noted above, pursuing a clustered approach will result in overall lower costs for all parties, including the CAISO, generation developers, Participating TOs, and transmission customers, because it eschews a wasteful series of incremental studies in favor of an integrated and holistic approach to identifying the most efficient package of Network Upgrades. Therefore, costs savings will be realized both in terms of planning and overall capital costs.

Also, the bifurcated clustered approach that the CAISO plans to pursue will not result in any Interconnection Customer paying higher study costs than it otherwise would under a unified serial study approach, because Interconnection Customers that will be included in the clustered study will not be charged for the clustered SIS. Rather, each applicable Interconnection Customer will continue to be charged for the separate, serial SIS in accordance with the appropriate interconnection provisions. Moreover, for those interconnection customers in the affected region that have not yet initiated SISs, it is likely that the bifurcated approach will reduce study costs by narrowing the scope of the subsequent separate, generating-facility-specific SIS.

¹⁷ See Order No. 2003 at PP 153-155; *Midwest Independent Transmission System Operator, Inc.*, 108 FERC ¶ 61027 at P 131 (2004)(denying Midwest ISO's request to conduct studies of multiple Interconnection Requests without established windows).

Adopting a clustered SIS approach will result in little or no delay to the interconnection process for those generators that will interconnect in the TWRA while ensuring the efficient processing of SISs in the region. Virtually every Interconnection Customer to be included in the clustered SIS is currently at the “feasibility” study phase and therefore has not yet started its SIS, has not completed its SIS, or is subject to an SIS re-study due to a higher queued generating facility dropping out of the queue. As such, the CAISO does not foresee any material impact on the timing of completing any ongoing SIS. Indeed, in large part, a barrier to the efficient processing of SISs for interconnection requests in the TWRA is the absence of a comprehensive plan of service for Network Upgrades. The clustered SIS will provide certainty with respect to this plan of service and permit the more efficient administration of those SISs that have not commenced or are in progress.

Moreover, the clustering approach has a positive effect under circumstances where generators may be required to connect for an interim period to a bulk-transfer gen-tie and pay a transmission charge prior to the conversion of that facility to a Network Upgrade under the final plan of service. As discussed in footnote nine, *supra*, SCE proposes to charge a FERC-approved pro-rata rate to each generator based on its usage of a gen-tie. The residual revenue requirement for the unsubscribed portion of the line will either be collected from retail ratepayers under CPUC-approved rates or from all transmission customers in FERC-jurisdictional TAC rates if a future proposal by

the CAISO is approved.¹⁸ Generators will be charged for their proportionate use of bulk-transfer gen-ties whether clustering is or is not used. In fact, under clustering it is more likely that the full network buildout will proceed faster, and thus the gen-tie converted to Network facilities sooner, than without clustering. In this way, generators using the gen-tie are actually better off under clustering than they would have been otherwise because the transmission service charge will terminate sooner.

Facilities planning to interconnect outside of the TWRA during the requested Queue Cluster Window will likewise not be adversely affected by the granting of the CAISO's requested waiver. As noted above, consistent with Section 4.2 of the LGIP and Order No. 2003, which allows the CAISO to study facilities within the Queue Cluster Window separately based on electrical remoteness, the CAISO plans to study projects interconnecting outside of the Tehachapi area separately, pursuant to the standard process set forth in the LGIP. Therefore, these facilities will not be adversely impacted by the granting of a waiver that allows the CAISO to cluster the TWRA projects.

Finally, the CAISO's requested Queue Cluster Window will not adversely impact other projects that plan to interconnect in the TWRA. As noted above, there is approximately 1,260 MW of additional generation that entered the Queue

¹⁸ SCE has indicated that it will provide the initial funding of network upgrades and, presumably, gen-ties, if the CPUC issues a satisfactory decision on the applicability of California Public Utilities Code Section 399.25(b)(4). Section 399.25(b)(4) provides for recovery in CPUC-approved rates of the costs of Renewable Portfolio Standard transmission that are not approved for recovery by the Commission. Should SCE not receive a positive outcome at the CPUC, a risk does exist that any particular generator, which would not have triggered any Network Upgrades under a serial approach, would be worse off under the clustered approach. The CAISO will attempt to mitigate this risk by estimating in the serial SIS the Network Upgrades and costs that would have been triggered by that particular project.


after May 24, 2006 that plans to interconnect in the TWRA. However, as noted in the latest CS RTP-2006 report, the comprehensive package of Network Upgrades that will be built to interconnect the TWRA in an integrated fashion will be used by projects with a queue date after May 24, 2006 for low-cost interconnection to the ISO Controlled Grid.

V. CONCLUSION

WHEREFORE, for the foregoing reasons, the CAISO respectfully requests that the Commission grant the one-time waiver requested herein in order to allow the CAISO to establish a retroactive Queue Cluster Window between September 4, 2003 and May 24, 2006 in order to identify transmission Network Upgrades necessary to accommodate the interconnection of approximately 4,350 MW of generating facilities in the Tehachapi Wind Resource Area in the fairest, most efficient, and most cost-effective manner possible.


Respectfully submitted,

Grant Rosenblum
Senior Counsel
The California Independent System
Operator Corporation
151 Blue Ravine Road
Folsom, CA 95630
Telephone: (916) 608-7015


Sean A. Atkins
Michael Kunselman
Alston & Bird LLP
The Atlantic Building
950 F Street, N.W.
Washington, DC 20004
Tel: (202) 756-3300

Dated: January 19, 2007

ATTACHMENT A



CAISO South Regional Transmission Plan for 2006 (CSRTP-2006)

PART II: Findings and Recommendation on the Tehachapi Transmission Project

Prepared by:
**Regional Transmission – South
Planning and Infrastructure Development
California ISO**

December 29, 2006

CAISO South Regional transmission Plan for 2006 (CSRTP-2006) Report --- The Tehachapi Study ---

EXECUTIVE SUMMARY

INTRODUCTION AND SUMMARY CONCLUSIONS

The California ISO (CAISO) was asked to review and approve three proposals by the project proponents for new transmission projects in the Southern California region. The three projects are:

- **Sunrise Powerlink / Green Path (Sun Path) Project:** The project combines Sunrise Powerlink Project sponsored by San Diego Gas & Electric Company (SDG&E) and Phase 2 of Green Path Project sponsored by Citizens Energy and Imperial Irrigation District (IID) connecting Imperial Valley to the San Diego area and is intended to help meet the reliability and economic needs of the ISO Controlled Grid as well as to integrate renewable resources in the Salton Sea and southern Imperial Valley areas.
- **Tehachapi Transmission Project:** This project presents the transmission network infrastructure necessary to reliably interconnect generation resources (mainly wind generation) in the Tehachapi Wind Resource Area (TWRA) and, at the same time, to provide reliability and economic value for the ISO Controlled Grid. Southern California Edison Company (SCE) has voluntarily sponsored this project pursuant to the terms of the CAISO's Large Generator Interconnection Procedures (LGIP). The TWRA lies at the southern end of the San Joaquin Valley in the mountainous region between Bakersfield and Mohave and is California's largest wind resource area.
- **Lake Elsinore Advanced Pumped Storage (LEAPS) Project:** This project includes a 500 kV transmission line project (LEAPS Transmission Line) that connects SCE's transmission system with that of SDG&E and is accompanied by a 500 MW pumped storage power plant built next to Lake Elsinore itself (LEAPS Power Plant) and interconnected to the middle of the line. This project is intended to improve the reliability and economics of the ISO Controlled Grid and is sponsored by The Nevada Hydro Company (TNHC) and Elsinore Valley Municipal Water District (EVMWD).


Figure 1 presents the general location of the three proposed transmission projects against the backdrop of the 500 kV network in the same general geographic areas.

In this report, we focus on findings and recommendations for the Tehachapi Transmission Project. The Sun Path Project, which the CAISO Board of Governors previously approved, has been incorporated into the Base Case used for evaluating the Tehachapi Transmission Project.¹ However, given the novel and unprecedented proposed treatment of the Generating Facility of the LEAPS Project as a transmission asset, the CAISO's final findings and recommendation on the LEAPS Project can only follow the FERC determination on the operational control and related ratemaking aspects of the project.²

¹ However, the Sun Path Project does not have any direct impact on the results of this evaluation.

² FERC has directed CAISO to investigate this matter based on a stakeholder process.

Figure 1: General Location of Three Proposed Transmission Projects in Southern California



The origin of the Tehachapi Transmission Project is the Tehachapi Collaborative Study Group, coordinated by the California Public Utilities Commission (CPUC), which was formed in 2004 to develop a comprehensive transmission development plan for the phased expansion of transmission capabilities in the TWRA. The TCSG issued two study reports to the CPUC in March 2005 and in April 2006. The outcome of the collaborative study group process was the identification of a number of alternatives for the transmission infrastructure and a recommendation to further study of these alternative schemes by the CAISO. The CAISO studied the Tehachapi Transmission Project as part of its CAISO South Regional Transmission Plan for 2006 (CS RTP-2006) in full collaboration with SCE and other CS RTP-2006 participants³ and developed a least-cost solution for the network component of the transmission infrastructure that will interconnect planned generation projects in TWRA to the ISO Controlled Grid.

Under its federally approved tariff, the CAISO is responsible for ensuring open and non-discriminatory access to the ISO Controlled Grid for new Generating Facilities. The CAISO satisfies this obligation, in cooperation with the Participating Transmission Owners (PTOs), through its Large Generator Interconnection Procedures (LGIP). Because the primary purpose of the Tehachapi Transmission Project is to provide for the interconnection and delivery of generation in the TWRA, the CAISO has applied its LGIP within the context of its

³ CS RTP-2006 was launched on April 11, 2006. The CS RTP-2006 team included the CAISO, impacted Participating Transmission Owners (Pacific Gas and Electric Company (PG&E), SCE and SDG&E), technical representatives from all Project Sponsors (TNHC, Citizens Energy, IID, Oak Creek Energy System/Tehachapi Holdings), and technical representatives from the California Energy Commission (CEC) and the California Electricity Oversight Board (EOB). This team has provided and will continue to provide the CAISO with necessary technical data and advice needed to conduct its analyses.

CS RTP-2006 process to determine the least-cost transmission solution for integrating 4,350 MW⁴ of generating resources in the Tehachapi Area Generation Queue (TGQ). Under the LGIP, once the CAISO has identified the transmission facilities associated with interconnecting generation, the discretion whether to proceed with the associated Network Upgrades as well as pursuing the required siting approvals lies with the Interconnection Customer and the affected PTO. However, given the substantial investment embodied by the Tehachapi Transmission Project, the CAISO has elected to seek approval from the CAISO Board in order to facilitate the subsequent regulatory processes.

Specifically, the CAISO's determinations and findings on the Tehachapi Transmission Project, as presented in this report, are as follows:

1. The Tehachapi Transmission Project is the least-cost solution that reliably interconnects 4,350 MW of generating resources in TGQ;
2. The Tehachapi Transmission Project also addresses the reliability needs of the ISO Controlled Grid due to projected load growth in Antelope Valley area as well as helps to address South of Lugo (SOL) transmission constraints – an ongoing source of reliability concern for the Los Angeles (LA) Basin;⁵
3. The Tehachapi Transmission Project facilitates the ability of California utilities to comply with the state mandated Renewable Portfolio Standard (RPS) by providing access to planned renewable resources in the TWRA – also see points 6 and 7 below;
4. The Tehachapi Transmission Project is expected to provide economic benefits to the CAISO ratepayers mainly by providing access to wind and other efficient generating resources under development in TWRA;
5. The Tehachapi Transmission Project makes it possible to expand the transfer capability of Path 26 in the near future with a low cost upgrade of PG&E's portion of Midway-Vincent Line 3;
6. The Tehachapi Transmission Project will be used by other projects in TGQ queued beyond the start date of the CS RTP-2006 for low-cost interconnection to the ISO Controlled Grid;⁶ and
7. Although the detailed planning has not yet been performed, the Tehachapi Transmission Project lays the groundwork for the integration of large amounts of planned geothermal, solar, and wind generation in Inyo and northern San Bernardino counties with potential future 500 kV additions from the WindHub Substation (one of Tehachapi Transmission Project's substations) to the Kramer Substation.

PROJECT DESCRIPTION

Table 1 presents the entire Tehachapi Transmission Project plan of service.⁷ Figure 2 depicts the entire plan of service for the Tehachapi Transmission Project. The Tehachapi

⁴ 4,350 MW of generation projects correspond to the capacity of all generation projects in the TGQ up to the start date of the CS RTP-2006 process - 3,570 MW of this total consists of wind generation that will be developed to allow compliance with the California mandated Renewable Portfolio Standard program.

⁵ Concerns with the SOL transmission constraints are expected to increase as additional generation resources are sited outside the LA Basin. Delivery of this new generation to LA Basin load will require significant transmission additions as identified in this plan.

⁶ Around 1260 MW of such generation was already in the TGQ as of December 1, 2006.


Transmission Project will accommodate all targeted generation projects in the TGQ. However, sufficient flexibility is built into the rollout of the Tehachapi Transmission Project to reasonably respond to changes in the magnitude and the location of generation resources in the area.

Table 1: Tehachapi Transmission Project Plan of Services

Major Transmission Facilities	Planned In-Service Date
Antelope – Pardee 230 kV Line (500 kV Specifications) & Antelope Substation Expansion	Dec 2008
Antelope – Vincent 230 kV Line #1 (500 kV Specifications)	Mar 2009
WindHub Substation	Mar 2009
Antelope – WindHub (also known as Substation 1) 230 kV Line (500 kV Specifications)	Mar 2009
Antelope – Vincent 230 kV Line #2 (500 kV Specifications)	Mar 2011
LowWind 500/230 kV Substation (also known as Substation 5) with Loop in of Midway – Vincent #3 500 kV line	Aug 2011
Antelope – LowWind 500kV line	Aug 2011
WindHub Substation 500 kV Upgrade	Mar 2011
Antelope Substation 500 kV Upgrade	Mar 2011
Vincent Substation 500 kV & 220 kV Upgrade	Sep 2011
LowWind – WindHub 500 kV line	Oct 2011
Replacement of Vincent – Rio Hondo No. 2 230kV line	Nov 2011
Vincent – Mira Loma 500 kV line	Apr 2012
Vincent – Mesa 500/220 kV Line and Mesa Substation Work	Nov 2013

⁷ The planned in service dates are based on receiving all permits by January 2007 for the Antelope Transmission Project (segments 1 to 3) and the Tehachapi Renewable Transmission Project (segments 4 to 11) by January 2009.

Figure 2: Tehachapi Transmission Project
 (Routes shown on this diagram are for illustration purposes only)



PUBLIC PROCESS IN DEVELOPING RECOMMENDATION

Table 2 lists the CAISO’s public outreach initiatives for this project. In addition to several outreach programs intended to familiarize the public with the CSRTP-2006 process and studies assumptions that the CAISO held as part of the Sun Path project, the CAISO held two days of open houses on the CSRTP-2006 planning process and the Tehachapi Transmission Project in the Tehachapi area. The CAISO established additional outreach programs to local agencies and local community organizations and provided several presentations about the CSRTP-2006 process and the CAISO’s findings at workshops sponsored by the California Public Utilities Commission (CPUC) and the Southwest Transmission Expansion Plan (STEP). As a result of these public outreach programs, the CAISO received several valuable comments and suggestions from stakeholders that triggered modifications of study assumptions and approach and, eventually, the CAISO’s findings and conclusions. Table 2 below lists the outreach activities and their results.

Table 2: Stakeholder and Public Outreach for the CSRTP-2006 Process

Outreach Activity	Date
Open house in San Diego on CSRTP-2006 process	- May 19-20, 2006
Created tailored distribution lists to reach affected parties, including those wishing not to be on master communications lists.	- May 2006 through present
Hosted conference call to discuss assumptions and comments	- June 22, 2006
Collected written stakeholder comments on assumptions.	- Through June 29, 2006
Initiated 1:1 outreach to individuals and interested groups.	- May through present
Published and re-posted updated study assumptions	- July 17, 2006
Held joint Tehachapi Transmission Workshop with CPUC	- August 23, 2006
Presented the CSRTP-2006 process and interim findings on all projects, including the Tehachapi Transmission Project, at multiple Southwest Transmission Expansion Plan (STEP) meetings.	- May 5, 2006 - July 24, 2006 - September 21, 2006 - November 17, 2006 (planned)
Hosted an Open House in Tehachapi to display CAISO’s role in transmission planning and the Tehachapi Transmission Project final plan of service.	- September 25, 2006 - September 26, 2006
Presentation at CPUC Workshop on the Tehachapi Transmission	- November 21, 2006

COMPLIANCE WITH THE LGIP REQUIREMENTS

CAISO Management’s recommendations on the Tehachapi Transmission Project are primarily based on the CAISO’s obligation to identify least-cost transmission solutions to reliably interconnect generation projects in accordance with provisions of the CAISO’s LGIP. The CAISO worked with the project sponsor (SCE) and other participants in the CSRTP-2006 process to plan the Tehachapi Transmission Project in a manner that reliably interconnects all generating projects in the TGQ (4,350 MW) as of the commencement date of the CSRTP-2006 process (April of 2006).⁸ Accordingly, the CAISO has utilized the efforts of the CSRTP-2006 as a foundation to efficiently comply with its obligations under the LGIP. It has done so by accounting for all LGIP provisions related to “clustered” Interconnection System Impact Studies (SIS) in the CSRTP-2006 study process.

⁸ Around 1460 MW of TGQ projects queued beyond April 2006 will be studied individually or in additional clusters according to their Queue Position in accordance with the LGIP.

"Clustering" permits the CAISO to collectively study the system impacts of a group of Interconnection Requests, rather than evaluate each potential Generation Facility one-at-a-time. The principal benefit of studying Interconnection Requests in clusters is that it allows the CAISO to better coordinate Interconnection Requests with its overall transmission planning process, and, as a result, achieves greater efficiency in the design of needed Network Upgrades.⁹ Indeed, the reasoning that resulted in adoption of a Clustering study process option in the LGIP is strongly applicable to the situation faced by the CAISO with respect to the TWRA involving the interconnection of multiple projects in a proximate geographic location such that incremental study and transmission expansion would be inefficient in the design of the necessary Network Upgrades. By pursuing an integrated solution, the Clustering approach will result in substantial capital cost savings for Network Upgrades when compared to the probable outcome of any piecemeal solution associated with the traditional, sequential SIS approach.

However, the CAISO has deviated in several respects from a typical clustered Interconnection Study. First, unlike the product of a typical Interconnection Study, this report identifies only the network components or Network Upgrades of the transmission infrastructure necessary to interconnect the planned generation projects in TWRA to the ISO Controlled Grid.¹⁰ It excludes Interconnection Facilities, including radial wind collector transmission systems that interconnect the individual generation projects to the grid and are the responsibility of generation developers. Needed Interconnection Facilities, and their cost responsibilities, will be identified through a separate, more narrow Interconnection Study for each particular Generating Facility in the TGQ.¹¹ Second, an element of Clustering is the selection of a time window for determining which generation projects in the queue will be included in the clustered SIS, i.e., the "Queue Cluster Window." For the Tehachapi Transmission Project the Queue Cluster Window was defined to encompass the first project in the TGQ up through the start date of the CS RTP-2006 process or from August 19, 2003 through April 11, 2006.¹² The

⁹ Order No. 2003-A, *Standardization of Generator Interconnection Agreements and Procedures*, 106 FERC ¶ 61,220 (2004) at P 120.

¹⁰ Network Upgrades are defined in the ISO Tariff as "[t]he additions, modifications, and upgrades to the ISO Controlled Grid required at or beyond the Point of Interconnection to accommodate the interconnection of the Large Generating Facility to the ISO Controlled Grid. Network Upgrades shall consist of Delivery Network Upgrades and Reliability Network Upgrades." (ISO Tariff, Appendix A, at 515.) Delivery Network Upgrades are "[t]ransmission facilities at or beyond the Point of Interconnection, other than Reliability Network Upgrades, identified in the Interconnection Studies to relieve constraints on the ISO Controlled Grid." (*Id.* at 489.) Reliability Network Upgrades are "[t]he transmission facilities at or beyond the Point of Interconnection necessary to interconnect a Large Generating Facility safely and reliably to the ISO Controlled Grid, which would not have been necessary but for the interconnection of the Large Generating Facility, including Network Upgrades necessary to remedy short circuit or stability problems resulting from the interconnection... [or] to mitigate any adverse impact that Large Generating Facility's interconnection may have on a path's WECC rating."

Interconnection Facilities, on the other hand, are "all facilities and equipment between the Generating Facility and the Point of Interconnection, including any modification, additions, or upgrades that are necessary to physically and electrically interconnect the Generating Facility to the ISO Controlled Grid."

¹¹ As shown in Figure 2, the broader Tehachapi Transmission Project includes the 230 kV Highwind and Cottonwind substations as well as the radial transmission lines to these two substations. The costs for these facilities are not intended to be covered as part of this project.

¹² It should be noted that the duration of the Queue Cluster Window is generally intended to extend for only 180 days. This 180-day limit was adopted by FERC, in large part, to protect Interconnection Customers from undue delay in processing their study requests by transmission owners. This risk is not present in the context where the CAISO conducts the study. Nevertheless, in an abundance of

Tehachapi Transmission Project will also provide low cost integration into the ISO Controlled Grid for additional TGQ projects queued beyond April 11, 2006 (around 1,260 MW).

Finally, due to the specific circumstances presented by this project, CAISO will file a petition with FERC for approval to proceed with the proposed study approach on a one-time basis.

ECONOMIC, RELIABILITY AND ENVIRONMENTAL BENEFITS

In addition to interconnecting the TGQ generation projects, the Tehachapi Transmission Project offers System Reliability and efficiency (economy) benefits and facilitates compliance with the California's mandated RPS requirements. The CAISO is not relying on such reliability or economic benefits or RPS compliance to justify approval of the Tehachapi Transmission Project. Therefore, while significant, the CAISO does not attempt to quantify these or the following benefits of the Tehachapi Transmission Project for purposes of this study:

- Provision for the future low cost expansion capability for Path 26;
- Provision for the future expansion of transmission capability to integrate planned renewable resources in Inyo and northern San Bernardino counties area;
- Reduction in nitrogen oxides (NOx) and sulfur oxides (SOx) and other pollutant emissions from displaced fossil fuel generation;
- Potential reduction in natural gas prices stemming from lower fuel consumption by the natural gas generators that are displaced by the wind generation in TWRA - the benefits here would be both due to lower generation cost as well as other societal benefits stemming from lower natural gas costs;
- Augmentation of competitive wholesale Energy markets for California; and
- Further diversification of Energy resources.

PROJECT COST

The total cost of the Tehachapi Transmission Project is \$1.8 billion dollars in nominal terms. This cost includes the cost of the Antelope-Pardee line segment (\$90 million) previously approved by the CAISO Board, but excludes the cost of Interconnection Facilities, i.e., radial wind collector transmission systems that interconnect the individual generation projects to the grid and are the responsibility of generation developers. The full cost and ownership of the facilities associated with this project will be assigned to SCE. SCE will recover such costs, including the commensurate rate-of-return, directly through the CAISO transmission Access Charge (TAC).

RECOMMENDATION

Pursuant to CAISO's obligation to plan for least-cost transmission solutions to interconnect generation projects, as delineated in the LGIP, the CAISO Management recommends that CAISO Board approve the project and direct SCE, as the Project Sponsor, to proceed with the necessary permitting and construction of the project.

caution, the CAISO will file with FERC a petition requesting an explicit one-time waiver of the 180-day Queue Cluster Window to ensure expansion of the transmission grid in the TWRA can be accomplished in the most efficient manner reasonably achievable.

Furthermore, given the CAISO's pending petition before FERC for a one-time waiver of the 180-day Queue Cluster Window, Management recognizes that the Board's approval may be affected by the outcome of the CAISO's pending petition before FERC. Hence, CAISO Management recommends that the Board consider the "substance" of the report and approve the Tehachapi Transmission Project contingent upon FERC consent to the CAISO's implementation its Clustering authority in the present circumstances.

List of Acronyms

Acronyms	Definition
AFUDC	Allowance for Funds Used During Construction
CAISO	California Independent System Operator Corporation
CCCT	Combined Cycle Combustion Turbine
CEC	California Energy Commission
CPCN	Certificate of Public Convenience and Necessity
CPUC	California Public Utilities Commission
CS RTP	California Southern Region Transmission Plan
DT	Diesel Turbine
EPAAct 2005	Energy Policy Act of 2005
FERC	Federal Energy Regulatory Commission
FOD	Forced Outage Duration
FOR	Forced Outage Rate
IID	Imperial Irrigation District
IOU	Investor Owned Utility
LARS	Local Area Reliability Service
LCR	Local Capacity Requirement
LEAPS	Lake Elsinore Advanced Pumped Storage
LGIP	Large Generator Interconnection Procedures
LSE	Load Serving Entity
MRTU	Market Redesign & Technology Upgrade
NERC	North American Electric Reliability Council
NREL	National Renewable Energy Laboratory
NWPP	Northwest Power Pool
PAR	Phase Angle Regulator
PG&E	Pacific Gas and Electric Company
PTO	Participating Transmission Owner
PV	Present Value
PVD2	Palo Verde-Devers Line No. 2
QF	Qualifying Facility
RAS	Remedial Action Scheme
RMR	Reliability Must-Run
RPS	Renewables Portfolio Standard
RSI	Residual Supply Index
RTO	Regional Transmission Organization
SCCT	Simple Cycle Combustion Turbine
SCE	Southern California Edison Company
SDG&E	San Diego Gas & Electric Company
SPS	Special Protection System
SSG-WI	Seams Steering Group - Western Interconnection
STEP	Southwest Transmission Expansion Plan
TCSG	Tehachapi Collaborative Study Group
TEAM	Transmission Economic Assessment Methodology
TAC	Transmission Access Charge
TGQ	Tehachapi Generation Queue
TNHC	The Nevada Hydro Company
TPT	Technical Project Team
TWRA	Tehachapi Wind Resource Area
UPFC	Unified Power Flow Controller
WECC	Western Electricity Coordinating Council

CAISO South Regional Transmission Plan for 2006 (CSRTP-2006) Report Part II: The Tehachapi Transmission Project

Table of Contents

1	Introduction.....	13
1.1	Overall Objectives	13
1.2	Public Participation in the CSRTP-2006 Process Focusing on the Tehachapi Transmission Project.....	14
1.3	Overview of the Findings.....	15
1.4	Project Cost.....	16
1.5	Project Description and Schedule.....	16
2	Description of the Tehachapi Transmission Project.....	19
2.1	Tehachapi Study Reliability Concerns	19
2.2	Tehachapi Transmission Project Plan of Service.....	20
3	System Impact Study.....	25
3.1	Reliability Analysis.....	25
3.1.1	Starting Power Flow Base Case	25
3.1.2	Contingency Analysis	26
3.1.3	Transient Stability Study Results	27
3.2	Transmission Alternatives	29
3.2.1	Alternative 1	29
3.2.2	Alternatives 2 through 4.....	30
3.2.3	Alternatives 5	32
3.3	Major Findings	32
4	Other Non-Quantified Benefits	33
4.1	RPS Program	33
4.2	Expected Economic Benefits	33
4.3	Infrastructural Improvement Benefits	33
4.4	Other Non-Quantified Benefits	34
5	Conclusions.....	35

CAISO South Regional Transmission Plan for 2006 (CS RTP-2006) Report Part II: The Tehachapi Transmission Project

1 Introduction

1.1 Overall Objectives

The CAISO is responsible for coordinating, reviewing and approving the transmission expansion for its service area. In April 2006, the CAISO initiated its South Regional Transmission Planning process for 2006 (CS RTP-2006) to assess on a regional basis three major transmission expansion projects located in southern California. These projects are:

- Sun Path Project: Combination of the San Diego Gas and Electric (SDG&E) Sunrise Powerlink Project and Citizens Energy (Citizens) and Imperial Irrigation District (IID) Green Path Project;
- Tehachapi Transmission Project: Tehachapi Wind Resource Area (TWRA) transmission infrastructure project, and
- LEAPS Project covering the Lake Elsinore Advanced Pumped Storage (LEAPS) plant and the associated transmission line.

This report is the second of three coordinated reports that will comprise the CS RTP-2006 and provides results and recommendations for the Tehachapi Transmission Project. The first report provided the findings and recommendations for the Sun Path Project.¹³ The third pending report will cover LEAPS.¹⁴


The CAISO's CS RTP-2006 assessment team included technical representatives from the three sponsoring and/or impacted Participating Transmission Owners (PTOs) (Pacific Gas and Electric Company (PG&E), Southern California Edison Company (SCE) and SDG&E), other project sponsors (The Nevada Hydro Company, Citizens, IID, Oak Creek Energy System/Tehachapi Holdings), the California Energy Commission (CEC), and the California Electricity Oversight Board (EOB). The CS RTP-2006 process was not intended as a stakeholder process, but rather was intended to provide technical focus and "real-time" technical advice for the analyses needed to study these projects.

Figure 1.1 presents the general location of the three proposed transmission projects against the backdrop of the 500kV network in the same general geographic areas.

¹³ Additional information and details of the Sun Path Project may be found at <http://www.caiso.com/1841/1841b1925a320.pdf>.

¹⁴ The CAISO has taken a phased approach for the CS RTP-2006 process to enhance study efficiency and flexibility, including the timing of study review and approval. The CAISO completed the assessment of the Sun Path Project in the first phase and received CAISO Board of Governors approval for that project on August 3, 2006. Evaluation of the LEAPS and the Tehachapi Transmission Projects continued following the Sun Path approval. The CAISO is currently awaiting guidance from FERC on the operational and rate treatment aspects of LEAPS' power plant. A separate report for the LEAPS Project (Part 3 and the final CS RTP-2006 report) will be prepared at that time.

Figure 1.1: Locations of the Projects Studied under CS RTP 2006



For additional details on the CS RTP-2006 process, please refer to Part I of the CS RTP-2006 report.

1.2 Public Participation in the CS RTP-2006 Process Focusing on the Tehachapi Transmission Project

While CS RTP-2006 participation was mainly limited to technical representation from the project sponsors, the impacted PTOs, the CEC, and the EOB for practical considerations, the CAISO launched several initiatives to share information with and receive input from the public. The CAISO's public outreach initiatives are listed in detail in Table 1.1 below.

In addition to several outreach programs held as part of the Sun Path project review intended to familiarize the public with the CS RTP-2006 process and general study assumptions, the CAISO held two days of "open house" on the CS RTP-2006 planning process and the Tehachapi Transmission Project in TWRA. The CAISO established additional outreach programs for local agencies and local community organizations and made several presentations regarding the CS RTP-2006 process and preliminary findings at workshops sponsored by the California Public Utilities Commission (CPUC) and the Southwest Transmission Expansion Plan (STEP). As a result of these public outreach programs, the CAISO received valuable comments and suggestions from stakeholders that resulted in modifications to study assumptions and methodology and, eventually, to the CAISO's findings and conclusions. Finally, this report will be posted on the CAISO website prior to the January 2007 Board of Governors meeting to facilitate public comment at that meeting.

Table 1.1 below lists the outreach activities and their results.

Table 1.1: Stakeholder and Public Outreach for the CS RTP-2006 Process

Outreach Activity	Date
Open house in San Diego on CS RTP-2006 process	- May 19 – 20, 2006
Created tailored distribution lists to reach affected parties, including those wishing not to be on master communications lists.	- May 2006 through present
Hosted conference call to discuss assumptions and comments	- June 22, 2006
Collected written stakeholder comments on assumptions.	- Through June 29, 2006
Initiated 1:1 outreach to individuals and interested groups.	- May through present
Published and re-posted updated study assumptions	- July 17, 2006
Held joint Tehachapi Transmission Workshop with CPUC	- August 23, 2006
Presented the CS RTP-2006 process and interim findings on all projects, including the Tehachapi Transmission Project, at multiple Southwest Transmission Expansion Plan (STEP) meetings.	- May 5, 2006 - July 24, 2006 - September 21, 2006 - November 17, 2006
Hosted an Open House in Tehachapi to display ISO's role in transmission planning and the Tehachapi Transmission Project final plan of service.	- September 25, 2006 - September 26, 2006
Presentation at CPUC Workshop on the Tehachapi Transmission	- November 21, 2006

1.3 Overview of the Findings

The CAISO's determinations and findings on the Tehachapi Transmission Project as presented in this report are as follows:

- i. The Tehachapi Transmission Project is the least-cost solution that reliably interconnects 4,350 MW of generating resources in TGQ;
- ii. The Tehachapi Transmission Project also addresses the reliability needs of the CAISO Controlled Grid due to projected load growth in Antelope Valley area as well as helps to address South of Lugo (SOL) transmission constraints – an ongoing source of reliability concern for the Los Angeles (LA) Basin;¹⁵
- iii. The Tehachapi Transmission Project facilitates the ability of California utilities to comply with the state mandated Renewable Portfolio Standard (RPS) by providing access to planned renewable resources in the TWRA – also see points 6 and 7 below;
- iv. The Tehachapi Transmission Project is expected to provide economic benefits to the CAISO ratepayers mainly by providing access to wind and other efficient generating resources under development in TWRA;
- v. The Tehachapi Transmission Project makes it possible to expand the transfer capability of Path 26 in the near future with a low cost upgrade of the PG&E's portion of Midway-Vincent Line 3;

¹⁵ Concerns with the SOL transmission constraints are expected to increase as additional generation resources are sited outside the LA Basin. Delivery of this new generation to LA Basin load will require significant transmission additions as identified in this plan.

- vi. The Tehachapi Transmission Project will be used by other projects in TGQ queued beyond the start date of the CS RTP-2006 for low-cost interconnection to the CAISO transmission grid;¹⁶ and
- vii. Although the detailed planning is not yet performed, the Tehachapi Transmission Project lays the groundwork for the integration of large amounts of planned geothermal, solar, and wind generation in Inyo and northern San Bernardino counties with potential future 500 kV additions from the WindHub Substation (one of Tehachapi Transmission Project's substations) to the Kramer Substation.

1.4 Project Cost

Based on estimates provided by SCE, the total cost of the Tehachapi Transmission Project is \$1.8 billion dollars in nominal terms. This cost includes the cost of the Antelope-Pardee line segment (\$90 million) previously approved by the CAISO Board of Governors, but excludes the cost of Interconnection Facilities, i.e., radial wind collector transmission systems that interconnect the individual generation projects to the grid and are the responsibility of generation developers.

The Tehachapi Transmission Project cost estimate has been developed by SCE based on planning level cost studies that include a typical twenty five percent (25%) contingency uplift to cover potential future cost increases. These planning level cost figures can still vary by as much as +/- 40% from those calculated through full scale engineering studies.

As noted above, there will also be Interconnection Facilities or generation collector systems (substations and lines) outside the scope of the Tehachapi Transmission Project presented here that will radially interconnect generators in the Tehachapi Area Generation Queue (TGQ) to the Tehachapi Transmission Project infrastructure. Such Interconnection Facilities as well as their costs and cost responsibilities are directly assigned to generation developers and will be determined based on individual System Impact Studies (SISs) for each TGQ project.¹⁷

1.5 Project Description and Schedule

Figure 1.2 depicts the major components of the Tehachapi Transmission Project at full build-out in 2013. Table 1.2 sets forth the schedule for the rollout of the major components of the Tehachapi Transmission Project. Due to the expansive nature of the Tehachapi Transmission Project, the components of this infrastructure will be developed and put into service over a five-year period starting from 2008. The addition of each component allows added access to TGQ generation as well as ensures compliance with reliability standards given projected load growth in the area. This schedule is intended to be flexible and subject to change in response to actual wind generation development in the TWRA.

¹⁶ Around 1260 MW of such generation is already in TGQ as of December 1, 2006.

¹⁷ Special rate treatment for such radial collectors systems may be provided from both the CAISO and the CPUC consistent with their respective regulatory authority.

Figure 1.2: Tehachapi Transmission Project Configuration in 2013 and Beyond




Table 1.2: Tehachapi Transmission Project Schedule

Major Transmission Facilities	Planned In-Service Date
Antelope – Pardee 230 kV Line (500 kV Specifications) & Antelope Substation Expansion*	Dec 2008
Antelope – Vincent 230 kV Line #1 (500 kV Specifications)	Mar 2009
WindHub Substation	Mar 2009
Antelope – WindHub (also known as Substation 1) 230 kV Line (500 kV Specifications)	Mar 2009
Antelope – Vincent 230 kV Line #2 (500 kV Specifications)	Mar 2011
LowWind 500/230 kV Substation (also known as Substation 5) with Loop in of Midway – Vincent #3 500 kV line	Aug 2011
Antelope – LowWind 500kV line	Aug 2011
WindHub Substation 500 kV Upgrade	Mar 2011

Antelope Substation 500 kV Upgrade	Mar 2011
Vincent Substation 500 kV & 220 kV Upgrades	Sep 2011
LowWind – WindHub 500 kV line	Oct 2011
Replacement of Vincent – Rio Hondo No. 2 230kV line	Nov 2011
Vincent – Mira Loma 500 kV line	Apr 2012
Vincent – Mesa 500/220 kV Line and Mesa Substation Work	Nov 2013

* This line segment was approved by the CAISO Board on July 29, 2004.

2 Description of the Tehachapi Transmission Project

The TWRA lies at the southern end of the San Joaquin Valley in the mountainous region between Bakersfield and Mohave. The TWRA is California's largest wind resource area. The primary goal of the Tehachapi Transmission Project is to provide transmission infrastructure to allow the wind generation potential in Tehachapi, estimated at a minimum of 4,500 MW, to reach California consumers.¹⁸

The Tehachapi Collaborative Study Group (TCSG) was formed to develop a comprehensive transmission development plan for the phased expansion of transmission capabilities in the TWRA. The CPUC Staff coordinated the TCSG. The TCSG issued the first study report to the CPUC in March 2005. The TCSG report identified a number of alternatives for the transmission infrastructure and recommended further study in order to select the best expansion plan. This second TCSG report, issued on April 2006, narrows and refines the alternatives submitted in the first report. In addition, the second TCSG report makes further recommendations to facilitate completion of the planning process and detailed technical studies.

2.1 Tehachapi Study Reliability Concerns

Path 26

Path 26 is the major interface between northern and southern California (specifically the PG&E and SCE systems) and is also a measure of the power flow between northern and southern California. Path 26 is comprised of three 500 kV lines between PG&E's Midway Substation and SCE's Vincent Substation. TWRA lies geographically and electrically between these two points. Path 26 has interface limits for both North to South (N-S) and South to North (S-N) flow. The Path 26 N-S flow rating is 4000 MW, which is limited by the double line outage of Midway-Vincent #1 and #2 500 kV lines. Path 26 N-S is supported with a Special Protection Scheme (SPS) that protects for this contingency and when armed, trips 1400 MW of local generation at Midway and 500 MW of load on the SCE system. The Path 26 S-N limit is 3000 MW.

One objective of interconnection studies is to identify Network Upgrades that prevent an adverse impact of any proposed interconnection on a path's WECC rating. Thus, the Tehachapi studies were evaluated based on maintaining the existing Path 26 limits.

Antelope Valley Area Load

The Antelope Valley area has seen continued growth and is forecast to grow at about 5% per year. The 2006 summer peak load was about 700 MW and is projected to increase to 1100 MW by 2016. SCE has identified reliability concerns in meeting the Antelope area load from the sub-transmission system by 2008 and on the bulk transmission system by year 2011. Today, existing operating procedures are used to mitigate problems on the 230 kV system that occur during heavy load conditions under both normal and contingency conditions.

¹⁸ Second Report of the Tehachapi Collaborative Study Group: Development Plan for the Phased Expansion of Electric Power Transmission Facilities in the Tehachapi Wind Resource Area, <ftp://ftp.cpuc.ca.gov/tehachapi>.

South of Lugo Transmission Constraint

Similar to the Antelope Valley area, load in eastern Los Angeles and San Bernardino Counties served by SCE substations of Mesa, Rio Hondo, Laguna Bell, Walnut, Chino, Mira Loma, Vista, etc., has also experienced rapid growth in recent years that is expected to continue in the future. This area South of Vincent is currently served via 230 kV transmission from Pardee and Vincent, and three 500 kV lines South of Lugo. A new Rancho Vista 500/230 kV substation was approved by the CAISO Board of Governors on January 27, 2005, to help supply the local area and will be served via one of the existing 500 kV lines from Lugo and Mira Loma substations. The local 230 kV transmission system in the area will become heavily stressed during conditions with heavy Path 26 N-S flows, high Ventura generation west of Pardee, high generation from North of Lugo and high deliveries from El Dorado, and with low generation south of the Mesa area. Current limit on the South of Lugo path is 6,100 MW, and is expected to be 6,400 MW with the completion of Rancho Vista 500/230kV Substation in 2009. However, under the CAISO's Local Capacity Requirements (LCR) study, South of Lugo flow is projected to be the limitation under a double-line contingency¹⁹ beyond 2011. The transmission upgrades, identified in the plan of service, are expected to mitigate these South of Lugo reliability problems.

2.2 Tehachapi Transmission Project Plan of Service

A list of the facilities constituting the Tehachapi Transmission Project plan of service is presented in the following. Table 2.1 presents the planned in-service date and the overall cost of these components. The timing of complete build-out of the facilities will be eventually influenced by the actual generation development in the area. However, the cost impact of the schedule change is expected to be very small.

New or Upgraded Substations:

- Three new substations used as collector stations for the wind farms in the TWRA: WindHub, LowWind and HighWind Substations. The first two of the three new substations are part of the network component of the overall plan of service. The cost of the third substation is the responsibility of the wind developers and not included in the Tehachapi Transmission Project plan.
 - WindHub 500/230/66 kV will include up to four 500/230 kV transformer banks, four breaker-and-half 500 kV bus positions, six initial breaker-and-half 230 kV bus positions, static voltage support devices, and dynamic voltage support if necessary. Additional equipment will be added as wind generation develops in the region.
 - LowWind 500/230 kV will include up to two 500/230 kV transformer banks, four breaker-and-half 500 kV bus positions, three initial breaker-and-half 230 kV bus positions, static voltage support devices, and dynamic voltage support if necessary. Also includes loop in of Midway-Vincent #3 line to connect substation to grid. Additional equipment will be added as wind generation develops in the region.

¹⁹ Double-line contingency of Palo Verde – Devers 500kV # 1 & 2 lines

- Upgrades to existing substations:
 - The Pardee 230/66 kV substation will be upgraded by outfitting existing 230 kV line position.
 - The existing Mira Loma 500/230/66 kV substation will be upgraded by outfitting existing 500 kV line position.
 - The existing 230/66 kV Antelope Substation will be expanded to include a new 500 kV switchyard, additional 230 kV line positions and static and dynamic voltage support.
 - The existing 500/230 kV Vincent Substation will be expanded to include additional 500 kV and 230 kV line positions, additional static and dynamic voltage support and additional 500/230 kV bank capacity.
 - The Mesa 230/66 kV substation will be upgraded by outfitting existing 230 kV line position.
 - The Gould 230/66 kV substation will be upgraded by outfitting existing 230 kV line position.

New or Upgraded Transmission Lines:

- New 25.6-mile 500 kV transmission line between Antelope and Pardee substations initially operated at 230 kV. This line is also known as Phase 1-Segment 1 of the original Antelope Transmission Project. Construction to 500 kV specifications with initial operation at 230 kV is required to maximize the capability of limited transmission corridors and minimize environmental impacts associated with multiple 230 kV lines and/or multiple tear-down and rebuild activities. Actual operation of 500 kV will be determined by the amount of generation build out in the system and changes to system conditions.²⁰
- New 25.6-mile 500 kV transmission line between WindHub and Antelope substations. This line is also known as Phase 1-Segment 3 of the original Antelope Transmission Project and will initially operate at 230 kV.
- Two new 500 kV transmission lines between Antelope and Vincent substations.
 - The initial 500 kV transmission line will be approximately 21.0 miles built on new right-of-way mostly adjacent to the existing right-of-way. This line is also known as the Phase 1-Segment 2 of the original Antelope Transmission Project and will initially operate at 230 kV. This new transmission line is primarily required to meet the reliability needs of the CAISO controlled grid due to projected load growth in Antelope Valley.
 - The second 500 kV transmission line will be approximately 18.0 miles built on existing right-of-way replacing the existing Antelope-Vincent and Antelope-Mesa 230 kV transmission lines. This transmission line will also be initially operated at 230 kV.
- New 75-mile 500 kV transmission line between Vincent and Mira Loma substations. This transmission line is required to eliminate the South of Lugo transmission constraints, which have been a source of ongoing reliability concern for the LA Basin, especially in light of

²⁰ The CAISO Board of Governors approved the line on July 29, 2004; however, the CAISO included it as part of the proposed comprehensive solution for the Tehachapi and surrounding areas as presented in this report.

projected load growth in Mira Loma area, and is planned to go into service by 2012 timeframe. This line will utilize the existing Vincent-Rio Hondo No.2 230 kV transmission line (portion already built to 500 kV standards), portion of the existing Antelope-Mesa 230 kV South of Vincent, portions of existing idle 230 kV transmission line segments, and portions of new construction between the Mesa area and Mira Loma area. Between Vincent and the northern boundary of the City of Duarte (adjacent to Angeles National Forest), the transmission line will be constructed as single-circuit 500 kV specifications. From this point to the Mira Loma area, the transmission line will be constructed as double-circuit 500 kV specifications to maximize the capability of limited corridors and to minimize environmental impacts associated with multiple 230 kV lines and/or multiple tear-down and rebuild activities.

- New 32.5-mile 500/230 kV transmission line between Vincent and Rio Hondo is required to replace the existing Vincent-Rio Hondo No.2 230 kV transmission line that was utilized for the new Vincent-Mira Loma 500 kV transmission line. This line will utilize portion of existing Antelope-Mesa 230 kV transmission line and will be built to 500 kV specifications to maximize capability of limited transmission corridors avoid waste and numerous minimize environmental impacts associated with multiple 230 kV transmission lines and/or multiple tear-down and rebuild activities. As discussed above, such construction standard will allow for a future low cost upgrade to 500 kV operation.
- New 14-mile 500 kV transmission line between proposed LowWind and upgraded Antelope substations.
- New 42-mile 500/230 kV transmission line between Vincent and Mesa substations. Between Vincent and the Gould substation areas, this line will be built to 500 kV specifications to maximize capability of limited transmission corridors and minimize environmental impacts associated with multiple 230 kV transmission lines and/or multiple tear-down and rebuild activities and to allow for future low cost upgrade to 500 kV operation.

Table 2.1: Tehachapi Transmission Project Plan of Service

Segment	Major Transmission Facilities	Planned In-Service Date
1	New Antelope – Pardee 230 kV Line (500 kV Specifications) ¹ & Antelope Substation Expansion	Dec 2008
2 & 3	New Antelope – Vincent 230 kV Line #1 (500 kV Specifications)	Mar 2009
	WindHub Substation New Antelope – WindHub (also known as Substation 1) 230 kV Line (500 kV Specifications)	Mar 2009
5	New Antelope – Vincent 230 kV Line #2 (500 kV Specifications)	Mar 2011
4	New LowWind 500/230 kV Substation (also known as Substation 5) with Loop in of Midway – Vincent #3 500 kV line	Aug 2011
	Antelope – LowWind 500kV line	Aug 2011


Segment	Major Transmission Facilities	Planned In-Service Date
9	WindHub Substation 500 kV Operation	Mar 2011
	Antelope Substation 500 kV Operation	Mar 2011
	Vincent Substation 500 kV & 220 kV Upgrades	Sep 2011
10	New LowWind – WindHub 500 kV line	Oct 2011
6	Replacement of Vincent – Rio Hondo No. 2 230kV line	Nov 2011
7 & 8	New Vincent – Mira Loma 500 kV line	Apr 2012
11	New Vincent – Mesa 500/220 kV Line and Mesa Substation Work	Nov 2013
Total Cost Estimate for the Tehachapi Transmission Project (Nominal dollars)		\$1,800M

It must be noted that the project schedule and cost figures presented here are all planning level estimates developed based on best available information of SCE on the constructability of the facilities and the actual cost of procurement of necessary material and construction of the facilities in the years that the actual construction takes place. Some of the costs are based on detailed engineering analysis (around +/-10% accurate) and others are based on planning studies (around +/- 40% accurate).²¹ The CAISO estimates that the total cost is also accurate within 40%. The CAISO realizes that the actual schedule and cost may vary once detailed engineering analysis of the entire Tehachapi Transmission Project plan of service is complete – expected by mid-2007.

Figure 2.1 presents the overall Tehachapi Transmission Project plan of service upon completion.

²¹ All cost figures include a 25% contingency markup.

**Figure 2.1: Tehachapi Transmission Project Plan of Service
(Routes shown below are for illustration purposes only)**



3 System Impact Study

The CAISO worked with the project sponsor (SCE) and other participants in the CS RTP-2006 process to plan the Tehachapi Transmission Project in a manner that reliably interconnects and allows delivery of all generating projects (4,350 MW) in the TGQ up to the date the CS RTP-2006 process was launched (April of 2006). Table 3.1 provides the list of such targeted generation in the TGQ.

Table 3.1 – Tehachapi Generation Queue through April 2006

Project	Queue Date	Queue Position	Type	Capacity (MW)
Project 1	9/4/2003	20	WT	300
Project 2	5/11/2004	31	WT	201
Project 3	7/19/2004	34	WT	300
Project 4	11/18/2004	41	CT	158.8
Project 5	6/17/2005	WDAT	CT	49.9
Project 6	6/27/2005	73	WT	250
Project 7	9/7/2005	79	WT	51
Project 8	12/1/2005	84	WT	400
Project 9	12/28/2005	85	WT	120
Project 10	1/20/2006	86A	WT	33.1
Project 11	1/20/2006	86B	WT	34
Project 12	2/22/2006	91	WT	51
Project 13	2/24/2006	92	CC	570
Project 14	3/1/2006	93	WT	220
Project 15	3/1/2006	94	WT	180
Project 16	3/1/2006	95	WT	550
Project 17	3/1/2006	96	WT	600
Project 18	3/1/2006	97	WT	160
Project 19	4/5/2006	100	WT	120
TOTAL				4,350

* WT: Wind Turbine; CT: Combustion Turbine; CC: Combined Cycle

The CAISO utilized the efforts of the CS RTP-2006 in order to efficiently comply with its obligations under the LGIP. It did so by accounting for all the LGIP provisions for System Impact Studies (SIS) into the CS RTP-2006 study process. As such, the study that was performed was type of "clustered" system impact study to interconnect all targeted generation in the TGQ.

3.1 Reliability Analysis

3.1.1 Starting Power Flow Base Case

The CAISO provided a power flow case based on 2015 summer peak load condition. In addition to the power flow basecase, the power flow case was adjusted to reflect possible stress on the ISO Controlled Grid. The emphasis was on the northern SCE area with full network representation of the SCE's proposed transmission upgrades required for connecting

the Tehachapi generation projects in the queue position through April 2006. The adjusted power flow case was tested along with dynamic data for system stability, and was determined to be stable.

3.1.2 Contingency Analysis

Based on the targeted generation projects of 4,350 MW in Tehachapi area, the study results indicated no facility overload and voltage issue for normal (N-0) and contingency (N-1 and N-2) conditions. Table 3.2 provides the summary listing of the critical contingencies that were evaluated for the study.

Table 3.2 – List of Contingencies for the Tehachapi Transmission Project Study

	Contingencies	NERC/WECC Category
1	WindHub (Sub.1) – Antelope 500kV Line	B
2	WindHub (Sub.5) – LowWind (Sub.5) 500kV Line	B
3	LowWind (Sub.5) – Midway 500kV Line	B
4	Vincent – Mesa 230kV Line	B
5	Vincent – Mira Loma 500kV Line	B
6	Vincent – Rio Hondo 230kV Line	B
7	Lugo – Vincent 500kV Line	B
8	Vincent – Antelope 500kV Line	B
9	Lugo – Mira Loma 500kV Double Lines	C
10	Lugo – Vincent 500kV Double Lines	C
11	Midway – Vincent 500kV Double Lines (with SPS for 4000 MW Path 26 flow)	C
12	LowWind (Sub.5) – South 500kV Double Lines (Sub.5 – Antelope & Sub.5 – Vincent 500kV Lines)	C
13	Vincent – Antelope 500kV Double Lines	C
14	Vincent – Mesa 230kV Double Lines	C
15	Vincent – North 500kV Double Lines (Vincent – Antelope & Vincent – LowWind (Sub.5) 500kV Lines)	C
16	Vincent – Rio Hondo 230kV Double Lines	C

Table 3.3 shows the results of the post-transient governor power flow studies with the Tehachapi Transmission Project modeled in the study power flow case. With the proposed plan of service for the Tehachapi Transmission Project, up to 4,350 MW of new generation in the Tehachapi area can be connected to the ISO Controlled Grid.

**Table 3.3 – Line Loading under Basecase and Contingency conditions
(Post-transient Governor Power Flow Study Results Summary)**

Equipment	Normal Rating Amps/MVA	Emergency Rating Amps/MVA	Loading	N	Contingency Description
Lugo - Ranchvst 500 Ckt 1	3950	5330	4980.3*	N-2	Lugo-Miraloma-DLO
Vincent - Rihondo 230 Ckt 1	2480	3300	2213.2	N-0	Basecase
			2923.1*	N-1	Vincent-Rihondo-SLO
			N/A	N-2	Vincent-South-DLO (Vincent-Mesa & Vincent-Serrano 500kV)

* Above normal but below emergency rating.

3.1.3 Transient Stability Study Results

Transient stability with 10-second run was performed for the proposed Tehachapi Transmission Project under the assumptions of 4,000 MW flow for Path 26 (Midway – Vincent 500kV lines) in the North – South direction and with 4,350 MW of new generation additions in the TWRA. With the proposed plan of service for the Tehachapi Transmission Project, the study results met the NERC/WECC Planning Standards and the criteria of the WECC Disturbance Performance Table. Since many of these generation projects have not completed the LGIP process, typical dynamic data for the wind generating units were modeled. In addition, typical dynamic data for the combined and simple cycle generating units in the area were modeled for the proposed thermal generation projects. As more detailed and accurate dynamic data for these new generation units become available, additional further transient analyses will be required to ensure that there are no transient stability concerns with the new data.

**Table 3.4: Transient Voltage and Frequency Study Results
Category B - Loss of Single Element**

Contingency	Transient Voltage Dip (%) and Damping	Lowest Transient Frequency at Load Bus (Hz)	Comments
1 Lugo-Vincent 500kV	Rio Hondo 66kV, $\Delta V = 0.9\%$, Rio Hondo 230kV, $\Delta V = 0.9\%$, Damping > 0	Gold Hills 115kV, $f = 59.99$ Hz	Meet WECC Planning Standards
2 Sub.1 – Antelope 500kV	Marshall 92kV, $\Delta V = 1.3\%$, MRedwtp 69kV, $\Delta V = 1.2\%$, Damping > 0	Wilsona 66kV, $f = 59.42$ Hz for $t < 6$ cycles	Meet WECC Planning Standards
3 Sub.1 – Sub.5 500kV	Marshall 92kV, $\Delta V = 1.3\%$, Shields 92kV, $\Delta V = 1.3\%$, Damping > 0	Wilsona 66kV, $f = 59.42$ Hz for $t < 6$ cycles	Meet WECC Planning Standards
4 Sub.5 – Midway 500kV	Northcst 69kV, $\Delta V = 2.1\%$, MRedwtp 69kV, $\Delta V = 2.0\%$, Damping > 0	Wilsona 66kV, $f = 59.28$ Hz for $t < 6$ cycles	Meet WECC Planning Standards

	Contingency	Transient Voltage Dip (%) and Damping	Lowest Transient Frequency at Load Bus (Hz)	Comments
5	Vincent-Antelope 500kV	La Cienega 66kV, $\Delta V=6.5\%$, Tehachmm 66kV, $\Delta V=12.1\%$, Damping >0	Rio Hondo 66kV, $f=59.07$ Hz for $t < 6$ cycles, Searles 34.5kV, $f < 59.6$ Hz for 9 cycles	Meet WECC Planning Standards
6	Vincent-Mesa 230kV	Rector 66kV, $\Delta V=10.9\%$, Rector 230kV, $\Delta V=12.7\%$, Damping >0	Rio Hondo 66kV, $f=59.15$ Hz for $t < 6$ cycles	Meet WECC Planning Standards
7	Vincent – Mira Loma 500kV	Goldhills 115kV, $\Delta V=4.5\%$, Tehachmm 66kV, $\Delta V=4.2\%$, Damping >0	Mira Loma 66kV, $f=59.06$ Hz for $t < 6$ cycles, Searles 34.5kV, $f < 59.6$ Hz for 9 cycles	Meet WECC Planning Standards
8	Vincent – Rio Hondo 230kV	Rector 66kV, $\Delta V=4.5\%$, Rector 230kV, $\Delta V=4.2\%$, Damping >0	Rio Hondo 66kV, $f=59.15$ Hz for $t < 6$ cycles	Meet WECC Planning Standards

**Table 3.5: Transient Voltage and Frequency Study Results
Category C Events (Loss of Two or More Elements)**

	Contingency	Highest Transient Voltage Dip (%) and Damping	Lowest Transient Frequency at Load Bus (Hz)	Comments
1	Lugo-Mira Loma 500kV Double Line	Goldhills 115kV, $\Delta V=9\%$, Tap604 115kV, $\Delta V=8.7\%$, Damping >0	Searles 34.5kV, $f=59.68$ Hz	Meet WECC Planning Standards
2	Lugo-Vincent 500kV Double Line	Rio Hondo 66kV, $\Delta V=4\%$, Rio Hondo 230kV, $\Delta V=3.7\%$, Damping >0	Aurora 69kV, $f=59.95$ Hz	Meet WECC Planning Standards
3	Midway-Vincent 500kV DLO with SPS	Lakeview 69kV, $V=8.2\%$ Hackamor 69kV, $\Delta V=7.9\%$ Damping >0	Wilsona 66kV, $f=59.15$ Hz	Meet WECC Planning Standards
4	Sub.5-Antelope & Sub.5-Vincent 500kV Double Line (aka Sub.5-South Double Line)	Goldhills 115kV, $\square V=2.5\%$, Tap601 115kV, $\square V=2.4\%$, Damping >0	Wilsona 66kV, $f=59.28$ Hz	Meet WECC Planning Standards
5	Vincent-Antelope 500kV Double Line	La Cienega 66kV, $\Delta V=21.8\%$, La Cienega 230kV, $\Delta V=15.9\%$, Damping >0	Rio Hondo 66kV, $f=59.07$ Hz Searles 34.5kV, $f < 59.6$ Hz for 6.8 cycles	Meet WECC Planning Standards, except for Searles 34.5kV (this is an existing pre-project concern)
6	Vincent-Mesa 230kV Double Line	Rio Hondo 66kV, $\Delta V=4.9\%$, Rio Hondo 230kV, $\Delta V=4.6\%$, Damping >0	Rio Hondo 66kV, $f=59.15$ Hz	Meet WECC Planning Standards,

	Contingency	Highest Transient Voltage Dip (%) and Damping	Lowest Transient Frequency at Load Bus (Hz)	Comments
7	Vincent-Antelope & Vincent-Sub.5 500kV Double Line (aka Vincent – North 500kV DLO)	La Cienega 66kV, $\Delta V=20.1\%$, La Cienega 230kV, $\Delta V=14.5\%$, Damping >0	Rio Hondo 66kV, $f=59.07$ Hz Searles 34.5kV, $f<59.6$ Hz for 6.8 cycles	Meet WECC Planning Standards, except for Searles 34.5kV (existing pre-project concern)
8	Vincent – Rio Hondo 230kV Double Line	Rector 66kV, $\Delta V=5.1\%$, Rector 230kV, $\Delta V=4.7\%$, Damping >0	Rio Hondo 66kV, $f=59.15$ Hz	Meet WECC Planning Standards

3.2 Transmission Alternatives

The CS RTP-2006 process reviewed and investigated several major project alternatives in order to optimize the recommended plan of service. This section presents the five most promising alternatives that were considered and studied in some detail for this project. Figures 5.1 To 5.5 show alternative configurations considered and the related estimated costs.²² In all these alternatives, South of Vincent upgrades are common with those identified in the Tehachapi Transmission Project plan of service as presented in this report.


As shown below, all the alternatives considered were more expensive than the selected plan of service for the Tehachapi Transmission Project. At the same time, all alternatives are comparable with the selected method of service in regards to integrating TGQ generation projects, addressing load growth in Antelope Valley area, and mitigating South of Lugo constraints.

3.2.1 Alternative 1

Alternative 1 was the first alternative considered by the CS RTP-2006 team and was studied to a great extent. It was shown to provide the same level of benefits as the proposed Tehachapi Transmission Project, however, at a higher cost.

²² The cost estimates are planning level estimates based on unit costs. Cost Estimates do not include Right-of-way (R/W) for transmission lines and land use for substations.

Figure 4.1: Alternative 1



3.2.2 Alternatives 2 through 4

Alternatives 2 through 4 were recommended by the Tehachapi Collaborative Study Group (TCSG). All these alternatives cost more than the proposed Tehachapi Transmission Project.

Figure 4.2: Alternative 2




Figure 4.3: Alternative 3






Figure 4.4: Alternative 4



3.2.3 Alternatives 5

Alternative 5 was an interim alternative proposed by SCE which would provide additional benefits compared to that of the proposed Tehachapi Transmission Project but at higher cost.

Figure 4.5: Alternative 5



3.3 Major Findings

1. The Tehachapi Transmission Project is the least cost network transmission solution to reliably interconnect a total of 4,350MW capacity of the TGQ generation projects under the 2015 summer peak load condition.
2. Even though the LGIP “clustering” study was performed to determine the total network upgrade to connect a total of 4,350MW new generation additions in the Tehachapi area, individual System Impact Studies will still be needed for these projects to determine direct facility assignment requirements to connect these projects to the ISO Controlled Grid.
3. Detailed dynamic data will still be required from the generation developer for accurate dynamic model in future WECC power flow base cases. At this time, only typical General Electric (GE) new wind model is used for the study.

4 Other Non-Quantified Benefits

In the course of CS RTP-2006 studies, the CAISO quantified Tehachapi Transmission Project benefits based on the quantifiable energy saving, green house gas (GHG) reduction benefits, and additional regulation costs. The CAISO also accounted for the reliability benefits of this project. However, many other operational and strategic benefits for the proposed Tehachapi Transmission Project are presently difficult to quantify. In the following, the sources of these benefits are discussed qualitatively.

4.1 RPS Program

Senate Bill 1078 established the California Renewables Portfolio Standard (RPS) program, which requires an annual increase in renewable generation by CPUC-jurisdictional utilities equivalent to at least 1 percent of sales, with an aggregate goal of 20 percent by 2017. The CPUC is aggressively implementing this policy, with the intention of accelerating the completion date to 2010. The CPUC is also considering ways to achieve 33 percent renewable energy by 2020. Other load serving entities (LSEs), including municipal and other public utilities, are also required to adopt RPS standards.

According to the CPUC²³, actual renewable deliveries in 2005 were:

- PG&E – 13.5 % (9,801 GWh)
- SCE – 17.7% (13,195 GWh)
- SDG&E - 5.5% (830 GWh)

In 2005, renewable resources consumption in California is about 23,800 GWh, which amounts to about 14.6% of total energy consumption.

The Tehachapi Transmission Project provides needed access to the renewable resources in the TWRA. The Tehachapi Transmission Project allows California LSEs to tap into the renewable power sources in this area. Because of the lack of sufficient transmission infrastructure to the TWRA, the renewable resources potential of the area cannot be readily available or developed without the Tehachapi Transmission Project. Although the renewable resources potential cannot be the only consideration for the proposed transmission investments, it is indeed one of the key concerns for optimizing statewide transmission capacity and accommodating renewable energy potentials.

4.2 Expected Economic Benefits

Significant economic benefits are expected as the Tehachapi Transmission Project provides access to renewable and efficient generation projects slated in the TWRA.

4.3 Infrastructural Improvement Benefits

The Tehachapi Transmission Project helps improve the robustness of the California's aging electric transmission system. It mitigates grid congestion and brings new renewable and conventional power plants online. Without transmission infrastructure upgrades, Californian may face negative impacts on the future economy in the region when frequent outages or disturbances might occur due to equipment degradation. The specific infrastructural

²³ http://www.cpuc.ca.gov/Static/energy/electric/renewableenergy/060224_rpssummary.htm

improvement benefits that the Tehachapi Transmission Project will bring include the followings:

- Provide the potential to expand Path 26 capability at a low cost in the near future with the upgrade of PG&E's portion of Midway-Vincent Line 3;
- Provide more options for future transmission expansions and realize the long-term vision of California's transmission infrastructure; and
- Integrate large amount of planned renewable resources (mainly solar generation) in Inyo and northern San Bernardino counties by future addition of a 500 kV line from WindHub Substation (one of Tehachapi Transmission Project's substations) and the Kramer Substation.

4.4 Other Non-Quantified Benefits

The Tehachapi Transmission Project provides the following additional listed benefits:

- Reduction in NOx and SOx and other pollutant emissions from displaced fossil fuel generation;
- Potential reduction in gas prices stemming from lower fuel consumption by the gas generators that are displaced by the wind generation in TWRA - the benefits here would be both due to lower generation cost as well as other societal benefits stemming from lower gas costs;
- Augmentation of competitive wholesale energy markets for California; and
- Further diversification of energy resources.

The CAISO has not attempted to quantify these additional benefits.

5 Conclusions

The CSRTP-2006 assessment of the Tehachapi Transmission Project leads to the following major findings regarding the project:

- The Tehachapi Transmission Project is the least-cost solution that reliably interconnects 4,350 MW of generating resources in TGQ;
- The Tehachapi Transmission Project also addresses the reliability needs of the CAISO controlled grid due to projected load growth in Antelope Valley area as well as helps to address the South of Lugo (SOL) transmission constraints, an ongoing source of reliability concern for the Los Angeles (LA) Basin;
- The Tehachapi Transmission Project facilitates California utilities to comply with the state mandated Renewable Portfolio Standard (RPS) by providing access to planned renewable resources in the TWRA;
- The Tehachapi Transmission Project is expected to provide significant economic benefits to the CAISO ratepayers by providing access to wind and other efficient generating resources under development in TWRA;
- The Tehachapi Transmission Project makes it possible to expand the transfer capability of Path 26 in the near future with a low cost upgrade of the PG&E's portion of Midway-Vincent Line 3;
- The Tehachapi Transmission Project will be used by other projects in TGQ queued beyond the start date of the CSRTP-2006 for low-cost interconnection to the CAISO transmission grid; and
- Although the detailed planning is not yet performed, the Tehachapi Transmission Project lays the groundwork for the integration of large amounts of planned geothermal, solar, and wind generation in Inyo and northern San Bernardino counties with potential future 500 kV additions from the WindHub Substation (one of Tehachapi Transmission Project's substations) to the Kramer Substation.

Based on the aforementioned findings, the CAISO Management has concluded that the build out of the entire Tehachapi Transmission Project by SCE should move forward effective immediately.

CERTIFICATE OF SERVICE

I hereby certify that I have this day served the foregoing document upon all of the parties listed in the attached filing as receiving service, in accordance with the requirements of Rule 2010 of the Commission's Rules of Practice and Procedure (18 C.F.R. § 385.2010).

Dated at Folsom, California, on this 19th of January, 2007.

Charity Wilson (WNLK)
Charity Wilson