

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA**

Application of Pacific Gas and Electric Company for Recovery of Costs to Implement Electric Rule 24 Direct Participation Demand Response (U39E).	Application 14-06-001 (Filed June 2, 2014)
And Related Matters	Application 14-06-002 Application 14-06-003

CORRECTIONS TO THE JUNE 22, 2015 WORKSHOP REPORT

On June 15, 2015, the California Public Utilities Commission (Commission) held a workshop regarding investor-owned utility applications seeking cost recovery to implement Electric Rules 24 and 32. Pursuant to the Administrative Law Judge’s June 11, 2015 E-mail Ruling providing workshop details, Pacific Gas & Electric Company (PG&E), San Diego Gas and Electric Company (SDG&E) and Southern California Edison Company (SCE) submitted a joint workshop report June 22, 2015 (Workshop Report). The California Independent System Operator Corporation (CAISO) submits the following correction to the Workshop Report.

Page 3 of the Workshop Report currently reads as follows:

Q. Ali Miremadi (CAISO): The 15 minute parsing to 5 minute data is still available for energy, but not applicable for ancillary services (capacity). The CAISO determines whether a resource met its DR requirements (i.e. if capacity is or is not available) through 5 minute telemetry. This whole issue is still going through the CAISO processes but OK for now. The baseline from telemetry data could be different from the baseline from 5 minute interval data. (Footnotes omitted.)

The CAISO believes this paragraph should be modified to read as follows:

Q. Ali Miremadi (CAISO): CAISO rules allow parsing of 15-minute settlement meter data into 5-minute settlement meter data. CAISO is also changing its telemetry scan rate for energy only resources to 5 minutes partially in anticipation that 5 minute settlement meter data can be used for telemetry.

CAISO settlement uses 5-minute meter data to see if DR Resource met its capacity obligation for No Pay provisions.

The baseline for a resource with 15-minute meter data parsed into 5-minute meter data can be different than the baseline for the same resource with 5-minute settlement meter reads.

Other than this correction, the CAISO has no further comments on or corrections to the Workshop Report.

Respectfully submitted,

By: /s/ Jordan Pinjuv

Roger E. Collanton

General Counsel

Anthony Ivancovich

Deputy General Counsel

Anna A. McKenna

Assistant General Counsel

Jordan Pinjuv

Counsel

California Independent System

Operator Corporation

250 Outcropping Way

Folsom, CA 95630

T – 916-351-4429

F – 916-608-7222

jpinjuv@caiso.com

Dated: June 25, 2015