

Application No.: 15-08-027
Exhibit No.: CAISO-
Witness: Weiwu Chen

In the Matter of the Application of
NEXTERA ENERGY TRANSMISSION
WEST, LLC for a Certificate of Public
Convenience and Necessity for the Suncrest
Dynamic Reactive Power Support Project

Application 15-08-027

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

May 16, 2017

Table of Contents

I.	INTRODUCTION.....	1
II.	BACKGROUND.....	4
III.	DISCUSSION.....	7
A.	Deliverability Benefits.....	7
B.	San Diego Import Capability Benefits.....	12
C.	Reliability Benefits.....	15
D.	Local Capacity Requirement Benefits.....	20
E.	Project Timing.....	21
IV.	CONCLUSION.....	22
	APPENDIX A.....	23

1 **BEFORE THE PUBLIC UTILITIES COMMISSION OF THE**
2 **STATE OF CALIFORNIA**

In the Matter of the Application of
NEXTERA ENERGY TRANSMISSION
WEST, LLC for a Certificate of Public
Convenience and Necessity for the Suncrest
Dynamic Reactive Power Support Project

Application 15-08-027

3
4
5 **TESTIMONY OF WEIWU CHEN**
6 **ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR**
7 **CORPORATION**
8

9 **I. INTRODUCTION**

10 **Q1. What is your name and by whom are you employed?**

11 **A1.** My name is Weiwu Chen and I am employed as a Regional Transmission Engineer Lead
12 at the California Independent System Operator Corporation (CAISO), 250 Outcropping
13 Way, Folsom, California.

14
15 **Q2. Please describe your educational and professional background.**

16 **A2.** I hold a Master of Engineering degree from University of Alberta, Canada, and received
17 both Bachelor of Science and Master of Science degrees in electrical engineering from
18 Xi'an Jiaotong University, China. I have been in the electric power industry for 28 years.
19 More specifically, I have experience in transmission planning, system operation, resource
20 adequacy, and energy economics. I have worked at the CAISO for 8 years and before
21 that I spent 8 years with Kansas City Power & Light. Prior to working at Kansas City
22 Power & Light I spent 12 years with Hatch consulting firm and State Grid Energy
23 Research Institute in Canada and China, respectively.

24
25 **Q3. What is the purpose of your testimony?**

26 **A3.** The purpose of this testimony is to provide an overview of the CAISO's technical
27 analysis underlying the CAISO's recommendation that the Commission approve NextEra
28 Energy Transmission West, LLC's (NEET West's) application for a certificate of public
29 convenience and necessity authorizing the construction of the Suncrest Dynamic Reactive
30 Power Support Project (Proposed Project). This testimony presents an updated analysis of

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

Page 2 of 26

1 the policy-driven need for the Proposed Project to achieve the California greenhouse gas
2 emission targets and meet California’s Renewables Portfolio Standard (RPS) goals. The
3 CAISO analysis confirms the need for the Proposed Project, which provides an important
4 network addition to achieve the state-mandated RPS goals and significant additional
5 benefits for CAISO.

6
7 **Q4. Please provide an overview of the Proposed Project and why it is needed as a policy-**
8 **driven project addition to the CAISO Controlled Grid.**

9 **A4.** The 2013-14 CAISO Transmission Plan identified a need for a dynamic reactive power
10 device connected to the Suncrest substation as a policy-driven transmission addition to
11 the CAISO Controlled Grid¹ necessary to meet the RPS goal. The Proposed Project
12 meets the reactive power requirements by installing a +300/-100 mega volt-ampere
13 reactive (“Mvar”) static var compensator (SVC) that will be connected to the existing
14 Suncrest substation via a 1.5 mile 230 kV underground transmission line. The initial
15 driver for the Project was a post-transient voltage deviation performance concern in the
16 southern California transmission grid based on the 33% RPS goal, which was established
17 in 2002 under Senate Bill 1078, accelerated in 2006 under Senate Bill 107, and expanded
18 in 2011 under Senate Bill 2. The concern was mainly caused by the addition of renewable
19 generation in the general Imperial area as part of the RPS portfolios, coupled with the
20 early retirement of generation in the southern California area, including the San Onofre
21 Nuclear Generating Station (SONGS), and gas-fired generation that plans to close in
22 compliance with the State’s policy to eliminate coastal water use in once-through
23 cooling. Since the 2013-14 Transmission Plan, there have been some changes in the
24 southern California power grid that this analysis takes into account. The updated analysis
25 confirms that the Proposed Project is required to meet California state RPS policy while
26 meeting all applicable system reliability performance requirements specified in the North
27 American Electric Reliability Corporation (NERC) and Western Electricity Coordinating
28 Council (WECC) standards and CAISO planning standards grid operation procedures. If

¹ Terms not otherwise defined herein are defined in the CAISO Tariff, Appendix A.

TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027

Page 3 of 26

1 the Proposed Project is approved by the Commission, it will provide various benefits to
2 the CAISO Controlled Grid in the southern California area, which include, but are not
3 limited to:

- 4 • increasing renewable generation deliverability from the Imperial, Baja, and Arizona
5 renewable energy zones to the CAISO Controlled Grid by as much as 1045 MW,
6 while ensuring system operation within applicable reliability criteria and the grid
7 operation procedures;
- 8 • increasing San Diego power import capability by as much as 306 MW. This increased
9 import capability helps to accommodate more renewable energy by allowing the
10 California wholesale energy market to access lower cost electricity, and making the
11 grid operation less constrained to address the oversupply concerns;
- 12 • reducing the risk of potential post-transient voltage instability under emergency
13 conditions in the San Diego area and Los Angeles Basin by boosting the San Diego
14 Import Transmission (SDIT) system potential Interconnected Reliability Operating
15 Limit (IROL) by as much as 220 MW;
- 16 • providing additional reliability benefits by deferring or alleviating potential needs for
17 reliability upgrades in the San Diego area that are estimated to cost \$48 million-\$136
18 million;
- 19 • reducing local capacity requirements in the San Diego area and Miramar sub-area by
20 about 326 MW and 30 MW, respectively;
- 21 • reducing the potential exposure of cross-tripping SDG&E's 230 kV tie with
22 CENACE², which may jeopardize reliability in the CENACE system and result in
23 potential voltage instability in the Los Angeles Basin and the San Diego area.

24 The CAISO details each of these benefits below.
25

² CENACE is the grid operator for Baja California, which is electrically interconnected with the CAISO and WECC system.

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

Page 4 of 26

1 **II. BACKGROUND**

2 **Q5. Please explain the CAISO's assumptions and approaches used to update its analysis.**


3 **A5.** The CAISO conducted power flow simulations to update the technical assessments that
4 justify the need for the Proposed Project. The underlying assumptions are based on the
5 Commission-developed RPS portfolio used in the CAISO's 2015-16 transmission
6 planning process. The CAISO also verified the need based on the California Energy
7 Commission's latest load demand forecast and the unified planning assumptions in the
8 CAISO 2016-17 TPP cycle. The key assumptions are summarized in Appendix A. Below
9 is a brief description of the CAISO's four approaches to calculate the incremental
10 benefits of the Proposed Project discussed above.

11
12 1. Deliverability Benefits

13 The CAISO approximated generation deliverability, based on transmission system
14 transfer capability, to calculate potential increases in deliverability of renewable
15 generation attributable to the Proposed Project. The benefit was estimated based on
16 differences between electrical transmission system performance under two distinct
17 operational conditions. In each operational condition, the CAISO determined the levels
18 of deliverability with and without the Proposed Project. Figure 1 illustrates generation
19 deliverability paths from the renewable zones (Point A) to the CAISO Controlled Grid
20 (Point B1/B2/B3).

21

1 **Figure 1: Generation Deliverability Path to CAISO Controlled Grid**




2
3 **2. San Diego Import Capability Benefits**

4 The CAISO used its System Operating Limits Methodology for the Planning Horizon to
5 calculate power import or transfer capabilities for the SDG&E Import Transmission
6 System. Post-transient governor power flow analysis was carried out as required to
7 evaluate system performance under stressful power flow conditions for applicable
8 contingencies to identify thermal, voltage, and voltage stability limits. The SDIT system
9 performances, such as System Operating Limits (SOL) and Interconnected Reliability
10 Operating Limits (IROL), were compared between two scenarios with and without the
11 Proposed Project in order to quantify the benefits of the Proposed Project. Figure 2

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 illustrates the power transfer path via the SDIT System from the Imperial Valley area
2 (Point C) to the San Diego area (Point B1).

3 **Figure 2: Transfer Path via SDG&E Import Transmission (SDIT) System**



4
5 **3. Reliability Benefits**
6 The CAISO evaluated reliability benefits, such as the potential to defer reliability
7 upgrades or alleviate reliability concerns, by comparing power flow impacts on
8 associated facilities with and without the Proposed Project.

9

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

Page 7 of 26

1 4. Local Capacity Requirement Benefits

2 The CAISO used the local capacity technical study approach to test long-term local
3 capacity requirements with and without the Proposed Project.

4
5 **III. DISCUSSION**

6 **Q6. Please provide a brief overview of the interconnected nature of the southern**
7 **California transmission system.**

8 **A6.** The southern California transmission system is heavily interconnected. Modifications to
9 the system condition and configuration are carefully designed to address clean energy
10 trends by working in conjunction with existing and planned system elements.

11
12 In this case, the Proposed Project delivers maximum system benefits when combined
13 with an operational modification to bypass existing series capacitors on the Southwest
14 Powerlink (SWPL) and Sunrise Powerlink (SPL) 500 kilovolt (kV) transmission lines. In
15 general, bypassing the series capacitors increases thermal constraint limits and also
16 results in lower voltage constraint limits. The Proposed Project mitigates the voltage
17 constraint and therefore increases the overall transmission capability. Neither the
18 Proposed Project nor the operational modification can increase the transmission
19 capability alone, but together they achieve the system performance necessary to deliver
20 renewable generation to load in conformance with the RPS goals. The relationship
21 between the Proposed Project and bypassing the series capacitors is discussed in detail in
22 the sections describing the project benefits.

23
24 **A. Deliverability Benefits**

25 **Q7. Please explain how much incremental renewable generation deliverability can be**
26 **attributed to the Proposed Project.**

27 **A7.** In the 2014-15 CAISO Transmission Plan, the CAISO described the need to bypass series
28 capacitors on the SWPL and Sunrise 500 kV transmission lines to allow an incremental
29 900 to 1,100 megawatts (MW) of renewable generation in the Baja and Imperial zones to

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

Page 8 of 26

1 be deliverable.³ As described in Q&A 6, that deliverability benefit could not be achieved
2 without bypassing the 500 kV series capacitors on SWPL and SPL. Without bypassing
3 the series capacitors the thermal limit (1705 MW) is the binding constraint. Bypassing the
4 series capacitors increases the thermal limit, but creates unacceptable voltage
5 performance in the SPL system that reduces the voltage limit to 1676 MW. The Suncrest
6 SVC project together with the bypassing increases the binding constraint by over 1000
7 MW, to 2750 MW. Both the bypassing and the Suncrest SVC project are necessary to
8 achieve the incremental increase in deliverability. The CAISO identified the Suncrest
9 SVC project as a cost-effective solution to mitigate the voltage problem and therefore the
10 generation deliverability benefit is attributable to the Proposed Project.

11
12 **Q8. Please describe the studies that were performed to demonstrate the incremental**
13 **renewable generation deliverability and why it is attributable to the Suncrest SVC**
14 **project?**

15 **A8.** Renewable generation deliverability from the Imperial Valley, Baja California and
16 Arizona renewable zones is confined by a binding constraint that is either thermal or
17 voltage related, depending on the utilization of series capacitors on the SWPL and SPL
18 lines. Table 1 presents approximate renewable generation deliverability estimates without
19 the Proposed Project under two distinct operational conditions: (1) with the series
20 capacitors in SWPL and SPL energized (*i.e.*, not bypassed); and (2) with the series
21 capacitors de-energized (*i.e.*, by-passed). Bypassing the series capacitors alone increases
22 the thermal limit to 2750 MW from 1705 MW, but reduces the voltage limit from 3088
23 MW to 1676 MW because the bypass causes a voltage concern at the Suncrest substation
24 in SPL. Despite the fact that bypassing the series capacitors increases the thermal limits,
25 it would actually reduce renewable generation deliverability by 29 MW by reducing the
26 voltage limit. The Proposed Project effectively mitigates the voltage concern and makes

³ The additional 900 MW to 1,100 MW of generation deliverability is estimated by comparing between the 1900-2100 MW of deliverable generation in the Baja and Imperial zones that is asserted on page 219 of the CAISO 2014-2015 Transmission Plan and the 1000 MW of deliverable generation discussed on page 202 of the CAISO 2013-2014 Transmission Plan.

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 the bypass a feasible operational mitigation solution to increase the generation
2 deliverability by as much as 1045 MW (from 1705 MW to 2750 MW). The voltage
3 concern was identified in the Suncrest 500/230 kV substation based on the WECC
4 regional reliability standard TPL-001-WECC-CRT-3 and CAISO’s Operation Procedure
5 3100, which is discussed in Q&A 11.

**Table 1.
Approximate Generation Deliverability Results with and without the Suncrest SVC
Project**

Status of SWPL and SPL Series Capacitors	Constraint				Deliverability in MW	
	Worst Contingency	Limiting Element	NERC Category	Type	w/o the Project	with the Project
Energized (Not Bypassed)	Ocotillo-Suncrest 500 kV line with SPS Gen tripping at IV	ECO-Miguel 500 kV line	P1	Thermal	1705	1705
	ECO-Miguel 500 kV line with SPS Gen Tripping at IV	Suncrest 500 kV bus	P1	Voltage	3088	3407
De-energized (Bypassed)	Ocotillo-Suncrest 500 kV line with SPS Gen tripping at IV	ECO-Miguel 500 kV line	P1	Thermal	2750	2750
	ECO-Miguel 500 kV line with SPS Gen Tripping at IV	Suncrest 500 kV bus	P1	Voltage	1676	2778

6
7 Table 1 shows the deliverability estimates with and without the Suncrest SVC project
8 under the same two operational conditions (*i.e.*, both with and without the series capacitor
9 by-passed). The results demonstrate that the Proposed Project would effectively alleviate
10 the Suncrest 500 kV bus voltage constraint and boost the voltage limit to 2778 MW,
11 which would no longer be the binding constraint because it is 28 MW higher than the
12 2750 MW thermal limit. Therefore, generation deliverability can be increased from 1705
13 MW to as high as 2750 MW after the bypassing. In other words, the Proposed Project
14 enables the CAISO to bypass the series capacitors, which results in approximately 1045

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**


Page 10 of 26

1 MW of additional renewable generation deliverability available from the renewable zones
2 to the CAISO Controlled Grid.⁴ Figure 3 illustrates the binding approximate generation
3 deliverability results by consolidating the results in Table 1.

⁴ This conclusion echoes Section 4.3.3 SDG&E Area Policy-Driven Deliverability Assessment Results and Mitigations of the CAISO 2014-2015 Transmission Plan on page 219 that state “deliverability of new renewable resources in the Baja and Imperial zones is limited by Category B and C overloads in the Imperial Valley area. Using an SPS to trip generation is not sufficient to eliminate all of the identified overloads. The overloads can be partially mitigated by by-passing the series capacitors on the ECO-Miguel and Ocotillo-Suncrest 500 kV lines under normal conditions. This mitigation is sufficient to make 1,900 to 2,100 MW of the Baja and Imperial zones deliverable”. This was concluded assuming existence of the Suncrest SVC project.

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 **Figure 3. Illustration of the Approximate Generation Deliverability Results**



2
3 **Q9. Can the CAISO only bypass the series capacitors in SWPL but leave the series**
4 **capacitors energized in the Ocotillo-Suncrest 500 kV line to avoid the voltage problem**
5 **on the Suncrest 500 kV bus?**

6 **A9.** This question is worth considering because bypassing the series capacitors on the
7 Ocotillo-Suncrest 500 kV line creates the voltage problems that drive the need for the
8 Suncrest SVC project. The CAISO did further investigation assuming that the series

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 capacitors on the Sunrise 500 kV line were not bypassed when the series capacitors on
2 the ECO-Miguel 500 kV line were de-energized or by-passed. Table 2 presents
3 associated thermal constraint limits on the generation deliverability. As can be seen from
4 the table, although the voltage constraint on the Suncrest 500 kV bus is not binding
5 anymore, the thermal constraint on the Suncrest-Sycamore 230 kV lines for the single
6 contingency of ECO-Miguel 500 kV line (P1) will become binding. The generation
7 deliverability is reduced to 1405 MW, which is 1345 MW lower than with the series
8 capacitors on both lines bypassed and the Proposed Project.
9

**Table 2.
Approximate Generation Deliverability Results
with Series Capacitors De-Energized on SWPL but not on SPL**

	Constraints				Generation Deliverability
	Worst Contingency	Limiting Element	NERC Category	Type	MW
No Upgrade	ECO-Miguel 500 kV line with SPS Gen Tripping at IV	Suncrest-Sycamore 230 kV lines	P1	Thermal	1405
	Ocotillo-Suncrest 500 kV line with SPS Gen tripping at IV	ECO-Miguel 500 kV line	P1	Thermal	2656

10
11
12
13
14
15
16
17

B. San Diego Import Capability Benefits

Q10. How much can the San Diego power import capability be increased by the Suncrest SVC project?

A10. The San Diego power import capability is known as San Diego System Operating Limit (SOL) via the SDIT system. Table 3 presents a comparison of San Diego import capability test results under thermal and voltage constraints for the two scenarios with and without the Proposed Project, assuming that the series capacitors on SWPL and SPL

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 are energized (not bypassed) and de-energized (bypassed), respectively. Figure 4
2 illustrates the thermal and voltage constraint limits of the SDIT system accordingly.
3

**Table 3.
Approximate System Operating Limits of San Diego Import Transmission System**


Status of the 500 kV Series Capacitors	Constraint				SOL in MW	
	Worst Contingency	Limiting Element	NERC Category	Type	w/o the Project	with the Project
Energized (Not Bypassed)	Ocotillo-Suncrest 500 kV line with SPS Gen tripping at IV	ECO-Miguel 500 kV line	P1	Thermal	2860	2860
	ECO-Miguel 500 kV line with SPS Gen Tripping at IV	Suncrest 500 kV bus	P1	Voltage	3274	3550
De-energized (Bypassed)	Ocotillo-Suncrest 500 kV line with SPS Gen tripping at IV	ECO-Miguel 500 kV line	P1	Thermal	3166	3166
	ECO-Miguel 500 kV line with SPS Gen Tripping at IV	Suncrest 500 kV bus	P1	Voltage	2840	3214

4
5

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1

Figure 4. Illustration of the San Diego Import Capability Test Results



2

3

As can be seen in Table 2 and Figure 4:

4

- without the Proposed Project, the lower voltage constraint becomes binding and limits the San Diego import capability to 2840 MW after the SPL series capacitors are de-energized or bypassed, about 20 MW lower than the 2860 MW of thermal transfer limit before by-passing the series capacitors;

5

6

7

8

- with the Project, the voltage constraint is alleviated, and the SDIT thermal limit would become a binding constraint. The San Diego import capability increases to

9

TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027

Page 15 of 26

1 3166 MW, or 306 MW higher than the 2860 MW before by-passing the series
2 capacitors.

3 As the development of renewable generation grows to achieve the 33% and the 50% RPS
4 goals, the benefits of increasing San Diego import capability will grow. The higher San
5 Diego import capability makes the grid more reliable and less constrained, thereby
6 helping the California energy market to import clean renewable energy, avoid oversupply
7 conditions, and access to more economic electricity.

8
9 **C. Reliability Benefits**

10 **Q11. Is the Suncrest SVC project needed to comply with the NERC, WECC, and CAISO**
11 **Reliability Standards while achieving the California regulatory policies?**

12 **A11.** Yes. The CAISO's updated analysis confirms the policy-driven need for the Proposed
13 Project to meet all applicable reliability requirements while achieving the California
14 greenhouse gas emission targets and meeting the RPS goals. These reliability
15 requirements are specified in NERC Standard TPL-001-4 and WECC regional reliability
16 standard TPL-001-WECC-CRT-3. In addition to the NERC and WECC standards, the
17 CAISO plans its transmission system to meet California ISO Planning Standards along
18 with its grid operation practices.

19
20 Table 4 presents post-transient voltage performances under the two scenarios with and
21 without the Proposed Project, assuming the 500 kV series capacitors in SWPL and SPL
22 are bypassed. Without the Proposed Project, the voltage and voltage deviation on the
23 Suncrest 500 kV and 230 kV buses will be lower than 0.90 pu and equal to the 8% of
24 threshold for the single contingency of ECO-Miguel 500 kV line (NERC category P1
25 event). The voltage issues were identified under an assumption that all available facilities
26 and operational procedures are utilized to protect the buses against the voltage issues.
27 This does not meet the requirements specified in WECC reliability criterion TPL-001-

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 WECC-RBP-3⁵ and CAISO operation procedure 3100.⁶ The results in the table
2 demonstrate that the Project can mitigate the unacceptable voltage performances while
3 maintaining the generation deliverability and the San Diego import capability. The
4 Proposed Project is required to support the voltage performance requirements in the
5 Sunrise system during the outage to maintain the generation deliverability and the SDIT
6 import capability.

**Table 4.
Post-Transient Voltage Performance**

	Worst Single Contingency (P1)	Concern	Unit	Suncrest 500 kV Bus	Suncrest 230 kV bus
No Upgrade	ECO-Miguel 500 kV line outage followed by SPS gen tripping at IV	Low Voltage	pu	0.87	0.89
		Voltage Deviation	%	-8	-8
With Suncrest SVC Project		Low Voltage	pu	0.90	0.94
		Voltage Deviation	%	-4	-3

7

8 **Q12. Does the Suncrest SVC project provide a reliability benefit by alleviating potential**
9 **post-transient voltage instability under emergency conditions in the San Diego and**
10 **Los Angeles Basin areas?**

11 **A12.** Yes. The CAISO performed post-transient voltage stability analysis with 5% positive
12 reactive power margin in the SDG&E area and Los Angeles Basin for the 2025 planning
13 horizon in accordance with the CAISO SOL/IROL Methodology. A post-transient
14 voltage stability concern was identified for the single outage of ECO-Miguel 500 kV line
15 with high import via the SDIT system when there is low generation support in the San
16 Diego area and Los Angeles Basin.⁷ This established a potential Interconnected

⁵ WR1.1.2 of TPL-001-WECC-CRT-3 requires that steady-state voltages at all applicable BES buses shall stay within 0.90 pu to 1.05 pu of nominal voltage for P1-P7 events (WR1.1.2), and WR1.2 requires post-contingency steady-state voltage deviation at each applicable BES bus serving load shall not exceed 8% for P1 events.

⁶ CAISO OP3100B requires that voltage in SDG&E 500/230 kV system shall stay above 0.90 pu of nominal voltage for post-contingency.

⁷ For the purpose of this analysis, thermal overloads and low voltage concerns are ignored. This section focuses on the relative impact of the Proposed Project on post-transient voltage instability.

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 Reliability Operating Limit (IROL) in SDIT that, if violated, could lead to instability,
2 uncontrolled separation, or cascading events that adversely impact reliability in the
3 southern California bulk transmission system.

4
5 Table 5 presents SDIT’s potential IROL test results under the two scenarios with and
6 without the Project, assuming the series capacitors in SWPL and SPL are bypassed.⁸ The
7 Proposed Project increases the potential IROL by as much as 220 MW (from 3346 MW
8 to 3566 MW) and effectively reduces the risk of post-transient voltage instability concern
9 in the San Diego area and Los Angeles Basin.

**Table 5.
IROL Transfer Limits of San Diego Import Transmission System**

Constraint				IROL in MW	
Worst Contingency	Limiting Element	NERC Category	Type	without the Project	with the Project
TL50001 ECO-Miguel 525 kV line with CGCC ⁹ and SPS Gen Tripping at IV	Voltage Instability Concern in the San Diego Area and LA Basin	P1	Post-Transient Voltage Instability	3346	3566

10
11 **Q13. Does the IROL of 3566 MW with the Suncrest SVC project or 3346 MW without the**
12 **Proposed Project mean that the ISO can normally import that much power into the**
13 **San Diego area?**

14 **A13.** Not necessarily, because import limits depend on system conditions. The IROL indicates
15 that under emergency conditions, such as after the loss of a large generating facility, the
16 system is not at risk of voltage collapse or instability for a subsequent contingency as
17 long as the flow is below the IROL. The normal import capability or SOL is established

⁸ WR5.3 of TPL-001-WECC-CRT-3 requires that all P0-P1 events shall demonstrate a positive reactive power margin at a minimum of 105 percent of forecasted peak load.

⁹ The automatic centralized capacitor control schemes were assumed to be available in the areas

TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027

Page 18 of 26

1 by ensuring that there are no thermal overloads and voltages concerns under the single
2 contingency.

3
4 **Q14. Can the Proposed Project provide other potential reliability benefits in the southern**
5 **California area and its adjacent systems?**

6 **A14.** Yes. In addition to the benefits described above, the Proposed Project also provides the
7 following reliability benefits:

- 8 • Deferring the potential need to mitigate a reliability concerns on the southern San
9 Diego 230/138/69 kV system from Bay Boulevard to Old Town substations. The
10 2015-16 CAISO Transmission Plan identified that one of the two transformer
11 banks in the planned Bay Boulevard 230/69 kV substation overloaded for
12 Category P2, P4, or P6 outages. Separately mitigating this concern would cost an
13 estimated \$13 million to \$101 million.
- 14 • Either deferring a potential reliability network upgrade or reducing customer load
15 shedding in the Poway area to address a potential thermal overload concern on the
16 Sycamore-Pomerado 69 kV lines. Table 6 shows that one of the two Sycamore-
17 Pomerado 69 kV lines is loaded as high as 98.2% of its emergency rating in the
18 event of a single outage of other Sycamore-Pomerado 69 kV line (Category P1).
19 Bypassing the series capacitors could defer a future need for a network addition to
20 address the potential thermal overload. Mitigation would cost an estimated \$35
21 million. In addition, without the potential upgrade, an N-1-1 event (Category P6)
22 would result in local load shedding. It is estimated that bypassing the series
23 capacitors could reduce exposure to load shedding by up to 25 MW.
- 24 • Lessening the potential thermal overloading concern in CENACE's 230 kV
25 system between La Rosita and Tijuana under an N-1-1 contingency (Category
26 P6), that would consequently trigger CENACE's existing Valle-Costa Path SPS
27 designed to cross trip one of the two 230 kV tie lines between SDG&E and
28 CENACE. The cross-tripping will result in a radial connection between the two

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 systems, which may jeopardize reliability in the CENACE system and result in
2 potential voltage instability in the Los Angeles Basin and the San Diego area.
3 Table 6 presents detailed power flow impact on the Bay Boulevard 230/69 kV
4 transformers, the Sycamore-Pomerado 69 kV lines, and CENACE’s 230 kV path between
5 La Rosita and Tijuana, with and without bypassing the series capacitors.

**Table 6.
Power Flow Impact on the potential reliability concerns**

Area	Worst Contingency	Overloaded Facility	NERC Category	Post-Contingency Power Loading (%)		Incremental Flow Impact
				Series Capacitors in SWPL and SPL NOT Bypassed	Series Capacitors in SWPL and SPL Bypassed	%
Southern San Diego	Bay Blvd-Silvergate 230 kV line followed by one of the two 230/69 kV Banks in Bay Blvd Substation	Other 230/69 kV Bank at Bay Blvd	P6	106.9	103.8	3.1
Poway	One of the two Sycamore-Pomerado 69 kV Lines	other Sycamore-Pomerado 69 kV Line	P1	98.2	93.5	4.7
	One of the two Sycamore-Pomerado 69 kV Lines + Sycamore-Artesian 230 kV line	other Sycamore-Pomerado 69 kV Line	P6	132.5	122.4	10.1
CENACE	ECO-Miguel 500 kV line + Ocotillo-Suncrest 230 kV line	ROA-RUM 230 kV line	P6	96.3	87.9	8.4

6
7

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

D. Local Capacity Requirement Benefits

Q15. What is the reduction in local capacity requirements in the San Diego area attributable to the Proposed Project?

A15. As discussed earlier, bypassing the series capacitors in SWPL and SPL can alleviate power flow stress in the San Diego area. This also results in reduction of local capacity requirements in the following sub-areas:

- San Diego sub-area – The Proposed Project reduces local capacity requirements by as much as 326 MW (from 3104 MW to 2778 MW);
- Miramar sub-area – The Proposed Project reduces local capacity requirements in the Miramar sub-area by as much as 30 MW (from 118 MW to 88 MW).

Table 7 shows the local capacity requirement test results and associated constraints in the San Diego and Miramar sub-areas with and without bypassing the SWPL and SPL series capacitors banks.

**Table 7.
Local Capacity Requirement (LCR) Test Results**

Sub-Area	Constraint			Long-term Local Capacity Requirement (MW)		LCR Reduction
	Worst Contingency	Overloaded Facility	NERC Category	Series Capacitors in SWPL and SPL NOT Bypassed	Series Capacitors in SWPL and SPL Bypassed	MW
San Diego	Otay Mesa Plant out of service followed by the Ocotillo-Suncrest 500 kV line outage with SPS Gen tripping at IV	ECO-Miguel 500 kV line	P3	3104	2778	326
Miramar	The Sycamore-Penasquitos 230 kV line outage followed by the Bay Blvd-Silvergate 230 kV line outage	Sycamore-Scripps 69 kV line	P6	118	88	30

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

Page 21 of 26

E. Project Timing

Q16. When is the Suncrest SVC project needed?

A16. As discussed above, the major system change that drives the need for the Proposed Project is the renewable generation development in the Imperial, Arizona, and Baja zones. The Proposed Project, together with bypassing the series capacitors, is designed to improve transfer capability for renewable generation with the existence of the Imperial Valley phase shifting transformers project, which was placed in service in May 2017. There is a total of approximately 2724 MW of renewable resources operational under the CAISO control in the greater Imperial Valley, Baja, and Arizona areas by the end of 2017. This is approaching the 2820 MW identified in the latest Commission-developed RPS portfolio. The CAISO confirmed the low voltage concern discussed above in a recent transmission planning stakeholder process, based on anticipated delay of the Proposed Project beyond the initial in-service date. Therefore deliverability of existing renewable generation is limited today, which is discussed in Q&A 17. The Proposed Project is needed as soon as possible, preferably before the summer of 2018 because even more renewable generation is expected to be coming on-line in the Imperial, Arizona, and Baja areas.

Q17. Did the CAISO conduct any updated analysis on the need for the Proposed Project based on the 2016-2017 transmission plan?

A17. Yes, the 2016-2017 transmission plan again confirms the need for the Proposed Project. The voltage concern limiting renewable generation deliverability was confirmed based on the latest California Energy Commission (CEC) load forecast under the 2018 summer peak base case. Table 8 presents the voltage results with and without the project assuming the 500 kV series capacitor banks in SWPL and SPL are bypassed. The voltage results are similar to the previous results. The results indicate that the Proposed Project need and its incremental benefits are primarily driven by the renewable generation and are not significantly affected by other circumstances, such as load growth. In addition, this updated analysis indicates that most of the CAISO connected, Imperial area

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 renewable generation in the Commission-developed RPS portfolio has materialized and
2 will be on-line by 2018.

**Table 8.
Post-Transient Voltage Performance based on the latest information**

	Worst Contingency	Concern	Unit	Suncrest 500 kV Bus	Suncrest 230 kV bus
No Upgrade	ECO-Miguel 500 kV line outage followed by SPS gen tripping at IV	Low Voltage	pu	0.88	0.90
		Voltage Deviation	%	-9.10	-9.00
Suncrest SVC Project		Low Voltage	pu	0.93	0.95
		Voltage Deviation	%	-3.80	-2.60

3
4 **IV. CONCLUSION**

5 **Q18. Please summarize your testimony.**

6 **A18.** The Proposed Project is necessary to meet the State’s RPS goals. The CAISO’s updated
7 analysis confirms that without the Proposed Project, the transmission system will not be
8 capable of meeting applicable reliability standards while simultaneously enabling
9 deliverability for existing and planned renewable resources in the Imperial, Arizona and
10 Baja areas.

11
12 In addition to the deliverability benefits necessary to meet the RPS goals, the Proposed
13 Project provides considerable secondary benefits in the form of increased import
14 capability into the San Diego area, positive effects on existing or emerging southern
15 California reliability concerns and reductions in long-term local capacity requirements.

16
17 Based on these significant benefits, the Commission should approve the Proposed
18 Project.

19

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 **APPENDIX A**

2 The assumptions utilized in the CAISO’s updated analysis on the Suncrest SVC project are
3 consistent with the CAISO 2015~2016 TPP, which includes:

- 4 • Load forecast by California Energy Commission (CEC);
- 5 • San Onofre Nuclear Generating Station (SONGS) retirement;
- 6 • Once-Through Cooled (OTC) generation retirement schedule;
- 7 • The Commission’s 33% Renewable Portfolio Standards;
- 8 • CEC/Commission Long-Term Procurement Process Track-1 and Track-4 decisions,
9 including energy efficiency (AAEE), behind the meter solar, Energy Storage, Demand
10 Response, and conventional resources;
- 11 • Network upgrade projects implemented and approved by CAISO, including the
12 Imperial Valley phase shifting transformers and the Delaney-Colorado River 500 kV
13 line projects.

14
15 **Load forecast**

16 Table A-1 summarizes the load assumption used in the 2025 Summer Peak cases. The forecasted
17 SDG&E 1-in-10 coincident peak load in the 2025 Summer Peak case is 5850 MW. In addition,
18 there is 401 MW of load reduction built into the 2025 Summer Peak case as a result of projected
19 energy efficiency. Therefore, the net peak load in the 2025 Summer Peak case is about 5449 MW.
20 The CEC’s latest load demand forecast in 2018 is also presented in the table, which was used for
21 the analysis in Q&A 17.

22

**Table A-1.
1-in-10 Load Forecast in the SDG&E Area**

1-in-10 Load Level	Unit	2025 Demand in CAISO 2015-16 TPP	2018 Demand (2016 CEC Forecast)
Load Forecast	MW	5850	4906
Energy Efficiency (AAEE)	MW	-401	-120
Net Load	MW	5449	4786

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 **Generation Resources**

2 Table A-2 lists a summary of the generation resources under CAISO operational control in the San
3 Diego study area by location and technology, respectively, which includes all available resources
4 modeled in the study years. The heavy renewable generation output assumptions are shown in
5 Table A-3.

**Table A-2.
Resources in the SDG&E-Imperial Valley Area under CAISO Control**

Generation Resources		MW (in year 2025)
by location	San Diego Metro	2607
	ECO	255
	Ocotillo	265
	Imperial Valley	2065
	Arizona	582
by technology	Gas	3544
	PV	1593
	Wind	570
	Biomass	27
	Storage	40
Total		5774

6

**Table A-3
Heavy Renewable Generation Output**

Type	Area	Pgen
		% of net capacity (Pmax)
Wind	SDGE**	37%
	SCE Eastern**	47%
Solar	SDGE*	96%
	SCE Eastern**	93%
Biomass		100%

Note: * 20% exceedance level
** 50% exceedance level

7

8

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
A.15-08-027**

1 **Transmission Upgrades**

2 The transmission system modeled in the analysis include the existing system and all future transmission
3 projects that received ISO approval in the 2014-2015 or earlier ISO transmission plans. This includes the
4 South Orange County Reliability Enhancement Project, the Sycamore Canyon-Penasquitos 230 kV line,
5 the phase shifting transformers at the Imperial Valley 230 kV substation, and new reactive power support
6 facilities at San Luis Rey and SONGS. NEET’s Suncrest SVC project and status is turned on or off based
7 on the purpose of test studies. Figure A-1 is a one-line diagram of the SDG&E bulk transmission
8 system representing the year 2025, assuming the Project is in service. .

9
10 Definition of San Diego Gas & Electric Import Transmission interface

11 Figure A-1 also illustrates the San Diego Gas & Electric Import Transmission interface that consists of
12 Southwest Powerlink, Sunrise Powerlink, south of SONGS path, and Otay Mesa-Tijuana 230 kV tie with
13 CFE (TL23040), including following transmission elements:

- | | | | |
|----|---|--------------------|-------------------|
| 14 | • | ECO-MIGUEL | 500 kV Ckt#1 Line |
| 15 | • | OCOTILLO-SUNCRESTE | 500 kV Ckt#1 Line |
| 16 | • | OTAY MESA-TIJUANA | 230 kV Ckt#1 Line |
| 17 | • | SONGS-SAN LUIS REY | 230 kV Ckt#1 Line |
| 18 | • | SONGS-SAN LUIS REY | 230 kV Ckt#2 Line |
| 19 | • | SONGS-SAN LUIS REY | 230 kV Ckt#3 Line |
| 20 | • | SONGS-TALEGA | 230 kV Ckt#1 Line |
| 21 | • | SONGS-CAPISTRANO | 230 kV Ckt#1 Line |

22

**TESTIMONY OF WEIWU CHEN
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR CORPORATION
A.15-08-027**

Figure A-1. San Diego-Imperial Valley Bulk Transmission System Configuration by the Year of 2025

