

California ISO Metering Exemption Listing Report

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	12/19/2016	1/13/2017	Brookfield Tehachapi 3	Requested exemption due to communication issue that prevents direct polling of the meter.	DTCHWD_2_BT3WND
Granted	12/19/2016	1/13/2017	Brookfield Tehachapi 4	Requested exemption due to communication issue that prevents direct polling of the meter.	DTCHWD_2_BT4WND
Granted	12/19/2016	1/6/2017	Dillon Wind	Requested exemption due to communication issue that prevents direct polling of the meter.	TIFFNY_1_DILLON
Granted	12/20/2016	1/20/2017	Santa Cruz Energy LLC	Requested exemption due to communication issue that prevents direct polling of the meter.	PSWEET_1_STCRUZ
Granted	1/1/2017	6/30/2017	PacifiCorp - Jim Bridger	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	JIMBRIDG_7_UNITS
Granted	1/1/2017	6/30/2017	PacifiCorp - Monsanto	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	MONSANTO_NCL1 MONSANTO_NCL2
Granted	1/1/2017	6/30/2017	Pacificorp - Nucor	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	NUCOR_NCL2
Granted	1/1/2017	6/30/2017	Pacificorp - US Magnesium Corp	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	ROWLEY_NCL1 ROWLEY_NCL2 ROWLEY_NCL3
Granted	1/1/2017	12/31/2017	Woodward Powerhouse	Requested exemption to use modem due to infeasibility of connecting the ECN.	VLYHOM_Y_SSID

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	1/1/2017	12/31/2017	Frankenheimer Powerhouse	Requested exemption to use modem due to infeasibility of connecting the ECN.	COTTLE_2_FRKNH
Granted	1/1/2017	12/31/2017	Desert Hot Springs 2	Requested exemption to use modem due to infeasibility of connecting the ECN.	DEVERS_2_DHSPG2
Granted	1/1/2017	12/31/2021	California Valley Solar	Exemption from 5.1.2 raw, unedited and un-aggregate meter data	CAVLSR_2_BSOLAR CAVLSR_2_RSOLAR
Granted	12/13/2016	1/9/2019	Pearblossom Solar	Missing one of the CT/PT unit	PBLOSM_2_SOLAR
Granted	12/7/2016	1/23/2017	Kern River Cogeneration	Requested exemption due to communication issue that prevents direct polling of the meter.	OMAR_2_UNIT 4
Granted	1/1/2017	12/31/2017	CSU East Bay Fuel Cell	Requested exemption to use modem due to infeasibility of connecting the ECN.	CASTVL_2_FCELL
Granted	1/1/2017	12/31/2017	San Francisco State Fuel Cell	Requested exemption to use modem due to infeasibility of connecting the ECN.	DALYCT_1_FCELL
Granted	1/1/2017	12/31/2017	Houwelings Nurseries	Requested exemption to use modem due to infeasibility of connecting the ECN.	SNCLRA_2_HOWLNG
Granted	1/1/2017	6/30/2017	Argus Cogeneration Project	Requested exemption to use modem due to infeasibility of connecting the ECN.	SEARLES_7_ARGUS
Granted	1/1/2017	12/31/2017	Sunshine Gas Producers	Requested exemption to use modem due to infeasibility of connecting the ECN.	SUNSHN_2_LNDFL

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	1/1/2017	12/31/2017	Otay Landfill Gas VI	Requested exemption to use modem due to infeasibility of connecting the ECN.	OTAY_6_LNDFL6
Granted	1/1/2017	12/31/2017	Otay Landfill Gas V	Requested exemption to use modem due to infeasibility of connecting the ECN.	OTAY_6_LNDFL5
Granted	1/1/2017	12/31/2017	Otay Landfill 3	Requested exemption to use modem due to infeasibility of connecting the ECN.	OTAY_7_UNITC1
Granted	1/1/2017	12/31/2017	Otay 1 & 2	Requested exemption to use modem due to infeasibility of connecting the ECN.	OTAY_6_UNITB1
Granted	1/1/2017	12/31/2017	Mission Solar	Requested exemption to use modem due to infeasibility of connecting the ECN.	MERCED_1_SOLAR1
Granted	1/1/2017	12/31/2017	Merced Solar	Requested exemption to use modem due to infeasibility of connecting the ECN.	MERCED_1_SOLAR2
Granted	1/1/2017	12/31/2017	Hollister Solar	Requested exemption to use modem due to infeasibility of connecting the ECN.	HOLSTR_1_SOLAR2
Granted	1/1/2017	12/31/2017	Bear Creek Solar	Requested exemption to use modem due to infeasibility of connecting the ECN.	LOCKFD_1_BEARCK
Granted	1/1/2017	12/31/2017	ABEC Bidart-Old River LLC	Requested exemption to use modem due to infeasibility of connecting the ECN.	OLDRIV_6_BIOGAS

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	12/17/2016	1/17/2016	Banning Substation Banks 1, 2 and 3	Requested exemption due to communication issue that prevents direct polling of the meter.	DEVERS_6_BANN DLAP_SCE_BAN1
Granted	11/30/2016	12/31/2016	Sycamore Energy I	Requested exemption due to communication issue that prevents direct polling of the meter.	CHILLS_7_SYCENG
Granted	5/1/2014	12/31/2017	Oroville Cogeneration	Requested exemption to use modem due to infeasibility of connecting the ECN.	OROVIL_6_UNIT
Granted	1/1/2017	12/31/2017	Ameresco Forward	Requested exemption to use modem due to infeasibility of connecting the ECN.	WEBER_6_FORWRD
Granted	1/1/2017	12/31/2017	Ameresco Johnson Canyon	Requested exemption to use modem due to infeasibility of connecting the ECN.	GONZLS_6_UNIT
Granted	1/1/2017	12/31/2017	Ameresco Foothill	Requested exemption to use modem due to infeasibility of connecting the ECN.	CORRAL_6_SJOAQN
Granted	1/1/2017	12/31/2017	Ameresco Vasco	Requested exemption to use modem due to infeasibility of connecting the ECN.	CAYTNO_2_VASCO
Granted	1/1/2015	12/31/2017	Kekawaka Hydropower	Requested exemption to use modem due to infeasibility of connecting the ECN.	KEKAWK_6_UNIT
Granted	1/1/2017	3/31/2017	Frito Lay	Requested exemption to use modem due to infeasibility of connecting the ECN.	FRITO_1_LAY

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	1/1/2017	12/31/2017	CA PV Energy Jurupa	Requested exemption to use modem due to infeasibility of connecting the ECN.	CHINO_2_JURUPA
Granted	1/1/2017	12/31/2017	CA PV Energy Champagne	Requested exemption to use modem due to infeasibility of connecting the ECN.	ETIWND_2_CHMPNE
Granted	1/1/2017	12/31/2017	Bailey Creek Hydroelectric	Requested exemption to use modem due to infeasibility of connecting the ECN.	VOLTA_6_BAILCK
Granted	1/1/2017	12/31/2017	Clover Creek Hydroelectric Project	Requested exemption to use modem due to infeasibility of connecting the ECN.	CLOVER_2_UNIT
Granted	1/1/2017	12/31/2017	G2 Energy (Hay Road), LLC	Requested exemption to use modem due to infeasibility of connecting the ECN.	PEABDY_2_LNDFIL
Granted	1/1/2017	12/31/2017	Western Power & Steam Cogeneration	Requested exemption to use modem due to infeasibility of connecting the ECN.	DEXZEL_1_UNIT
Granted	1/1/2017	12/31/2017	Virginia Ranch Dam PH	Requested exemption to use modem due to infeasibility of connecting the ECN.	BANGOR_6_HYDRO
Granted	11/18/2016	12/30/2016	Fairfield Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	CURTIS_1_FARFLD
Granted	12/2/2016	1/2/2017	Ontario Solar, SPVP#006	Requested exemption due to communication issue that prevents direct polling of the meter.	MIRLOM_2_ONTARO

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	11/23/2017	12/15/2016	G2 Energy (Hay Road), LLC	Requested exemption due to communication issue that prevents direct polling of the meter.	PEABDY_2_LNDFIL
Granted	12/9/2016	1/9/2017	High Sierra Limited	Requested exemption due to communication issue that intermittently prevents direct polling of the meter.	SIERRA_1_UNITS
Granted	11/29/2016	11/28/2017	Bell Bandini Commerce Refuse	Requested exemption for missing Nameplate information	LAGBEL_2_STG1
Granted	12/3/2016	12/26/2016	Maricopa West Solar PV	Requested exemption due to communication issue that prevents direct polling of the meter.	MARCPW_6_SOLAR1
Granted	11/14/2016	12/13/2016	Otay Landfill Gas V	Requested exemption extension due to communication issue that prevents direct polling of the meter.	OTAY_6_LNDFL5
Granted	1/9/2015	12/31/2017	Salmon Creek Hydroelectric Project	Requested exemption to use modem due to infeasibility of connecting the ECN.	ALLGNY_6_HYDRO1
Granted	12/1/2016	9/30/2017	New-Indy Oxnard	Requested exemption for missing Nameplate information	SNCLRA_2_UNIT1
Granted	11/9/2016	12/9/2016	High Sierra Limited	Requested exemption due to communication issue that prevents direct polling of the meter.	SIERRA_1_UNITS
Granted	11/3/2016	11/30/2016	Santa Cruz Energy LLC	Requested exemption due to communication issue that prevents direct polling of the meter.	PSWEET_1_STCRUZ
Granted	11/2/2016	12/2/2016	Maricopa West Solar PV	Requested exemption due to communication issue that prevents direct polling of the meter.	MARCPW_6_SOLAR1
Granted	11/17/2016	12/17/2016	Banning Substation Banks 1, 2 and 3	Requested exemption due to communication issue that prevents direct polling of the meter.	DEVERS_6_BANN DLAP_SCE_BAN1

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	10/24/2016	11/30/2016	Diablo Winds	Requested exemption due to communication issue that prevents direct polling of the meter.	FLOWD2_2_FLPWND
Granted	11/14/2016	11/14/2021	Big Sky Solar 4	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	BIGSKY_2_SOLAR2
Granted	11/14/2016	11/14/2021	Western Antelope Blue Sky Ranch B	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	BIGSKY_2_SOLAR4
Granted	11/10/2016	11/9/2021	Big Sky Solar 2	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	BIGSKY_2_SOLAR5
Granted	3/22/2016	12/31/2016	Clover Creek Hydroelectric Project	Requested exemption due to communication issue that prevents direct polling of the meter.	CLOVER_2_UNIT
Granted	11/10/2016	11/10/2017	Mill & Sulphur Creek Power Plant	Requested exemption to use modem due to infeasibility of connecting via ECN.	LOWGAP_1_SUPHR
Granted	11/12/2016	11/12/2017	Baker Station Hydroelectric	Requested exemption to use modem due to infeasibility of connecting via ECN.	BRDGVL_7_BAKER
Granted	11/1/2016	11/29/2016	Desert Star Energy Center	Requested exemption due to communication issue that prevents direct polling of the meter.	MRCHNT_2_PL1X3
Granted	10/14/2016	11/16/2016	Kettleman Solar	Requested exemption due to communication issue that prevents direct polling of the meters - both main and backup.	LOCKFD_1_KSOLAR

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	10/28/2016	11/25/2016	Merced Falls	Requested exemption due to communication issue that prevents direct polling of the meter.	MERCFL_6_UNIT
Granted	10/17/2016	11/17/2016	Banning Substation Banks 1, 2 and 3	Requested exemption due to communication issue that prevents direct polling of the meter.	DEVERS_6_BANN DLAP_SCE_BAN1
Granted	10/10/2016	11/30/2016	Middle Fork Power House	Requested exemption due to communication issue that prevents direct polling of the meter.	OXBOW_6_DRUM
Granted	10/14/2016	10/28/2016	Chicago Park Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	CHICKPK_7_UNIT1
Granted	10/7/2016	10/27/2016	Merced Falls	Requested exemption due to communication issue that prevents direct polling of the meter.	MERCFL_6_UNIT
Granted	9/26/2016	10/31/2016	Desert Star Energy Center	Requested exemption due to communication issue that prevents direct polling of the meter.	MRCHNT_2_PL1X3
Granted	9/9/2016	10/13/2016	Kirkwall Substation 1 & 2	Requested exemption due to communication issue that prevents direct polling of the meter.	RIOHDO_6_AZUA DLAP_SCE_AZUA
Granted	9/17/2016	10/7/2016	Nacimiento Hydroelectric Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	OILFLD_7_QFUNTS
Granted	9/16/2016	11/15/2016	French Meadows PH	Requested exemption due to communication issue that prevents direct polling of the meter.	FMEADO_7_UNIT

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	9/1/2016	10/1/2016	SPVP#023	Requested exemption due to communication issue that prevents direct polling of the meter.	ETIWND_2_RTS023
Granted	8/15/2016	9/15/2016	Pacific Gas & Electric Drum Hyrdo - Halsey, Narrows, Newcastle, , Chili Bar, Wise	Requested exemption due to communication issue that prevents direct polling of the meter.	HALSEY_6_UNIT NAROW1_2_UNIT NWCSTL_7_UNIT1 PLACVL_1_CHILIB WISE_1_UNIT1
Granted	9/4/2016	10/4/2016	Garnet Solar Power Generation Station 1, LLC	Requested exemption due to communication issue that prevents direct polling of the meter.	GARNET_1_SOLAR2
Granted	8/12/2016	9/30/2016	High Sierra Limited	Requested exemption due to communication issue that prevents direct polling of the meter.	SIERRA_1_UNITS
Granted	8/19/2016	9/16/2016	Nacimiento Hydroelectric Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	OILFLD_7_QFUNTS
Granted	8/15/2016	9/15/2016	Middle Fork Power House	Requested exemption due to communication issue that prevents direct polling of the meter.	MDFKRL_2_PROJECT
Granted	8/15/2016	9/15/2016	Oxbow Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	OXBOW_6_DRUM
Granted	8/3/2016	9/3/2016	Garnet Solar Power Generation Station 1, LLC	Requested exemption due to communication issue that prevents direct polling of the meter.	GARNET_1_SOLAR2
Granted	8/8/2016	8/15/2016	Argus Cogeneration Project	Requested exemption due to communication issue that prevents direct polling of the meter.	SEARLS_7_ARGUS

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	8/15/2016	8/15/2021	Elevation Solar C	Raw & Unedited Data	BIGSKY_2_SOLAR2
Granted	8/15/2016	8/15/2021	Western Antelope Blue Sky R	Raw & Unedited Data	BIGSKY_2_SOLAR4
Granted	7/25/2016	9/15/2016	French Meadows PH	Requested exemption due to communication issue that prevents direct polling of the meter.	FMEADO_7_UNIT
Granted	8/1/2016	8/31/2016	San Dimas Wash Hydroelectric Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	PADUA_7_SDIMAS
Granted	7/13/2016	9/5/2016	Oasis Crest	Requested exemption due to communication issue that prevents direct polling of the meter.	OASIS_6_CREST7
Granted	7/20/2016	8/5/2016	Russell City Energy Center	Requested exemption due to communication issue that prevents direct polling of the meter.	RUSCTY_2_UNITS
Granted	7/30/2016	8/26/2016	CDWR - Crafton Hills, Las Perillas, Badger Hill, Devils Den, Polonio, Del Valle, Barker Slough and Cordelia	Requested exemption due to communication issue that prevents direct polling of the meter.	CLAP_CDWR05_CDWR CLAP_CDWR04_CDWR DLAP_SCE_CDWR
Granted	7/13/2016	8/12/2016	Sycamore Cogeneration Facility	Requested exemption extension due to communication issue that prevents direct polling of the meter.	SYCAMR_2_UNIT1 SYCAMR_2_UNIT2 SYCAMR_2_UNIT3
Granted	7/25/2016	8/18/2016	MDW Lake Mathews	Requested exemption extension due to communication issue that prevents direct polling of the meter.	MIRLOM_7_MWDLKM

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	7/20/2016	8/20/2016	Kettleman Solar	Requested exemption due to communication issue that prevents direct polling of the meters - both main and backup.	LOCKFD_1_KSOLAR
Granted	7/8/2016	7/29/2016	CDWR - Crafton Hills, Las Perillas, Badger Hill, Devils Den, Polonio, Del Valle, Barker Slough and Cordelia	Requested exemption due to communication issue that prevents direct polling of the meter.	CLAP_CDWR05_CDWR CLAP_CDWR04_CDWR DLAP_SCE_CDWR
Granted	7/8/2016	8/11/2016	Shell Martinez Refinery	Requested exemption due to communication issue that prevents direct polling of the meter.	SHELRF_1_UNITS
Granted	6/29/2016	7/10/2016	Ameresco Butte County	Requested exemption due to communication issue that prevents direct polling of the meter.	ESQUON_6_LNDFIL
Granted	6/28/2016	7/14/2016	WhiteWater Hydro	Use of Test Device for Non Generating Unit	GARNET_2_HYDRO
Granted	6/22/2016	8/22/2016	El Sobrante Power Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	VALLEY_7_UNITA1
Granted	6/22/2016	7/31/2016	Eurus Oasis	Requested exemption due to communication issue that prevents direct polling of the meter.	VINCNT_2_WESTWD
Granted	6/15/2016	7/31/2016	Potter Valley	Requested exemption to use PT w/ .45% accuracy until available PT w/ .3% accuracy arrived	POTTER_6_UNITS
Granted	6/8/2016	7/8/2016	Bear Creek Hydroelectric Project	Requested exemption extension due to communication issue that prevents direct polling of the meter.	TKOPWR_6_HYDRO
Granted	6/3/2016	7/3/2016	Otay Landfill Gas V	Requested exemption extension due to communication issue that prevents direct polling of the meter.	OTAY_6_LNDFL5
Granted	6/1/2016	7/6/2016	Cabazon Wind Project	Requested exemption extension due to communication issue that prevents direct polling of the meter.	CABZON_1_WINDA1
Granted	5/29/2016	5/30/2018	Desert Sunlight Solar	Exemption from 10.2.1.2 format data submission .1.2 "raw, unedited and un-aggregate Meter Data"	DSRTSN_2_SOLAR1 DSRTSN_2_SOLAR2
Granted	5/25/2016	5/25/2017	Lassen Station Hydro	Modem Exemption	BUCKCK_2_HYDRO

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	5/23/2016	7/9/2016	Dinuba Energy	Requested exemption extension due to communication issue that prevents direct polling of the meter.	DINUBA_6)UNIT
Granted	5/23/2016	7/1/2016	French Meadows PH	Requested exemption extension due to communication issue that prevents direct polling of the meter.	FMEADO_7_UNIT
Granted	5/23/2016	7/25/2016	MDW Lake Mathews	Requested exemption extension due to communication issue that prevents direct polling of the meter.	MIRLOM_7_MWDLKM
Granted	5/20/2016	6/30/2016	Geysers Geothermal Power Plant	Requested exemption extension due to communication issue that prevents direct polling of the meter.	GEYS11_7_UNIT11 GEYS12_7_UNIT12 GEYS14_7_UNIT14 GEYS17_7_UNIT17 GYS5X6_7_UNITS GYS7X8_7_UNITS
Granted	5/4/2016	6/3/2016	Otay Landfill Gas V	Requested exemption extension due to communication issue that prevents direct polling of the meter.	OTAY_6_LNDFL5
Granted	5/4/2016	7/7/2016	Shell Martinez Refinery	Requested exemption due to communication issue that prevents direct polling of the meter.	SHELRF_1_UNITS
Granted	5/1/2016	6/30/2016	High Sierra Limited	Requested exemption extension due to communication issue that prevents direct polling of the meter.	SIERRA_1_UNITS
Granted	4/22/2016	6/22/2016	Brookfield Tehachapi 3	Requested exemption for CT burden that is out of tolerance	DTCHWD_2_BT3WND
Granted	4/22/2016	4/22/2021	Brookfield Tehachapi 3, 4	Peer-Peer Scheme	DTCHWD_2_BT3WND, DTCHWD_2_BT4WND
Granted	4/22/2016	6/22/2016	Brookfield Tehachapi 4	Requested exemption for CT burden that is out of tolerance	DTCHWD_2_BT4WND
Granted	4/12/2016	11/30/2016	New-Indy Oxnard	Requested exemption for missing Nameplate information	SNCLRA_2_UNIT1
Granted	4/4/2016	5/4/2016	Otay Landfill Gas V	Requested exemption extension due to communication issue that prevents direct polling of the meter.	OTAY_6_LNDFL5
Granted	4/1/2016	8/1/2016	EUI Windpark I	Requested exemption for missing Nameplate information	VENWD_1_WIND1
Granted	4/1/2016	8/1/2016	EUI Windpark II	Requested exemption for missing Nameplate information	VENWD_1_WIND2
Granted	4/1/2016	8/1/2016	Painted Hills Wind Park	Requested exemption for missing Nameplate information	VENWD_1_WIND3
Granted	4/1/2016	4/30/2016	Windland Refresh 2	Requested exemption due to communication issue that prevents direct polling of the meter.	MIDWD_2_WIND1
Granted	3/23/2016	5/4/2016	Shell Martinez Refinery	Requested exemption due to communication issue that prevents direct polling of the meter.	SHELRF_1_UNITS
Granted	3/22/2016	12/31/2016	Clover Creek	Modem Exemption	CLOVER_2_UNIT
Granted	3/22/2016	4/8/2016	Crafton Hills	Requested exemption due to communication issue that prevents direct polling of the meter.	DLAP_SCE_CDWR
Granted	3/19/2016	4/30/2016	High Sierra Limited	Requested exemption extension due to communication issue that prevents direct polling of the meter.	SIERRA_1_UNITS
Granted	3/16/2016	7/15/2016	Otay Landfill 3	Requested exemption due to communication issue that prevents direct polling of the meter.	OTAY_7_UNITC1

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	3/7/2016	4/30/2016	EBMUD Wastewater	Requested exemption due to communication issue that prevents direct polling of the meter.	OAK L_1_GTG1 , OAK C_1_EBMUD
Granted	3/7/2016	4/7/2016	Garnet Solar Gen 1	Requested exemption extension due to communication issue that prevents direct polling of the meter.	GARNET_1_SOLAR2
Granted	3/7/2016	3/21/2016	Mt. Poso	Requested exemption due to communication issue that prevents direct polling of the meter.	MTNPOS_1_UNIT
Granted	3/1/2016	4/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_7_CT
Granted	3/1/2016	4/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_2_CANYN4
Granted	3/1/2016	4/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_2_CANYN3
Granted	3/1/2016	4/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_2_CANYN2
Granted	3/1/2016	4/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_2_CANYN1
Granted	3/1/2016	4/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	MLAP_ANHM_ANHM
Granted	3/1/2016	3/1/2021	Mustang	Raw & Unedited Data	
Granted	3/1/2016	3/1/2021	Mustang 3	Raw & Unedited Data	
Granted	3/1/2016	3/1/2021	Mustang 4	Raw & Unedited Data	
Granted	3/1/2016	6/15/2016	Potter Valley	Requested exemption to use PT w/ .45% accuracy until available PT w/ .3% accuracy arrived	POTTER_6_UNITS
Granted	2/23/2016	3/23/2016	Kennedy 3, SPVP#033	Requested exemption due to communication issue that prevents direct polling of the meter.	MIRLOM_2_RTS033
Granted	2/22/2016	4/1/2016	Windland Refresh 2	Requested exemption due to communication issue that prevents direct polling of the meter.	MIDWD_2_WIND1
Granted	2/18/2016	3/18/2016	High Sierra Limited	Requested exemption due to communication issue that prevents direct polling of the meter.	SIERRA_1_UNITS
Granted	2/10/2016	2/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_7_CT
Granted	2/10/2016	2/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_2_CANYN4
Granted	2/10/2016	2/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_2_CANYN3
Granted	2/10/2016	2/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_2_CANYN2
Granted	2/10/2016	2/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	ANAHM_2_CANYN1
Granted	2/10/2016	2/29/2016	City of Anaheim	Requested exemption due to communication issue that prevents direct polling of the meter.	MLAP_ANHM_ANHM

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	2/1/2016	2/29/2016	Creed, LLC	Requested exemption extension due to communication issue that prevents direct polling of the meter.	LMBEPK_2_UNITA2
Granted	1/22/2016	3/8/2016	Little Rock Pham Solar	Requested exemption due to communication issue that prevents direct polling of the meter.	LITLRK_6_SOLAR4
Declined	1/20/2016	2/18/2016	Cherry Valley Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	DLAP_SCE_CDWR
Granted	1/20/2016	1/25/2015	San Joaquin # 2 Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	CRNEVL_6_SJQN 2
Granted	1/20/2016	1/25/2015	San Joaquin # 3 Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	CRNEVL_6_SJQN 3
Declined	1/19/2016	2/17/2016	Crafton Hills	Requested exemption due to communication issue that prevents direct polling of the meter.	DLAP_SCE_CDWR
Granted	1/13/2016	12/31/2016	Frito Lay	Modem Exemption	FRITO_1_LAY
Granted	1/1/2016	1/6/2016	Facility 1	Use of Test Device for Non Generating Unit	FRIANT_6_UNITS
Granted	12/31/2015	12/31/2020	North Sky River	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	JA WBNE_2_NSRWND
Granted	12/31/2015	12/31/2020	Sky River Wind Energy Center	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	JAWBNE_2_SRWND
Granted	12/21/2015	2/29/2016	Monterey Regional Waste Mgmt	Requested permanent communications exemption for Marina- LFG.	CSTRVL_7_PL1X2
Granted	12/18/2015	1/31/2016	San Diego Energy Miramar	Requested exemption due to communication issue that prevents direct polling of the meter.	MSHGTS_6_MMARLF
Granted	12/17/2015	12/31/2020	Hayworth Solar Farm	Raw & Unedited Data	LAMONT_1_SOLAR4
Granted	12/17/2015	12/31/2020	Woodmere Solar Farm	Raw & Unedited Data	LAMONT_1_SOLAR3
Granted	12/10/2015	12/31/2016	Sand Hill	Modem Exemption	ALTMID_2_WINDA
Granted	12/8/2015	1/15/2016	G2 Energy Hay Road	Requested exemption due to communication issue that prevents direct polling of the meter.	PEABDY_2_LNDFIL
Granted	12/4/2015	1/31/2016	Fresno Cogen Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	AGRICO_7_UNIT
Granted	12/4/2015	1/31/2016	Fresno Peaker Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	AGRICO_6_PL3N5
Granted	12/4/2015	1/31/2016	Fresno Solar South	Requested exemption due to communication issue that prevents direct polling of the meter.	KERMAN_6_SOLAR1
Granted	12/4/2015	1/31/2016	Fresno Solar West	Requested exemption due to communication issue that prevents direct polling of the meter.	KERMAN_6_SOLAR2
Granted	12/1/2015	1/31/2016	Digger Creek Hydro	Requested exemption due to communication issue that prevents direct polling of the meter.	VOLTA_6_DIGHYD
Granted	12/1/2015	12/31/2020	Golden Hills A	Raw & Unedited Data	USWND2_1_WIND1
Granted	12/1/2015	12/31/2020	Golden Hills B	Raw & Unedited Data	USWND2_1_WIND2
Granted	11/30/2015	12/31/2016	Bailey Creek Hydro Inc.	Requested exemption to use modem due to infeasibility of connecting the ECN.	VOLTA_6_BAILCK
Granted	11/30/2015	12/31/2015	Kern Front Limited	Requested exemption due to communication issue that prevents direct polling of the meter.	KERNFT_1_UNITS
Granted	11/26/2015	12/31/2015	Double C Limited	Requested exemption due to communication issue that prevents direct polling of the meter.	DOUBLCL_1_UNITS

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	11/19/2015	12/31/2020	Yerba Buena NaS	Exemption from 5.1.2 raw, unedited and un-aggregate meter data	SWIFT_1_NAS
Granted	11/18/2015	12/7/2015	G2 Energy Ostrom Road	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	11/10/2015	11/10/2016	Mill & Sulphur Creek Power	Requested exemption to use modem due to infeasibility of connecting the ECN.	LOWGAP_1_SUPHR
Granted	11/13/2015	1/31/2016	MM Yolo Power LLC	Requested exemption due to communication issue that prevents direct polling of the meter.	DAVIS_7_MNMETH
Granted	11/11/2015	11/30/2015	Adlin Power Plant, SMUD Geothermal, Westford Flat Power, Geysers, Calistoga Power Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	ADLIN_1_UNITS SMUDGO_7_UNIT WDFRDF_2_UNITS GYS5X6_7_UNITS GYS7X8_7_UNITS GEYS11_7_UNIT11 GEYS12_7_UNIT12 GEYS13_7_UNIT13 GEYS14_7_UNIT14 GEYS16_7_UNIT16 GEYS17_7_UNIT17 GEYS18_7_UNIT18 SANTFG_7_UNITS GEYS20_7_UNIT20
Granted	11/9/2015	1/31/2016	Creed, LLC	Requested exemption while fiber is repaired and all fiber based communication is tested.	LMBEPK_2_UNITA2
Granted	11/7/2015	12/18/2015	San Diego Energy Miramar	Requested exemption due to communication issue that prevents direct polling of the meter.	MSHGTS_6_MMARLF
Granted	11/6/2015	12/7/2015	G2 Energy Hay Road	Requested exemption due to communication issue that prevents direct polling of the meter.	PEABDY_2_LNDFIL
Granted	10/30/2015	11/30/2015	SCEW_1_PDRP15	Telemetry Exemption for PDR	
Granted	10/30/2015	11/30/2015	SCEW_1_PDRP15	Telemetry Exemption for PDR	
Granted	10/22/2015	12/31/2016	Otay Landfill 3	Requested exemption due to communication issue that prevents direct polling of the meter.	OTAY_7_UNITC1
Granted	10/19/2015	11/17/2015	G2 Energy Ostrom Road	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	10/16/2015	11/30/2015	Bailey Creek Hydro Inc.	Requested exemption due to communication issue that prevents direct polling of the meter.	VOLTA_6_BAILCK
Granted	10/15/2015	1/15/2016	Chevron Richmond	Requested exemption due to communication issue that prevents direct polling of the meter.	STOILS_1_UNITS
Granted	10/1/2015	11/30/2015	Digger Creek Hydro	Requested exemption due to communication issue that prevents direct polling of the meter.	VOLTA_6_DIGHYD
Granted	10/1/2015	11/30/2015	Edom Hill Project	Requested exemption due to communication issue that prevents direct polling of the meter.	

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	10/1/2015	12/31/2016	Pacificorp - Nucor	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	NUCOR_NCL2
Granted	10/1/2015	12/31/2016	Pacificorp - US Magnesium Corp	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	ROWLEY_NCL1 ROWLEY_NCL2 ROWLEY_NCL3
Granted	10/1/2015	12/31/2016	PacifiCorp - US Monsanto	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	MONSANTO_NCL1 MONSANTO_NCL2
Granted	9/30/2015	11/6/2015	San Diego Energy Miramar	Requested exemption due to communication issue that prevents direct polling of the meter.	MSHGTS_6_MMARLF
Granted	9/25/2015	10/31/2015	Desert Hot Springs 2	Requested exemption due to communication issue that prevents direct polling of the meter.	DEVERS_2_DHSPG2
Granted	9/18/2015	10/9/2015	Healdsburg Sub	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	9/16/2015	Pending	NCPA GEO PLANT 1 UNIT 1	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	9/16/2015	Pending	NCPA GEO PLANT 1 UNIT 2	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	9/16/2015	Pending	NCPA GEO PLANT 1 UNIT 3	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	9/16/2015	Pending	NCPA GEO PLANT 1 UNIT 4	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	9/16/2015	12/31/2015	Oakland Station C	Requested exemption due to communication issue that prevents direct polling of the meter.	OAKC_7_UNIT1, OAKC_7_UNIT2, ADLIN_1_UNITS
Granted	9/11/2015	11/11/2015	Adlin Power Plant, SMUD Geothermal, Westford Flat Power, Geysers, Calistoga Power Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	SMUDGO_7_UNIT WDFRDF_2_UNITS GYS5X6_7_UNITS GYS7X8_7_UNITS GEYS11_7_UNIT11 GEYS12_7_UNIT12 GEYS13_7_UNIT13 GEYS14_7_UNIT14 GEYS16_7_UNIT16 GEYS17_7_UNIT17 GEYS18_7_UNIT18 SANTFG_7_UNITS GEYS20_7_UNIT20
Granted	9/1/2015	9/30/2015	Digger Creek Hydro	Requested exemption due to communication issue that prevents direct polling of the meter.	VOLTA_6_DIGHYD

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	8/31/2015	9/30/2015	SMUD Solano Wind Project	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	8/22/2015	9/22/2015	Edmonton	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	8/17/2015	9/18/2015	Crocket CoGen	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	8/14/2015	12/31/2016	Western Power & Steam	Requested exemption to use modem due to infeasibility of connecting the ECN.	DEXZEL_1_UNIT
Granted	8/7/2015	8/7/2015	AP N Lake Solar	Requested for non ANSI standard PTs	
Granted	7/16/2015	12/31/2015 then 3/31/16, then 7/31/16, then 6/30/2017	SCE RDRR Integration	SCE RDRR Exemption, extended to 3/31/16 then 7/31/16 then 6/30/2017	Multiple
Granted	7/7/2015	7/7/2016	New Castle	Use of Test Device for Non Generating Unit	
Granted	7/6/2015	7/31/2015	NCPA_OAKSTA-J	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	7/1/2015	7/31/2015	Digger Creek Hydro	Requested exemption due to communication issue that prevents direct polling of the meter.	VOLTA_6_DIGHYD
Granted	7/1/2015	8/12/2015	Industry MetroLink PV	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	7/1/2015	12/31/2020	Redcrest Solar Farm	Raw & Unedited Data	LAMONT_1_SOLAR5
Granted	6/30/2015	12/31/2016	Kekawaka Hydropower	Requested exemption to use modem due to infeasibility of connecting the ECN.	KEKAWK_6_UNIT
Granted	6/16/2015	10/29/2015	SCEW_2_PDRP14(20MW)	Telemetry Exemption for PDR	
Granted	6/16/2015	10/29/2015	SCEW_2_PDRP15(40MW)	Telemetry Exemption for PDR	
Granted	6/10/2015	7/23/2015	Big Creel WW	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	6/9/2015	6/30/2015	Digger Creek Hydro	Requested exemption due to communication issue that prevents direct polling of the meter.	VOLTA_6_DIGHYD
Granted	6/8/2015	6/8/2016	Madera Chowchilla 1	Use of Test Device for Non Generating Unit	
Granted	6/1/2015	12/31/2016	Sunshine Gas Producers	Requested exemption to use modem due to infeasibility of connecting the ECN.	SUNSHN_2_LNDFL
Granted	5/29/2015	5/29/2016	Desert Sunlight Solar	Exemption from 10.2.1.2 format data submission.	DSRTSN_2_SOLAR1 DSRTSN_2_SOLAR2
Granted	5/29/2015	5/29/2016	Desert Sunlight Solar	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	DSRTSN_2_SOLAR1 DSRTSN_2_SOLAR2
Granted	5/28/2015	5/28/2016	Drum1	Use of Test Device for Non Generating Unit	
Granted	5/23/2015	12/31/2016	Hollister Solar	Requested exemption to use modem due to infeasibility of connecting the ECN.	HOLSTR_1_SOLAR2
Granted	5/22/2015	5/22/2016	Canal Creek Powerhouse	Use of Test Device for Non Generating Unit	
Granted	5/22/2015	5/22/2016	Fairfield Powerhouse	Use of Test Device for Non Generating Unit	
Granted	5/22/2015	7/10/2015	Otay Landfill 3	Requested exemption due to communication issue that prevents direct polling of the meter.	OTAY_7_UNITC1
Granted	5/20/2015	7/20/2015	Johnson Canyon LFG	Requested exemption due to communication issue that prevents direct polling of the meter.	

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	5/20/2015	12/31/2016	PacifiCorp Jim Bridger	Requested exemption to use 15 minute granularity Meters	JIMBRIDG_7_UNITS
Granted	5/8/2015	7/31/2015	Kumeyaay Wind Park	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	5/5/2015	9/15/2015	Belden_7_Unit1	Use of Test Device for Non Generating Unit	
Granted	4/30/2015	4/30/2016	Burney Biomass (14GEN773	Use of Test Device for Non Generating Unit	
Granted	4/27/2015	5/29/2015	Pointe City Gate	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	4/27/2015	6/4/2015	Windstar Energy	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	4/25/2015	6/30/2015	Oildale Energy LLC	Metering & Telemetry Waiver	OILDAL_1_UNIT1
Granted	4/13/2015	4/30/2015	French Meadows PH	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	4/6/2015	5/6/2015	SPVP 048	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	4/1/2015	10/1/2015	Pacificorp - Nucor	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	NUCOR_NCL2
Granted	4/1/2015	10/1/2015	PacifiCorp - US Monsanto	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	MONSANTO_NCL1 MONSANTO_NCL2
Granted	4/1/2015	3/1/2016	Potter Valley	Requested exemption to use PT w/ .45% accuracy until available PT w/ .3% accuracy arrived	POTTER_6_UNITS
Granted	4/1/2015	10/1/2015	US Magnesium Corp	PacifiCorp requests a waiver of CAISO Tariff section 10.2.12 in order to design and install 5-minute revenue quality metering.	ROWLEY_NCL1 ROWLEY_NCL2 ROWLEY_NCL3
Granted	4/1/2015	4/30/2015	Water Wheel Ranch	Requested exemption ECN Communication	
Granted	3/27/2015	12/31/2016	Merced Solar	Requested exemption to use modem due to infeasibility of connecting the ECN.	MERCED_1_SOLAR2
Granted	3/27/2015	12/31/2016	Mission Solar	Requested exemption to use modem due to infeasibility of connecting the ECN.	MERCED_1_SOLAR1
Granted	3/9/2015	7/22/2015	Central Valley Ag Pwr	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	3/9/2015	3/31/2015	NCPA-OAKSTA-J	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	3/6/2015	4/6/2015	SPVP 048	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	3/6/2015	6/6/2015	SPVP048	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	2/20/2015	3/20/2015	Ameresco Butte County	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	2/20/2015	4/6/2015	ERUS-OASIS WIND PROJECT	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	2/17/2015	3/17/2015	Azusa Substation 1	Requested exemption due to communication issue that prevents direct polling of the meter.	

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	2/17/2015	3/17/2015	Azusa Substation 2	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	2/15/2015	2/14/2016	Canal Creek Powerhouse	Requested exemption ECN Communication	CURTIS_1_CANLCLK
Granted	2/12/2015	2/12/2016	Imperial Valley West	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	IVWEST_2_SOLAR1
Granted	2/10/2015	2/10/2016	Water Wheel Ranch	Requested exemption ECN Communication	CEDRCK_6_UNIT
Granted	2/9/2015	3/25/2015	Coram Energy	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	2/4/2015	3/4/2015	Lost Creek 2	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	2/2/2015	2/23/2015	NCPA Gridley	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	2/1/2015	2/28/2015	Wellhead Panoche	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	1/19/2015	2/10/2014	Container Corporation of	Requested exemption due to data issue that prevents direct polling of the meter.	
Granted	11/12/2015	11/12/2016	Baker Station Hydro	Requested exemption to use modem due to infeasibility of connecting the ECN.	BRDGLV_7_BAKER
Granted	1/13/2015	2/21/2014	Desert Star MPT 2	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	1/13/2015	2/13/2015	SPVP 005	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	1/12/2015	3/12/2015	Oxbow Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	1/9/2015	3/29/2015	Phoenix Wind Project	Requested exemption to use PT w/ .35% accuracy until available PT w/ .3% accuracy arrived	PWEST_1_UNIT
Granted	1/9/2015	1/9/2016	Salmon Creek Hydroelectric	Requested exemption to use modem due to infeasibility of connecting the ECN.	ALLGNY_6_HYDRO1
Granted	1/1/2015	1/31/2015	Portal Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	12/31/2014	12/31/2015	Rising Tree 1	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	RTREE_2_WIND1
Granted	12/31/2014	12/31/2015	Rising Tree 2	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	RTREE_2_WIND2
Granted	12/29/2014	4/11/2015	Inland Empire Energy Center,	Use of Test Device for Non Generating Unit	
Granted	12/29/2014	4/11/2015	Inland Empire Energy Center,	Use of Test Device for Non Generating Unit	
Granted	12/27/2014	1/31/2015	Wellhead Power Panoche	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	12/26/2014	1/31/2014	Mill Creek 3	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	12/24/2014	12/24/2015	North Sky River	Requested exemption from 5.1.2 "raw, unedited and un-aggregate Meter Data"	JA WBNE_2_NSRWND
Granted	12/23/2014	12/31/2016	Bear Creek Solar Project	Requested exemption to use modem due to infeasibility of connecting the ECN.	LOCKFD_1_BEARCK
Granted	12/23/2014	1/23/2014	SPVP 027	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	
Granted	12/19/2014	1/19/2014	SPVP 016	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	12/19/2014	1/19/2014	SPVP 022	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	
Granted	12/12/2014	12/31/2014	Portal Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	12/2/2014	1/16/2015	Phoenix Wind Project	Requested exemption due to communication issue that prevents direct polling of the meter.	PWEST_1_UNIT
Granted	11/26/2014	12/26/2014	Ontario Solar, SPVP#006	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	11/25/2014	12/25/2014	Mill Creek 3	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	11/21/2014	12/5/2014	Blackbutte PH	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	11/20/2014	5/20/2015	PacifiCorp Jim Bridger	Requested exemption to use 15 minute granularity Meters	JIMBRIDG_7_UNITS
Granted	11/18/2014	12/31/2016	2081 Terzian	Requested exemption to use modem due to infeasibility of connecting the ECN.	REEDLY_6_SOLAR
Granted	11/18/2014	12/31/2016	Desert Hot Springs 2	Requested exemption to use modem due to infeasibility of connecting the ECN.	DEVERS_2_DHSPG2
Granted	11/15/2014	12/31/2014	Chowchilla Peaker Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	11/14/2014	12/14/2014	Portal Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	11/10/2014	12/10/2014	New Hogan	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	11/9/2014	5/9/2015	PacifiCorp Huntington 2 & Naughton 3	Requested exemption to use 15 minute granularity Meters	NAUGHTON_7_UNIT3 HUNTINGT_7_UNIT2

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	11/1/2014	N/A	EIM Only	<p>Section 10.4.2 of the CAISO Tariff provides the CAISO authority to grant exemptions from metering requirements to either individual scheduling coordinators or to a class of entities. With the implementation of the Energy Imbalance Market (EIM), the CAISO has determined it is appropriate to grant the following class exemption for Scheduling Coordinators representing Scheduling Coordinator Metered Entities:</p> <p>All Scheduling Coordinators and other entities submitting meter data related to EIM resources for either generation not associated with Ancillary Services, Flow Gates (Interties), or load, may submit meter data in the following granularity levels not already stated in section 10.3.2.2 of the CAISO Tariff:</p> <ul style="list-style-type: none"> a. Generation for participating generators at 5-minute intervals; non-participating generators at 5, 15 or 60-minute intervals. b. Flow Gates (Interties) at 5-minute intervals. c. Load at 5, 15 or 60-minute intervals. <p>This class exemption only applies to Scheduling Coordinators who submit Settlement Quality Meter Data for EIM related resources. A change made for a resource is expected to be a one-time change and the resource will maintain the granularity unless a meter or meter program change requires a future adjustment. Granularity levels cannot be changed to a granularity lower than what is currently programmable within the individual meters.</p>	

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	5/1/2014	N/A	FERC 764 Only	<p>Section 10.4.2 of the CAISO Tariff provides the CAISO authority to grant exemptions from metering requirements to either individual scheduling coordinators or to a class of entities. With the implementation of FERC 764, and in accordance with the market notice titled "FERC 764 OMAR Data Submission Granularity Changes Extended to April 14, 2014 in Spring 2014 Release" issued on March 14, 2014, the CAISO has determined it is appropriate to grant the following class exemption for Scheduling Coordinators representing Scheduling Coordinator Metered Entities:</p> <p>All Scheduling Coordinators and other entities submitting meter data for either generation not associated with Ancillary Services, inerties, or load, may submit meter data in the following granularity levels not already stated in section 10.3.2.2 of the CAISO Tariff:</p> <ul style="list-style-type: none"> a. Generation at 5, 15 or 60-minute intervals. b. Load at 60-minute intervals. <p>This class exemption only applies to Scheduling Coordinators who submit Settlement Quality Meter Data. A change made for a resource is expected to be a one-time change and the resource will maintain the granularity unless a meter or meter program change requires a future adjustment. Granularity levels cannot be changed to a granularity lower than what is currently programmable within the individual meters.</p>	
Granted	10/31/2014	12/24/2014	Keller Canyon LFG	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	10/31/2014	12/8/2014	Red Bluff Peaker Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	10/24/2014	12/24/2014	Oasis Wind Project	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	10/22/2014	12/31/2016	Woodward Power house	Requested exemption due to communication issue that prevents direct polling of the meter.	VLYHOM_Y_SSJID
Granted	10/20/2014	10/31/2014	Red Bluff Peaker Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	10/18/2014	10/31/2014	Lodi Industrial	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	10/17/2014	11/21/2014	Azusa Substation Maintenance	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	
Granted	10/16/2014	11/14/2014	Chowchilla Peaker Plant	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	10/15/2014	11/15/2015	Baker Station Hydroelectric	Requested exemption to use modem due to infeasibility of connecting the ECN.	
Granted	10/15/2014	11/15/2014	CENTER6PEAKER	Requested exemption due to communication issue that prevents direct polling of the meter.	

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	10/15/2014	11/15/2015	Mill & Sulphur Creek Power	Requested exemption to use modem due to infeasibility of connecting the ECN.	
Granted	10/8/2014	11/8/2014	Mustang Hills	Requested exemption due to communication issue that prevents direct polling of the meter.	ALTA4B_2_CPCW6
Granted	10/7/2014	11/7/2014	Portal Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	9/22/2014	10/22/2014	Frankenheimer Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	COTTLE_2_FRNKNH
Granted	9/22/2014	10/22/2014	Woodward Power house	Requested exemption due to communication issue that prevents direct polling of the meter.	VLYHOM_Y_SSID
Granted	9/17/2014	12/31/2016	Kettleman Solar	Requested exemption to use modem due to infeasibility of connecting the ECN.	LOCKFD_1_KSOLAR
Granted	9/17/2014	10/8/2014	Palo Alto COBUG	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	9/17/2014	12/31/2016	Vintner Solar	Requested exemption to use modem due to infeasibility of connecting the ECN.	TMPLTN_2_SOLAR
Granted	9/10/2014	12/31/2016	Virginia Ranch Dam PH	Requested exemption to use modem due to infeasibility of connecting the ECN.	BANGOR_6_HYDRO
Granted	9/7/2014	10/7/2014	KERN1-4	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	9/1/2014	12/31/2016	Altamont Landfill Gas to Energy	Requested exemption to use modem due to infeasibility of connecting the ECN.	USWND4_2_UNITS
Granted	8/29/2014	10/3/2014	Cherry Valley	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	8/28/2014	9/22/2014	Frankenheimer Powerhouse	Requested exemption due to communication issue that prevents direct polling of the meter.	COTTLE_2_FRNKNH
Granted	8/28/2014	9/22/2014	Woodward Power house	Requested exemption due to communication issue that prevents direct polling of the meter.	VLYHOM_Y_SSID
Granted	8/27/2014	10/18/2014	Camp Far West	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	8/15/2014	8/14/2015	Western Power & Steam	Requested exemption to use modem due to infeasibility of connecting the ECN.	DEXZEL_1_UNIT
Granted	8/7/2014	9/7/2014	Kern River 1, Unit 4		
Granted	7/24/2014	8/8/2014	SAN GORGONIO FARMS WIND FARM	PT and two fuses at the SANWIND substation failed caused our CAISO revenue meters to read incorrectly	
Granted	7/16/2014	8/21/2014	Del Valle	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	7/16/2014	8/21/2014	Del-valle	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	7/16/2014	8/21/2014	Pine Flat	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	7/11/2014	12/31/2016	CA PV Energy - Champagne	Requested exemption to use modem due to infeasibility of connecting the ECN.	ETIWND_2_CHMPNE
Granted	7/11/2014	12/31/2016	CA PV Energy - Jurupa	Requested exemption to use modem due to infeasibility of connecting the ECN.	CHINO_2_JURUPA
Granted	7/9/2014	8/31/2014	Berry Cogen 18	Requested exemption due to communication issue that prevents direct polling of the meter.	
Granted	7/9/2014	8/31/2014	Berry Cogen 38	Requested exemption due to communication issue that prevents direct polling of the meter.	

Exemption Status	Exemption Start Date	Exemption Expiration Date	Site Name	Description	Resource ID
Granted	7/8/2014	8/29/2014	Diablo Canyon Unit 1	Requested exemption to use plant logs as an error has occurred in meter data due to the failure in A phase current element.	
Granted	7/7/2014	8/7/2014	MM Prima Deshecha, LLC	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	
Granted	7/2/2014	12/31/2016	G2 Energy Hay Road	Requested exemption to use modem due to infeasibility of connecting the ECN.	PEABDY_2_LNDFIL
Granted	7/1/2014	6/30/2015	Kekawaka Hydropower	Requested exemption to use modem due to infeasibility of connecting the ECN.	KEKAWK_6_UNIT
Granted	7/1/2014	12/31/2016	Parker Hydro Plant	Requested exemption to use modem due to infeasibility of connecting the ECN.	CRESSY_1_PARKER
Granted	6/26/2014	12/31/2014	Hell Hole PCWA	Request Exemption to stay SCME until they can convert to a CAISOME	
Granted	6/23/2014	7/25/2014	Bear Creek Solar Project	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	LOCKFD_1_BEARCK
Granted	6/23/2014	7/23/2014	EBMUD Wastewater	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	OAK L_1_EBMUD
Granted	6/23/2014	7/23/2014	OAK L_1_GTG1	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	
Granted	6/16/2014	7/11/2014	Biggs60kv	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	
Granted	6/9/2014	7/9/2014	Narrows Power House No. 1	Requested exemption due to communication issue that prevents direct polling of the meter. CSV files to be provided.	
Granted	6/4/2014	6/30/2014	Harbor Cogeneration Company	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	
Granted	6/4/2014	7/4/2014	MM Prima Deshecha, LLC	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	
Granted	6/2/2014	7/2/2014	Kaweah Unit 3	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	
Granted	6/2/2014	6/1/2015	Sunshine Gas Producers	Requested exemption due to communication issue that prevents direct polling of the meter. HHF files to be provided.	SUNSHN_2_LNDFL