



California ISO

# 2019 & 2023 Draft LCR Study Results Greater Bay Area


Binaya Shrestha

Regional Transmission Engineer Lead

Stakeholder Meeting

April 9, 2019

# Greater Bay Area Transmission System



# New major transmission projects

2019:

- Metcalf-Evergreen 115 kV Line Reconductoring
- South of San Mateo Capacity Increase (revised scope)
- San Jose-Trimble 115 kV Line Limiting Facility Upgrade
- Moss Landing–Panoche 230 kV Path Upgrade
- San Jose-Trimble 115 kV Series Reactor

2023 (Additional):

- Oakland Clean Energy Initiative Project (Oakland CTs assumed retired)
- Morgan Hill Area Reinforcement (revised scope)
- Metcalf-Piercy & Swift and Newark-Dixon Landing 115 kV Upgrade
- East Shore-Oakland J 115 kV Reconductoring Project
- Vaca Dixon-Lakeville 230 kV Corridor Series Compensation

# Power plant changes

## Additions:

- No new resource addition

## Retirements:

- United Co
- Tres Vaqueros Wind
- Container

# Bay Area Load and Resources (MW)

		<b>2019</b>	<b>2023</b>
Gross Load	=	10,160	10,502
AAEE	=	-137	- 465
Behind the meter DG	=	-230	-61
<b>Net Load</b>	<b>=</b>	<b>9,793</b>	<b>9,976</b>
Transmission Losses	=	217	245
Pumps	=	264	264
<b>Load + Losses + Pumps</b>	<b>=</b>	<b>10,274</b>	<b>10,221</b>
Market Generation	=	6,128	5,963
Wind Generation	=	321	321
Muni Generation	=	255	255
QF Generation	=	245	245
Total Qualifying Capacity	=	<b>6,949</b>	<b>6,784</b>

# San Jose Sub Area

## **San Jose Sub-area – Category B**

2019 LCR need: No requirement.

2023 LCR need: No requirement.

## **San Jose Sub-area – Category C**

Contingency: Newark-Los Esteros 230kV Line overlapped with Metcalf-Los Esteros 230kV Line

Limiting component: Newark-NRS 115kV Line

2019 LCR need: 177 MW

2023 LCR need: 293 MW

# Llagas Sub Area

## **Llagas Sub-area – Category B**

Contingency: Metcalf D-Morgan Hill 115 kV with one of the Gilroy peakers off line

Limiting component: Morgan Hill-Llagas 115 kV line

2019 LCR need: 77 MW

2023 LCR need: No requirement.

## **Llagas Sub-area – Category C**

2019 LCR need: Same as Category B

Contingency: Metcalf-Morgan Hill 115 kV overlapped with outage of Morgan Hill-Green Valley 115 kV line

Limiting component: Morgan Hill-Llagas 115 kV Line

2023 LCR need: 13 MW

# South Bay-Moss Landing Sub Area

## **South Bay-Moss Landing Sub-area – Category B**

2019 LCR need: No requirement.

2023 LCR need: No requirement.

## **South Bay-Moss Landing Sub-area – Category C**

Contingency: Tesla-Metcalf 500 kV and Moss Landing-Los Banos 500 kV

Limiting component: Thermal overload of Las Aguillas-Moss Landing 230 kV

2019 LCR need: 1653 MW

2023 LCR need: 1977 MW

Resources in San Jose and Llagas sub-areas are also included in this sub-area.



# Oakland Sub Area

## **Oakland Sub-area – Category B**

2019 LCR need: No requirement

2023 LCR need: No requirement

## **Oakland Sub-area – Category C**

Contingency: overlapping D-L and C-X #3 115 kV cables

Limiting component: Thermal overload on the C-X #2 115 kV cable.

2019 LCR need: 20 MW

2023 LCR need: No requirement

# Ames/Pittsburg/Oakland Sub-Area

## NCNB Sub-area – Category B

Contingency: Vaca Dixon-Tulucay 230 kV line with Delta Energy Center power plant out of service

Limiting component: Thermal overload on the Vaca Dixon-Lakeville 230 kV line

## Ames/Pittsburg/Oakland Sub-area – Category C

Contingency1: DCTL Newark-Ravenswood & Tesla-Ravenswood 230 kV

Limiting component: Thermal overload on the Ames-Ravenswood #1 115 kV line

Contingency2: Moraga-Sobrante & Moraga-Claremont #1 115 kV

Limiting component: Thermal overload on the Moraga-Claremont #2 115 kV line

	<u>2019 LCR need:</u>	<u>2023 LCR need:</u>
NCNB:	689 MW	553 MW
Ames/Pittsburg/Oakland :	1741 MW	1630 MW

# Contra Costa Sub Area

## **Contra Costa Sub-area – Category B**

Contingency: Kelso-Tesla 230 kV with the Gateway off line

Limiting component: Thermal overload on the Delta Switching Yard-Tesla 230 kV Line

2019 LCR need: 1067 MW

2023 LCR need: 1145 MW

## **Contra Costa Sub-area – Category C**

Same as Category B.

# Greater Bay Area Overall

## **Bay Area Overall – Category B**

Contingency: Tesla-Metcalf 500 kV line with Delta Energy Center out of service

Limiting component: Reactive margin within the Bay Area

2019 LCR need: 3593 MW

2023 LCR need: 3676 MW

## **Bay Area Overall – Category C**

2019 LCR need: Sum of Category C from sub-area needs: 4461 MW

2023 LCR need: Sum of Category C from sub-area needs: 4752 MW

# Greater Bay Area

## Available Generation

Year	QF (MW)	Muni (MW)	Wind (MW)	Market (MW)	Max. Qualifying Capacity (MW)
2019	245	255	321	6128	6949
2023	245	255	321	5963	6784

## Total LCR need

	Existing Generation Capacity Needed (MW)		Deficiency (MW)		Total MW Need	
	2019	2023	2019	2023	2019	2023
Category B (Single)	3670	3676	0	0	3670	3676
Category C (Multiple)	4461	4752	0	0	4461	4752

# Changes

## Since last year:

- 1) Updated NQC
- 2) 2019 load forecast is higher by 27 MW vs. 2018
- 3) LCR need has decreased by 699 MW vs. 2018 – due to new transmission projects
- 4) 2023 load forecast is higher by 41 MW vs. 2022
- 5) LCR need has decreased by 563 MW vs. 2022 – due to new transmission projects

# THANK YOU

Your comments and questions are welcome.

For written comments, please send to: [RegionalTransmission@caiso.com](mailto:RegionalTransmission@caiso.com)

---

## Stay connected



@California\_ISO



Download ISO Today  
mobile app



Sign up for the Daily Briefing  
at [www.caiso.com](http://www.caiso.com)