


# 2017 Final LCR Study Results Greater Bay Area

Bryan Fong

Senior Regional Transmission Engineer


Stakeholder Call

April 14, 2016





# Greater Bay Area Transmission System



# New major transmission projects

- Contra Costa – Moraga 230 kV Line Reconductoring – 06/16
- Embarcadero-Potrero 230 kV Transmission Project – 04/16
- Moraga Transformers Capacity Increase – 10/16
- Pittsburg – Tesla 230 kV Reconductoring – 10/15

# Bay Area Load and Resources (MW)

		<b>2017</b>	<b>M-L</b>	<b>Total</b>
Load	=	9,543	595	10,138
AAEE	=	-135	-11	-146
Transmission Losses	=	191	30	221
Pumps	=	264	0	264
<b>Total Load</b>	<b>=</b>	<b>9,863</b>	<b>614</b>	<b>10,477</b>
Market Generation	=	6,262	2,530	8,792
Wind Generation	=	291	0	291
Muni Generation	=	547	0	547
QF Generation	=	232	0	232
<b>Total Qualifying Capacity</b>	<b>=</b>	<b>7,332</b>	<b>2,530</b>	<b>9,862</b>

# San Jose Sub Area

## **San Jose Sub-area – Category B**

Contingency: North Receiving Station-Scott Receiving Stations 115 kV Line #2 (NRS300-SRS#2) with Duane PP out of service

Limiting component: Thermal overload of North Receiving Station-Scott Receiving Stations 115 kV Line #1 (NRS300-SRS #1)

2017 LCR need: 788 MW (includes 5 MW of QF and 230 MW of generation as well as 232 MW of deficiency)

## **San Jose Sub-area – Category C**

Contingency: Same as Category B



# Llagas Sub Area

## **Llagas Sub-area – Category B**

Contingency: Metcalf D-Morgan Hill 115 kV with one of the Gilroy peakers off line

Limiting component: 5% voltage drop at the Morgan Hill substation

2017 LCR need: 131 MW (includes 0 MW of QF/Muni generation)

## **Llagas Sub-area – Category C**

2017 LCR need: Same as Category B

# South Bay-Moss Landing Sub Area

## **South Bay-Moss Landing Sub-area – Category B**

2017 LCR need: No requirement.

## **South Bay-Moss Landing Sub-area – Category C**

Contingency: Tesla-Metcalf 500 kV and Moss Landing-Los Banos 500 kV

Limiting component: Thermal overload of Las Aguillas-Moss Landing 230 kV

2017 LCR need: 2178 MW (includes 5 MW of QF and 230 MW of Muni generation)

Resources in San Jose and Llagas sub-areas are also included in this sub-area.



# Oakland Sub Area

## **Oakland Sub-area – Category B**

2017 LCR need: No requirement

## **Oakland Sub-area – Category C**

Contingency: overlapping C-X #2 and C-X #3 115 kV cables

Limiting component: Thermal overload on the Moraga – Claremont #1 or #2  
230 kV Line.

2017 LCR need: 45 MW (includes 49 MW of Muni generation)

**This requirement does not include the need for the Pittsburg/  
Oakland sub-area**

# Pittsburg/Oakland Sub Area

## **Pittsburg/Oakland Sub-area – Category B**

2017 LCR need: No requirement.

## **Pittsburg/Oakland Sub-area – Category C**

2017 LCR need: No requirement.

# Ames/Pittsburg Sub-Area

## **NCNB Sub-area – Category B**

Contingency: Vaca Dixon-Tulucay 230 kV line with Delta Energy Center power plant out of service

Limiting component: Thermal overload on the Vaca Dixon-Lakeville 230 kV line

## **Ames/Pittsburg Sub-area – Category C**

Contingency: DCTL Newark-Ravenswood & Tesla-Ravenswood 230 kV

Limiting component: Thermal overload on the Newark-Ames #2 115 kV line

### 2017 LCR need:

NCNB: 721 MW (includes 14 MW of QF and 114 MW Muni generation)

Ames: 596 MW (includes 0 MW of QF and Muni generation)

Pittsburg: 1485 MW (includes 200 MW of QF and Muni generation)

# Contra Costa Sub Area

## **Contra Costa Sub-area – Category B**

Contingency: Kelso-Tesla 230 kV with the Gateway off line

Limiting component: Thermal overload on the Delta Switching Yard-  
Tesla 230 kV Line

2017 LCR need: 1,081 MW (includes 289 MW of Wind generation and  
264 MW of MUNI pumps)

## **Contra Costa Sub-area – Category C**

Same as Category B

# Greater Bay Area Overall

## **Bay Area Overall – Category B**

Contingency: Tesla-Metcalf 500 kV line with Delta Energy Center out of service

Limiting component: Reactive margin within the Bay Area

2017 LCR need: 4260 MW (includes 232 MW of QF, 547 MW of MUNI and 291 MW of wind generation)

## **Bay Area Overall – Category C**

Sum of Category C from sub-area needs: 5385 MW (includes 232 MW of QF, 547 MW of MUNI and 291 MW of wind generation)

# Greater Bay Area

## *Available Generation*

Year	QF (MW)	Muni (MW)	Wind (MW)	Market (MW)	Max. Qualifying Capacity (MW)
2017	232	547	291	8792	9862

## *Total LCR need*

	Existing Generation Capacity Needed (MW)	Deficiency (MW)	Total MW Need
2017			
Category B (Single)	4260	232	4492
Category C (Multiple)	5385	232	5617



# Changes

## Since last year:

- 1) 2017 load forecast is higher by 394 MW vs. 2016 (due to expanded Bay Area)
- 2) Additional 614 MW of load in the Moss Landing area
- 3) LCR need has increased by 1,268 MW vs. 2016 – due deficiency increase in the San Jose sub pocket and new requirement in the South Bay-Moss Landing sub-area
- 4) The “Existing Generation Capacity Needed” has increased by 1,167 MW
- 5) Area definition expanded to include Moss Landing resources and load

## Since last stakeholder meeting:

- 1) Updated NQC.
- 2) Updated studies after load was increased by 520 MW (load behind the meter) in order for the base case to correlate well with CEC forecast.

**Your comments and questions are welcome.**

**For written comments, please send to: [RegionalTransmission@caiso.com](mailto:RegionalTransmission@caiso.com)**