

2019 & 2023 Final LCR Study Results San Diego-Imperial Valley non-bulk sub-areas


Luba Kravchuk – Senior Regional Transmission Engineer

Frank Chen - Regional Transmission Engineer Lead

Stakeholder Call

May 1, 2018

San Diego-Imperial Valley LCR Area



Major Network Upgrades Modeled by 2019

- 1. Ocean Ranch 69 kV substation
- 3. Mesa Height TL600 Loop-in
- 4. Re-conductor of Mission-Mesa Heights 69 kV
- 4. Re-conductor of Kearny-Mission 69 kV line
- 5. TL6906 Mesa Rim rearrangement
- 6. Upgrade Bernardo Rancho Carmel 69kV line
- 7. Re-conductor of Japanes Mesa–Basilone–Talega Tap 69 kV lines
- 8. 2nd Miguel-Bay Boulevard 230 kV line
- 9. Sycamore–Penasquitos 230kV line
- 10. 2nd Mission 230/69 kV bank
- 11. Suncrest SVC project
- 12. By-passing 500 kV series capacitor banks on SWPL and SPL
- 13. Encina generation retirement
- 14. Carlsbad Energy Center (5x100 MW)
- 15. Battery energy storage projects (total of 78 MW)



ISO Public Slide 3

Additional Network Upgrades by 2023

- 1. TL632 Granite loop-in and TL6914 reconfiguration
- 2. 2nd San Marcos-Escondido 69kV line
- 3. Reconductor of Stuart Tap-Las Pulgas 69 kV line (TL690E)
- 4. 2nd Poway-Pomerado 69 kV line
- 5. Artesian 230 kV expansion with 69kV upgrade
- 6. South Orange County Reliability Enhancement
- 7. Imperial Valley bank #80 replacement



ISO Public Slide 4

Sub-areas studied:

- El Cajon sub-area
- Esco sub-area
- Pala sub-area
- Border sub-area
- Mission sub-area
- Miramar sub-area



El Cajon Sub-area Critical Contingencies

Category C:

2019: Contingency: loss of Miguel–Granite–Los Coches three-terminal 69 kV line(TL632) followed by the loss of El Cajon Unit 2.

Limiting component: El Cajon-Los Coches 69 kV (TL631) overloaded.

LCR need: 88 MW

2023: Contingency: loss of Granite – Los Coches 69 kV lines #1 and #2.

Limiting component: El Cajon-Los Coches 69 kV (TL631) overloaded.

LCR need: 35 MW

Category B:

2019: Contingency: loss of El Cajon Unit 2 followed by the loss of Miguel–Granite–Los Coches 69 kV (TL632)

Limiting component: El Cajon -Los Coches 69 kV (TL631) overloaded

LCR need: 88 MW

2023: LCR need: 0 MW



ISO Public Slide 6

Esco Sub-area Critical Contingency

Category C:

2019:

No LCR need in 2019 due to the addition of the Sycamore-Penasquitos 230 kV line, along with load reduction of energy efficient (AAEE) and distributed self-generation (BTM PV).

2023:

Contingency: loss of either one of the two Sycamore-Pomerado 69 kV (TL6915 or TL6924) lines followed by the loss of Artesian 230/69kV bank or vice versa.

Limiting component: remaining Sycamore-Pomerado 69 kV line overloaded.

LCR need: 20 MW

Category B:



Pala Sub-area Critical Contingency

Category C:

Contingency: loss of Pendleton-San Luis Rey 69 kV line (TL6912) followed by loss of Lilac-Pala 69kV (TL6908).

Limiting component: Melrose-Morro Hill Tap 69kV (TL694) overloaded.

2019 LCR need: 10 MW

2023 LCR need: 10 MW

Category B:



Border Sub-area Critical Contingency

Category C:

Contingency: loss of Bay Boulevard-Otay 69 kV #1 (TL645) followed by loss of Bay Boulevard-Otay 69 kV #2 (TL646)

Limiting component: Imperial Beach-Bay Boulevard 69 kV (TL647) overloaded

2019 LCR need: 100 MW 2023 LCR need: 108 MW

Category B:



Mission Sub-area Critical Contingency

The LCR need for the Mission sub-area is eliminated with the completions of the T600 Loop-in to Mesa Heights 69 kV and TL676 Mission – Mesa Heights 69 kV re-conductor projects.

ISO Public

Category C:

No LCR need in 2019 and 2023.

Category B:



Miramar Sub-area Critical Contingency

The LCR need for the Miramar sub-area is eliminated with the addition of the Sycamore-Penasquitos 230 kV project.

Category C:

No LCR need in 2019 and 2023

Category B:

No LCR need in 2019 and 2023



THANK YOU

Your comments and questions are welcome.

For written comments, please send to: RegionalTransmission@caiso.com

Stay connected



@California_ISO



Download ISO Today mobile app



Sign up for the Daily Briefing at www.caiso.com



ISO Public