

NorthernGrid

Interregional Coordination
March 9, 2023


Overview


Regional Transmission Plan

Economic Study Scope: Pumped Storage Hydro


Economic Study Scope: Offshore Wind








Regional Projects



G:\GEO.SPATIAL\Geoworkspaces\Transmission\NorthernGrid_CONFIDENTIAL_DATA\Maps\Regional Transmission Projects.mxd

Regional Transmission Process

- Work together to create a Regional Plan that “exceeds” a simple rollup of all the Local Area Plans



A Regional Transmission Plan is not a Construction Plan

*Economic Study Requests occur annually



Study Approach

4 “starting” base cases

Toggle regional projects in and out


Run reliability analysis on the combinations

Evaluate output as basis for Regional Planning



SUM, Heavy Summer 2032

- Southbound Northwest to California
- Eastbound Northwest to Idaho
- Southbound MATL






WIN, Heavy Winter 2032

- Typical seasonal dispatch
- Northbound MATL

CAL-X, Light Spring 2031

- Northbound California to Northwest
- 2032 loading





WY: High Wyoming wind export case

- Export hour from Production Cost Modeling

Economic Study Request: Pumped Storage Hydro

±900 MW
500 kV Aeolus Substation



Pumped Storage Analysis Approach


Production Cost Modeling

2032 Anchor Data Set

NorthernGrid Transmission additions



Economic Study Request: Offshore Wind



Offshore Wind: Power Flow

2032 Heavy
Summer base
case "Stock"

Account for
NorthernGrid
Data
submittals

Model in
Offshore Wind
at maximum
output

Perform
reliability
analysis



"Transmission
Solution"

Existing Infrastructure Improvements

New high-capacity 230 kV line from the Coos Bay area to Lane


New high-capacity 230 kV line from the Coos Bay area to Dixonville

Substation work at Lane, Dixonville, new telecom


Dynamic reactive devices throughout


Upgrade the 230 kV system in the Eugene area

Upgrade Dixonville transformation and line



Initial reliability findings, "N-0"






500kV
230kV
115kV

500 kV Upgrades Needed

- Fairview 500 kV substation
- Wendson 500 kV substation
- Dixonville 500 kV substation upgrades
- Lane 500 kV substation upgrades
- Alvey 500 kV substation upgrades
- 49 mile 500 kV line from Fairview to Dixonville
- 41 mile 500 kV line from Wendson to Lane
- 63 mile 500 kV line from Fairview to Wendson
- 14-mile 500 kV line from Lane to Alvey
- Series compensation in Fairview-Wendson 500 kV line
- Fairview 500/230 kV transformer
- Wendson 500/230 transformer



Reliability Findings

No Reliability violations, N-0 OR N-1



Offshore Wind: Production Cost

1. Anchor Data Set

Account for NorthernGrid Data Submittals


Run Production Cost, establish "baseline"

Add in offshore wind and "Transmission Solution"


Run Production Cost, establish changes



Offshore Wind Output




Fairview Cut Plane



- FV PF 230
- FV PF 500

Fairview Cut Plane Congestion



- FV Cong 230
- FV Cong 500

Thank you!

Chelsea Loomis

Regional Transmission Activities

Chelsea.loomis@westernpowerpool.org

