



Resource adequacy enhancements discussion

Lauren Carr

Bridget Sparks, Ph.D

Gabe Murtaugh

Infrastructure and Regulatory Policy

Market Surveillance Committee Meeting

General Session

October 9, 2020

Resource adequacy enhancements is a comprehensive initiative to enhance the RA program

1. Determining system RA requirements
2. **Unforced capacity evaluations***
3. System RA showings and sufficiency testing
4. Must offer obligations and bid insertion modifications
5. Planned outage process enhancements
6. RA import provisions
7. **Operationalizing storage resources***
8. Flexible resource adequacy
9. Local resource adequacy
10. Backstop capacity procurement provisions

* These proposal elements will be discussed today

Resource adequacy enhancements policy development schedule

Date	Milestone
September 15,17	Working Group
Oct 1	Stakeholder comments on Working Group due
Oct 9	Market Surveillance Committee Meeting
Nov 3	Draft final proposal
Nov 10-12	Stakeholder meeting on draft final proposal
Nov 13	Market Surveillance Committee Meeting
Dec 3	Stakeholder comments on draft final proposal
Aug 2020 - Q1 2021	Draft Business Requirements Specifications and Tariff
January 2021	Final proposal
Q1 2021	Present proposal to ISO Board

UNFORCED CAPACITY (UCAP) EVALUATIONS

OUTAGE DEFINITIONS, PRIORITIES, AND UCAP IMPACTS

ISO proposes to align ISO BA outages with existing RC West outage definitions

- **Forced Outage** – Facility/equipment that is removed from service in real-time with limited or no notice
 - **Urgent Outage** – Facility/equipment that is known to be operable, yet carries an increased risk of a forced outage occurring
 - Facility/equipment remains in service until personnel, equipment and/or system conditions allow the outage to occur
 - Urgent outages allow facilities to be removed from service at an optimal time for overall system reliability
 - The work may or may not be able to wait for the short range outage window
 - An urgent outage must have a justification of its urgency documented in the BA/TOP comments section of the outage submission
- *Full requirements are documented in the RC0630 Procedure

ISO proposes to align ISO BA outages with existing RC West outage definitions

- **Planned Outage** – Facility/equipment outage with enough advance notice to meet short range submittal requirements
 - **Opportunity Outage** – A Facility/equipment outage that can be taken due to a change in system conditions, weather or availability of field personnel
 - Opportunity outages did not meet the short range window requirements
 - Opportunity outages that cause reliability issues or conflict with other submitted or confirmed outages of a higher priority cannot be implemented
 - Opportunity outages should have an emergency return time of 8 hours or less
- *Full requirements are documented in the RC0630 Procedure

Outage priorities and UCAP impacts

- Outage priorities (from highest to lowest)
 - Forced outage, urgent outage
 - Planned outage
 - Opportunity outage
- Forced and urgent outages will be considered in the UCAP calculation
- Planned and opportunity outages will not be considered in the UCAP calculation

ISO will not include a limited set of certain forced or urgent outages in the UCAP calculation

- ISO is evaluating the outage exemption proposal to ensure it:
 - Incentivizes resource maintenance and availability
 - Provides clear exemption criteria
- Considering updating the proposal such that if outage is caused by equipment failure that is not owned, operated, or maintained by generator, then the outage should be UCAP exempt
- ISO is evaluating existing forced outage nature of work categories for this purpose
 - Nature of work categories as currently defined can lead to ambiguity with respect to RAIM exemptions

UCAP METHODOLOGY: SEASONAL AVAILABILITY FACTORS

ISO has updated seasonal availability factor proposal for UCAP evaluations

- ISO will develop and utilize a seasonal availability factor based approach for UCAP determinations during the tightest system conditions
- Resource availability factors will incorporate historical derates and forced and urgent outages
 - Excludes planned and approved opportunity outages
- ISO believes this updated UCAP determination proposal, based on seasonal availability factors, is best applied to the following resource types:
 - Thermal, hydro, and storage resources
 - For resources with QC values calculated using an ELCC methodology, ISO will use ELCC value as the UCAP value

ISO proposes to calculate resource availability on a seasonal basis measured on tight supply cushion hours

- Considers different impacts of availability during seasons across the year to better reflect unit reliability
- A large supply cushion indicates less real-time system resource adequacy risk because more energy remains available to respond to unplanned market events
- A low supply cushion indicates the system has fewer assets available to react to unexpected outages or load increases, indicating a high real-time system resource adequacy risk
- Stakeholder comments generally support a seasonal approach

Proposes to assess forced outages during 20% of tightest supply cushion hours

- Today we assess 5 RAIM hours per day, which is roughly 20% of all hours
- Using RAIM as inspiration, we are proposing to calculate UCAP based on the top 20% of tightest supply cushion hours for peak and off peak months
- Advantages
 - Penalizing resources for being on a forced outage when the grid really needed them
 - Unlike RAIM, these assessment hours can fall at any point in the day, and thus resources are incentivized to always be available
 - Simpler than an EFORd methodology (allows for utilization of OMS rather than GADs data), or weighting of all hours
 - Provides consistency across evaluation periods, and more predictable risk of any one outage on a resource's capacity value
 - Provides observations for the majority of days and covers a large enough sample size 800+ hours

Defining top 20% tightest supply cushion hours

- **Supply Cushion = Daily Shown RA (excluding wind and solar) – Planned Outages – Opportunity Outages – Urgent Outages – Forced Outages – Net Load – Contingency Reserves**
- Supply cushion represents how much shown RA MWs are leftover after we take into account outages, serving net demand, and covering contingency reserves
- Contingency reserves represents regulation up, spin and non-spin reserves
- Measured in MWs
- Because net load is a 5 minute measure, to convert the supply cushion into an hourly value we take the mean of the supply cushion across all 12 RTD intervals to represent the supply cushion in each operating hour

Defining peak and off peak months

- Proposal to calculate seasonal UCAP values for:
 - Peak Months- May- October
 - Off-Peak Months- November- April
- Appendix slide presents the monthly hourly supply cushion distribution, and evidence supports peak and off peak definition
- Next slide further provides evidence of the need for seasonal approach- which could lead to over sampling of hours in off-peak months, and thus may not capture resource availability during summer months when grid is known to be more stressed or when ambient derates tend to be higher

Data analysis of supply cushion hours shows:

- Appendix shows analysis on supply cushion hours for May 2018-April 2020.
- Shows significant difference in top 20% supply cushion MW threshold- peak months tight supply cushion hours are ≤ 8800 MWs; Off-peak months tight supply cushion hours are ≤ 2800 MWs
- Majority UCAP assessment hours fall during evening net load ramp (70% of hours fall between HE 18-22), and morning ramp during off-peak months (10% of hours fall between HE 6-8)
- Median number of UCAP assessment hours are 4 hours during off-peak months and 5 hours during peak months
- Covers on average 82% of days

Summary of UCAP process steps

1. Determine UCAP assessment hours by identify which hours fall into the top 20% of tightest supply cushion hours for each season
2. Determine hourly unavailability factors (HUF) for each UCAP assessment hours each season
3. Determine seasonal average availability factors (SAAF) using HUFs for each season of prior year
4. Determine weighted seasonal average availability factors (WSAAF) using proposed weighting approach
5. Apply WSAAFs for each season of the prior 3 annual periods to determine monthly UCAP (On-peak and Off-peak) values for each resource

Proposed UCAP calculation steps

- ISO will determine each resource's hourly unavailability factor (HUF) for each of the 20% tightest supply cushion hours per season

$$\text{Hourly Unavailability Factor} = \frac{\text{Forced} + \text{Urgent Outage Impacts}}{P_{\max}}$$

- ISO is considering additional multiplier for outages during staged emergencies
- ISO will utilize the average of hourly unavailability factors (HUF) for each season for each of the past 3 years to create a seasonal average availability factor (SAAF) for each resource

$$\text{Seasonal Average Availability Factor} = 1 - \frac{\sum \text{Hourly Unavailability Factors}}{\text{Number of Observed Hours}}$$

Proposed UCAP calculation steps (continued)

- ISO also proposes a weighting method for determining a resource's UCAP values over three year period
- ISO proposes the following percentage weights for the availability factor calculation by year from most recent to most historic: 45-35-20%
- In other words, the following percentage weights will be applied to the seasonal availability factors:
 - 45% weight for the most recent year's seasonal availability factor
 - 35% weight on the second year
 - 20% on the third year

Proposed UCAP calculation steps (continued)

- Seasonal average availability factors (SAAF) will be calculated for each of the 3 prior historical years (for both on-peak and off-peak seasons)
- SAAFs will be based on each hourly unavailability factor (HUF) derived by assessing forced and urgent outages compared to the Pmax value for each resource
- ISO will then apply proposed weighting to each of the three previous annual periods (for each on-peak and off-peak season) to create weighted seasonal average availability factors (WSAAF)

$$\text{Weighted Seasonal Average Availability Factor} = \text{Annual Weighting} * \text{Seasonal Average Availability Factor}$$

Proposed UCAP calculation steps (continued)

- Once the weighted seasonal average availability factors (WSAAF) are established for each season of each of prior 3 years, ISO will sum the factors and apply them to each resource's NQC to determine the resource's seasonal UCAP ratings

On Peak UCAP

$$= \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Summer}} * \text{NQC}$$

Off Peak UCAP

$$= \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Winter}} * \text{NQC}$$

ISO proposed the following UCAP methodologies for non-conventional generation

- Wind and Solar: Use ELCC values as UCAP
- Demand response: Use ELCC if adopted, otherwise use performance metric
- Hydro: Longer term historical year weighted average assessment
- Storage: Consider state of charge constraints in UCAP calculation
- Hybrids: Consider dynamic limits in UCAP calculation
- Imports: Consider transmission curtailments for non-frim transmission

RA showings converted to UCAP

Fuel Type	Peak Month WSAAF	June NQC Shown	June UCAP Estimate
Battery	0.969	110.00	106.60
Biomass	0.832	540.00	449.30
Coal	0.950	18.00	17.10
Demand Response*	0.977	235.00	229.60
Gas	0.877	27,002.00	23,680.80
Geothermal	0.869	984.00	855.10
Hydro*	0.863	5,544.00	4,784.50
Nuclear	0.992	1,640.00	1,626.90
Pump Hydro*	0.863	1,285.00	1,109.00
Interchange*		4,118.00	4,118.00
Solar	ELCC	3,303.00	3,303.00
Wind	ELCC	1,688.0	1,688.00
HRCV	0.915	29.00	26.50
Other	0.977	0.13	0.13
Pumping Load		59.00	59.00
Total		46,555.13	42,053.53


- Taking the RA showings for June 2020, we applied the Peak Month WSAAF to estimate the UCAP value of the June 2020 Showings
- Shows a 9.66% reduction, which matches the roughly 10% force outage rate of the system.
- Note DR, Hydro, and interchange resources are estimates based on forced outage rates, which differs from the methodologies covered in the 5th RSP
- Appendix slides provides more details on WSAAF calculations by Fuel Type

OPERATIONALIZING STORAGE


Battery storage is a rapidly growing segment of California's resource mix

- The CPUC authorized new resource procurement for 3,300 MW of resource adequacy capacity
- Retirement over next few years includes older steam resources and Diablo Canyon nuclear facility in 2024
- Today there are about 550 MW of storage online, but the ISO may be dispatching thousands of MW shortly
- Much of the new procurement may come in the form of battery storage and hybrid (solar + storage) resources
- These resources bring new integration challenges
- The minimum charge requirement (MCR) will work with other RA tools to ensure storage is charged

Today the ISO has about enough (traditional) resources to meet peak net-demand



After traditional generation partial retirement the ISO will rely on storage to meet net peaks



Storage resources will be critical to meet peak net demand in the future

- The ISO will rely on storage resources to meet peak load in the future
- The day-ahead market will schedule storage resources to charge during the lowest priced hours and discharge during the highest hours
 - Storage ‘moves energy’ but does not produce additional energy
 - Imposes additional cost to the grid to move this energy
- In the event that these resources are not charged the ISO may not be able to serve load
 - Resources may not charge in the real-time market if ‘low prices’ do not materialize
 - Resources may discharge ‘too soon’ if there are spikey or volatile prices in the real-time market

There are a number of potential ways to solve the reliability issue in the real-time market

1. Impose a heavy charge on resources if they are not available (i.e. charged) in the real-time market
2. Institute high penalty prices for market infeasibilities
3. Increase look-ahead of real-time market to 12+ hours
4. Use a 'STUC like' tool to commit batteries in the real-time market if insufficient SOC detected
5. Require resources maintain certain state of charge values from the day-ahead market
6. Impose system and local requirements on gross SOC
7. Copy day-ahead schedules explicitly into real-time

ISO proposes a solution to this problem with a new tool called the minimum charge requirement (MCR)

- The MCR uses individual day-ahead discharge schedules to set a minimum amount of state of charge that a resource must carry until the discharge hours
- The MCR is imposed as a market constraint that may be relaxed, similar to other constraints
- Storage resources will be ‘guaranteed’ of meeting their day-ahead schedules in the real-time market
 - Reduces risk that a resource without energy will have to buy back day-ahead schedules
- Storage resources will not have an MCR imposed if they do not receive a discharge schedule in the day-ahead market
- The MCR does not bind if resources bid in such a way to charge above the minimum requirements

Stakeholders asked if there are considerations for not imposing the minimum charge requirement each day

- Some stakeholders have asked that the ISO only impose the MCR on the 20 peak load days
- The ISO may consider only imposing requirements on days when batteries are nearly 'critical'
 - Use CEC 1-in-2 year daily forecasts prior to the start of each month
 - Determine non-storage capacity
 - Flag days when load exceeds 90% of non-storage capacity as days when the minimum charge requirement is imposed
- Seeking MSC guidance on other potential exceptions that could be offered and would not jeopardize grid reliability
- Also discuss relaxation of constraint with high prices and imposing the constraint either at the later of day-charging hours or lowest priced energy hour

APPENDIX: EXISTING PLANNED OUTAGE STUDY WINDOWS AND EXAMPLES

ISO BA and RC West outage processes are designed to work in tandem but outage definitions are different under these processes

- In the ISO balancing authority (BA) outage process, generator owners (GO) and participating transmission owners (PTO) submit outages to the CAISO BA
- In the RC West outages process, BAs and transmission operators (TOP) submit outages to the RC on behalf of generator owners and transmission owners
- Both processes include a long-range, mid-range, and short-range study window process for planned outages and a real-time process for other outage types
- Currently, outage definitions differ in the ISO BA outage process and the RC West outage process


Purpose of outage definition proposal

- Align ISO BA outage definitions with existing RC outage definitions
- Classify outage definitions for UCAP purposes
- Maintain existing timelines for both the ISO BA outage process and RC outage process, to the extent possible

Existing long range study window

- Long range study window process is optional
- Long range outage submission deadlines:
 - Generator Owners (GO) and Participating Transmission Owners (PTO) submit outages to ISO BA: Prior to the first day of the month one full calendar month in advance of the Reliability Coordinator's (RC) long-range submission deadline
 - ISO provides study results prior to the RC's Long-Range outage submission deadline
 - Balancing Authorities (BA) and Transmission Operators (TOP) submit outages to RC West: Prior to the first day of the month three months prior to the start of the month being studied
 - RC provides study results no later than the end of the month after outage submittal

Long range study window example




CAISO BA outage submission (GOs and PTOs submit to CAISO BA)
RC outage submission (TOPs and BAs submit to RC)

Existing mid range study window

- Mid range study window process is optional
- RC and ISO BA study timelines are the same
- Mid range outage submission deadlines:
 - GO/PTO submit outages to ISO BA and BAs/TOPs submit outages to RC West: prior to 45 days prior to the start of the month being studied (e.g., outages occurring in April must be submitted prior to 0001 on February 15th)
 - ISO BA and RC provides study results no later than the end of the month of outage submittal

Mid-range study window example



ISO BA outage submission (GOs and PTOs submit to ISO BA) &
RC outage submission (TOPs and BAs submit to RC)

Existing short range study window

- Short range study process is mandatory
- Short range submission deadlines
 - GO/PTO submit outages to ISO BA: No less than 5 full business days in advance of the Reliability Coordinator's short-range submission deadline
 - BA/TOP submit outages to RC West: one (1) week prior to the start of the week being studied

Short range study window example

Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
June 4	5	6	7	8	9	10
Planned outages in the yellow colored week should be submitted to the CAISO BA by 0001 on Monday						
11	12	13	14	15	16	17
Planned outages in yellow colored week should be submitted by 0001 on Monday						
18	19	20	21	22	23	24
Planned outage start time (Monday)	Planned outage start time (Tuesday)	Planned outage start time (Wednesday)	Planned outage start time (Thursday)	Planned outage start time (Friday)	Planned outage start time (Saturday)	Planned outage start time (Sunday)

CAISO BA outage submission (GOs and PTOs submit to CAISO BA)
 RC outage submission (TOPs and BAs submit to RC)

REAL-TIME STUDY WINDOW

Outages submitted after the short range submission deadline – current process

- Today, BA/TOP outages submitted after the short range study window are either an planned if its submitted before T-7 (T = start of the outage) or forced if it is submitted T-7 or after
 - Planned outages that fall between short range window and T-7 are currently studied as opportunity outages in the RC study process
 - Forced outages (submitted at T-7 or after) are submitted when resource has increased risk of breaking, or if outage happens in real time
- Today, RC opportunity, urgent, and forced outages can be used after the short range study window closes

Outages submitted after the short range submission deadline – proposed process

- If outages are not submitted as planned (i.e., before the short range window ends), outages should be submitted as opportunity, urgent, or forced in alignment with the RC outage definitions
 - Opportunity and urgent outages should not be abused to avoid submitting outages in the planned outage timeframe
 - ISO will have discretion over whether a submitted opportunity outage is studied and approved
 - Planned outages will be prioritized over opportunity outages
 - Because urgent outages have the same priority as forced outages, they will be subject to UCAP

APPENDIX: SUPPLY CUSHION ANALYSIS

Monthly distribution of the hourly supply cushion

P	1	2	3	4	5	6	7	8	9	10	11	12
1%	-692	-2641	-2268	-2127	1529	-3097	-4213	-2691	1937	-23	-3354	-3136
5%	1132	-597	-590	711	3704	955	-1518	1059	4650	2390	-1804	-720
10%	2158	626	662	2314	5229	3777	1050	3252	6884	4330	-609	400
20%	4019	2444	2325	4924	7333	7228	4726	6678	10612	6648	1270	2432
25%	4674	3308	3075	5855	8143	8230	6368	7981	11690	7634	2221	3279
50%	7801	6434	5798	9494	10949	11827	10836	12446	15627	11314	5257	6338
75%	10589	10624	9943	13299	14290	15630	16346	15942	18782	14353	7945	9469
90%	13697	14120	13794	17412	16958	19670	20620	18893	21739	17864	10827	12595
95%	15230	15570	15207	19164	17969	21436	23144	20680	23664	20227	12544	14348
99%	17753	18402	16842	20782	20325	23246	26594	24368	28161	22911	14710	17509
Mean	7857	6988	6549	9590	11068	11712	11097	11816	15099	11166	5178	6455

- The October distribution of hourly supply cushion looks more similar to peak/summer months than an off peak month.
 - It has a similar high mean of 11,000+ MWs, and
 - The 20th percentile tends to be above 5000 for peak months and under 5000 for off peak month, and October is over 5000 MMs, and thus similar to peak months.

Seasonal distribution of supply cushion hours (in MWs):

Percentile	Peak Months 2018	Off Peak Months 2018-2019	Peak Months 2019	Off Peak Months 2019-2020
1.0	-2985	-2318	-1109	-2868
5.0	554	-439	3545	-697
10.0	2752	967	5866	628
20.0	5806	2878	8759	2734
25.0	6843	3639	9820	3573
50.0	10551	6687	14217	6715
75.0	13895	10030	17923	10790
90.0	16709	13478	21237	14322
95.0	18298	14993	23135	16741
99.0	20999	17376	26522	20018
Hours	4416	4344	4416	4367

Note: A negative value indicates there was a capacity shortfall- did not have enough shown RA to cover outages, net load, and contingency reserves

HE	Peak Months 2018		Off Peak Months 2018-2019		Peak Months 2019		Off Peak Months 2019-2020	
	# of Obs.	% of Obs.	# of Obs.	% of Obs.	# of Obs.	% of Obs.	# of Obs.	% of Obs.
1	3	0.34	4	0.46	18	2.04	5	0.57
2	1	0.11	2	0.23	7	0.79	2	0.23
3	0	0.00	1	0.12	4	0.45	1	0.11
4	0	0.00	1	0.12	4	0.45	1	0.11
5	0	0.00	2	0.23	5	0.57	1	0.11
6	2	0.23	8	0.92	17	1.93	9	1.03
7	12	1.36	54	6.21	26	2.94	51	5.84
8	9	1.02	38	4.37	17	1.93	34	3.89
9	2	0.23	8	0.92	5	0.57	10	1.15
10	2	0.23	2	0.23	4	0.45	5	0.57
11	1	0.11	0	0.00	3	0.34	3	0.34
12	1	0.11	0	0.00	5	0.45	0	0.00
13	7	0.79	0	0.00	6	0.68	0	0.00
14	14	1.59	1	0.12	8	0.91	1	0.11
15	24	2.72	4	0.46	13	1.47	2	0.23
16	33	3.74	8	0.92	23	2.60	12	1.37
17	40	4.52	40	4.60	32	3.62	54	6.19
18	78	8.83	95	10.93	61	6.91	106	12.14
19	119	13.48	127	14.61	106	12.00	127	14.55
20	152	17.21	147	16.92	129	15.74	133	15.23
21	151	17.10	143	16.46	143	16.19	129	14.78
22	125	14.16	114	13.12	125	14.16	112	12.83
23	78	8.83	56	6.44	79	8.95	56	6.41
24	29	3.28	14	1.61	34	3.85	19	2.18
Total	883	100.0	869	100.0	883	100.0	873	100.0

Distribution of the top 20% of supply cushion hours by operating hour:

- This table shows the distribution of the top 20% of tight supply conditions hours by operating hour.
- As expected, the majority of tight supply cushion hours are around the evening ramp/peak- HE 18-22, averages 69.34% of hours. In off peak months, we also see a spike during the morning ramp.
- However, because there are hours that fall outside these ramps, it further incentivizes resources to be available for all hours, b/c there is a chance a tight supply cushion hour could fall outside these predictable periods.
- This approach will include a majority of the possible days (averages 82%)

# of tight supply hours per day	Peak Months 2018		Off Peak Months 2018/2019		Peak Months 2019		Off Peak Months 2019/2020	
	# of Days	% of Days	# of Days	% of Days	# of Days	% of Days	# of Days	% of Days
0	25	13.59	28	15.47	36	19.57	46	25.27
1	8	4.35	2	1.10	7	3.80	2	1.10
2	13	7.07	8	4.42	10	5.43	4	2.20
3	26	14.13	24	13.26	23	12.50	10	5.49
4	20	10.87	19	10.50	25	13.59	13	7.14
5	34	18.48	29	16.02	21	11.41	22	12.09
6	9	4.89	23	12.71	15	8.15	29	15.93
7	9	4.89	13	7.18	7	3.80	18	9.89
8	13	7.07	12	6.63	11	5.98	17	9.34
9	6	3.26	14	7.73	12	6.52	6	3.30
10	8	4.35	2	1.10	4	2.17	5	2.75
11	3	1.63	0	0.00	3	1.63	3	1.65
12	4	2.17	4	2.21	1	0.54	3	1.65
13	3	1.63	3	1.66	0	0.00	1	0.55
14	1	0.54	0	0.00	1	0.54	1	0.00
15	1	0.54	0	0.00	1	0.54	0	0.00
16	0	0.00	0	0.00	0	0.00	1	0.55
17	1	0.54	0	0.00	1	0.54	0	0.00
18	0	0.00	0	0.00	3	1.63	0	0.00
19	0	0.00	0	0.00	2	1.09	1	0.55
20	0	0.00	0	0.00	0	0.00	0	0.00
21	0	0.00	0	0.00	0	0.00	0	0.00
22	0	0.00	0	0.00	0	0.00	0	0.00
23	0	0.00	0	0.00	0	0.00	0	0.00
24	0	0.00	0	0.00	1	0.54	0	0.00
Total	184	100.00	181	100.0	184	100.0	182	100.0

Distribution UCAP assessment hours per day: October as peak

- This table shows the distribution of the number of days with how many UCAP assessment hours observed.
- 81.53% of days captured
- Peak months have a median of 4 UCAP assessment hours per day and off peak months have a median of 5 UCAP assessment hours per day.

APPENDIX: WSAAF BY FUEL TYPE

Pulled CIRA data to estimate the fuel type WSAAF to assess fleet impact

- Daily Outage rates were taken from CIRA and merged with the UCAP assessment hours for May 2018- April 2020.
- Year 3 was estimated as the average of Year 1 and 2
- While individual resource's outage data may vary from the fleet wide fuel type average, this data can provide some estimation of the impact of moving towards a UCAP paradigm.
- Appendix slides provide estimates for bio-gas, bio-mass, coal, natural gas, geothermal, and storage (doesn't take into account EOH SOC impacts)

Estimating fleet UCAP by fuel type: Bio Gas

$$\text{UCAP} = \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Season}} * \text{NQC}$$

Year	Peak Months SAAF	Annual Weight	Weighted SAAF (Summer/ On-Peak)
3	0.850	20%	0.170
2	0.854	35%	0.299
1	0.819	45%	0.369
Total = 100%			0.838
Year	Off Peak SAAF	Annual Weight	Weighted SAAF (Winter/ Off-Peak)
3	0.891	20%	0.178
2	0.882	35%	0.287
1	0.857	45%	0.386
Total = 100%			0.851

Bio-gas fleet WSAAF (Peak Months)	Bio-gas fleet WSAAF (Off Peak Months)	Example NQC of Bio-gas resource	On-Peak UCAP	Off-Peak UCAP
0.838	0.851	30 MW	25.14 MW	45.53 MW

Note: Based on daily outage rates weighted by the number of UCAP assessment hours, actual resource UCAP values will vary

Estimating fleet UCAP by fuel type: Bio Mass

$$\text{UCAP} = \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Season}} * \text{NQC}$$

Year	Peak Months SAAF	Annual Weight	Weighted SAAF (Summer/ On-Peak)
3	0.834	20%	0.167
2	0.848	35%	0.297
1	0.846	45%	0.381
Total = 100%			0.850
Year	Off Peak SAAF	Annual Weight	Weighted SAAF (Winter/ Off-Peak)
3	0.838	20%	0.168
2	0.819	35%	0.308
1	0.901	45%	0.405
Total = 100%			0.891

Bio-mass fleet WSAAF (Peak Months)	Bio-mass fleet WSAAF (Off Peak Months)	Example NQC of Bio-mass resource	On-Peak UCAP	Off-Peak UCAP
0.850	0.891	50 MW	42.5 MW	44.55 MW

Note: Based on daily outage rates weighted by the number of UCAP assessment hours, actual resource UCAP values will vary

Estimating fleet UCAP by fuel type: Coal

$$\text{UCAP} = \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Season}} * \text{NQC}$$

Year	Peak Months SAAF	Annual Weight	Weighted SAAF (Summer/ On-Peak)
3	0.947	20%	0.189
2	0.915	35%	0.320
1	0.979	45%	0.441
Total = 100%			0.950
Year	Off Peak SAAF	Annual Weight	Weighted SAAF (Winter/ Off-Peak)
3	0.942	20%	0.188
2	0.901	35%	0.315
1	0.984	45%	0.443
Total = 100%			0.946

Coal fleet WSAAF (Peak Months)	Coal fleet WSAAF (Off Peak Months)	Example NQC of Coal resource	On-Peak UCAP	Off-Peak UCAP
0.950	0.946	10 MW	9.5 MW	9.46 MW

Note: Based on daily outage rates weighted by the number of UCAP assessment hours, actual resource UCAP values will vary

Estimating fleet UCAP by fuel type: Natural Gas

$$\text{UCAP} = \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Season}} * \text{NQC}$$

Year	Peak Months SAAF	Annual Weight	Weighted SAAF (Summer/ On-Peak)
3	0.877	20%	0.175
2	0.886	35%	0.310
1	0.869	45%	0.391
Total = 100%			0.877
Year	Off Peak SAAF	Annual Weight	Weighted SAAF (Winter/ Off-Peak)
3	0.893	20%	0.179
2	0.901	35%	0.315
1	0.884	45%	0.398
Total = 100%			0.892

Natural gas fleet WSAAF (Peak Months)	Natural gas fleet WSAAF (Off Peak Months)	Example NQC of Natural Gas resource	On-Peak UCAP	Off-Peak UCAP
0.877	0.892	500 MW	438.5 MW	446 MW

Note: Based on daily outage rates weighted by the number of UCAP assessment hours, actual resource UCAP values will vary

Estimating fleet UCAP by fuel type: Geo-Thermal

$$\text{UCAP} = \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Season}} * \text{NQC}$$

Year	Peak Months SAAF	Annual Weight	Weighted SAAF (Summer/ On-Peak)
3	0.871	20%	0.174
2	0.893	35%	0.313
1	0.848	45%	0.382
Total = 100%			0.869
Year	Off Peak SAAF	Annual Weight	Weighted SAAF (Winter/ Off-Peak)
3	0.788	20%	0.158
2	0.877	35%	0.307
1	0.699	45%	0.315
Total = 100%			0.780

Geo-thermal fleet WSAAF (Peak Months)	Geo-thermal fleet WSAAF (Off Peak Months)	Example NQC of Geo-thermal resource	On-Peak UCAP	Off-Peak UCAP
0.869	0.780	35 MW	30.42 MW	27.3 MW

Note: Based on daily outage rates weighted by the number of UCAP assessment hours, actual resource UCAP values will vary

Estimating fleet UCAP by fuel type: HRCV (Heat Recovery)

$$\text{UCAP} = \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Season}} * \text{NQC}$$

Year	Peak Months SAAF	Annual Weight	Weighted SAAF (Summer/ On-Peak)
3	0.919	20%	0.184
2	0.959	35%	0.336
1	0.879	45%	0.400
Total = 100%			0.920
Year	Off Peak SAAF	Annual Weight	Weighted SAAF (Winter/ Off-Peak)
3	0.876	20%	0.175
2	0.809	35%	0.283
1	0.944	45%	0.425
Total = 100%			0.883

HRCV fleet WSAAF (Peak Months)	HRCV fleet WSAAF (Off Peak Months)	Example NQC of HRCV resource	On-Peak UCAP	Off-Peak UCAP
0.920	0.891	15 MW	13.8 MW	13.25 MW

Note: Based on daily outage rates weighted by the number of UCAP assessment hours, actual resource UCAP values will vary

Estimating Fleet UCAP by Fuel Type: LESR (Energy Storage)

$$UCAP = \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Season}} * NQC$$

Year	Peak Months SAAF	Annual Weight	Weighted SAAF (Summer/ On-Peak)
3	0.969	20%	0.194
2	0.975	35%	0.341
1	0.964	45%	0.434
Total = 100%			0.969
Year	Off Peak SAAF	Annual Weight	Weighted SAAF (Winter/ Off-Peak)
3	0.948	20%	0.190
2	0.969	35%	0.339
1	0.927	45%	0.417
Total = 100%			0.946

Storage fleet WSAAF (Peak Months)	Storage fleet WSAAF (Off Peak Months)	Example NQC of Storage resource	On-Peak UCAP	Off-Peak UCAP
0.969	0.946	25 MW	24.23 MW	23.65 MW

Note: Based on daily outage rates weighted by the number of UCAP assessment hours, actual resource UCAP values will vary. Does not take into account impacts of EOH SOC parameter which hasn't been implemented yet

Estimating fleet UCAP by fuel type: Nuclear

$$UCAP = \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Season}} * NQC$$

Year	Peak Months SAAF	Annual Weight	Weighted SAAF (Summer/ On-Peak)
3	0.991	20%	0.198
2	0.983	35%	0.344
1	0.999	45%	0.450
Total = 100%			0.992
Year	Off Peak SAAF	Annual Weight	Weighted SAAF (Winter/ Off-Peak)
3	0.957	20%	0.191
2	0.946	35%	0.331
1	0.968	45%	0.436
Total = 100%			0.958

Nuclear fleet WSAAF (Peak Months)	Nuclear fleet WSAAF (Off Peak Months)	Example NQC of Nuclear resource	On-Peak UCAP	Off-Peak UCAP
0.992	0.958	800 MW	793.6 MW	766.4 MW

Note: Based on daily outage rates weighted by the number of UCAP assessment hours, actual resource UCAP values will vary

Estimating fleet UCAP by fuel type: Waste

$$\text{UCAP} = \sum \text{Weighted Seasonal Average Availability Factors}^{\text{Season}} * \text{NQC}$$

Year	Peak Months SAAF	Annual Weight	Weighted SAAF (Summer/ On-Peak)
3	0.907	20%	0.181
2	0.957	35%	0.335
1	0.857	45%	0.386
Total = 100%			0.902
Year	Off Peak SAAF	Annual Weight	Weighted SAAF (Winter/ Off-Peak)
3	0.865	20%	0.173
2	0.894	35%	0.313
1	0.835	45%	0.376
Total = 100%			0.862

Waste fleet WSAAF (Peak Months)	Waste fleet WSAAF (Off Peak Months)	Example NQC of Waste resource	On-Peak UCAP	Off-Peak UCAP
0.902	0.862	15 MW	13.53 MW	12.93 MW

Note: Based on daily outage rates weighted by the number of UCAP assessment hours, actual resource UCAP values will vary

APPENDIX: TOP 10% SUPPLY CUSHION, UCAP ASSESSMENT HOURS

Distribution of supply cushion hours (in MW's): October= Peak month

Percentile	2018 Peak Months	2018-2019 Off-Peak Months	2019 Peak Months	2019-2020 Off Peak Months
1.0	-2985	-2318	-1109	-2868
5.0	554	-439	3545	-697
10.0	2752	967	5866	628
20.0	5806	2878	8759	2734
25.0	6843	3639	9820	3573
50.0	10551	6687	14217	6715
75.0	13895	10030	17923	10790
90.0	16709	13478	21237	14322
95.0	18298	14993	23135	16741
99.0	20999	17376	26522	20018
Hours	4416	4344	4416	4367

Calpine suggested using the top 10% to tightest supply cushion hours, the following analysis shows the impact this would have

HE	Peak Months 2018		Off Peak Months 2018-2019		Peak Months 2019		Off Peak Months 2019-2020	
	# of Obs.	% of Obs.	# of Obs.	% of Obs.	# of Obs.	% of Obs.	# of Obs.	% of Obs.
1	0	0.00	1	0.23	2	0.45	1	0.23
2	0	0.00	1	0.23	1	0.23	0	0.00
3	0	0.00	1	0.23	1	0.23	0	0.00
4	0	0.00	1	0.23	0	0.00	0	0.00
5	0	0.00	1	0.23	1	0.00	0	0.00
6	0	0.00	0	0.00	1	0.00	1	0.23
7	1	0.23	13	3.00	4	0.90	14	3.20
8	1	0.23	8	1.84	2	0.45	12	2.75
9	1	0.23	0	0.00	1	0.23	4	0.92
10	0	0.00	0	0.00	0	0.00	0	0.00
11	0	0.00	0	0.00	0	0.00	0	0.00
12	0	0.00	0	0.00	1	0.23	0	0.00
13	0	0.00	0	0.00	1	0.23	0	0.00
14	3	0.68	0	0.00	4	0.90	0	0.00
15	9	2.04	0	0.00	6	1.36	0	0.00
16	13	2.94	2	0.26	11	2.49	2	0.46
17	22	4.98	24	5.53	18	4.07	22	5.03
18	33	7.47	56	12.90	32	7.24	68	15.56
19	73	16.52	84	19.35	65	14.71	95	21.74
20	98	22.17	98	22.58	95	21.49	97	22.20
21	98	22.17	83	19.12	101	22.85	68	15.56
22	66	14.93	51	11.75	63	14.25	42	9.61
23	22	4.98	8	1.84	25	5.66	10	2.29
24	2	0.45	2	0.46	7	1.58	1	0.23
Total	442	100.0	434	100.0	442	100.0	437	100.0

Distribution of the top 10% of supply cushion hours by operating hour: October as on peak

- This table shows the distribution of the top 10% of tight supply conditions hours by operating hour.
- As expected, the majority of tight supply cushion hours are around the evening ramp/peak- HE 18-22, averages 83.54% of hours. In Off Peak Months, we also see fewer hours that capture the morning ramp.
- Because less hours fall outside of the evening ramp, this would diminish the incentive to be available 24x7

# of tight supply hours per day	Peak Months 2018		Off Peak Months 2018/2019		Peak Months 2019		Off Peak Months 2019/2020	
	# of Days	% of Days	# of Days	% of Days	# of Days	% of Days	# of Days	% of Days
0	75	40.76	72	39.78	77	41.85	73	40.11
1	13	7.07	11	6.08	9	4.89	5	2.75
2	16	8.70	15	8.29	19	10.33	25	13.74
3	27	14.67	22	12.15	30	16.30	24	13.19
4	18	9.78	15	8.29	16	8.70	17	9.24
5	11	5.98	22	12.15	8	4.35	15	8.24
6	6	3.26	16	8.84	10	5.43	11	6.04
7	5	2.72	4	2.21	3	1.63	4	2.20
8	3	1.63	3	1.66	5	2.72	5	2.75
9	7	3.80	1	0.55	2	1.09	1	0.55
10	2	1.09	0	0.00	1	0.54	1	0.55
11	1	0.54	0	0.00	3	1.63	0	0.00
12					0	0.00	0	0.00
13					0	0.00	0	0.00
14					0	0.00	1	0.55
15					0	0.00		
16					0	0.00		
17					0	0.00		
18					0	0.00		
19					1	0.54		
20								
21								
22								
23								
24								
Total	184	100.00	181	100.0	184	100.0	182	100.0

Distribution top 10% UCAP assessment hours per day: October as peak

- Only covers 59% of days
- The median number of UCAP assessment hours per day is 2
- By selecting the top 20% of tightest supply cushion, we can capture a greater percentage of days, and more hours outside of the evening ramp which will increase the incentives to perform proper maintenance to avoid a UCAP reduction.