

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

**Table of Contents**

<u>27</u>	<u>CAISO Markets And Processes.....</u>	<u>2</u>
<u>27.1</u>	<u>LMPs And Ancillary Services Marginal Prices.....</u>	<u>2</u>
<u>27.1.1</u>	<u>Locational Marginal Prices For Energy.....</u>	<u>3</u>
<u>27.1.2</u>	<u>Ancillary Service Prices.....</u>	<u>4</u>
<u>27.1.3</u>	<u>Regulation Mileage Clearing Price.....</u>	<u>9</u>
<u>27.2</u>	<u>Load Aggregation Points (LAP).....</u>	<u>10</u>
<u>27.2.1</u>	<u>Metered Subsystems.....</u>	<u>10</u>
<u>27.2.2</u>	<u>Determination Of LAP Prices.....</u>	<u>11</u>
<u>27.3</u>	<u>Trading Hubs.....</u>	<u>12</u>
<u>27.4</u>	<u>Optimization In The CAISO Markets Processes.....</u>	<u>13</u>
<u>27.4.1</u>	<u>Security Constrained Unit Commitment.....</u>	<u>13</u>
<u>27.4.2</u>	<u>Security Constrained Economic Dispatch.....</u>	<u>14</u>
<u>27.4.3</u>	<u>CAISO Markets Scheduling And Pricing Parameters.....</u>	<u>14</u>
<u>27.5</u>	<u>Full Network Model.....</u>	<u>16</u>
<u>27.5.1</u>	<u>Network Models used in CAISO Markets.....</u>	<u>16</u>
<u>27.5.2</u>	<u>Metered Subsystems.....</u>	<u>20</u>
<u>27.5.3</u>	<u>Integrated Balancing Authority Areas.....</u>	<u>21</u>
<u>27.5.4</u>	<u>Accounting For Changes In Topology In FNM.....</u>	<u>29</u>
<u>27.5.5</u>	<u>Load Distribution Factors.....</u>	<u>29</u>
<u>27.5.6</u>	<u>Management &amp; Enforcement of Constraints in the CAISO Markets.....</u>	<u>30</u>
<u>27.6</u>	<u>State Estimator.....</u>	<u>32</u>
<u>27.7</u>	<u>Constrained Output Generators.....</u>	<u>32</u>
<u>27.7.1</u>	<u>Election Of Constrained Output Generator Status.....</u>	<u>32</u>
<u>27.7.2</u>	<u>Election To Waive COG Status.....</u>	<u>33</u>
<u>27.7.3</u>	<u>Constrained Output Generators In The IFM.....</u>	<u>33</u>
<u>27.7.4</u>	<u>Constrained Output Generators In RUC.....</u>	<u>33</u>
<u>27.7.5</u>	<u>Constrained Output Generators In The Real-Time Market.....</u>	<u>34</u>
<u>27.8</u>	<u>Multi-Stage Generating Resources.....</u>	<u>34</u>
<u>27.8.1</u>	<u>Registration and Qualification.....</u>	<u>34</u>
<u>27.8.2</u>	<u>Informational Requirements.....</u>	<u>36</u>
<u>27.8.3</u>	<u>Changes in Status and Configurations of Resource.....</u>	<u>36</u>
<u>27.9</u>	<u>Non-Generator Resources MWh Constraints.....</u>	<u>37</u>
<u>27.10</u>	<u>Flexible Ramping Constraint.....</u>	<u>38</u>

## **27 CAISO Markets And Processes**

In the Day-Ahead and Real-Time time frames the CAISO operates a series of procedures and markets that together comprise the CAISO Markets Processes. In the Day-Ahead time frame, the CAISO conducts the Market Power Mitigation (MPM) process, the Integrated Forward Market (IFM) and the Residual Unit Commitment (RUC) process. In the Real-Time time frame, the CAISO does the following: 1) accepts the Economic Bids and Self-Schedules used in the Real-Time Market procedures, 2) conducts the MPM process for the RTM, 3) accepts and awards HASP Block Intertie Schedules for Energy and Ancillary Services, 4) provides HASP Advisory Schedules for Energy and Ancillary Services for Bids that do not create a HASP Block Intertie Schedule, 5) conducts the Real-Time Unit Commitment (RTUC), 6) conducts the Short-Term Unit Commitment (STUC), 7) conducts the Fifteen Minute Market (FMM), and 8) conducts the five-minute Real-Time Dispatch (RTD). As appropriate, the CAISO Markets Processes utilize transmission and Security Constrained Unit Commitment and dispatch algorithms in conjunction with a Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6 to optimally commit, schedule and Dispatch resources and determine marginal prices for Energy, Ancillary Services and RUC Capacity. Congestion Revenue Rights are available and entitle holders of such instruments to a stream of hourly payments or charges associated with revenue the CAISO collects or pays from the Marginal Cost of Congestion component of hourly Day-Ahead LMPs. Through the operation of the CAISO Markets Processes the CAISO develops Day-Ahead Schedules, Day-Ahead AS Awards and RUC Schedules, , HASP Block Intertie Schedules for Energy and AS Awards, HASP Advisory Schedules, FMM Energy Schedules, and FMM Ancillary Services Awards, Real-Time AS Awards and Dispatch Instructions to ensure that sufficient supply resources are available in Real-Time to balance Supply and Demand and operate in accordance with Reliability Criteria.

### **27.1 LMPs And Ancillary Services Marginal Prices**

The CAISO Markets are based on: 1) Locational Marginal Prices as provided below in Section 27.1.1 and further provided in Appendix C; and 2) Ancillary Services Marginal Prices as provided below in Section 27.1.2.

### **27.1.1 Locational Marginal Prices For Energy**

As further described in Appendix C, the LMP for Energy at any PNode is the marginal cost of serving the next increment of Demand at that PNode consistent with existing Transmission Constraints and the performance characteristics of resources, also considering, among other things, Energy Bid Curves. The LMP at any given PNode is comprised of three cost components: the System Marginal Energy Cost (SMEC); Marginal Cost of Losses (MCL); and Marginal Cost of Congestion (MCC). The IFM calculates LMPs for each Trading Hour of the next Trading Day. The FMM calculates distinct financially binding fifteen-minute LMPs for each of the four fifteen-minute intervals within a Trading Hour. The Real-Time Dispatch runs every five (5) minutes throughout each Trading Hour and calculates five-minute LMPs for the next Dispatch Interval. The CAISO uses the FMM or RTD LMPs for Settlements of the Real-Time Market. In the event that a Pricing Node becomes electrically disconnected from the market model during a CAISO Market run, the LMP, including the SMEC, MCC and MCL, at the closest electrically connected Pricing Node will be used as the LMP at the affected location.

#### **27.1.1.1 System Marginal Energy Cost**

The System Marginal Energy Cost (SMEC) component of the LMP reflects the marginal cost of providing Energy from a designated reference Location. For this designated reference Location the CAISO will utilize a distributed Reference Bus whose constituent PNodes are weighted in proportions referred to as Reference Bus distribution factors. The SMEC shall be the same throughout the system.

#### **27.1.1.2 Marginal Cost of Losses**

For all PNodes and Aggregated PNodes in the CAISO Balancing Authority Area, including Scheduling Points, the use of the Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6 in the DAM and the RTM processes incorporates Transmission Losses. At each PNode or Aggregated PNode, the Marginal Cost of Losses is the System Marginal Energy Cost multiplied by the Marginal Loss factor at that PNode or Aggregated PNode. The Marginal Cost of Losses at a Location (PNode or APNode) may be positive or negative depending on whether an increase in Demand at that Location marginally increases or decreases the cost of Transmission

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

Losses, using the distributed Reference Bus to balance it. The Marginal Loss factors are determined through a process that calculates the sensitivities of Transmission Losses with respect to changes in injection at each Location in the FNM. For CAISO Controlled Grid facilities outside the CAISO Balancing Authority Area, the CAISO shall assess the cost of Transmission Losses to Scheduling Coordinators using each such facility based on the quantity of losses agreed upon with the neighboring Balancing Authority multiplied by the LMP at the PNode of the Transmission Interface with the neighboring Balancing Authority Area. The MCLs calculated for Locations within the CAISO Balancing Authority Area shall not reflect the cost of Transmission Losses on those facilities.

**27.1.1.3 Marginal Cost of Congestion**

The Marginal Cost of Congestion at a PNode reflects a linear combination of the Shadow Prices of the binding Transmission Constraints in the network, multiplied by the corresponding Power Transfer Distribution Factor (PTDF). The Marginal Cost of Congestion may be positive or negative depending on whether a power injection (i.e., incremental Load increase) at that Location marginally increases or decreases Congestion.

**27.1.2 Ancillary Service Prices**

**27.1.2.1 Ancillary Service Marginal Prices – Sufficient Supply**

As provided in Section 8.3, Ancillary Services are procured and awarded through the IFM and the FMM, and the CAISO also accepts and awards HASP Block Intertie Schedules for Ancillary Services in HASP. Ancillary Services awarded through HASP are made financially binding in the FMM. The IFM calculates hourly Day-Ahead Ancillary Service Awards and establishes Ancillary Service Marginal Prices (ASMPs) for the accepted Regulation Up, Regulation Down, Spinning Reserve and Non-Spinning Reserve Bids. The IFM co-optimizes Energy and Ancillary Services subject to resource, network and regional constraints. In the HASP, the CAISO accepts and awards Ancillary Services from HASP Block Intertie Schedules for the next Trading Hour as described in Section 34.2. The CAISO calculates the price for the settlement of Ancillary Services accepted and awarded in HASP based on the FMM ASMP as described herein and further described in Section 34.4. The FMM process that is performed every fifteen (15) minutes

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

establishes fifteen (15) minute Ancillary Service Schedules, Awards, and prices for the upcoming quarter of the given Trading Hour. ASMPs are determined by first calculating Shadow Prices of Ancillary Services for each Ancillary Service type and the applicable Ancillary Services Regions. The Ancillary Services Shadow Prices are produced as a result of the co-optimization of Energy and Ancillary Services through the IFM and the Real-Time Market, subject to resource, network, and requirement constraints. The Ancillary Services Shadow Prices represent the marginal cost of the relevant binding regional constraints at the optimal solution, or the reduction of the combined Energy and Ancillary Service procurement cost associated with a marginal relaxation of that constraint. If the constraint for an Ancillary Services Region is not binding, the corresponding Ancillary Services Shadow Price in the Ancillary Services Region is zero (0). During periods in which supply is sufficient, the ASMP for a particular Ancillary Service type and Ancillary Services Region is then the sum of the Ancillary Services Shadow Prices for the specific type of Ancillary Service and all the other types of Ancillary Services for which the subject Ancillary Service can substitute, as described in Section 8.2.3.5, for the given Ancillary Service Region and all the other Ancillary Service Regions that include that given Ancillary Service Region. During periods in which supply is insufficient, the ASMP for a particular Ancillary Service type and Ancillary Services Region will reflect the Scarcity Reserve Demand Curve Values set forth in Section 27.1.2.3.

**27.1.2.2 Opportunity Cost in ASMP**

The Ancillary Services Shadow Price, which, as described above, is a result of the Energy and Ancillary Service co-optimization, includes the foregone opportunity cost of the marginal resource, if any, for not providing Energy or other types of Ancillary Services the marginal resource is capable of providing in the relevant market. The ASMPs determined by the IFM or FMM optimization process for each resource whose Ancillary Service Bid is accepted will be no lower than the sum of (i) the Ancillary Service capacity Bid price submitted for that resource, and (ii) the foregone opportunity cost of Energy in the IFM or FMM for that resource. The foregone opportunity cost of Energy for this purpose is measured as the positive difference between the IFM or FMM LMP at the resource's Pricing Node and the resource's Energy Bid price. If the

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

resource's Energy Bid price is higher than the LMP, the opportunity cost measured for this calculation is \$0. If a resource has submitted an Ancillary Service Bid but no Energy Bid and is under an obligation to offer Energy in the Day-Ahead Market (e.g. a non-hydro Resource Adequacy Resource), its Default Energy Bid will be used, and its opportunity cost will be calculated accordingly. If a resource has submitted an Ancillary Service Bid but no Energy Bid and is not under an obligation to offer Energy in the Day-Ahead Market, its Energy opportunity cost measured for this calculation is \$0 since it cannot be dispatched for Energy. For Self-Scheduled Hourly Block Bids for Ancillary Services awarded in the Real-Time Market, the opportunity cost measured for this purpose is \$0 because, as provided in Section 34.2.3, the CAISO cannot Schedule Energy in the Real-Time Market from the Energy Bid under the same Resource ID as the submitted Ancillary Service Bid.

**27.1.2.3 Ancillary Services Pricing – Insufficient Supply**

The CAISO will develop Scarcity Reserve Demand Curves as further described in an applicable Business Practice Manual that will apply to both the Day-Ahead Market and the Real-Time Market during periods in which supply is insufficient to meet the minimum procurement requirements for Regulation Down, Non-Spinning Reserve, Spinning Reserve and Regulation Up as required by Section 8.3. During the first three (3) years in which the CAISO's Scarcity Reserve Demand Curves are effective, the CAISO shall conduct an annual review of the performance of the Scarcity Reserve Demand Curves and assess whether changes are necessary, with the exception that the ISO will not conduct this assessment in any year in which the Scarcity Reserve Demand Curves are not triggered. Thereafter, the CAISO shall review the performance of the Scarcity Reserve Demand Curves and assess whether changes are necessary every three (3) years or more frequently, if the CAISO determines more frequent reviews are appropriate. When supply is insufficient to meet any of the minimum procurement requirements for Regulation Down, Non-Spinning Reserve, Spinning Reserve and Regulation Up, the Scarcity Reserve Demand Curve Values for the affected Ancillary Services, as set forth in this Section 27.1.2.3 and as reflected in the in the Scarcity Demand Curve Value table below, shall apply to determine the Shadow Prices of the affected Ancillary Services. ASMPs for an Ancillary

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

Service type will not sum these Shadow Prices across Ancillary Service Regions, if there is insufficient supply for the Ancillary Service type in both the Expanded System Region and an Ancillary Service Sub-Region.

Reserve	Scarcity Demand Curve Value (\$/MWh)					
	Percent of Energy Max Bid Price		Max Energy Bid Price = \$750/MWh		Max Energy Bid Price = \$1000/MWh	
	Expanded System Region	System Region and Sub-Region	Expanded System Region	System Region and Sub-Region	Expanded System Region	System Region and Sub-Region
Regulation Up	20%	20%	\$150	\$150	\$200	\$200
Spinning	10%	10%	\$75	\$75	\$100	\$100
Non-Spinning						
Shortage > 210 MW	70%	70%	\$525	\$525	\$700	\$700
Shortage > 70 & ≤ 210 MW	60%	60%	\$450	\$450	\$600	\$600
	50%	50%	\$375	\$375	\$500	\$500
Shortage ≤ 70 MW						
<b>Upward Sum</b>	<b>100%</b>	<b>100%</b>	<b>\$750</b>	<b>\$750</b>	<b>\$1000</b>	<b>\$1000</b>
Regulation Down						
Shortage > 84 MW	70%	70%	\$525	\$525	\$700	\$700
Shortage > 32 & ≤ 84 MW	60%	60%	\$450	\$450	\$600	\$600
	50%	50%	\$375	\$375	\$500	\$500

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

Shortage $\leq$ 32 MW						
--------------------------	--	--	--	--	--	--

**27.1.2.3.1 Regulation Down Pricing – Insufficient Supply**

When the shortage of supply to meet the Regulation Down requirement in the Expanded System Region or in an Ancillary Service Sub-Region is less than or equal to thirty-two (32) MW, the Scarcity Reserve Demand Curve Value for Regulation Down shall be fifty (50) percent of the maximum Energy Bid price permitted under Section 39.6.1.1. When the shortage of supply to meet the Regulation Down requirement in the Expanded System Region is less than or equal to eighty-four (84) MW but greater than thirty-two (32) MW, the Scarcity Reserve Demand Curve Value for Regulation Down shall be sixty (60) percent of the maximum Energy Bid price permitted under Section 39.6.1.1. When the shortage of supply to meet the Regulation Down requirement in the Expanded System Region is greater than eighty-four (84) MW, the Scarcity Reserve Demand Curve Value for Regulation Down shall be seventy (70) percent of the maximum Energy Bid price permitted under Section 39.6.1.1.

**27.1.2.3.2 Non-Spinning Reserve Pricing – Insufficient Supply**

When the shortage of supply to meet the Non-Spinning Reserve requirement in the Expanded System Region or in an Ancillary Service Sub-Region is less than or equal to seventy (70) MW, the Scarcity Reserve Demand Curve Value for Non-Spinning Reserve shall be fifty (50) percent of the maximum Energy Bid price permitted under Section 39.6.1.1. When the shortage of supply to meet the Non-Spinning Reserve requirement in the Expanded System Region is less than or equal to two-hundred ten (210) MW but greater than seventy (70) MW, the Scarcity Reserve Demand Curve Value for Non-Spinning Reserve shall be sixty (60) percent of the maximum Energy Bid price permitted under Section 39.6.1.1. When the shortage of supply to meet the Non-Spinning Reserve requirement in the Expanded System Region is greater than two-hundred ten (210) MW, the Scarcity Reserve Demand Curve Value for Non-Spinning Reserve shall be seventy (70) percent of the maximum Energy Bid price permitted under Section 39.6.1.1.

**27.1.2.3.3 Spinning Reserve Pricing – Insufficient Supply**



California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

The Scarcity Reserve Demand Curve Value for Spinning Reserve in the Expanded System Region or in an Ancillary Service Sub-Region shall be ten (10) percent of the maximum Energy Bid price permitted under Section 39.6.1.1.

**27.1.2.3.4 Regulation Up Pricing – Insufficient Supply**

The Scarcity Reserve Demand Curve Value for Regulation Up in the Expanded System Region or in an Ancillary Service Sub-Region shall be twenty (20) percent of the maximum Energy Bid price permitted under Section 39.6.1.1.

**27.1.2.4 Opportunity Cost in LMPs for Energy**

In the event that there is insufficient supply to meet an Ancillary Services procurement requirement in a particular Ancillary Service Region or Sub-Region, the Ancillary Services Shadow Prices will rise automatically to the Scarcity Reserve Demand Curve Values in that Ancillary Service Region or Sub-Region. LMPs for Energy will reflect the forgone opportunity cost of the marginal resource, if any, for not providing the scarce Ancillary Services consistent with the CAISO's co-optimization design.

**27.1.3 Regulation Mileage Clearing Price**

As provided in Section 8.3, Regulation Up and Regulation Down are procured and awarded through the Day Ahead Market and Real-Time Market. The CAISO will calculate uniform Mileage clearing prices for Regulation Up and Regulation Down, respectively, based on the intersection of the demand curve for Mileage requirements and supply curve for Bid-in Mileage. These uniform Mileage clearing prices shall apply to the CAISO Expanded System Region.

The CAISO will calculate a System Mileage Multiplier for Regulation Up by summing the total Mileage provided by all resources with Regulation Up awards each week for a corresponding hour of each Trading Day and then dividing that sum by the Regulation Up capacity procured for that week in that same hour. The CAISO will calculate a System Mileage Multiplier for Regulation Down by summing the total Mileage provided by all resources with Regulation Down awards each week for a corresponding hour of each Trading Day and then dividing that sum by the Regulation Down capacity procured for that week in that same hour. For purposes of these calculations, the CAISO shall calculate each week using a rolling seven-day period. The CAISO will use the

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

System Mileage Multiplier to assess Mileage requirements for Regulation Up and Regulation Down capacity.

The CAISO will calculate resource specific Mileage multipliers and apply these multipliers to resources' Bid-in Regulation Up and Regulation Down capacity. The resource specific Mileage multipliers will reflect resources' Historic Regulation Performance Accuracy and certified 10-minute ramp capability. The CAISO will apply resource specific Mileage multipliers to Bid-in Regulation Up and Regulation Down capacity to determine the expected Mileage. In the event that an existing certified resource has not provided Regulation over the prior thirty (30) days, the CAISO will use the resource's last Historic Regulation Performance Accuracy as an adjustment factor. For newly certified or recertified resources, the CAISO will use the simple average Historic Regulation Performance Accuracy for all resources from the prior thirty (30) days as an initial adjustment factor. Upon request, the CAISO will provide a resource with historical data used to derive its Mileage multipliers. A resource will receive a Mileage award that is at least as much as its self-provided or awarded Regulation Up or Regulation Down capacity, but not more than the product of its resource specific mileage multiplier and its self-provided or awarded capacity. The CAISO may adjust resource specific Mileage multipliers to align a resource's awarded Mileage with the resource's expected Mileage. The CAISO will use Mileage awards to determine a uniform clearing mileage price for Regulation Up and Regulation Down, but the Mileage quantity awards will not be financially binding. Resources will receive payments based upon Instructed Mileage as calculated pursuant to Section 11.10.1.7. The CAISO will publish on OASIS the Mileage clearing prices for each hour of the Day-Ahead Market and each fifteen (15) minute period in Real-Time for the Trading Day.

**27.2 Load Aggregation Points (LAP)**

The CAISO shall create Load Aggregation Points and shall maintain Default LAPs at which all Demand shall Bid and be settled, except as provided in Sections 27.2.1 and 30.5.3.2.

**27.2.1 Metered Subsystems**

The CAISO shall define specific MSS LAPs for each MSS. The MSS LAP shall be made up of the PNodes within the MSS that have Load served off of those Nodes. The MSS LAPs have

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

unique Load Distribution Factors that reflect the distribution of the MSS Demand to the network Nodes within the MSS. These MSS LAPs are separate from the Default LAPs, and the Load Distribution Factors of the Default LAP do not reflect any MSS Load. As further provided in Sections 11.2.3 and 11.5, MSS Demand is settled either at the price at the Default LAP for MSS Operators that have selected gross Settlement or at the price at the applicable MSS LAP for MSS Operators that have selected net Settlement.

**27.2.2 Determination Of LAP Prices**

**27.2.2.1 IFM LAP Prices**

The IFM LAP Price for a given Trading Hour is the weighted average of the individual IFM LMPs at the PNodes within the LAP, with the weights equal to the nodal proportions of Demand associated with that LAP that is scheduled by the IFM, excluding Demand specified in Sections 27.2.1 and 30.5.3.2.

**27.2.2.1.1 Default LAPs Pricing**

The IFM LAP Price for Settlement of Demand at Default LAPs for a given Trading Hour is the price as produced by the IFM optimization run based on the distribution of system Load at the constituent Pricing Nodes within the applicable Default LAP and is determined by the effectiveness of the Load within the Default LAP in relieving a Transmission Constraint within the effectiveness threshold as specified in Section 27.3.4.6.

**27.2.2.1.2 Custom LAP Pricing**

The IFM LAP Price for Settlement of Demand at Custom LAPs for a given Trading Hour is calculated as a Load-weighted average of the individual IFM LMPs at the PNodes within the Custom LAP, where the weights are equal to the nodal proportions of CAISO Demand associated with that Custom LAP scheduled by the IFM.

**27.2.2.2 Real-Time Market LAP Prices**

The Default LAP Hourly Real-Time Prices and the Custom LAP Hourly Real-Time Prices are calculated as described below and in Section 11.5.2.2.

**27.2.2.2.1 Default LAP Pricing**

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

The FMM and RTD Default LAP Price for a fifteen-minute FMM interval and five minute Dispatch Interval is the price as produced by the FMM and RTD optimization runs, respectively, based on the distribution of system Load at the constituent Pricing Nodes within the applicable Default LAP and is determined by the effectiveness of the Load within the Default LAP in relieving a Transmission Constraint within the effectiveness threshold as specified in Section 27.3.4.6. The Default LAP Hourly Real-Time Price is then determined for Settlement purposes as further described in Section 11.5.2.2.

**27.2.2.2.2 Custom LAP Pricing**

The FMM and RTD LAP Prices for Settlement of Demand at Custom LAPs for a given fifteen-minute FMM interval and five minute Dispatch interval are calculated as a Load-weighted average of the individual FMM and RTD LMPs at the PNodes within the Custom LAP, respectively, where the weights are calculated based on Meter Data. The Custom LAP Hourly Real-Time Price is then determined for Settlement purposes as further described in Section 11.5.2.2.

**27.3 Trading Hubs**

The CAISO shall create and maintain Trading Hubs, including Existing Zone Generation Trading Hubs, to facilitate bilateral Energy transactions in the CAISO Balancing Authority Area. Each Trading Hub will be based on a pre-defined set of PNodes. The CAISO Market run will produce a Trading Hub price for each Settlement Period or Settlement Interval that is derived from the CAISO Market optimization based on the effectiveness of the Trading Hub aggregation in relieving congestion. The Trading Hub price will reflect congestion on Transmission Constraints whose effectiveness factor for the respective Trading Hub is greater than the effectiveness threshold specified in Section 27.3.4.6. There are three Existing Zone Generation Trading Hubs, which correspond geographically to the three Existing Zones. Each Existing Zone Generation Trading Hub is comprised of an aggregation of PNodes for Generating Units within the corresponding Existing Zone. The specification of seasons will be identical to the seasons used in the annual CRR Allocation, and the annual calculation of Existing Zone Generation Trading Hub weights will be performed in a timely manner to be coordinated with the annual CRR Allocation and CRR Auction processes.

## **27.4 Optimization In The CAISO Markets Processes**

The CAISO runs the Day-Ahead Market and Real-Time Market and their component CAISO Markets Processes utilizing a set of integrated optimization programs, including SCUC and SCED.

### **27.4.1 Security Constrained Unit Commitment**

The CAISO uses SCUC to run the MPM process associated with the DAM and the RTM. SCUC is conducted over multiple varying intervals to commit and schedule resources as follows: (1) in the Day-Ahead time frame, to meet Demand reflected in Bids submitted in the Day-Ahead Market and considered in the MPM process and IFM, and to procure AS in the IFM; (2) to meet the CAISO Forecast Of CAISO Demand in the RUC, HASP, STUC and FMM, and in the MPM process utilized in the HASP and RTM; and (3) to procure any incremental AS in the RTM . In the Day-Ahead MPM, IFM and RUC processes, the SCUC commits resources over the twenty-four (24) hourly intervals of the next Trading Day. In the FMM, which runs every fifteen (15) minutes and commits resources for the RTM, the SCUC optimizes over a number of 15-minute intervals corresponding to the Trading Hours for which the Real-Time Markets have closed. The Trading Hours for which the Real-Time Markets have closed consist of (a) the Trading Hour in which the applicable run is conducted and (b) all the fifteen-minute intervals of the entire subsequent Trading Hour. In the HASP, which runs once per hour, the SCUC: 1) accepts and awards HASP Block Intertie Schedules for Energy and Ancillary Services, respectively; 2) provides HASP Advisory Schedules to Economic Hourly Block Bids with Intra-Hour Option that will change for economic reasons at most once in the Trading Hour; and 3) provides HASP Advisory Schedules to all other participants in the RTM. In the STUC, which runs once an hour, the SCUC commits resources over the last fifteen (15) minutes of the imminent Trading Hour and the entire next four Trading Hours. The CAISO will commit Extremely Long Start Resources, for which commitment in the DAM does not provide sufficient time to Start-Up and be available to supply Energy during the next Trading Day as provided in Section 31.7.

#### **27.4.1.1 Timing of Unit Commitment Instructions**

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

For the applicable market intervals of any given CAISO Markets Process, the associated SCUC optimization will typically commit resources having different Start-Up Times, not all of which need to be started up immediately upon completion of that CAISO Markets Process. The CAISO may defer issuing a Start-Up Instruction to a resource that can be started at a later time and still be available to supply Energy at the time the CAISO Markets Process indicated it would be needed. The CAISO shall re-evaluate the need to commit such resources in a subsequent CAISO Markets Process based on the most recent forecasts and other information about system conditions.

**27.4.2 Security Constrained Economic Dispatch**

SCED is the optimization engine used to run the RTD to determine the optimal five-minute Dispatch Instructions throughout the Trading Hour consistent with resource constraints and Transmission Constraints within the CAISO Balancing Authority Area. In any given hour, the Real-Time Economic Dispatch of the Real-Time Market runs every five (5) minutes during which the SCED produces binding Dispatch Instructions for the immediately subsequent five-minute interval. For the applicable five-minute period, through its SCED, the CAISO produces LMPs at each PNode that are used for Settlements as described in Section 11.5.

**27.4.3 CAISO Markets Scheduling And Pricing Parameters**

The SCUC and SCED optimization software for the CAISO Markets utilize a set of configurable scheduling and pricing parameters to enable the software to reach a feasible solution and set appropriate prices in instances where Effective Economic Bids are not sufficient to allow a feasible solution. The scheduling parameters specify the criteria for the software to adjust Non-priced Quantities when such adjustment is necessary to reach a feasible solution. The scheduling parameters are configured so that the SCUC and SCED software will utilize Effective Economic Bids as far as possible to reach a feasible solution, and will skip Ineffective Economic Bids and perform adjustments to Non-priced Quantities pursuant to the scheduling priorities for Self-Schedules specified in Sections 31.4 and 34.10. The scheduling parameters utilized for relaxation of enforced internal and Intertie Transmission Constraints are specified in Section 27.4.3.1. The pricing parameters specify the criteria for establishing market prices in instances where one or more Non-priced Quantities are adjusted by the Market Clearing software. The

pricing parameters are specified in Sections 27.1.2.3, 27.4.3.2, 27.4.3.3 and 27.4.3.4. The complete set of scheduling and pricing parameters used in all CAISO Markets is maintained in the Business Practice Manuals.

**27.4.3.1 Scheduling Parameters for Transmission Constraint Relaxation**

In the IFM, the enforced internal and Intertie Transmission Constraint scheduling parameter is set to \$5,000 per MWh for the purpose of determining when the SCUC and SCED software in the IFM will relax an enforced internal and Intertie Transmission Constraint rather than adjust Supply or Demand bids or Non-priced Quantities as specified in Sections 31.3.1.3, 31.4 and 34.12 to relieve Congestion on the constrained facility. This scheduling parameter is set to \$1,500 per MWh for the RTM. The effect of this scheduling parameter value is that if the optimization can re-dispatch resources to relieve Congestion on a Transmission Constraint at a cost of \$5,000 per MWh or less for the IFM (or \$1,500 per MWh or less for the RTM), the Market Clearing software will utilize such re-dispatch, but if the cost exceeds \$5,000 per MWh in the IFM (or \$1,500 per MWh for the RTM) the market software will relax the Transmission Constraint. The corresponding scheduling parameter in RUC is set to \$1,250 per MWh.

**27.4.3.2 Pricing Parameters for Transmission Constraint Relaxation**

For the purpose of determining how the relaxation of a Transmission Constraint will affect the determination of prices in the IFM and RTM, the pricing parameter of the Transmission Constraint being relaxed is set to the maximum Energy Bid price specified in Section 39.6.1.1. The corresponding pricing parameter used in the RUC is set at the maximum RUC Availability Bid price specified in Section 39.6.1.2.

**27.4.3.3 Insufficient Supply to Meet Self-Scheduled Demand in IFM**

In the IFM, when available supply is insufficient to meet all self-scheduled Demand, self-scheduled Demand is reduced to the point where the available supply is sufficient to clear the market. For price-setting purposes in such cases, the cleared self-scheduled Demand is deemed to be willing to pay the maximum Energy Bid price specified in Section 39.6.1.1.

**27.4.3.4 Insufficient Supply to Meet CAISO Forecast of CAISO Demand in the RTM**

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

In the RTM, in the event that Energy offers are insufficient to meet the CAISO Forecast of CAISO Demand, the SCUC and SCED software will relax the system energy-balance constraint. In such cases the software utilizes a pricing parameter set to the maximum Energy Bid price specified in Section 39.6.1.1 for price-setting purposes.

**27.4.3.5 Protection of TOR, ETC and Converted Rights Self-Schedules in the IFM**

In accordance with the submitted and accepted TRTC Instructions, valid Day-Ahead TOR Self-Schedules, Day-Ahead ETC Self-Schedules and Day-Ahead Converted Rights Self-Schedules shall not be adjusted in the IFM in response to an insufficiency of Effective Economic Bids. The scheduling parameters associated with the TOR, ETC, or Converted Rights Self-Schedules will be set to values higher than the scheduling parameter associated with relaxation of an enforced internal and Intertie Transmission Constraint as specified in Section 27.4.3.1, so that when there is a congested Transmission Constraint that would otherwise subject a Supply or Demand resource submitted in a valid and balanced ETC, TOR or Converted Rights Self-Schedule to adjustment in the IFM, the IFM software will relax the Transmission Constraint rather than curtail the TOR, ETC, or Converted Rights Self-Schedule. This priority will be adhered to by the operation of the IFM Market Clearing software, and if necessary, by adjustment of Schedules after the IFM has been executed and the results have been reviewed by the CAISO operators.

**27.4.3.6 Effectiveness Threshold**

The CAISO Markets software includes a lower effectiveness threshold setting which governs whether the software will consider a bid "effective" for managing congestion on a congested Transmission Constraint. The CAISO will set this threshold at two (2) percent.

**27.5 Full Network Model**

**27.5.1 Network Models used in CAISO Markets**

The FNM is a representation of the WECC network model including the CAISO Balancing Authority Area that enables the CAISO to produce a Base Market Model that the CAISO then uses as the basis for formulating the individual market models used to conduct power flow analyses to manage Transmission Constraints for the optimization of each of the CAISO Markets.

**27.5.1.1 Base Market Model used in the CAISO Markets**



California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

Based on the FNM the CAISO creates the Base Market Model, which is used as the basis for formulating, as described in section 27.5.6, the individual market models used in each of the CAISO Markets to establish, enforce, and manage the enforced internal and Intertie Transmission Constraints associated with network facilities. The Base Market Model is derived from the FNM by (1) introducing locations for modeling Intertie Schedules; and (2) introducing market resources that do not currently exist in the FNM due to their size and lack of visibility. In the Base Market Model, external Balancing Authority Areas and external transmission systems are modeled to the extent necessary to 1) improve the accuracy of the CAISO Market solutions for purposes of reliable operations, and 2) support the commercial requirements of the CAISO Markets. For those portions of the FNM that are external to the CAISO Balancing Authority Area, the Base Market Model may model the resistive component for accurate modeling of Transmission Losses, but accounts for losses in the external portions of the market model separately from Transmission Losses within the CAISO Balancing Authority Area. As a result, the Marginal Cost of Losses in the LMPs is not affected by external losses. For portions of the Base Market Model that are external to the CAISO Balancing Authority Area, the CAISO Markets only enforce Transmission Constraints that reflect limitations of the transmission facilities and Entitlements turned over to the Operational Control of the CAISO by a Participating Transmission Owner, or that affect Congestion Management within the CAISO Balancing Authority Area or on Interties. External connections are retained between Intertie branches within Transmission Interfaces. Certain external loops are modeled, which allows the CAISO to increase the accuracy of the Congestion Management process. The CAISO Markets' optimizations also factor in forecasted unscheduled flow at the Interties consistent with the requirements specified in the Business Practice Manuals. Resources are modeled at the appropriate network Nodes. The pricing Location (PNode) of a Generating Unit generally coincides with the Node where the relevant revenue quality meter is connected or corrected, to reflect the point at which the Generating Unit is connected to the CAISO Controlled Grid. The Dispatch, Schedule, and LMP of a Generating Unit refers to a PNode, but the Energy injection is modeled in the Base Market Model for network analysis purposes at the corresponding

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

Generating Unit's physical interconnection point), taking into account any losses in the non-CAISO Controlled Grid leading to the point where Energy is delivered to CAISO Controlled Grid. Based on the Base Market Model, the market models used in each of the CAISO Markets incorporate physical characteristics needed for determining Transmission Losses and model Transmission Constraints within the CAISO Balancing Authority Area, which are then reflected in the Day-Ahead Schedules, AS Awards and RUC Awards, FMM Schedules, Dispatch Instructions, and LMPs resulting from each CAISO Markets Process. The Dispatch, Schedule, and LMP of a Dynamic System Resource or Pseudo-Tie of a Generating Unit to the CAISO Balancing Authority Area refer to a PNode, or Aggregated Pricing Node, if applicable, of the resource at its physical location in the external transmission systems that are modeled in the Base Market Model, subject to the modeling of Transmission Losses in the portions of the FNM and exclusion of such Transmission Losses' effects on the LMPs that are external to the CAISO Balancing Authority Area described in this Section 27.5.1.1. The LMP price thus associated with a Dynamic System Resource or Pseudo-Tie Generating Unit will be used for Settlement of Energy and will include the Marginal Cost of Congestion and Marginal Cost of Losses components of the LMP to that Dynamic System Resource or Pseudo-Tie Generating Unit point, excluding losses and congestion external to the CAISO Balancing Authority Area, in accordance with this Section 27.5.1.1. Further, in formulating the market models for the CAISO Market processes, except for specific Intertie locations as specified in the BPM, power flow parameters developed from applicable data sources, including available outage information, system status data, and the State Estimator for the Real-Time Dispatch, are applied to the Base Market Model.

**27.5.1.2 Accuracy Metric for Modeled External Unscheduled Flow in the Day-Ahead Market**

**27.5.1.2.1 Accuracy Metric**

For each Day-Ahead Market, the CAISO will calculate the external unscheduled flow accuracy metric as described further in this Section 27.5.1.2. The accuracy metric is a comparison of the magnitude of the difference between the following two amounts under two scenarios: 1) the actual unscheduled flows on the Interties caused by external Balancing Authority Area generation, load, and interchanges; and 2) the CAISO's modeled Day-Ahead external

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

unscheduled flow on the Interties per hour in MW. In the first scenario, the CAISO models the external unscheduled flow impacts of external Balancing Authority Area schedules in the Day-Ahead Market. In the second scenario, the CAISO does not model these flow impacts. For purposes of the accuracy metric, the external unscheduled flow is defined as the flow impact over the CAISO Interties of supply, demand, and area-to-area net scheduled interchanges between external Balancing Authority Areas. The external unscheduled flow will be derived based on a power flow solution and will be calculated separately for the Day-Ahead and actual network conditions on an average hourly basis for each Intertie. For the Day-Ahead, the CAISO will rerun a solved case and isolate the flow impact of external Balancing Authority Areas, if modeled, to derive the modeled external unscheduled flow. For the actual network conditions, the CAISO will use the actual external area-to-area net scheduled Interchange and the State Estimator solution to capture the actual supply, demand, and topology, and will isolate the flow impact of external Balancing Authority Areas to derive the actual external unscheduled flow. To calculate the external unscheduled flow accuracy metric, the CAISO will compare the Day-Ahead modeled external unscheduled flow and the actual external unscheduled flow for each of the scenarios. For the first scenario, the CAISO will take the difference per Intertie, per Trading Hour of the actual external unscheduled flow and the modeled Day-Ahead external unscheduled flow. For the second scenario, the CAISO will also take the difference per Intertie, per Trading Hour of the actual external unscheduled flow and the modeled Day-Ahead external unscheduled flow. Under the second scenario, the modeled Day-Ahead external unscheduled flow is zero, so the resulting difference is the absolute value of the actual external unscheduled flow. The CAISO will sum the absolute value of these sets of differences under the two scenarios.

**27.5.1.2.2 Accuracy Metric Threshold and Suspension**

To determine whether or not the CAISO has met the accuracy metric, the CAISO calculates the accuracy metric on an Intertie basis per Trading Hour and then sums the absolute value of the differences per Intertie, per Trading Hour across all Interties and all Trading Hours to calculate a three-week rolling average per the scenarios described in Section 27.5.1.2.1. The CAISO excludes from the accuracy metric the impact of the following unforeseen Real-Time events:

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

the loss of direct current transmission lines, unexpected outages of generators over 1,000 MW, or a derate of over 1,000 MW at any Intertie. If the three-week rolling average of the aggregated accuracy metric shows that the magnitude of the difference under the first scenario is greater than the magnitude of the difference under the second scenario, as described in Section 27.5.1.2.1, the CAISO will suspend its consideration of external unscheduled flow due to external Balancing Authority Area schedules in the Day-Ahead Market by disabling the impact of the net scheduled interchange between external Balancing Authority Areas. The suspension will be in place until the CAISO demonstrates that the three-week rolling average of the aggregated accuracy metric under the first scenario is less than it is under the second scenario. Even when the accuracy metric threshold is met, if the CAISO determines that the consideration of the external unscheduled flow is hampering the CAISO's ability to operate the system reliably, the CAISO may elect to suspend the consideration of the unscheduled flow in the Day-Ahead Market until it has determined that considering the external unscheduled flow no longer hampers its ability to operate the system reliably. Any suspension and return of the CAISO's consideration of external unscheduled flow in the Day-Ahead Market will be conducted as soon as practicable, consistent with and as permitted by the CAISO Markets timelines and the CAISO's processes. During any period of suspension, the CAISO will continue to calculate the accuracy metric offline and will base its reinstatement of external unscheduled flow consideration in the Day-Ahead Market on the accuracy metric being met based on the three-week rolling average.

**27.5.1.2.3 Sunset**

Section 27.5.1.2 and its subsections will no longer be effective, if the CAISO has not failed the metric described therein for twelve (12) consecutive months after the first twelve months that this section is effective.

**27.5.2 Metered Subsystems**

The FNM includes a full model of MSS transmission networks used for power flow calculations and Congestion Management in the CAISO Markets Processes. Transmission Constraints (i.e. circuit ratings, thermal ratings, etc.) within the MSS, or at its boundaries, that are modeled in the

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

Base Market Model shall be monitored but not enforced in operation of the CAISO Markets. If overloads are observed in the forward markets, are internal to the MSS or at the MSS boundaries, and are attributable to MSS operations, the CAISO shall communicate such events to the Scheduling Coordinator for the MSS and coordinate any manual Re-dispatch required in Real-Time. If, independent of the CAISO, the Scheduling Coordinator for the MSS is unable to resolve Congestion internal to the MSS or at the MSS boundaries in Real-Time, the CAISO will use Exceptional Dispatch Instructions on resources that have been bid into the RTM to resolve the Congestion. The costs of such Exceptional Dispatch will be allocated to the responsible MSS Operator. Consistent with Section 4.9, the CAISO and MSS Operator shall develop specific procedures for each MSS to determine how Transmission Constraints will be handled.

**27.5.3 Integrated Balancing Authority Areas**

To the extent sufficient data are available or adequate estimates can be made for an IBAA, the Base Market Model used by the CAISO for the CAISO Markets Processes will include a model of the IBAA's network topology. The CAISO monitors but does not enforce the Transmission Constraints for an IBAA in running the CAISO Markets Processes. Similarly, the CAISO models the resistive component for transmission losses on an IBAA but does not allow such losses to determine LMPs that apply for pricing transactions to and from an IBAA and the CAISO Balancing Authority Area, unless allowed under a Market Efficiency Enhancement Agreement. For Bids and Schedules between the CAISO Balancing Authority Area and the IBAA, the CAISO will model the associated sources and sinks that are external to the CAISO Balancing Authority Area using individual or aggregated injections and withdrawals at locations in the FNM that allow the impact of such injections and withdrawals on the CAISO Balancing Authority Area to be reflected in the CAISO Markets Processes as accurately as possible given the information available to the CAISO.

**27.5.3.1 Currently Established Integrated Balancing Authority Areas**

The FNM includes the established IBAA's listed below. Additional details regarding the modeling specifications for these IBAA's are provided in the Business Practice Manuals.

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

- (1) The Sacramento Municipal Utility District (SMUD) IBAA including the transmission facilities of the following entities:
  - (a) Western Area Power Administration – Sierra Nevada Region
  - (b) Modesto Irrigation District
  - (c) City of Redding
  - (d) City of Roseville
- (2) Turlock Irrigation District IBAA

**27.5.3.2 Information Required to Develop and Obtain Pricing under a Market Efficiency Enhancement Agreement**

The CAISO shall enter into an MEEA with an entity controlling supply resources within an IBAA to provide modeling and pricing for imports or exports between the IBAA and the CAISO Balancing Authority Area if the entity agrees to provide the information as specified herein. These information requirements apply to all entities seeking to enter into and having entered into an MEEA, including external Balancing Authorities within the IBAA or sub-entities therein such as Scheduling Coordinators or sub-Balancing Authority Areas in control of specific resources or a portfolio of resources. For these purposes, the term resource includes sources or sinks within the IBAA. An MEEA signatory may use generation as a resource to support an import to the CAISO and may use load or reduce generation to support an export from the CAISO. Control includes ownership or any contractual arrangements that provide authority to schedule and/or receive the financial benefits of a resource. Entities controlling a portfolio of resources within the IBAA are eligible to enter into MEEAs for interchange transactions using portfolios of resources. For the purposes of this provision, Western Area Power Administration base resource customers have sufficient control over Western Area Power Administration base resource portfolio of resources within the IBAA to be eligible to enter into MEEAs for interchange transactions utilizing these resources.

In order to obtain non-default, location-specific pricing for interchange transactions with the CAISO Balancing Authority Area, an MEEA signatory must provide the information described in this section 27.5.3.2. The information is necessary to: (i) establish the location of the resources that will be used to calculate location-specific prices under the MEEA, (ii) verify that the resources

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

operating to implement an interchange transaction are the same as the resources identified in the MEEA, (iii) verify the amount of an interchange transaction that was implemented by the dispatch of resources identified in the MEEA, and (iv) settle all charges and payments for interchange transactions under the MEEA.

Subject to the requirements in Section 27.5.3.2.2, the CAISO will provide an LMP to an MEEA signatory for an interchange transaction between the CAISO Balancing Authority Area and the IBAA at the Scheduling Point at which the actual Import or Export Bid is submitted to the CAISO Markets. This MEEA-specific LMP for MEEA transactions shall be calculated for each such Scheduling Point and reflect the nodes where the specific import or export is demonstrated in the MEEA to actually be located. The CAISO will develop generation distribution factors that apply to the relevant MEEA transactions as provided in Section 27.5.3.2.1. The CAISO and an MEEA signatory may negotiate an alternative to the historical average distribution generation factors of MEEA resources, if an MEEA signatory establishes that a different structure more accurately identifies the actual location of resources within the IBAA that support interchange transactions with the CAISO.

**27.5.3.2.1 Information Required to Develop a Market Efficiency Enhancement Agreement**

An entity seeking to enter into an MEEA with the CAISO will provide the CAISO with historical hourly metered generation data for the supply resources to be identified in the MEEA and the historical hourly metered load data within the IBAA for the load served by the MEEA signatory, if any. The data shall be provided in a format that the WECC accepts or other commonly used format. MEEA pricing will typically be based on historical average distribution of generation among a portfolio of resources identified in an MEEA, using negotiated generation distribution factors, subject to revision to reflect changes in usage. The CAISO and an MEEA signatory may, therefore, agree on a set of weighted distribution factors for a specified set of resource locations, which will be used to calculate the MEEA price that will apply to Bids, including Self-Schedules, cleared and processed as further provided in the CAISO Tariff, submitted for resources identified in an MEEA. By applying a set of weighted distribution factors to a set of generator locations, an

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

MEEA signatory is not required to associate a specific generator within a MEEA portfolio of resources with a specific customer of the MEEA signatory. The CAISO will negotiate any generation distribution factors as provided below. For portfolios of resources, the CAISO and a potential MEEA signatory will develop a weighted average price methodology based upon an agreed set of weights for the resources that comprise the MEEA portfolio. Such weights will be based on historical data of operation of the resources comprising the portfolio.

The distribution factors may reflect seasonal, peak and off-peak or other usage and may be periodically revised through bilateral negotiations using updated historical operation data of the MEEA portfolio. All executed MEEAs between the CAISO and an entity with resources within the IBAA must include:

- (a) a list of the external supply resources and loads within the IBAA over which the MEEA signatory has control or serves (for these purposes control includes ownership or any contractual arrangements that provide authority to schedule and/or receive the financial benefits of a resource);
- (b) the location of the resources identified in the MEEA for which non-default LMPs will be calculated;
- (c) the injection and withdrawal points for the resources identified in the MEEA; and
- (d) the appropriate Resource IDs that apply for the MEEA transactions.

**27.5.3.2.2 Information Needed to Determine Application of MEEA-Specific Pricing in any Settlement Interval or Settlement Period**

If an MEEA signatory submits a Bid in the CAISO Market and seeks to obtain an MEEA-specific LMP for an interchange transaction, the CAISO must be capable of verifying what portion (output in megawatt hours) of the resources identified in the MEEA, if any, were dispatched to implement the interchange transaction. To the extent that the resources identified in the MEEA, or portion thereof, were dispatched and operated for purposes other than the interchange transaction submitted in the CAISO Market, the Schedule or Imbalance Energy associated with the Bid submitted and cleared in the CAISO Market will not receive an MEEA-specific LMP, and will instead receive the default IBAA price specified in Appendix C, Section G.1.1. The CAISO will establish Resource IDs that are to be used only to submit Bids, including Self-Schedules, for the



California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

purpose of obtaining MEEA-specific pricing. MEEA signatories may obtain and use other Resource IDs to submit Bids, including Self-Schedules, that are not covered by an MEEA. Prior to obtaining and settling Resource IDs under the terms of the MEEA, the relevant Scheduling Coordinator shall attest that use of the Resource ID shall mean that the MEEA signatory dispatched a resource identified in an MEEA to support the MEEA interchange transaction. This attestation shall be executed under oath by an officer of the MEEA with knowledge of the MEEA signatory's operations. By actually using such Resource IDs, the Scheduling Coordinator represents that MEEA resources are dispatched to support such Bids, including Self-Schedules. The CAISO may challenge the use of these Resource IDs and conduct an audit under Section 27.5.3.7.

In connection with any such audit, the MEEA signatory shall support its certification with information demonstrating that an MEEA signatory resource was dispatched to support the interchange transaction. This information may include, but is not limited to, NERC tags, OASIS transmission service data, day-ahead load and resource plans, power purchase agreements or contracts demonstrating use of the California Oregon Transmission Project as well as marginal cost information. An MEEA signatory, however, is not required to provide marginal cost information to the CAISO to support its self-certification and may support its self-certification with other information, including information identified in the preceding sentence. The MEEA signatory shall provide data in a format that the WECC accepts or other commonly used format. For any Settlement Interval or Period for which the CAISO challenges the use of Resource IDs under an MEEA, the CAISO shall apply MEEA pricing to the Settlement Interval or Period pending resolution of the challenge.

In addition, in the event that there is a Dynamic Resource-Specific System Resource in the IBAA, the MEEA may further provide that the MEEA signatory in control of such resource may also obtain pricing under the MEEA for imports to the CAISO Balancing Authority Area from the Dynamic Resource-Specific System Resource. For any portion of an interchange transaction for which the MEEA Entity has not self-certified that the resources were used to support interchange

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

transactions, the default IBAA price specified in Appendix C, Section G.1.1 will apply for the corresponding volume and time period.

**27.5.3.3 Process for Establishing a Market Efficiency Enhancement Agreement**

Any entity seeking to negotiate an MEEA with the CAISO may submit a written request to the CAISO. The CAISO and the requesting entity shall negotiate in good faith the terms and conditions of the MEEA. The CAISO shall file any executed MEEA with FERC for review and approval under Section 205 of the Federal Power Act. In the event an MEEA is not executed within 180 days of the initial written request for an MEEA, a requesting entity may invoke the CAISO ADR Procedures under Section 13.

**27.5.3.4 Use of Data Provided under a Market Efficiency Enhancement Agreement**

Data provided to the CAISO pursuant to an MEEA shall be used for purposes of modeling and pricing Interchange transactions between the CAISO Balancing Authority Area and the relevant IBAA at Scheduling Points specified in the MEEA. The configuration of the pricing points for the MEEA, which may include specific distribution factors for the represented resources, established through the negotiation of the MEEA will also be used for the purposes of modeling the resources in the IBAA subject to the MEEA. The CAISO and the MEEA signatory may agree to changes to these configurations over time that do not require the renegotiation of the terms of the MEEA or may agree to static terms until such time the parties re-execute a new MEEA. Such modeling information regarding the location of the resources will be incorporated into the Full Network Model, including the CRR FNM, which is used for all CAISO Markets as further described in Sections 27.3, 27.5.1 and 27.5.6. The FNM and the CRR FNM will not include the hourly transactional data provided pursuant to Section 27.5.3.2, except in such cases where the CAISO and the MEEA signatory have agreed to dynamic changes to the configuration of the modeling of the MEEA resources during the life of the agreement as further provided by the MEEA.

**27.5.3.5 Measures to Preserve Confidentiality of Data under a Market Efficiency Enhancement Agreement**

Subject to the provisions of Section 27.5.3.4, data provided to the CAISO by any entity under an MEEA or in connection with negotiations to develop an MEEA shall be treated as confidential data. Consistent with applicable law, the CAISO shall take all steps reasonably necessary to limit

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

disclosure of this information to CAISO personnel that need to review such information as part of their work-related responsibilities. In the event a disclosing entity does not execute an MEEA, the CAISO shall return the confidential data to the disclosing entity if the CAISO can physically return the data and shall destroy the confidential data if the CAISO cannot physically return the confidential data to the disclosing entity.

**27.5.3.6 Dispute Resolution under Market Efficiency Enhancement Agreements**

Any disputes arising out of or in connection with an MEEA shall be subject to the CAISO ADR Procedures of Section 13.

**27.5.3.7 Audit Rights under Market Efficiency Enhancement Agreements**

The CAISO reserves the right to audit data supplied under an MEEA by giving written notice at least ten (10) Business Days in advance of the date that the CAISO wishes to initiate such audit, with completion of the audit occurring within 180 days of such notice. The audit shall be for the limited purposes of verifying that the MEEA signatory has accurately represented available resources and has met the requirements specified for MEEA pricing. Upon request of the CAISO as part of such audit, any signatory to an MEEA shall provide information to support its certification under Section 27.5.3.2. An MEEA signatory may audit the price for any transaction entered into under an MEEA through the CAISO's Settlement and billing process set forth in Section 11 and through data provided to the MEEA signatory as a Market Participant under the CAISO Tariff. Each party will be responsible for its own expenses related to any audit.

**27.5.3.8 Process for Establishing a New IBAA or Modifying an Existing IBAA**

Except under exigent circumstances, the CAISO must follow a consultative process with the applicable Balancing Authority and CAISO Market Participants pursuant to the process further defined in the Business Practice Manuals, to establish a new IBAA or modify an existing IBAA. Changes to an existing IBAA may include among others changes to the modeling of the IBAA's network topology, the specification of the default Resource IDs or the default pricing points. Upon completion of this process and having determined it necessary to establish a new IBAA or modify an existing IBAA, the CAISO will seek FERC approval under Section 205 of the Federal Power Act of the proposed new IBAA or changes to the existing IBAA requirements, at which time the

CAISO shall also provide its supportive findings for the establishment of the new IBAA or modification to an existing IBAA.

**27.5.3.8.1 Factors to Be Considered in Establishing a New Integrated Balancing Authority Area or Modifying an Existing Integrated Balancing Authority Area**

In establishing a new IBAA or modifying an existing IBAA, the factors that the CAISO will consider shall include, but are not limited to, the following:

- (1) The number of Interties between the potential or existing IBAA and the CAISO Balancing Authority Area and the distance between them;
- (2) Whether the transmission system(s) within the other Balancing Authority Area runs in parallel to major parts of the CAISO Controlled Grid;
- (3) The frequency and magnitude of unscheduled power flows at applicable Interties;
- (4) The number of hours where the actual direction of power flows was reversed from scheduled directions;
- (5) The availability of information to the CAISO for modeling accuracy; and
- (6) The estimated improvement to the CAISO's power flow modeling and Congestion Management processes to be achieved through more accurate modeling of the Balancing Authority Area.

**27.5.3.9 Default Designation of External Resource Locations for Modeling Transactions Between the CAISO Balancing Authority Area and an IBAA**

Prior to the establishment of a new IBAA or a change to an existing IBAA, the CAISO will define and publish default Resource IDs to be used for submitting import and export Bids and for settling import and export Schedules between the CAISO Balancing Authority Area and the potential or existing IBAA. These default Resource IDs will specify in the Master File the default associations of Intertie Scheduling Point Bids and Schedules to supporting individual or aggregate injection or withdrawal locations in the FNM. The CAISO will determine the supporting injection and withdrawal locations to allow the impact of the associated Intertie Scheduling Point Bids and Schedules to be reflected in the CAISO Markets Processes as accurately as possible given the

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

information available to the CAISO. The CAISO's methodology for determining such default Resource IDs, as well as the specific default Resource IDs that have been adopted for the currently established IBAs, are provided in the Business Practice Manuals. Alternative Resource IDs to be used instead of the default Resource IDs will be created and adopted for use in conjunction with Intertie Scheduling Point Bids and Schedules between the CAISO Balancing Authority Area and the IBAA based on a Market Efficiency Enhancement Agreement.

**27.5.4 Accounting For Changes In Topology In FNM**

The CAISO will incorporate into the FNM information received pursuant to Section 24 for transmission expansion and Section 25 for generation interconnection to account for changes to the CAISO Controlled Grid and other facilities located within the CAISO Balancing Authority Area. This information will be incorporated into the network model data base in which the electrical network model is maintained for use by the State Estimator and which forms the basis for the Base Market Model used by the CAISO Markets. The updated power system network model will be transferred at periodic model update cycle intervals established by the CAISO and incorporated into the Base Market Model for use in the CAISO Markets. The Business Practice Manual for managing the Full Network Model will describe the information to be provided by Market Participants, the process by which the CAISO incorporates this information in the FNM, and operational details of the FNM. If the CAISO becomes aware of a material error or omission in the FNM, it will make a timely correction of the FNM.

**27.5.5 Load Distribution Factors**

The CAISO will maintain a library of system-wide Load Distribution Factors for use in distributing Demand scheduled at the Default LAPs. The system Load Distribution Factors are derived from the State Estimator and are stored in the Load Distribution Factor library, and are updated periodically. For IFM the Load Distribution Factor library uses a similar-day methodology for smoothing the most recent Load Distribution Factors. The similar-day methodology uses data separately for each type of day. More recent days are weighted more heavily in the smoothing calculations. The market application then uses the set of Load Distribution Factors from the library that best represents the Load distribution conditions expected for use in the CAISO

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

Markets Processes. For the RTM, the State Estimator solution is used as a source for determining Load Distribution Factors. The Load Distribution Factor are also maintained for use for Demand scheduled at Custom LAPs. These custom Load Distribution Factors are not generated from the State Estimator and are fixed quantities representing the characteristics of the Custom LAP.

**27.5.6 Management & Enforcement of Constraints in the CAISO Markets**

The CAISO operates the CAISO Markets through the use of a market software system that utilizes various information including the Base Market Model, the State Estimator, submitted Bids including Self-Schedules, Generated Bids, and Transmission Constraints, including Nomograms and Contingencies transmission and generation Outages. The market model used in each of the CAISO Markets is derived from the most current Base Market Model available at that time. To create a more relevant time-specific network model for use in each of the CAISO Markets, the CAISO will adjust the Base Market Model to reflect Outages and derates that are known and applicable when the respective CAISO Market will operate, and to compensate for observed discrepancies between actual real-time power flows and flows calculated by the market software. Through this process the CAISO creates the market model to be used in each Day-Ahead Market and each process of the Real-Time Market. The CAISO will manage the enforcement of Transmission Constraints, including Nomograms and Contingencies, consistent with good utility practice, to ensure, to the extent possible, that the market model used in each market accurately reflects all the factors that contribute to actual Real-Time flows on the CAISO Controlled Grid and that the CAISO Market results are better aligned with actual physical conditions on the CAISO Controlled Grid. In operating the CAISO Markets, the CAISO may take the following actions so that, to the extent possible, the CAISO Market solutions are feasible, accurate, and consistent with good utility practice:

- (a) The CAISO may enforce, not enforce, or adjust flow-based Transmission Constraints, including Nomograms and Contingencies, if the CAISO observes that the CAISO Markets produce or may produce results that are inconsistent with observed or reasonably anticipated

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

conditions or infeasible market solutions either because (a) the CAISO reasonably anticipates that the CAISO Market run will identify Congestion that is unlikely to materialize in Real-Time even if the Transmission Constraint were to be ignored in all the markets leading to Real-Time, or (b) the CAISO reasonably anticipates that the CAISO Market will fail to identify Congestion that is likely to appear in the Real-Time. The CAISO does not make such adjustments to Intertie Scheduling Limits.

- (b) The CAISO may enforce or not enforce Transmission Constraints, including Nomograms and Contingencies, if the CAISO has determined that non-enforcement or enforcement, respectively, of such Transmission Constraints may result in the unnecessary pre-commitment and scheduling of use-limited resources.
- (c) The CAISO may not enforce Transmission Constraints, including Nomograms and Contingencies, if it has determined it lacks sufficient visibility to conditions on transmission facilities necessary to reliably ascertain constraint flows required for a feasible, accurate and reliable market solution.
- (d) For the duration of a planned or unplanned Outage, the CAISO may create and apply alternative Transmission Constraints, including Nomograms and Contingencies, that may add to or replace certain originally defined constraints.
- (e) The CAISO may adjust Transmission Constraints, including Nomograms and Contingencies, for the purpose of setting prudent operating margins consistent with good utility practice to ensure reliable operation under anticipated conditions of unpredictable and uncontrollable flow volatility consistent with the requirements of Section 7.

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

To the extent that particular Transmission Constraints, including Nomograms and Contingencies, are not enforced in the operations of the CAISO Markets, the CAISO will operate the CAISO Controlled Grid and manage any Congestion based on available information including the State Estimator solutions and available telemetry to Dispatch resources through Exceptional Dispatch to ensure the CAISO is operating the CAISO Controlled Grid consistent with the requirements of Section 7.

**27.6 State Estimator**

The State Estimator produces a power flow solution based upon the modeled representation of the electrical network and available Real-Time SCADA telemetry. When this solution is applied to the FNM, it provides a reference of system conditions for determining Dispatch Instructions. The State Estimator also provides a reference for Real-Time Load Distribution Factors used to distribute the Real-Time CAISO Forecast of CAISO Demand as well as provide a source of historical data for the LDF library. If the State Estimator is not capable of providing CAISO with a solution to clear the CAISO Markets, the CAISO shall use the last best State Estimator solution for determining Dispatch Instructions, provided the State Estimator is not unavailable for an extended period. If the State Estimator is not available for an extended period of time, the CAISO shall use the Load Distribution Factors from the Load Distribution Factors library as applicable to the prevailing system and time of use conditions to determine Dispatch Instructions.

**27.7 Constrained Output Generators**

**27.7.1 Election Of Constrained Output Generator Status**

A Scheduling Coordinator on behalf of a Generating Unit eligible for COG status must make an election to have the resource treated as a COG before each calendar year by registering the resource's PMin in the Master File as equal to its PMax less 0.01 MW ( $P_{Min} = P_{Max} - 0.01 \text{ MW}$ ) within the timing requirements specified for Master File changes described in the applicable Business Practice Manual. Generating Units with COG status will be eligible to set LMPs in the IFM and RTM based on their Calculated Energy Bids.

As with all Generating Units that are not Use-Limited Resources, a Scheduling Coordinator on behalf of a COG that is not a Use-Limited Resource must use the Proxy Cost methodology, as



California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

provided in Section 30.4, for determining its Start-Up Costs and Minimum Load Costs. A Scheduling Coordinator on behalf of a COG that is a Use-Limited Resource must elect to use either the Proxy Cost methodology or the Registered Cost methodology, as provided in Section 30.4, for determining its Start-Up Costs and Minimum Load Costs. A Calculated Energy Bid of a COG that is not a Use-Limited Resource will be calculated based on the Proxy Cost methodology. A Calculated Energy Bid of a COG that is a Use-Limited Resource will be calculated based on its election of the Proxy Cost methodology or the Registered Cost methodology. Whenever a Scheduling Coordinator for a COG submits an Energy Bid into the IFM or RTM, the CAISO will override that Bid and substitute the Calculated Energy Bid if the submitted Bid is different from the Calculated Energy Bid.

**27.7.2 Election To Waive COG Status**

A Scheduling Coordinator on behalf of a Generating Unit eligible for COG status may elect to waive COG status. If such Generating Unit has a non-zero operating range (PMax greater than PMin), it is eligible to participate in the CAISO Markets like any other resource.

**27.7.3 Constrained Output Generators In The IFM**

In the IFM, resources electing COG status are modeled as though they are not constrained and can operate flexibly between zero (0) and their PMax. A COG is eligible to set IFM LMPs based on its Calculated Energy Bid in any Settlement Period in which a portion of its output is needed as a flexible resource to serve Demand. A COG is not eligible for recovery of Minimum Load Costs or BCR in the IFM due to the conversion of its Minimum Load Cost to an Energy Bid and its treatment by the IFM as a flexible resource. A COG is eligible for Start-Up Cost recovery based on its Commitment Period as determined in the IFM, RUC, STUC or RTUC.

**27.7.4 Constrained Output Generators In RUC**

In RUC, any COG that has capacity that did not fully clear in the IFM is treated as constrained, so that the entire capacity of the COG is committed by RUC. Any such RUC commitment would apply to scheduled capacity in RUC in excess of the higher of: (a) the relevant Day-Ahead Schedule; or (b) the relevant Minimum Load. In the event of a RUC commitment, the COG is not eligible to receive a RUC Award.

### **27.7.5 Constrained Output Generators In The Real-Time Market**

A COG that can be started up and complete its Minimum Run Time within a five-hour period can be committed by the STUC. A COG that can be started up within the applicable RTUC run as described in Section 34.3 can be committed by the RTUC. The RTD will dispatch a COG up to its PMax or down to zero (0) to ensure a feasible Real-Time Dispatch. The COG is eligible to set the RTM LMP in any Dispatch Interval in which a portion of its output is needed to serve Demand, not taking into consideration its Minimum Run Time constraint. For the purpose of making this determination and setting the RTM LMP, the CAISO treats a COG as if it were flexible with an infinite Ramp Rate between zero (0) and its PMax, and uses the COG's Calculated Energy Bid. In any Dispatch Interval where none of the output of a COG is needed as a flexible resource to serve Demand, the CAISO shall not dispatch the unit. In circumstances in which the output of the COG is not needed as a flexible resource to serve Demand, but the unit nonetheless is online as a result of a previous commitment or Dispatch Instruction by the CAISO, the COG is eligible for Minimum Load Cost compensation.

### **27.8 Multi-Stage Generating Resources**

#### **27.8.1 Registration and Qualification**

Scheduling Coordinators responsible for resources that meet the definition of a Multi-Stage Generating Resource based on their Master File registered characteristics must register such resources with the CAISO as Multi-Stage Generating Resources as further discussed in this Section, and must comply with all requirements that apply to such resources specified in the CAISO Tariff. Scheduling Coordinators must comply with the registration and qualification process described in this Section 27.8.1, in order to effectuate any of the changes described in Section 27.8.3. No less than sixteen (16) days prior to the date that Scheduling Coordinator seeks to have the resource participate in the CAISO Markets under the new settings or MSG Configuration details, the Scheduling Coordinator must complete and submit to the CAISO the registration form and the resource data template provided by the CAISO for registration and qualification purposes. After the Scheduling Coordinator submits a request for registration of a Generating Unit as a Multi-Stage Generating Resource or a change in the attributes in Section

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

27.8.3, the CAISO will coordinate with that Scheduling Coordinator to validate that the resource qualifies for the requested status and that all the requisite information has been successfully provided to the CAISO. The resource will be successfully registered and qualified as a Multi-Stage Generating Resource, or the requested changes in the attributes listed in Section 27.8.3 will be successfully registered and qualified as of the date on which the CAISO sends the responsible Scheduling Coordinator a notice that the resource has been successfully qualified as such. In the absence of extenuating circumstances and unless the Scheduling Coordinator requests additional time, the ISO will provide such notice on the sixteenth day after the Scheduling Coordinator provides new settings or MSG Configuration details. After the date on which the CAISO has provided such notice, any changes to the items listed in Section 27.8.3 will be subject to the timing and process requirements in this Section 27.8.1 and 27.8.3. The Scheduling Coordinator may modify all other Multi-Stage Generating Resource registered characteristics pursuant to the timing and processing requirements specified elsewhere in this CAISO Tariff, as they may apply. If the CAISO has reason to believe that the resource's operating and technical characteristics are not consistent with the registered and qualified attributes, the CAISO may request that the Scheduling Coordinator provide additional information necessary to support their registered status and, if appropriate, may require that the resource be registered and qualified more consistent with the resource's operating and technical characteristics, including the revocation of its status as a Multi-Stage Generating Resource. Failure to provide such information may be grounds for revocation of Multi-Stage Generating Resource status. Such changes in status or MSG Configuration details would be subject to the registration and qualification requirements in this Section 27.8. Scheduling Coordinators may register the number MSG Configurations as are reasonably appropriate for the resource based on the technical and operating characteristics of the resource, which may not, however, exceed a total of ten MSG Configurations and cannot be fewer than two MSG Configurations. The information requirements specified in Section 27.8.2 will apply.

### **27.8.2 Informational Requirements**

As part of the registration process described in Section 27.8.1, the Scheduling Coordinators for Generating Units that seek to qualify as Multi-Stage Generating Resources must submit to the CAISO a Transition Matrix, which contains the Transition Costs and operating constraints associated with MSG Transitions. The Scheduling Coordinator may register up to six (6) MSG Configurations without any limitation on the number of transitions between the registered MSG Configurations in the Transition Matrix. If the Scheduling Coordinator registers seven (7) or more MSG Configurations, then the Scheduling Coordinator may only include two (2) eligible transitions between MSG Configurations for upward and downward transitions, respectively, starting from the initial MSG Configuration in the Transition Matrix. For each MSG Configuration, the responsible Scheduling Coordinator shall submit an Operational Ramp Rate and, as applicable, an Operating Reserve Ramp Rate and Regulating Reserves ramp rate, each of which shall have at least one (1) segment and no more than two (2) segments. The Scheduling Coordinator must establish the default MSG Configuration and its associated Default Resource Adequacy Path that apply to Multi-Stage Generating Resources that are subject to Resource Adequacy must-offer obligations. The Scheduling Coordinator may submit changes to this information consistent with Sections 27.8.1 and 27.8.3, as they may apply.

### **27.8.3 Changes in Status and Configurations of Resource**

Scheduling Coordinators may seek modifications to the Multi-Stage Generating Resource attributes listed below consistent with the process and timing requirements specified in Section 27.8.1 and the additional requirements discussed below in this Section 27.8.3:

- (1) Registration and qualification of a Generating Unit as a Multi-Stage Generating Resource.
- (2) Changes to the MSG Configurations attributes, which include:
  - a. addition of new MSG Configurations;
  - b. removal of an existing MSG Configuration;
  - c. a change in the physical units supporting the MSG Configuration;
  - d. a change to the MSG Configuration Start Up and Shut Down flags;

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

- e. adding or removing an MSG Transition to the Transition Matrix;
- f. a material change in the Transition Times contained in the Master File, which consists of a change that more than doubles the Transition Times or reduces it to less than half; and
- g. a material change to the maximum Ramp Rate of the MSG Configuration(s) contained in the Master File, which consists of a change that more than doubles the maximum Ramp Rate or reduces it to less than half.

When transitioning to implement these changes across the midnight hour, for any Real-Time Market run in which the changes specified in this Section 27.8.3 are to take effect within the Time Horizon of any of the Real-Time Market runs, the CAISO will Schedule, Dispatch, or award resources consistent with either the prior or new status and definitions, as appropriate, and required by any Real-Time conditions regardless of the resource's state scheduled or awarded in the immediately preceding Day-Ahead Market. A Scheduling Coordinator may unregister a Generating Unit from its Multi-Stage Generating Resource status subject to the timing requirements for Master File changes, and such changes are not subject to the timing requirements in Section 27.8.3. For the first forty-four (44) days after the effective date of this Section, Scheduling Coordinators may not change any of Multi-Stage Generating Resource attributes listed above in this Section. On the forty-fifth (45th) day following the effective day of this Section, changes to the attributes listed above in this Section may take effect, including the registration of new Multi-Stage Generating Resources, provided Scheduling Coordinators have previously followed the registration process requirements listed in Section 27.8.1. Subsequently, further changes to the attributes listed above in this Section 27.8.3 may not take effect until after the one hundred fifth (105th) day following the effective date of this Section, subject to the procedures described in Section 27.8.1. As of the one hundred-fifth (105th) day following the effective date of this Section, changes to these attributes may only be made every sixty (60) days after the day on which any such changes have taken effect.

**27.9 Non-Generator Resources MWh Constraints**

**THIS TARIFF SECTION WILL BECOME EFFECTIVE ON NOVEMBER 27, 2012.**

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

The CAISO will observe Non-Generator Resources' MWh constraints in the IFM as part of the co-optimization unless the resources are using Regulation Energy Management. The CAISO will observe Non-Generator Resources' MWh constraints in RUC as part of the co-optimization unless the resources are using Regulation Energy Management. The CAISO will observe Non-Generator Resources' MWh constraints in Real-Time Unit Commitment and FMM as part of the co-optimization unless the resources are using Regulation Energy Management. The CAISO will observe Non-Generator Resources' MWh constraints in Real-Time Dispatch, including constraints of resources using Regulatory Energy Management

**27.10 Flexible Ramping Constraint**

The CAISO may enforce a Flexible Ramping Constraint in the RTM. Any flexible Dispatch capacity constrained to be available as a result of the Flexible Ramping Constraint in RTM will come from capacity that is not designated to provide Regulation or Operating Reserves, and will not offset the required procurement of Regulation or Operating Reserves in RTUC. To the extent a resource incurs an opportunity cost for not providing Energy or Ancillary Services in the FMM or RTD interval as a result of a binding Flexible Ramping Constraint, all resources resolving that Flexible Ramping Constraint will be compensated pursuant to Section 11.25. In the FMM or RTD the resources identified as resolving the Flexible Ramping Constraint in the corresponding RTUC run will be the only resources used to resolve the Flexible Ramping Constraint enforced in FMM or RTD. The Flexible Ramping Constraint can be satisfied only by committed online dispatchable Generating Units, Participating Load, and Proxy Demand Response resources with ramping capability for which a Scheduling Coordinator has submitted Economic Bids for Energy for the applicable Trading Hour, and Dynamic System resources as specified below. This constraint cannot be satisfied by System Resources that are not Dynamic System Resources. Dynamic System Resources can become eligible to participate in relieving the Flexible Ramping Constraint if the Scheduling Coordinator scheduling that Resource can demonstrate that it has firm transmission service to the CAISO Balancing Authority Area intertie that allows the resource to deliver additional Energy in Real-Time, consistent with the requirements of Section 1.5 of the Dynamic Scheduling Protocol in Appendix M. This Dynamic

California Independent System Operator Corporation  
Fifth Replacement Electronic Tariff

System Resource must demonstrate that the Dynamic System Resource has acquired sufficient firm transmission to support the total quantity of Energy and Ancillary Services offered in the Real-Time Market by submitting an E-Tag with a transmission profile that reflects the necessary transmission reservation(s) outside the CAISO Balancing Authority Area.

Procurement of Flexible Ramping Constraint capacity from Dynamic System Resources is limited by the available capacity in Real-Time for the applicable interval on the applicable intertie transmission constraint with which the Dynamic System Resource is associated. The quantity of the flexible ramping capacity for each applicable CAISO Market run will be determined by CAISO operators using tools that estimate the: 1) expected level of imbalance variability; 2) uncertainty due to forecast error; and 3) differences between the hourly, fifteen (15) minute average and historical five (5) minute Demand levels. The Flexible Ramping Constraint relaxation parameter is \$60.