

25 Interconnection Of Generating Units And Facilities

25.1 Applicability

This Section 25 and Appendix U (the Standard Large Generator Interconnection Procedures (LGIP)), Appendix Y (the Generator Interconnection Procedures (GIP)), Appendix S (the Small Generator Interconnection Procedures (SGIP)), or Appendix W, as applicable, shall apply to:

- (a) each new Generating Unit that seeks to interconnect to the CAISO Controlled Grid;
- (b) each existing Generating Unit connected to the CAISO Controlled Grid that will be modified with a resulting increase in the total capability of the power plant;
- (c) each existing Generating Unit connected to the CAISO Controlled Grid that will be modified without increasing the total capability of the power plant but has changed the electrical characteristics of the power plant such that its re-energization may violate Applicable Reliability Criteria;
- (d) each existing Generating Unit connected to the CAISO Controlled Grid whose total Generation was previously sold to a Participating TO or on-site customer but whose Generation, or any portion thereof, will now be sold in the wholesale market, subject to Section 25.1.2; and
- (e) each existing Generating Unit that is a Qualifying Facility and that is converting to a Participating Generator without repowering or reconfiguring the existing Generating Unit, subject to Section 25.1.2.

25.1.1 Interconnection Request And Generating Unit Requirements

The owner of a Generating Unit described in Section 25.1 (a), (b), or (c), or its designee, shall be an Interconnection Customer required to submit an Interconnection Request and comply with Appendix U (the LGIP), Appendix Y (the GIP), Appendix S (the SGIP), or Appendix W, as applicable, which applicability shall be based on the maximum rated capacity of the new total capability of the power plant, including the capability of all of multiple energy production devices at a site, consistent with Section 4.10 of the SGIP.

25.1.2 Affidavit Requirement

If the owner of a Generating Unit described in Section 25.1(d), or its designee, represents that the total capability and electrical characteristics of the Generating Unit will be substantially unchanged, then that entity must submit an affidavit to the CAISO and the applicable Participating TO representing that the total capability and electrical characteristics of the Generating Unit will remain substantially unchanged. If there is any change to the total capability and electrical characteristics of the Generating Unit, however, the affidavit shall include supporting information describing any such changes. The CAISO and the applicable Participating TO shall have the right to verify whether or not the total capability or electrical characteristics of the Generating Unit have changed or will change. **The CAISO may engage the services of the applicable Participating TO in the CAISO's conducting such verification activities, in which case such costs shall be borne by the party making the request under Section 25.1.2, and such costs shall be included in any CAISO invoice for verification activities.**

25.1.2.1 If the CAISO and the applicable Participating TO confirm that the electrical characteristics are substantially unchanged, then that request will not be placed into the interconnection queue. However, the owner of the Generating Unit, or its designee, will be required to execute a Standard Large Generator Interconnection Agreement in accordance with Section 11 of Appendix U (the LGIP), a Large Generator Interconnection Agreement in accordance with Section 11 of Appendix Y (the GIP), a Small Generator Interconnection Agreement in accordance with Section 3.3.4, 3.4.5, or 3.5.7 and Section 4.8 of the SGIP, or an interconnection agreement in accordance with Appendix W, as applicable.

25.1.2.2 If the CAISO and the applicable Participating TO cannot confirm that the total capability and electrical characteristics are and will be substantially unchanged, then the owner of the Generating Unit, or its designee, shall be an Interconnection Customer required to submit an Interconnection Request and comply with Appendix U (the LGIP), Appendix Y (the GIP), Appendix S (the SGIP), or Appendix W, as applicable.

25.2 Interconnections To The Distribution System

Any proposed interconnection by the owner of a planned Generating Unit, or its designee, to connect that Generating Unit to a Distribution System of a Participating TO will be processed, as applicable, pursuant to the Wholesale Distribution Access Tariff or CPUC Rule 21, or other Local Regulatory Authority

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

requirements, if applicable, of the Participating TO; provided, however, that the owner of the planned Generating Unit, or its designee, shall be required to mitigate any adverse impact on reliability of the CAISO Controlled Grid consistent with Appendix U (the Standard Large Generator Interconnection Procedures) and Appendix Y (the GIP). In addition, each Participating TO will provide to the CAISO a copy of the system impact study used to determine the impact of a planned Generating Unit on the Distribution System and the CAISO Controlled Grid pursuant to a request to interconnect under the applicable Wholesale Distribution Access Tariff or CPUC Rule 21, or other Local Regulatory Authority requirements, if applicable.

25.3 Maintenance Of Encumbrances

No new Generating Unit shall adversely affect the ability of the applicable Participating TO to honor its Encumbrances existing as of the time an Interconnection Customer submits its Interconnection Request to the CAISO. The applicable Participating TO, in consultation with the CAISO, shall identify any such adverse effect on its Encumbrances in the Interconnection System Impact Study performed under Section 7 of Appendix U (the LGIP), the Phase I Interconnection Study performed under Section 6 of Appendix Y (the GIP), the system impact study performed under Section 3.4 of the SGIP, or the System Impact Study performed under Section 5.1 of Appendix W, as applicable. To the extent the applicable Participating TO determines that the connection of the new Generating Unit will have an adverse effect on Encumbrances, the Interconnection Customer shall mitigate such adverse effect.

25.4 Asynchronous Generating Facilities

Asynchronous Generating Facilities that are the subject of Interconnection Requests in a serial study queue and for which a Large Generator Interconnection Agreement has not been executed or tendered for signature as of July 2, 2010 shall be subject to the Large Generator Interconnection Agreement set forth in Appendix BB. Asynchronous Generating Facilities that are the subject of Interconnection Requests in a Queue Cluster Window and for which a Large Generator Interconnection Agreement has not been executed or tendered for signature as of July 3, 2010 shall be subject to the Large Generator Interconnection Agreement set forth in Appendix CC. Asynchronous Generating Facilities that have been or should have been tendered a Large Generator Interconnection Agreement as of July 3, 2010 shall be subject to the Large Generator Interconnection Agreement set forth in Appendix Z.

26. Transmission Rates And Charges

26.1 Access Charges

All Market Participants withdrawing Energy from the CAISO Controlled Grid shall pay Access Charges in accordance with this Section 26.1 and Appendix F, Schedule 3, except as provided in Section 4.1 of Appendix I (Station Power Protocol). Prior to the TAC Transition Date determined under Section 4 of Schedule 3 of Appendix F, the Access Charge for each Participating TO shall be determined in accordance with the principles set forth in this Section 26.1 and in Section 5 of the TO Tariff. The Access Charge shall comprise two components, which together shall be designed to recover each Participating TO's Transmission Revenue Requirement. The first component shall be the annual authorized revenue requirement associated with the transmission facilities and Entitlements turned over to the Operational Control of the CAISO by a Participating TO approved by FERC. The second component shall be based on the Transmission Revenue Balancing Account (TRBA), which shall be designed to flow through the Participating TO's Transmission Revenue Credits calculated in accordance with Section 5 of the TO Tariff and other credits identified in Sections 6 and 8 of Schedule 3 of Appendix F of the CAISO Tariff.

Commencing on the TAC Transition Date determined under Section 4 of Schedule 3 of Appendix F, the Access Charges shall be paid by any UDC or MSS Operator that is serving Gross Load in a PTO Service Territory, and shall consist, where applicable, of a High Voltage Access Charge, a Transition Charge and a Low Voltage Access Charge. High Voltage Access Charges and Low Voltage Access Charges shall each comprise two components, which together shall be designed to recover each Participating TO's High Voltage Transmission Revenue Requirement and Low Voltage Transmission Revenue Requirement, as applicable. The first component shall be based on the annual authorized Transmission Revenue Requirement associated with the High Voltage Transmission Facilities or Low Voltage Transmission Facilities, as applicable, and Entitlements turned over to the CAISO Operational Control by a Participating TO. The second component shall be the Transmission Revenue Balancing Account (TRBA), which shall be designed to flow through the Participating TO's Transmission Revenue Credits associated with the high voltage or low voltage, as applicable, transmission facilities and Entitlements and calculated in accordance with Section 5 of the TO Tariff and other credits identified in Sections 6, 8 and 13 of Schedule 3 of Appendix F of the CAISO Tariff. Each Participating TO shall provide in its TO Tariff filing with FERC

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

an appendix to such filing that states the Participating TO's High Voltage Transmission Revenue Requirement, its Low Voltage Transmission Revenue Requirement (if applicable) and its Gross Load used in developing the rate. The allocation of each Participating TO's Transmission Revenue Requirement between the High Voltage Transmission Revenue Requirement and the Low Voltage Transmission Revenue Requirement shall be undertaken in accordance with Section 11 of Schedule 3 of Appendix F. To the extent necessary, each Participating TO shall make conforming changes to its TO Tariff.

The applicable High Voltage Access Charge and the Transition Charge shall be paid to the CAISO by each UDC and MSS Operator based on its Gross Load connected to a High Voltage Transmission Facility in a PTO Service Territory, either directly or through intervening distribution facilities, but not through a Low Voltage Transmission Facility. The applicable High Voltage Access Charge, the Transition Charge and the Low Voltage Access Charge for the applicable Participating TO shall be paid by each UDC and MSS Operator based on its Gross Load in the PTO Service Territory. The applicable High Voltage Access Charge and Transition Charge shall be assessed by the CAISO as a charge for transmission service under this CAISO Tariff, shall be determined in accordance with Schedule 3 of Appendix F, and shall include all applicable components of the High Voltage Access Charge and Transition Charge set forth therein.

The Low Voltage Access Charge for each Participating TO is set forth in that Participating TO's TO Tariff. Each Participating TO shall charge for and collect the Low Voltage Access Charge, as provided in its TO Tariff, except that the CAISO shall charge for and collect the Low Voltage Access Charge of each Non-Load-Serving Participating TO that qualifies under this Section 26.1 and Appendix F, Schedule 3, Section 13, unless otherwise agreed by the affected Participating TOs. If a Participating TO that is also a UDC, MSS Operator, or Scheduling Coordinator serving End-Use Customers is using the Low Voltage Transmission Facilities of another Participating TO, such Participating TO shall also be assessed the Low Voltage Access Charge of the other Participating TO by such other Participating TO, or by the CAISO pursuant to Section 13 of Schedule 3 of Appendix F. The CAISO shall provide to the applicable Participating TO a statement of the amount of Energy delivered to each UDC and MSS Operator serving Gross Load that utilizes the Low Voltage Transmission Facilities of that Participating TO on a monthly

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

basis. If a UDC or MSS Operator that is serving Gross Load in a PTO Service Territory has Existing Rights to use another Participating TO's Low Voltage Transmission Facilities, such entity shall not be charged the Low Voltage Access Charge for delivery of Energy to Gross Load for deliveries using the Existing Rights. Each Participating TO shall recover Standby Transmission Revenues directly from the Standby Service Customers of that Participating TO through its applicable retail rates.

Where a Non-Load-Serving Participating TO has Low Voltage Transmission Facilities, the CAISO shall assess the Low Voltage Access Charge for each project of that Non-Load-Serving Participating TO to the UDC or MSS Operator of each Participating TO that is directly connected to one or more Low Voltage Transmission Facilities of that project, unless otherwise agreed by the affected Participating TOs. The Non-Load-Serving Participating TO shall calculate separately its Low Voltage Transmission Revenue Requirement for each individual transmission project that includes one or more Low Voltage Transmission Facilities. If the Non-Load-Serving Participating TO's Low Voltage Transmission Facilities projects are directly connected to the facilities of the same Participating TO(s), the Low Voltage Access Charge shall be calculated for the group of Low Voltage Transmission Facilities. A separate Low Voltage Access Charge shall apply based on the Low Voltage Transmission Revenue Requirement for the relevant project or projects of such Non-Load-Serving Participating TO divided by the Gross Load of all UDCs or MSS Operators of a Participating TO that are directly connected to the relevant Low Voltage Transmission Facility or group of facilities.

A Non-Load-Serving Participating TO must include any over- or under-recovery of its annual Low Voltage Transmission Revenue Requirement for the relevant project or group of projects in its low voltage TRBA adjustment for its Low Voltage Access Charge for the relevant project or group of projects pursuant to Section 13.1 of Schedule 3 of Appendix F.

A Participating TO that is a UDC or MSS Operator to whom the Low Voltage Access Charge of a Non-Load-Serving Participating TO is assessed shall include these billed Low Voltage Access Charge amounts in its low voltage TRBA adjustment for its Low Voltage Access Charge, together with all other applicable low voltage TRBA adjustments.

26.1.1 Publicly Owned Electric Utilities Access Charge

Local Publicly Owned Electric Utilities whose transmission facilities are under CAISO Operational Control shall file with the FERC their proposed High Voltage Transmission Revenue Requirements, and any proposed changes thereto, under procedures determined by the FERC to be applicable to such filings and shall give notice to the CAISO and to all Scheduling Coordinators of any such filing. A prospective New Participating TO that is a Local Publicly Owned Electric Utility shall submit its first proposed High Voltage Transmission Revenue Requirement to the FERC and the CAISO at the time the Local Publicly Owned Electric Utility submits its application to become a New Participating TO in accordance with the Transmission Control Agreement. Federal power marketing agencies whose transmission facilities are under CAISO Operational Control shall develop their High Voltage Transmission Revenue Requirement pursuant to applicable federal laws and regulations.

The procedures for public participation in a federal power marketing agency's ratemaking process are posted on the federal power marketing agency's website. Each federal power marketing agency shall also post on its website the Federal Register notices and FERC orders for rate making processes that impact the federal power marketing agency's High Voltage Transmission Revenue Requirement. At the time the federal power marketing agency submits its application to become a New Participating TO in accordance with the Transmission Control Agreement, it shall submit its first proposed High Voltage Transmission Revenue Requirement to the FERC and the CAISO.

26.1.2 High Voltage Access Charge And Transition Charge Settlement

UDCs and MSS Operators serving Gross Load in a PTO Service Territory shall be charged on a monthly basis, in arrears, the applicable High Voltage Access Charge and Transition Charge. The High Voltage Access Charge and Transition Charge for a billing period is calculated by the CAISO as the product of the applicable High Voltage Access Charge or Transition Charge, as applicable, and Gross Load connected to the facilities of the UDC and MSS Operator in the PTO Service Territory. The High Voltage Access Charge and Transition Charge are determined in accordance with Schedule 3 of Appendix F. These rates may be adjusted from time to time in accordance with Schedule 3 of Appendix F. During the 10-year TAC Transition Period described in Section 4 of Schedule 3 of Appendix F, a UDC or MSS Operator that is also a Participating TO shall pay, or receive payment of, if applicable, the difference between (i)

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

the High Voltage Access Charge and the Transition Charge applicable to its transactions as a UDC or MSS Operator; and (ii) the disbursement of High Voltage Access Charge revenues to which it is entitled pursuant to Section 26.1.3.

26.1.3 Disbursement Of HVAC And Transition Charge Revenues

The CAISO shall collect and pay, on a monthly basis, to Participating TOs all High Voltage Access Charge and Transition Charge revenues at the same time as other CAISO charges and payments are settled. High Voltage Access Charge revenues received with respect to the High Voltage Access Charge and the Transition Charge shall be distributed to Participating TOs in accordance with Appendix F, Schedule 3, Section 10.

26.1.4 Wheeling

Any Scheduling Coordinator or other such entity submitting a Bid or Self-Schedule for a Wheeling transaction shall pay to the CAISO the product of (i) the applicable Wheeling Access Charge, and (ii) the total hourly Schedules and awards of Wheeling in kilowatt-hours for each month at each Scheduling Point associated with that transaction, except as provided in Section 4.1 of Appendix I (Station Power Protocol). Schedules and awards that include Wheeling transactions shall be subject to any charges resulting from the CAISO Markets in accordance with Section 27.

26.1.4.1 Wheeling Access Charge

The Wheeling Access Charge shall be determined by the TAC Area and transmission ownership or Entitlement, less all Encumbrances, associated with the Scheduling Point at which the Energy exits the CAISO Controlled Grid. The Wheeling Access Charge for Scheduling Points contained within a single TAC Area, that are not joint facilities, shall be equal to the High Voltage Access Charge for the applicable TAC Area in accordance with Schedule 3 of Appendix F plus the applicable Low Voltage Access Charge if the Scheduling Point is on a Low Voltage Transmission Facility. Wheeling Access Charges shall not apply for Wheeling under a bundled non-economy Energy coordination agreement of a Participating TO executed prior to July 9, 1996.

26.1.4.2 Wheeling Over Joint Facilities

To the extent that more than one Participating TO owns or has Entitlement to transmission capacity, less all Encumbrances, exiting the CAISO Controlled Grid at a Scheduling Point, the Scheduling Coordinator

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

shall pay the CAISO each month a rate for Wheeling at that Scheduling Point which reflects an average of the Wheeling Access Charge applicable to those Participating TOs, weighted by the relative share of such ownership or Entitlement to transmission capacity, less all Encumbrances, at such Scheduling Point. If the Scheduling Point is located at High Voltage Transmission Facilities, the Wheeling Access Charge will consist of a High Voltage Wheeling Access Charge component. Additionally, if the Scheduling Point is located at Low Voltage Transmission Facilities, the applicable Low Voltage Wheeling Access Charge component will be added to the Wheeling Access Charge. The methodology for developing the weighted average rate for Wheeling at each Scheduling Point is set forth in Appendix F, Schedule 3, Section 14.4.

26.1.4.3 Disbursement of Wheeling Revenues

The CAISO shall collect and pay to Participating TOs and other entities as provided in Section 24.10.3 all Wheeling revenues at the same time as other CAISO charges and payments are settled. For Wheeling revenues associated with CRRs allocated to Load Serving Entities outside the CAISO Balancing Authority Area, the CAISO shall pay to the Participating TOs and other entities as provided in Section 24.10.3 any excess prepayment amounts within thirty (30) days of the end of the term of the CRR Allocation. The CAISO shall provide to the applicable Participating TO and other entities as provided in Section 24.10.3 a statement of the aggregate amount of Energy delivered to each Scheduling Coordinator using such Participating TO's Scheduling Point to allow for calculation of Wheeling revenue and auditing of disbursements. Wheeling revenues shall be disbursed by the CAISO based on the following:

26.1.4.3.1 Scheduling Point with All Participating TOs in the Same TAC Area

With respect to revenues received for the payment of High Voltage Wheeling Access Charges for Wheeling to a Scheduling Point at which all of the facilities and Entitlements, less all Encumbrances, are owned by Participating TOs in the same TAC Area, Wheeling revenues shall be disbursed to each such Participating TO based on the ratio of each Participating TO's High Voltage Transmission Revenue Requirement to the sum of all such Participating TO's High Voltage Transmission Revenue Requirements. If the Scheduling Point is located at a Low Voltage Transmission Facility, revenues received with respect to Low Voltage Wheeling Access Charges for Wheeling to that Scheduling Point shall be disbursed to the Participating TOs that own facilities and Entitlements making up the Scheduling Point in proportion to their Low Voltage Transmission Revenue Requirements. Additionally, if a

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Participating TO has a transmission upgrade or addition that was funded by a Project Sponsor, the Wheeling revenue allocated to such Participating TO shall be disbursed as provided in Section 24.10.3.

26.1.4.3.2 Scheduling Point without All Participating TOs in the Same TAC Area

With respect to revenues received for the payment of Wheeling Access Charges for Wheeling to a Scheduling Point at which the facilities and Entitlements, less all Encumbrances, are owned by Participating TOs in different TAC Areas, Wheeling revenues shall be disbursed to such Participating TOs as follows. First, the revenues shall be allocated between such TAC Areas in proportion to the ownership and Entitlements of transmission capacity, less all Encumbrances, at the Scheduling Point of the Participating TOs in each such TAC Area. Second, the revenues thus allocated to each TAC Area shall be disbursed among the Participating TOs in the TAC Area in accordance with Section 26.1.4.3.1.

26.1.4.4 Information Required from Scheduling Coordinators

Scheduling Coordinators for Wheeling Out or Wheeling Through transactions to a Bulk Supply Point, or other point of interconnection between the CAISO Controlled Grid and the transmission system of a Non-Participating TO, that are located within the CAISO Balancing Authority Area, shall provide the CAISO, by eight (8) Business Days after the Trading Day (T+8B), details of such transactions (other than transactions submitted as Self-Schedules pursuant to Existing Contracts) sorted by Bulk Supply Point or point of interconnection for each Settlement Period (including kWh for each transaction). The CAISO shall use such information, which may be subject to review by the CAISO, to settle Wheeling Access Charges and payments. The CAISO shall publish a list of the Bulk Supply Points or interconnection points to which this Section 26.1.4.4 applies together with details of the electronic form and procedure to be used by Scheduling Coordinators to submit the required information on the CAISO Website.

26.1.5 Unbundled Retail Transmission Rates

The Access Charge for unbundled retail transmission service provided to End-Users by a FERC-jurisdictional electric utility Participating TO shall be determined by the FERC and submitted to the CAISO for information only. For a Local Publicly Owned Electric Utility, retail transmission service rates shall be determined by the Local Regulatory Authority and submitted to the CAISO for information only.

26.2 Tracking Account

If the Access Charge rate methodology implemented pursuant to Section 26.1 results in Access Charge rates for any Participating TO which are different from those in effect prior to the CAISO Operations Date, an amount equal to the difference between the new rates and the prior rates for the remainder of the period, if any, during which a cost recovery plan established pursuant to Section 368 of the California Public Utilities Code (as added by AB 1890) is in effect for such Participating TO shall be recorded in a tracking account. The balance of that tracking account will be recovered from customers and paid to the appropriate Participating TO after termination of the cost recovery plan set forth in Section 368 of California Public Utilities Code (as added by AB 1890). The recovery and payments shall be based on an amortization period not exceeding three years in the case of electric corporations regulated by the CPUC or five years for Local Publicly Owned Electric Utilities.

26.3 Addition Of New Facilities After CAISO Implementation

The costs of transmission facilities placed in service after the CAISO Operations Date shall be recovered consistent with the cost recovery determinations made pursuant to Appendix F, Schedule 3 and Section 24.10.3.

26.4 Effect On Tax-Exempt Status

Nothing in this Section 26 shall compel any Participating TO to violate any restrictions applicable to facilities financed with tax-exempt bonds or contractual restrictions and covenants regarding the use of transmission facilities.

26.5 Transition Mechanism

During the ten-year TAC Transition Period described in Section 4 of Schedule 3 of Appendix F, the Original Participating TOs collectively shall pay to the CAISO each year an amount equal to, annually, for all New Participating TOs, the amount, if any, by which the New Participating TO's cost of Existing High Voltage Facilities associated with Gross Loads in the PTO Service Territory of the New Participating TO is increased by the implementation of the High Voltage Access Charge described in Schedule 3 of Appendix F. Responsibility for such payments shall be allocated to Original Participating TOs in accordance with Schedule 3 of Appendix F. Amounts payable by Original Participating TOs under this section shall be recoverable as part of the Transition Charge calculated in accordance with Schedule 3 of Appendix F. Amounts received by the CAISO under this section shall be disbursed to New Participating TOs with Existing High Voltage Facilities based on the ratio of each New Participating TO's net increase in costs in the categories described in the first sentence of this section, to the sum of the net increases in such costs for all New Participating TOs with Existing High Voltage Facilities. At the conclusion of the ten-year TAC Transition Period, the obligations of this Section 26.5 shall cease to apply.

26.6 Location Constrained Resource Interconnection Facilities

The costs of an LCRIF shall be includable in a Participating TO's High Voltage Transmission Revenue Requirement. Any Participating TO that owns an LCRIF shall set forth in its TO Tariff a charge payable by LCRIGs connected to that facility. The charge shall require each LCRIG to pay on a going forward basis its pro rata share of the Transmission Revenue Requirement associated with the LCRIF, which shall be calculated based on the maximum capacity of the LCRIG relative to the capacity of the LCRIF. Each Participating TO shall credit its High Voltage TRR with revenues received from LCRIGs with respect to such charges either by recording such revenues in its TRBA or through another mechanism approved by FERC.

26.6.1 LCRIFs That Become Network Facilities

If the construction of a new transmission facility or upgrade causes an LCRIF to become a network facility, then, effective on the in-service date of such new transmission facility or upgrade, the LCRIGs connected to the LCRIF shall not be required to pay charges described in Section 26.6. The LCRIGs shall remain responsible for charges due prior to that date.

27 CAISO Markets And Processes

In the Day-Ahead and Real-Time time frames the CAISO operates a series of procedures and markets that together comprise the CAISO Markets Processes. In the Day-Ahead time frame, the CAISO conducts the Market Power Mitigation (MPM) process, the Integrated Forward Market (IFM) and the Residual Unit Commitment (RUC) process. In the Real-Time time frame, the CAISO conducts the MPM process, the Hour-Ahead Scheduling Process (HASP), the Short-Term Unit Commitment (STUC), the Real-Time Unit Commitment (RTUC) and the five-minute Real-Time Dispatch (RTD). The CAISO Markets Processes utilize transmission and Security Constrained Unit Commitment and dispatch algorithms in conjunction with a Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6 to optimally commit, schedule and Dispatch resources and determine marginal prices for Energy, Ancillary Services and RUC Capacity. Congestion Revenue Rights are available and entitle holders of such instruments to a stream of hourly payments or charges associated with revenue the CAISO collects or pays from the Marginal Cost of Congestion component of hourly Day-Ahead LMPs. Through the operation of the CAISO Markets Processes the CAISO develops Day-Ahead Schedules, Day-Ahead AS Awards and RUC Schedules, HASP Advisory Schedules, HASP Intertie Schedules and AS Awards, Real-Time AS Awards and Dispatch Instructions to ensure that sufficient supply resources are available in Real-Time to balance Supply and Demand and operate in accordance with Reliability Criteria.

27.1 LMPs And Ancillary Services Marginal Prices

The CAISO Markets are based on: 1) Locational Marginal Prices as provided below in Section 27.1.1 and further provided in Appendix C; and 2) Ancillary Services Marginal Prices as provided below in Section 27.1.2.

27.1.1 Locational Marginal Prices For Energy

As further described in Appendix C, the LMP for Energy at any PNode is the marginal cost of serving the next increment of Demand at that PNode consistent with existing Transmission Constraints and the performance characteristics of resources, also considering, among other things, Energy Bid Curves. The LMP at any given PNode is comprised of three cost components: the System Marginal Energy Cost (SMEC); Marginal Cost of Losses (MCL); and Marginal Cost of Congestion (MCC). The IFM calculates LMPs for each Trading Hour of the next Trading Day. The HASP, which is conducted hourly for

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

scheduling Non-Dynamic System Resources and exports for the subsequent Trading Hour, calculates fifteen-minute LMPs (HASP Intertie LMPs) for that Trading Hour. The simple average of the four fifteen-minute LMPs for the applicable Trading Hour computed at each Scheduling Point produces hourly LMPs for HASP Settlement of Energy at that Scheduling Point. The Real-Time Dispatch runs every five (5) minutes throughout each Trading Hour and calculates five-minute LMPs for the next Dispatch Interval. The CAISO uses the Resource-Specific Settlement Interval LMPs for Settlements of the Real-Time Market. In the event that a Pricing Node becomes electrically disconnected from the market model during a CAISO Market run, the LMP, including the SMEC, MCC and MCL, at the closest electrically connected Pricing Node will be used as the LMP at the affected location.

27.1.1.1 System Marginal Energy Cost

The System Marginal Energy Cost (SMEC) component of the LMP reflects the marginal cost of providing Energy from a designated reference Location. For this designated reference Location the CAISO will utilize a distributed Reference Bus whose constituent PNodes are weighted in proportions referred to as Reference Bus distribution factors. The SMEC shall be the same throughout the system.

27.1.1.2 Marginal Cost of Losses

For all PNodes and Aggregated PNodes in the CAISO Balancing Authority Area, including Scheduling Points, the use of the Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6 in the DAM and the RTM processes incorporates Transmission Losses. At each PNode or Aggregated PNode, the Marginal Cost of Losses is the System Marginal Energy Cost multiplied by the Marginal Loss factor at that PNode or Aggregated PNode. The Marginal Cost of Losses at a Location (PNode or APNode) may be positive or negative depending on whether an increase in Demand at that Location marginally increases or decreases the cost of Transmission Losses, using the distributed Reference Bus to balance it. The Marginal Loss factors are determined through a process that calculates the sensitivities of Transmission Losses with respect to changes in injection at each Location in the FNM. For CAISO Controlled Grid facilities outside the CAISO Balancing Authority Area, the CAISO shall assess the cost of Transmission Losses to Scheduling Coordinators using each such facility based on the quantity of losses agreed upon with the neighboring Balancing Authority multiplied by the LMP at the PNode of the Transmission

Interface with the neighboring Balancing Authority Area. The MCLs calculated for Locations within the CAISO Balancing Authority Area shall not reflect the cost of Transmission Losses on those facilities.

27.1.1.3 Marginal Cost of Congestion

The Marginal Cost of Congestion at a PNode reflects a linear combination of the Shadow Prices of the binding Transmission Constraints in the network, multiplied by the corresponding Power Transfer Distribution Factor (PTDF). The Marginal Cost of Congestion may be positive or negative depending on whether a power injection (i.e., incremental Load increase) at that Location marginally increases or decreases Congestion.

27.1.2 Ancillary Service Prices

27.1.2.1 Ancillary Service Marginal Prices – Sufficient Supply

As provided in Section 8.3, Ancillary Services are procured and awarded through the IFM, HASP and the Real-Time Market. The IFM calculates hourly Day-Ahead Ancillary Service Awards and establishes Ancillary Service Marginal Prices (ASMPs) for the accepted Regulation Up, Regulation Down, Spinning Reserve and Non-Spinning Reserve Bids. The IFM co-optimizes Energy and Ancillary Services subject to resource, network and regional constraints. In the HASP, the CAISO procures Ancillary Services from Non-Dynamic System Resources for the next Trading Hour as described in Section 33.7. The CAISO calculates the HASP settlement Ancillary Services price as described herein and further described in Section 33.8. In the Real-Time Market, the RTUC process that is performed every fifteen (15) minutes establishes fifteen (15) minute Ancillary Service Schedules, Awards, and prices for the upcoming quarter of the given Trading Hour. ASMPs are determined by first calculating Shadow Prices of Ancillary Services for each Ancillary Service type and the applicable Ancillary Services Regions. The Ancillary Services Shadow Prices are produced as a result of the co-optimization of Energy and Ancillary Services through the IFM, HASP, and the Real-Time Market, subject to resource, network, and requirement constraints. The Ancillary Services Shadow Prices represent the marginal cost of the relevant binding regional constraints at the optimal solution, or the reduction of the combined Energy and Ancillary Service procurement cost associated with a marginal relaxation of that constraint. If the constraint for an Ancillary Services Region is not binding, the corresponding Ancillary Services Shadow Price in the Ancillary Services Region is zero (0). During periods in which supply is sufficient, the ASMP for a particular

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Ancillary Service type and Ancillary Services Region is then the sum of the Ancillary Services Shadow Prices for the specific type of Ancillary Service and all the other types of Ancillary Services for which the subject Ancillary Service can substitute, as described in Section 8.2.3.5, for the given Ancillary Service Region and all the other Ancillary Service Regions that include that given Ancillary Service Region. During periods in which supply is insufficient, the ASMP for a particular Ancillary Service type and Ancillary Services Region will reflect the Scarcity Reserve Demand Curve Values set forth in Section 27.1.2.3.

27.1.2.2 Opportunity Cost in ASMP

The Ancillary Services Shadow Price, which, as described above, is a result of the Energy and Ancillary Service co-optimization, includes the forgone opportunity cost of the marginal resource, if any, for not providing Energy or other types of Ancillary Services the marginal resource is capable of providing in the relevant market. The ASMPs determined by the IFM or RTUC optimization process for each resource whose Ancillary Service Bid is accepted will be no lower than the sum of (i) the Ancillary Service capacity Bid price submitted for that resource, and (ii) the foregone opportunity cost of Energy in the IFM or RTUC for that resource. The foregone opportunity cost of Energy for this purpose is measured as the positive difference between the IFM or RTUC LMP at the resource's Pricing Node and the resource's Energy Bid price. If the resource's Energy Bid price is higher than the LMP, the opportunity cost measured for this calculation is \$0. If a resource has submitted an Ancillary Service Bid but no Energy Bid and is under an obligation to offer Energy in the Day-Ahead Market (e.g. a non-hydro Resource Adequacy Resource), its Default Energy Bid will be used, and its opportunity cost will be calculated accordingly. If a resource has submitted an Ancillary Service Bid but no Energy Bid and is not under an obligation to offer Energy in the Day-Ahead Market, its Energy opportunity cost measured for this calculation is \$0 since it cannot be dispatched for Energy. For Non-Dynamic System Resources that receive Ancillary Services Awards in HASP, the opportunity cost measured for this purpose is \$0 because, as provided in Section 33.7, the CAISO cannot Schedule Energy in HASP from the Energy Bid under the same Resource ID as the submitted Ancillary Service Bid.

27.1.2.3 Ancillary Services Pricing – Insufficient Supply

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

The CAISO will develop Scarcity Reserve Demand Curves as further described in an applicable Business Practice Manual that will apply to both the Day-Ahead Market and the Real-Time Market during periods in which supply is insufficient to meet the minimum procurement requirements for Regulation Down, Non-Spinning Reserve, Spinning Reserve and Regulation Up as required by Section 8.3. During the first three (3) years in which the CAISO's Scarcity Reserve Demand Curves are effective, the CAISO shall conduct an annual review of the performance of the Scarcity Reserve Demand Curves and assess whether changes are necessary, with the exception that the ISO will not conduct this assessment in any year in which the Scarcity Reserve Demand Curves are not triggered. Thereafter, the CAISO shall review the performance of the Scarcity Reserve Demand Curves and assess whether changes are necessary every three (3) years or more frequently, if the CAISO determines more frequent reviews are appropriate. When supply is insufficient to meet any of the minimum procurement requirements for Regulation Down, Non-Spinning Reserve, Spinning Reserve and Regulation Up, the Scarcity Reserve Demand Curve Values for the affected Ancillary Services, as set forth in this Section 27.1.2.3 and as reflected in the in the Scarcity Demand Curve Value table below, shall apply to determine the Shadow Prices of the affected Ancillary Services. ASMPs for an Ancillary Service type will not sum these Shadow Prices across Ancillary Service Regions, if there is insufficient supply for the Ancillary Service type in both the Expanded System Region and an Ancillary Service Sub-Region.

Reserve	Scarcity Demand Curve Value (\$/MWh)					
	Percent of Energy Max Bid Price		Max Energy Bid Price = \$750/MWh		Max Energy Bid Price = \$1000/MWh	
	Expanded System Region	System Region and Sub- Region	Expanded System Region	System Region and Sub- Region	Expanded System Region	System Region and Sub- Region

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Regulation Up	20%	20%	\$150	\$150	\$200	\$200
Spinning	10%	10%	\$75	\$75	\$100	\$100
Non-Spinning						
Shortage > 210 MW	70%	70%	\$525	\$525	\$700	\$700
Shortage > 70 & ≤ 210 MW	60%	60%	\$450	\$450	\$600	\$600
Shortage ≤ 70 MW	50%	50%	\$375	\$375	\$500	\$500
Upward Sum	100%	100%	\$750	\$750	\$1000	\$1000
Regulation Down						
Shortage > 84 MW	70%	70%	\$525	\$525	\$700	\$700
Shortage > 32 & ≤ 84 MW	60%	60%	\$450	\$450	\$600	\$600
Shortage ≤ 32 MW	50%	50%	\$375	\$375	\$500	\$500

27.1.2.3.1 Regulation Down Pricing – Insufficient Supply

When the shortage of supply to meet the Regulation Down requirement in the Expanded System Region or in an Ancillary Service Sub-Region is less than or equal to thirty-two (32) MW, the Scarcity Reserve Demand Curve Value for Regulation Down shall be fifty (50) percent of the maximum Energy Bid price permitted under Section 39.6.1.1. When the shortage of supply to meet the Regulation Down requirement in the Expanded System Region is less than or equal to eighty-four (84) MW but greater than thirty-two (32) MW, the Scarcity Reserve Demand Curve Value for Regulation Down shall be sixty (60) percent of the maximum Energy Bid price permitted under Section 39.6.1.1. When the shortage of supply

to meet the Regulation Down requirement in the Expanded System Region is greater than eighty-four (84) MW, the Scarcity Reserve Demand Curve Value for Regulation Down shall be seventy (70) percent of the maximum Energy Bid price permitted under Section 39.6.1.1.

27.1.2.3.2 Spinning Reserve Pricing – Insufficient Supply

When the shortage of supply to meet the Non-Spinning Reserve requirement in the Expanded System Region or in an Ancillary Service Sub-Region is less than or equal to seventy (70) MW, the Scarcity Reserve Demand Curve Value for Non-Spinning Reserve shall be fifty (50) percent of the maximum Energy Bid price permitted under Section 39.6.1.1. When the shortage of supply to meet the Non-Spinning Reserve requirement in the Expanded System Region is less than or equal to two-hundred ten (210) MW but greater than seventy (70) MW, the Scarcity Reserve Demand Curve Value for Non-Spinning Reserve shall be sixty (60) percent of the maximum Energy Bid price permitted under Section 39.6.1.1. When the shortage of supply to meet the Non-Spinning Reserve requirement in the Expanded System Region is greater than two-hundred ten (210) MW, the Scarcity Reserve Demand Curve Value for Non-Spinning Reserve shall be seventy (70) percent of the maximum Energy Bid price permitted under Section 39.6.1.1.

27.1.2.3.2 Spinning Reserve Pricing – Insufficient Supply

The Scarcity Reserve Demand Curve Value for Spinning Reserve in the Expanded System Region or in an Ancillary Service Sub-Region shall be ten (10) percent of the maximum Energy Bid price permitted under Section 39.6.1.1.

27.1.2.3.3 Regulation Up Pricing – Insufficient Supply

The Scarcity Reserve Demand Curve Value for Regulation Up in the Expanded System Region or in an Ancillary Service Sub-Region shall be twenty (20) percent of the maximum Energy Bid price permitted under Section 39.6.1.1.

27.1.2.3 Opportunity Cost in LMPs for Energy

In the event that there is insufficient supply to meet an Ancillary Services procurement requirement in a particular Ancillary Service Region or Sub-Region, the Ancillary Services Shadow Prices will rise automatically to the Scarcity Reserve Demand Curve Values in that Ancillary Service Region or Sub-

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Region. LMPs for Energy will reflect the forgone opportunity cost of the marginal resource, if any, for not providing the scarce Ancillary Services consistent with the CAISO's co-optimization design.

27.2 Load Aggregation Points (LAP)

The CAISO shall create Load Aggregation Points and shall maintain Default LAPs at which all Demand shall Bid and be settled, except as provided in Sections 27.2.1 and 30.5.3.2.

27.2.1 Metered Subsystems

The CAISO shall define specific MSS LAPs for each MSS. The MSS LAP shall be made up of the PNodes within the MSS that have Load served off of those Nodes. The MSS LAPs have unique Load Distribution Factors that reflect the distribution of the MSS Demand to the network Nodes within the MSS. These MSS LAPs are separate from the Default LAPs, and the Load Distribution Factors of the Default LAP do not reflect any MSS Load. As further provided in Sections 11.2.3 and 11.5, MSS Demand is settled either at the price at the Default LAP for MSS Operators that have selected gross Settlement or at the price at the applicable MSS LAP for MSS Operators that have selected net Settlement.

27.2.2 Determination Of LAP Prices

27.2.2.1 IFM LAP Prices

The IFM LAP Price for a given Trading Hour is the weighted average of the individual IFM LMPs at the PNodes within the LAP, with the weights equal to the nodal proportions of Demand associated with that LAP that is scheduled by the IFM, excluding Demand specified in Sections 27.2.1 and 30.5.3.2.

27.2.2.2 Real-Time Market LAP Prices

The Hourly Real-Time LAP Price is computed as described in Section 11.5.2.2. The weights used for calculating the Hourly Real-Time LAP Price at the time the RTM runs will not exclude the Demand specified in Sections 27.2.1 and 30.5.3.2. The weights used for calculating Hourly Real-Time LAP Price used for Settlements will be calculated based on Meter Data and will appropriately exclude the Demand specified in Sections 27.2.1 and 30.5.3.2. Hourly Real-Time LAP Price are further adjusted for Settlements purposes as described in Section 11.5.2.2.

27.3 Trading Hubs

The CAISO shall create and maintain Trading Hubs, including Existing Zone Generation Trading Hubs, to facilitate bilateral Energy transactions in the CAISO Balancing Authority Area. Each Trading Hub will be

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

based on a pre-defined set of PNodes. The CAISO shall calculate Trading Hub prices for each Settlement Period or Settlement Interval based on an average of the LMPs at the PNodes that constitute the Trading Hub. There will be three Existing Zone Generation Trading Hubs, which correspond geographically to the three Existing Zones. Each Existing Zone Generation Trading Hub will be comprised of an aggregation of PNodes for Generating Units within the corresponding Existing Zone, whose associated LMPs will be used to establish an Existing Zone Generation Trading Hub price representing the weighted-average price paid to Generating Units in that Existing Zone. The weights applied to the constituent nodal LMPs in each Existing Zone will be determined annually and separately for each season and on-peak and off-peak period based on the ratio of the prior year's total output of Energy at that PNode to the total Generation output in that Existing Zone, for the corresponding season and on-peak or off-peak period. The specification of seasons will be identical to the seasons used in the annual CRR Allocation, and the annual calculation of Existing Zone Generation Trading Hub weights will be performed in a timely manner to be coordinated with the annual CRR Allocation and CRR Auction processes.

27.4 Optimization In The CAISO Markets Processes

The CAISO runs the DAM, HASP and RTM and their component CAISO Markets Processes utilizing a set of integrated optimization programs, including SCUC and SCED.

27.4.1 Security Constrained Unit Commitment

The CAISO uses SCUC to run the MPM process associated with the DAM, the HASP, and the RTM. SCUC is conducted over multiple varying intervals to commit and schedule resources as follows: (1) in the Day-Ahead time frame, to meet Demand reflected in Bids submitted in the Day-Ahead Market and considered in the MPM process and IFM, and to procure AS in the IFM; (2) to meet the CAISO Forecast of CAISO Demand in the RUC, HASP, STUC and RTUC , and in the MPM process utilized in the HASP and RTM; and (3) to procure any incremental AS in the HASP and RTM. In the Day-Ahead MPM, IFM and RUC processes, the SCUC commits resources over the twenty-four (24) hourly intervals of the next Trading Day. In the RTUC, which runs every fifteen (15) minutes and commits resources for the RTM, the SCUC optimizes over a number of 15-minute intervals corresponding to the Trading Hours for which the Real-Time Markets have closed. The Trading Hours for which the Real-Time Markets have closed

consist of (a) the Trading Hour in which the applicable run is conducted and (b) all the fifteen-minute intervals of the entire subsequent Trading Hour. In the HASP, which is a special run of the RTUC that runs once per hour, the SCUC schedules Non-Dynamic System Resources and exports for the applicable subsequent Trading Hour. In the STUC, which runs once an hour, the SCUC commits resources over the last fifteen (15) minutes of the imminent Trading Hour and the entire next four Trading Hours. The CAISO will commit Extremely Long Start Resources, for which commitment in the DAM does not provide sufficient time to Start-Up and be available to supply Energy during the next Trading Day as provided in Section 31.7.

27.4.1.1 Timing of Unit Commitment Instructions

For the applicable market intervals of any given CAISO Markets Process, the associated SCUC optimization will typically commit resources having different Start-Up Times, not all of which need to be started up immediately upon completion of that CAISO Markets Process. The CAISO may defer issuing a Start-Up Instruction to a resource that can be started at a later time and still be available to supply Energy at the time the CAISO Markets Process indicated it would be needed. The CAISO shall re-evaluate the need to commit such resources in a subsequent CAISO Markets Process based on the most recent forecasts and other information about system conditions.

27.4.2 Security Constrained Economic Dispatch

SCED is the optimization engine used to run the RTD to determine the optimal five-minute Dispatch Instructions throughout the Trading Hour consistent with resource constraints and Transmission Constraints within the CAISO Balancing Authority Area. In any given hour, the Real-Time Economic Dispatch of the Real-Time Market runs every five (5) minutes during which the SCED produces binding Dispatch Instructions for the immediately subsequent five-minute interval. For the applicable five-minute period, through its SCED, the CAISO produces LMPs at each PNode that are used for Settlements as described in Section 11.5.

27.4.3 CAISO Markets Scheduling And Pricing Parameters

The SCUC and SCED optimization software for the CAISO Markets utilize a set of configurable scheduling and pricing parameters to enable the software to reach a feasible solution and set appropriate prices in instances where Effective Economic Bids are not sufficient to allow a feasible solution. The

scheduling parameters specify the criteria for the software to adjust Non-priced Quantities when such adjustment is necessary to reach a feasible solution. The scheduling parameters are configured so that the SCUC and SCED software will utilize Effective Economic Bids as far as possible to reach a feasible solution, and will skip Ineffective Economic Bids and perform adjustments to Non-priced Quantities pursuant to the scheduling priorities for Self-Schedules specified in Sections 31.4 and 34.10. The scheduling parameters utilized for relaxation of internal Transmission Constraints are specified in Section 27.4.3.1. The pricing parameters specify the criteria for establishing market prices in instances where one or more Non-priced Quantities are adjusted by the Market Clearing software. The pricing parameters are specified in Sections 27.1.2.3, 27.4.3.2, 27.4.3.3 and 27.4.3.4. The complete set of scheduling and pricing parameters used in all CAISO Markets is maintained in the Business Practice Manuals.

27.4.3.1 Scheduling Parameters for Transmission Constraint Relaxation

The internal Transmission Constraint scheduling parameter is set to \$5000 per MWh for the purpose of determining when the SCUC and SCED software in the IFM and RTM will relax an internal Transmission Constraint rather than adjust Supply or Demand bids or Non-priced Quantities as specified in Sections 31.3.1.3, 31.4 and 34.10 to relieve Congestion on the constrained facility. The effect of this scheduling parameter value is that if the optimization can re-dispatch resources to relieve Congestion on a Transmission Constraint at a cost of \$5000 per MWh or less, the Market Clearing software will utilize such re-dispatch, but if the cost exceeds \$5000 per MWh the market software will relax the Transmission Constraint. The corresponding scheduling parameter in RUC is set to \$1250 per MWh.

27.4.3.2 Pricing Parameters for Transmission Constraint Relaxation

For the purpose of determining how the relaxation of a Transmission Constraint will affect the determination of prices in the IFM and RTM, the pricing parameter of the Transmission Constraint being relaxed is set to the maximum Energy Bid price specified in Section 39.6.1.1. The corresponding pricing parameter used in the RUC is set at the maximum RUC Availability Bid price specified in Section 39.6.1.2.

27.4.3.3 Insufficient Supply to Meet Self-Scheduled Demand in IFM

In the IFM, when available supply is insufficient to meet all Self-Scheduled demand, Self-Scheduled demand is reduced to the point where the available supply is sufficient to clear the market. For price-

setting purposes in such cases, the cleared Self-Scheduled demand is deemed to be willing to pay the maximum Energy Bid price specified in Section 39.6.1.1.

27.4.3.4 Insufficient Supply to Meet CAISO Forecast of CAISO Demand in the RTM

In the RTM, in the event that Energy offers are insufficient to meet the CAISO Forecast of CAISO Demand, the SCUC and SCED software will relax the system energy-balance constraint. In such cases the software utilizes a pricing parameter set to the maximum Energy Bid price specified in Section 39.6.1.1 for price-setting purposes.

27.4.3.5 Protection of TOR, ETC and Converted Rights Self-Schedules in the IFM

In accordance with the submitted and accepted TRTC Instructions, valid Day-Ahead TOR Self-Schedules, Day-Ahead ETC Self-Schedules and Day-Ahead Converted Rights Self-Schedules shall not be adjusted in the IFM in response to an insufficiency of Effective Economic Bids. The scheduling parameters associated with the TOR, ETC, or Converted Rights Self-Schedules will be set to values higher than the scheduling parameter associated with relaxation of an internal Transmission Constraint as specified in Section 27.4.3.1, so that when there is a congested Transmission Constraint that would otherwise subject a Supply or Demand resource submitted in a valid and balanced ETC, TOR or Converted Rights Self-Schedule to adjustment in the IFM, the IFM software will relax the Transmission Constraint rather than curtail the TOR, ETC, or Converted Rights Self-Schedule. This priority will be adhered to by the operation of the IFM Market Clearing software, and if necessary, by adjustment of Schedules after the IFM has been executed and the results have been reviewed by the CAISO operators.

27.4.3.6 Effectiveness Threshold

The CAISO Markets software includes a lower effectiveness threshold setting which governs whether the software will consider a bid "effective" for managing congestion on a congested Transmission Constraint. The CAISO will set this threshold at two (2) percent.

27.5 Full Network Model

27.5.1 Network Models used in CAISO Markets

The FNM is a representation of the WECC network model including the CAISO Balancing Authority Area that enables the CAISO to produce a Base Market Model that the CAISO then uses as the basis for

formulating the individual market models used to conduct power flow analyses to manage Transmission Constraints for the optimization of each of the CAISO Markets.

27.5.1.1 Base Market Model used in the CAISO Markets

Based on the FNM the CAISO creates the Base Market Model, which is used as the basis for formulating, as described in section 27.5.6, the individual market models used in each of the CAISO Markets to establish, enforce, and manage the Transmission Constraints associated with network facilities. The Base Market Model is derived from the FNM by (1) introducing locations for modeling Intertie Schedules; and (2) introducing market resources that do not currently exist in the FNM due to their size and lack of visibility. In the Base Market Model, external Balancing Authority Areas and external transmission systems are modeled to the extent necessary to support the commercial requirements of the CAISO Markets. For those portions of the FNM that are external to the CAISO Balancing Authority Area, the Base Market Model may model the resistive component for accurate modeling of Transmission Losses, but accounts for losses in the external portions of the market model separately from Transmission Losses within the CAISO Balancing Authority Area. As a result, the Marginal Cost of Losses in the LMPs is not affected by external losses. For portions of the Base Market Model that are external to the CAISO Balancing Authority Area, the CAISO Markets only enforce Transmission Constraints that reflect limitations of the transmission facilities and Entitlements turned over to the Operational Control of the CAISO by a Participating Transmission Owner, or that affect Congestion Management within the CAISO Balancing Authority Area or on Interties. External connections are retained between Intertie branches within Transmission Interfaces. Certain external loops are modeled, which allows the CAISO to increase the accuracy of the Congestion Management process. Resources are modeled at the appropriate network Nodes.

The pricing Location (PNode) of a Generating Unit generally coincides with the Node where the relevant revenue quality meter is connected or corrected, to reflect the point at which the Generating Unit is connected to the CAISO Controlled Grid. The Dispatch, Schedule, and LMP of a Generating Unit refers to a PNode, but the Energy injection is modeled in the Base Market Model for network analysis purposes at the corresponding Generating Unit's physical interconnection point), taking into account any losses in the non-CAISO Controlled Grid leading to the point where Energy is delivered to CAISO Controlled Grid.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Based on the Base Market Model, the market models used in each of the CAISO markets incorporate physical characteristics needed for determining Transmission Losses and model Transmission Constraints within the CAISO Balancing Authority Area, which are then reflected in the Day-Ahead Schedules, AS Awards and RUC Awards, HASP Intertie Schedules, Dispatch Instructions and the LMPs resulting from each CAISO Markets Process. The Dispatch, Schedule, and LMP of a Dynamic System Resource or Pseudo-Tie of a Generating Unit to the CAISO Balancing Authority Area refer to a PNode, or Aggregated Pricing Node, if applicable, of the resource at its physical location in the external transmission systems that are modeled in the Base Market Model, subject to the modeling of Transmission Losses in the portions of the FNM and exclusion of such Transmission Losses' effects on the LMPs that are external to the CAISO Balancing Authority Area described in this Section 27.5.1.1. The LMP price thus associated with a Dynamic System Resource or Pseudo-Tie Generating Unit will be used for Settlement of Energy and will include the Marginal Cost of Congestion and Marginal Cost of Losses components of the LMP to that Dynamic System Resource or Pseudo-Tie Generating Unit point, excluding losses and congestion external to the CAISO Balancing Authority Area, in accordance with this Section 27.5.1.1. Further, in formulating the market models for the HASP, STUC, RTUC, and RTD processes, the Real-Time power flow parameters developed from the State Estimator are applied to the Base Market Model.

27.5.2 Metered Subsystems

The FNM includes a full model of MSS transmission networks used for power flow calculations and Congestion Management in the CAISO Markets Processes. Transmission Constraints (i.e. circuit ratings, thermal ratings, etc.) within the MSS, or at its boundaries, that are modeled in the Base Market Model shall be monitored but not enforced in operation of the CAISO Markets. If overloads are observed in the forward markets, are internal to the MSS or at the MSS boundaries, and are attributable to MSS operations, the CAISO shall communicate such events to the Scheduling Coordinator for the MSS and coordinate any manual Re-dispatch required in Real-Time. If, independent of the CAISO, the Scheduling Coordinator for the MSS is unable to resolve Congestion internal to the MSS or at the MSS boundaries in Real-Time, the CAISO will use Exceptional Dispatch Instructions on resources that have been bid into the HASP and RTM to resolve the Congestion. The costs of such Exceptional Dispatch will be allocated to

the responsible MSS Operator. Consistent with Section 4.9, the CAISO and MSS Operator shall develop specific procedures for each MSS to determine how Transmission Constraints will be handled.

27.5.3 Integrated Balancing Authority Areas

To the extent sufficient data are available or adequate estimates can be made for an IBAA, the Base Market Model used by the CAISO for the CAISO Markets Processes will include a model of the IBAA's network topology. The CAISO monitors but does not enforce the Transmission Constraints for an IBAA in running the CAISO Markets Processes. Similarly, the CAISO models the resistive component for transmission losses on an IBAA but does not allow such losses to determine LMPs that apply for pricing transactions to and from an IBAA and the CAISO Balancing Authority Area, unless allowed under a Market Efficiency Enhancement Agreement. For Bids and Schedules between the CAISO Balancing Authority Area and the IBAA, the CAISO will model the associated sources and sinks that are external to the CAISO Balancing Authority Area using individual or aggregated injections and withdrawals at locations in the FNM that allow the impact of such injections and withdrawals on the CAISO Balancing Authority Area to be reflected in the CAISO Markets Processes as accurately as possible given the information available to the CAISO.

27.5.3.1 Currently Established Integrated Balancing Authority Areas

The FNM includes the established IBAA's listed below. Additional details regarding the modeling specifications for these IBAA's are provided in the Business Practice Manuals.

- (1) The Sacramento Municipal Utility District (SMUD) IBAA including the transmission facilities of the following entities:
 - (a) Western Area Power Administration – Sierra Nevada Region
 - (b) Modesto Irrigation District
 - (c) City of Redding
 - (d) City of Roseville
- (2) Turlock Irrigation District IBAA

27.5.3.2 Information Required to Develop and Obtain Pricing under a Market Efficiency Enhancement Agreement

The CAISO shall enter into an MEEA with an entity controlling supply resources within an IBAA to provide modeling and pricing for imports or exports between the IBAA and the CAISO Balancing Authority Area if

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

the entity agrees to provide the information as specified herein. These information requirements apply to all entities seeking to enter into and having entered into an MEEA, including external Balancing Authorities within the IBAA or sub-entities therein such as Scheduling Coordinators or sub-Balancing Authority Areas in control of specific resources or a portfolio of resources. For these purposes, the term resource includes sources or sinks within the IBAA. An MEEA signatory may use generation as a resource to support an import to the CAISO and may use load or reduce generation to support an export from the CAISO. Control includes ownership or any contractual arrangements that provide authority to schedule and/or receive the financial benefits of a resource. Entities controlling a portfolio of resources within the IBAA are eligible to enter into MEEAs for interchange transactions using portfolios of resources. For the purposes of this provision, Western Area Power Administration base resource customers have sufficient control over Western Area Power Administration base resource portfolio of resources within the IBAA to be eligible to enter into MEEAs for interchange transactions utilizing these resources.

In order to obtain non-default, location-specific pricing for interchange transactions with the CAISO Balancing Authority Area, an MEEA signatory must provide the information described in this section 27.5.3.2. The information is necessary to: (i) establish the location of the resources that will be used to calculate location-specific prices under the MEEA, (ii) verify that the resources operating to implement an interchange transaction are the same as the resources identified in the MEEA, (iii) verify the amount of an interchange transaction that was implemented by the dispatch of resources identified in the MEEA, and (iv) settle all charges and payments for interchange transactions under the MEEA.

Subject to the requirements in Section 27.5.3.2.2, the CAISO will provide an LMP to an MEEA signatory for an interchange transaction between the CAISO Balancing Authority Area and the IBAA at the Scheduling Point at which the actual Import or Export Bid is submitted to the CAISO Markets. This MEEA-specific LMP for MEEA transactions shall be calculated for each such Scheduling Point and reflect the nodes where the specific import or export is demonstrated in the MEEA to actually be located. The CAISO will develop generation distribution factors that apply to the relevant MEEA transactions as provided in Section 27.5.3.2.1. The CAISO and an MEEA signatory may negotiate an alternative to the historical average distribution generation factors of MEEA resources, if an MEEA signatory establishes

that a different structure more accurately identifies the actual location of resources within the IBAA that support interchange transactions with the CAISO.

27.5.3.2.1 Information Required to Develop a Market Efficiency Enhancement Agreement

An entity seeking to enter into an MEEA with the CAISO will provide the CAISO with historical hourly metered generation data for the supply resources to be identified in the MEEA and the historical hourly metered load data within the IBAA for the load served by the MEEA signatory, if any. The data shall be provided in a format that the WECC accepts or other commonly used format. MEEA pricing will typically be based on historical average distribution of generation among a portfolio of resources identified in an MEEA, using negotiated generation distribution factors, subject to revision to reflect changes in usage. The CAISO and an MEEA signatory may, therefore, agree on a set of weighted distribution factors for a specified set of resource locations, which will be used to calculate the MEEA price that will apply to Bids, including Self-Schedules, cleared and processed as further provided in the CAISO Tariff, submitted for resources identified in an MEEA. By applying a set of weighted distribution factors to a set of generator locations, an MEEA signatory is not required to associate a specific generator within a MEEA portfolio of resources with a specific customer of the MEEA signatory. The CAISO will negotiate any generation distribution factors as provided below. For portfolios of resources, the CAISO and a potential MEEA signatory will develop a weighted average price methodology based upon an agreed set of weights for the resources that comprise the MEEA portfolio. Such weights will be based on historical data of operation of the resources comprising the portfolio.

The distribution factors may reflect seasonal, peak and off-peak or other usage and may be periodically revised through bilateral negotiations using updated historical operation data of the MEEA portfolio. All executed MEEAs between the CAISO and an entity with resources within the IBAA must include:

- (a) a list of the external supply resources and loads within the IBAA over which the MEEA signatory has control or serves (for these purposes control includes ownership or any contractual arrangements that provide authority to schedule and/or receive the financial benefits of a resource);
- (b) the location of the resources identified in the MEEA for which non-default LMPs will be calculated;

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (c) the injection and withdrawal points for the resources identified in the MEEA; and
- (d) the appropriate Resource IDs that apply for the MEEA transactions.

27.5.3.2.2 Information Needed to Determine Application of MEEA-Specific Pricing in any Settlement Interval or Settlement Period

If an MEEA signatory submits a Bid in the CAISO Market and seeks to obtain an MEEA-specific LMP for an interchange transaction, the CAISO must be capable of verifying what portion (output in megawatt hours) of the resources identified in the MEEA, if any, were dispatched to implement the interchange transaction. To the extent that the resources identified in the MEEA, or portion thereof, were dispatched and operated for purposes other than the interchange transaction submitted in the CAISO Market, the Schedule or Imbalance Energy associated with the Bid submitted and cleared in the CAISO Market will not receive an MEEA-specific LMP, and will instead receive the default IBAA price specified in Appendix C, Section G.1.1. The CAISO will establish Resource IDs that are to be used only to submit Bids, including Self-Schedules, for the purpose of obtaining MEEA-specific pricing. MEEA signatories may obtain and use other Resource IDs to submit Bids, including Self-Schedules, that are not covered by an MEEA. Prior to obtaining and settling Resource IDs under the terms of the MEEA, the relevant Scheduling Coordinator shall attest that use of the Resource ID shall mean that the MEEA signatory dispatched a resource identified in an MEEA to support the MEEA interchange transaction. This attestation shall be executed under oath by an officer of the MEEA with knowledge of the MEEA signatory's operations. By actually using such Resource IDs, the Scheduling Coordinator represents that MEEA resources are dispatched to support such Bids, including Self-Schedules. The CAISO may challenge the use of these Resource IDs and conduct an audit under Section 27.5.3.7.

In connection with any such audit, the MEEA signatory shall support its certification with information demonstrating that an MEEA signatory resource was dispatched to support the interchange transaction. This information may include, but is not limited to, NERC tags, OASIS transmission service data, day-ahead load and resource plans, power purchase agreements or contracts demonstrating use of the California Oregon Transmission Project as well as marginal cost information. An MEEA signatory, however, is not required to provide marginal cost information to the CAISO to support its self-certification and may support its self-certification with other information, including information identified in the preceding sentence. The MEEA signatory shall provide data in a format that the WECC accepts or other

commonly used format. For any Settlement Interval or Period for which the CAISO challenges the use of Resource IDs under an MEEA, the CAISO shall apply MEEA pricing to the Settlement Interval or Period pending resolution of the challenge.

In addition, in the event that there is a Dynamic Resource-Specific System Resource in the IBAA, the MEEA may further provide that the MEEA signatory in control of such resource may also obtain pricing under the MEEA for imports to the CAISO Balancing Authority Area from the Dynamic Resource-Specific System Resource. For any portion of an interchange transaction for which the MEEA Entity has not self-certified that the resources were used to support interchange transactions, the default IBAA price specified in Appendix C, Section G.1.1 will apply for the corresponding volume and time period.

27.5.3.3 Process for Establishing a Market Efficiency Enhancement Agreement

Any entity seeking to negotiate an MEEA with the CAISO may submit a written request to the CAISO. The CAISO and the requesting entity shall negotiate in good faith the terms and conditions of the MEEA. The CAISO shall file any executed MEEA with FERC for review and approval under Section 205 of the Federal Power Act. In the event an MEEA is not executed within 180 days of the initial written request for an MEEA, a requesting entity may invoke the CAISO ADR Procedures under Section 13.

27.5.3.4 Use of Data Provided under a Market Efficiency Enhancement Agreement

Data provided to the CAISO pursuant to an MEEA shall be used for purposes of modeling and pricing Interchange transactions between the CAISO Balancing Authority Area and the relevant IBAA at Scheduling Points specified in the MEEA. The configuration of the pricing points for the MEEA, which may include specific distribution factors for the represented resources, established through the negotiation of the MEEA will also be used for the purposes of modeling the resources in the IBAA subject to the MEEA. The CAISO and the MEEA signatory may agree to changes to these configurations over time that do not require the renegotiation of the terms of the MEEA or may agree to static terms until such time the parties re-execute a new MEEA. Such modeling information regarding the location of the resources will be incorporated into the Full Network Model, including the CRR FNM, which is used for all CAISO Markets as further described in Sections 27.3, 27.5.1 and 27.5.6. The FNM and the CRR FNM will not include the hourly transactional data provided pursuant to Section 27.5.3.2, except in such cases

where the CAISO and the MEEA signatory have agreed to dynamic changes to the configuration of the modeling of the MEEA resources during the life of the agreement as further provided by the MEEA.

27.5.3.5 Measures to Preserve Confidentiality of Data under a Market Efficiency Enhancement Agreement

Subject to the provisions of Section 27.5.3.4, data provided to the CAISO by any entity under an MEEA or in connection with negotiations to develop an MEEA shall be treated as confidential data. Consistent with applicable law, the CAISO shall take all steps reasonably necessary to limit disclosure of this information to CAISO personnel that need to review such information as part of their work-related responsibilities. In the event a disclosing entity does not execute an MEEA, the CAISO shall return the confidential data to the disclosing entity if the CAISO can physically return the data and shall destroy the confidential data if the CAISO cannot physically return the confidential data to the disclosing entity.

27.5.3.6 Dispute Resolution under Market Efficiency Enhancement Agreements

Any disputes arising out of or in connection with an MEEA shall be subject to the CAISO ADR Procedures of Section 13.

27.5.3.7 Audit Rights under Market Efficiency Enhancement Agreements

The CAISO reserves the right to audit data supplied under an MEEA by giving written notice at least ten (10) Business Days in advance of the date that the CAISO wishes to initiate such audit, with completion of the audit occurring within 180 days of such notice. The audit shall be for the limited purposes of verifying that the MEEA signatory has accurately represented available resources and has met the requirements specified for MEEA pricing. Upon request of the CAISO as part of such audit, any signatory to an MEEA shall provide information to support its certification under Section 27.5.3.2. An MEEA signatory may audit the price for any transaction entered into under an MEEA through the CAISO's Settlement and billing process set forth in Section 11 and through data provided to the MEEA signatory as a Market Participant under the CAISO Tariff. Each party will be responsible for its own expenses related to any audit.

27.5.3.8 Process for Establishing a New IBAA or Modifying an Existing IBAA

Except under exigent circumstances, the CAISO must follow a consultative process with the applicable Balancing Authority and CAISO Market Participants pursuant to the process further defined in the Business Practice Manuals, to establish a new IBAA or modify an existing IBAA. Changes to an existing

IBAA may include among others changes to the modeling of the IBAA's network topology, the specification of the default Resource IDs or the default pricing points. Upon completion of this process and having determined it necessary to establish a new IBAA or modify an existing IBAA, the CAISO will seek FERC approval under Section 205 of the Federal Power Act of the proposed new IBAA or changes to the existing IBAA requirements, at which time the CAISO shall also provide its supportive findings for the establishment of the new IBAA or modification to an existing IBAA.

27.5.3.8.1 Factors to Be Considered in Establishing a New Integrated Balancing Authority Area or Modifying an Existing Integrated Balancing Authority Area

In establishing a new IBAA or modifying an existing IBAA, the factors that the CAISO will consider shall include, but are not limited to, the following:

- (1) The number of Interties between the potential or existing IBAA and the CAISO Balancing Authority Area and the distance between them;
- (2) Whether the transmission system(s) within the other Balancing Authority Area runs in parallel to major parts of the CAISO Controlled Grid;
- (3) The frequency and magnitude of unscheduled power flows at applicable Interties;
- (4) The number of hours where the actual direction of power flows was reversed from scheduled directions;
- (5) The availability of information to the CAISO for modeling accuracy; and
- (6) The estimated improvement to the CAISO's power flow modeling and Congestion Management processes to be achieved through more accurate modeling of the Balancing Authority Area.

27.5.3.9 Default Designation of External Resource Locations for Modeling Transactions Between the CAISO Balancing Authority Area and an IBAA

Prior to the establishment of a new IBAA or a change to an existing IBAA, the CAISO will define and publish default Resource IDs to be used for submitting import and export Bids and for settling import and export Schedules between the CAISO Balancing Authority Area and the potential or existing IBAA.

These default Resource IDs will specify in the Master File the default associations of Intertie Scheduling Point Bids and Schedules to supporting individual or aggregate injection or withdrawal locations in the FNM. The CAISO will determine the supporting injection and withdrawal locations to allow the impact of

the associated Intertie Scheduling Point Bids and Schedules to be reflected in the CAISO Markets Processes as accurately as possible given the information available to the CAISO. The CAISO's methodology for determining such default Resource IDs, as well as the specific default Resource IDs that have been adopted for the currently established IBAs, are provided in the Business Practice Manuals. Alternative Resource IDs to be used instead of the default Resource IDs will be created and adopted for use in conjunction with Intertie Scheduling Point Bids and Schedules between the CAISO Balancing Authority Area and the IBAA based on a Market Efficiency Enhancement Agreement.

27.5.4 Accounting For Changes In Topology In FNM

The CAISO will incorporate into the FNM information received pursuant to Section 24 for transmission expansion and Section 25 for generation interconnection to account for changes to the CAISO Controlled Grid and other facilities located within the CAISO Balancing Authority Area. This information will be incorporated into the network model data base in which the electrical network model is maintained for use by the State Estimator and which forms the basis for the Base Market Model used by the CAISO Markets. The updated power system network model will be transferred at periodic model update cycle intervals established by the CAISO and incorporated into the Base Market Model for use in the CAISO Markets. The Business Practice Manual for managing the Full Network Model will describe the information to be provided by Market Participants, the process by which the CAISO incorporates this information in the FNM, and operational details of the FNM. If the CAISO becomes aware of a material error or omission in the FNM, it will make a timely correction of the FNM.

27.5.5 Load Distribution Factors

The CAISO will maintain a library of system-wide Load Distribution Factors for use in distributing Demand scheduled at the Default LAPs. The system Load Distribution Factors are derived from the State Estimator and are stored in the Load Distribution Factor library, and are updated periodically. For IFM the Load Distribution Factor library uses a similar-day methodology for smoothing the most recent Load Distribution Factors. The similar-day methodology uses data separately for each type of day. More recent days are weighted more heavily in the smoothing calculations. The market application then uses the set of Load Distribution Factors from the library that best represents the Load distribution conditions expected for use in the CAISO Markets Processes. For the RTM, the State Estimator solution is used as

a source for determining Load Distribution Factors. The Load Distribution Factor are also maintained for use for Demand scheduled at Custom LAPs. These custom Load Distribution Factors are not generated from the State Estimator and are fixed quantities representing the characteristics of the Custom LAP.

27.5.6 Management & Enforcement of Constraints in the CAISO Markets

The CAISO operates the CAISO Markets through the use of a market software system that utilizes various information including the Base Market Model, the State Estimator, submitted Bids including Self-Schedules, Generated Bids, and Transmission Constraints, including Nomograms and Contingencies transmission and generation Outages. The market model used in each of the CAISO Markets is derived from the most current Base Market Model available at that time. To create a more relevant time-specific network model for use in each of the CAISO Markets, the CAISO will adjust the Base Market Model to reflect Outages and derates that are known and applicable when the respective CAISO Market will operate, and to compensate for observed discrepancies between actual real-time power flows and flows calculated by the market software. Through this process the CAISO creates the market model to be used in each Day-Ahead Market, HASP, and each process of the Real-Time Market. The CAISO will manage the enforcement of Transmission Constraints, including Nomograms and Contingencies, consistent with good utility practice, to ensure, to the extent possible, that the market model used in each market accurately reflects all the factors that contribute to actual Real-Time flows on the CAISO Controlled Grid and that the CAISO Market results are better aligned with actual physical conditions on the CAISO Controlled Grid. In operating the CAISO Markets, the CAISO may take the following actions so that, to the extent possible, the CAISO Market solutions are feasible, accurate, and consistent with good utility practice:

- (a) The ISO may enforce, not enforce, or adjust flow-based Transmission Constraints, including Nomograms and Contingencies, if the CAISO observes that the CAISO Markets produce or may produce results that are inconsistent with observed or reasonably anticipated conditions or infeasible market solutions either because (a) the CAISO reasonably anticipates that the CAISO Market run will identify Congestion that is unlikely to materialize in Real-Time even if the Transmission Constraint were to be ignored in all the markets leading to Real-

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Time, or (b) the CAISO reasonably anticipates that the CAISO Market will fail to identify Congestion that is likely to appear in the Real-Time. The ISO does not make such adjustments to intertie Scheduling Limits.

- (b) The ISO may enforce or not enforce Transmission Constraints, including Nomograms and Contingencies, if the CAISO has determined that non-enforcement or enforcement, respectively, of such Transmission Constraints may result in the unnecessary pre-commitment and scheduling of use-limited resources.
- (c) The CAISO may not enforce Transmission Constraints, including Nomograms and Contingencies, if it has determined it lacks sufficient visibility to conditions on transmission facilities necessary to reliably ascertain constraint flows required for a feasible, accurate and reliable market solution.
- (d) For the duration of a planned or unplanned Outage, the CAISO may create and apply alternative Transmission Constraints, including Nomograms and Contingencies, that may add to or replace certain originally defined constraints.
- (e) The CAISO may adjust Transmission Constraints, including Nomograms and Contingencies, for the purpose of setting prudent operating margins consistent with good utility practice to ensure reliable operation under anticipated conditions of unpredictable and uncontrollable flow volatility consistent with the requirements of Section 7.

To the extent that particular Transmission Constraints, including Nomograms and Contingencies, are not enforced in the operations of the CAISO Markets, the CAISO will operate the CAISO Controlled Grid and manage any Congestion based on available information including the State Estimator solutions and available telemetry to Dispatch resources through Exceptional Dispatch to ensure the CAISO is operating the CAISO Controlled Grid consistent with the requirements of Section 7.

27.6 State Estimator

The State Estimator produces a power flow solution based upon the modeled representation of the electrical network and available Real-Time SCADA telemetry. When this solution is applied to the FNM, it

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

provides a reference of system conditions for determining Dispatch Instructions. The State Estimator also provides a reference for Real-Time Load Distribution Factors used to distribute the Real-Time CAISO Forecast of CAISO Demand as well as provide a source of historical data for the LDF library. If the State Estimator is not capable of providing CAISO with a solution to clear the CAISO Markets, the CAISO shall use the last best State Estimator solution for determining Dispatch Instructions, provided the State Estimator is not unavailable for an extended period. If the State Estimator is not available for an extended period of time, the CAISO shall use the Load Distribution Factors from the Load Distribution Factors library as applicable to the prevailing system and time of use conditions to determine Dispatch Instructions.

27.7 Constrained Output Generators

27.7.1 Election Of Constrained Output Generator Status

A Scheduling Coordinator on behalf of a Generating Unit eligible for COG status must make an election to have the resource treated as a COG before each calendar year by registering the resource's PMin in the Master File as equal to its PMax less 0.01 MW ($P_{Min} = P_{Max} - 0.01 \text{ MW}$) within the timing requirements specified for Master File changes described in the applicable Business Practice Manual. Generating Units with COG status will be eligible to set LMPs in the IFM and RTM based on their Calculated Energy Bids.

As with all Generating Units, a Scheduling Coordinator on behalf of a COG must elect either the Proxy Cost option or the Registered Cost option, as provided in Section 30.4, for determining its Start-Up Costs and Minimum Load Costs. A COG's Calculated Energy Bid will be calculated based on this election. Whenever a Scheduling Coordinator for a COG submits an Energy Bid into the IFM or RTM, the CAISO will override that Bid and substitute the Calculated Energy Bid if the submitted Bid is different from the Calculated Energy Bid.

27.7.2 Election To Waive COG Status

A Scheduling Coordinator on behalf of a Generating Unit eligible for COG status may elect to waive COG status. If such Generating Unit has a non-zero operating range (PMax greater than PMin), it is eligible to participate in the CAISO Markets like any other resource.

27.7.3 Constrained Output Generators In The IFM

In the IFM, resources electing COG status are modeled as though they are not constrained and can operate flexibly between zero (0) and their PMax. A COG is eligible to set IFM LMPs based on its Calculated Energy Bid in any Settlement Period in which a portion of its output is needed as a flexible resource to serve Demand. A COG is not eligible for recovery of Minimum Load Costs or BCR in the IFM due to the conversion of its Minimum Load Cost to an Energy Bid and its treatment by the IFM as a flexible resource. A COG is eligible for Start-Up Cost recovery based on its Commitment Period as determined in the IFM, RUC, HASP, STUC or RTUC.

27.7.4 Constrained Output Generators In RUC

In RUC, any COG that has capacity that did not fully clear in the IFM is treated as constrained, so that the entire capacity of the COG is committed by RUC. Any such RUC commitment would apply to scheduled capacity in RUC in excess of the higher of: (a) the relevant Day-Ahead Schedule; or (b) the relevant Minimum Load. In the event of a RUC commitment, the COG is not eligible to receive a RUC Award.

27.7.5 Constrained Output Generators In The Real-Time Market

A COG that can be started up and complete its Minimum Run Time within a five-hour period can be committed by the STUC. A COG that can be started up within the applicable RTUC run as described in Section 34.2 can be committed by the RTUC. The RTD will dispatch a COG up to its PMax or down to zero (0) to ensure a feasible Real-Time Dispatch. The COG is eligible to set the RTM LMP in any Dispatch Interval in which a portion of its output is needed to serve Demand, not taking into consideration its Minimum Run Time constraint. For the purpose of making this determination and setting the RTM LMP, the CAISO treats a COG as if it were flexible with an infinite Ramp Rate between zero (0) and its PMax, and uses the COG's Calculated Energy Bid. In any Dispatch Interval where none of the output of a COG is needed as a flexible resource to serve Demand, the CAISO shall not dispatch the unit. In circumstances in which the output of the COG is not needed as a flexible resource to serve Demand, but the unit nonetheless is online as a result of a previous commitment or Dispatch Instruction by the CAISO, the COG is eligible for Minimum Load Cost compensation.

27.8 Multi-Stage Generating Resources

27.8.1 Registration and Qualification

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Scheduling Coordinators must comply with the registration and qualification process described in this Section 27.8.1, in order to effectuate any of the changes described in Section 27.8.3. No less than sixteen (16) days prior to the date that Scheduling Coordinator seeks to have the resource participate in the CAISO Markets under the new settings or MSG Configuration details, the Scheduling Coordinator must complete and submit to the CAISO the registration form and the resource data template provided by the CAISO for registration and qualification purposes. After the Scheduling Coordinator submits a request for registration of a Generating Unit or Dynamic Resource-Specific System Resource as a Multi-Stage Generating Resource or a change in the attributes in Section 27.8.3, the CAISO will coordinate with that Scheduling Coordinator to validate that the resource qualifies for the requested status and that all the requisite information has been successfully provided to the CAISO. The resource will be successfully registered and qualified as a Multi-Stage Generating Resource, or the requested changes in the attributes listed in Section 27.8.3 will be successfully registered and qualified as of the date on which the CAISO sends the responsible Scheduling Coordinator a notice that the resource has been successfully qualified as such. After the date on which the CAISO has provided such notice, any changes to the items listed in Section 27.8.3 will be subject to the timing and process requirements in this Section 27.8.1 and 27.8.3. The Scheduling Coordinator may modify all other Multi-Stage Generating Resource registered characteristics pursuant to the timing and processing requirements specified elsewhere in this CAISO Tariff, as they may apply. If the CAISO has reason to believe that the resource's operating and technical characteristics are not consistent with the registered and qualified attributes, the CAISO may request that the Scheduling Coordinator provide additional information necessary to support their registered status and, if appropriate, may require that the resource be registered and qualified more consistent with the resource's operating and technical characteristics, including the revocation of its status as a Multi-Stage Generating Resource. Failure to provide such information may be grounds for revocation of Multi-Stage Generating Resource status. Such changes in status or MSG Configuration details would be subject to the registration and qualification requirements in this Section 27.8. Scheduling Coordinators may register the number MSG Configurations as are reasonably appropriate for the resource based on the technical and operating characteristics of the resource, which may not, however,

exceed a total of ten MSG Configurations and cannot be fewer than two MSG Configurations. The information requirements specified in Section 27.8.2 will apply.

27.8.2 Informational Requirements

As part of the registration process described in Section 27.8.1, the Scheduling Coordinators for Generating Units or Dynamic Resource-Specific System Resources that seek to qualify as Multi-Stage Generating Resources must submit to the CAISO a Transition Matrix, which contains the Transition Costs and operating constraints associated with MSG Transitions. The Scheduling Coordinator may register up to six (6) MSG Configurations without any limitation on the number of transitions between the registered MSG Configurations in the Transition Matrix. If the Scheduling Coordinator registers seven (7) or more MSG Configurations, then the Scheduling Coordinator may only include two (2) eligible transitions between MSG Configurations for upward and downward transitions, respectively, starting from the initial MSG Configuration in the Transition Matrix. For each MSG Configuration, the responsible Scheduling Coordinator shall submit an Operational Ramp Rate and, as applicable, an Operating Reserve Ramp Rate and Regulating Reserves ramp rate, each of which shall have at least one (1) segment and no more than two (2) segments. The Scheduling Coordinator must establish the default MSG Configuration and its associated Default Resource Adequacy Path that apply to Multi-Stage Generating Resources that are subject to Resource Adequacy must-offer obligations. The Scheduling Coordinator may submit changes to this information consistent with Sections 27.8.1 and 27.8.3, as they may apply.

27.8.3 Changes in Status and Configurations of Resource

Scheduling Coordinators may seek modifications to the Multi-Stage Generating Resource attributes listed below consistent with the process and timing requirements specified in Section 27.8.1 and the additional requirements discussed below in this Section 27.8.3:

- (1) Registration and qualification of a Generating Unit or Dynamic Resource-Specific System Resource as a Multi-Stage Generating Resource.
- (2) Changes to the MSG Configurations attributes, which include:
 - a. addition of new MSG Configurations;
 - b. removal of an existing MSG Configuration;
 - c. a change in the physical units supporting the MSG Configuration;

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- d. a change to the MSG Configuration Start Up and Shut Down flags;
- e. adding or removing an MSG Transition to the Transition Matrix;
- f. a material change in the Transition Times contained in the Master File, which consists of a change that more than doubles the Transition Times or reduces it to less than half; and
- g. a material change to the maximum Ramp Rate of the MSG Configuration(s) contained in the Master File, which consists of a change that more than doubles the maximum Ramp Rate or reduces it to less than half.

When transitioning to implement these changes across the midnight hour, for any Real-Time Market run in which the changes specified in this Section 27.8.3 are to take effect within the Time Horizon of any of the Real-Time Market runs, the CAISO will Schedule, Dispatch, or award resources consistent with either the prior or new status and definitions, as appropriate, and required by any Real-Time conditions regardless of the resource's state scheduled or awarded in the immediately preceding Day-Ahead Market. A Scheduling Coordinator may unregister a Generating Unit or Dynamic Resource-Specific System Resource from its Multi-Stage Generating Resource status subject to the timing requirements for Master File changes, and such changes are not subject to the timing requirements in Section 27.8.3. For the first forty-four (44) days after the effective date of this Section, Scheduling Coordinators may not change any of Multi-Stage Generating Resource attributes listed above in this Section. On the forty-fifth (45th) day following the effective day of this Section, changes to the attributes listed above in this Section may take effect, including the registration of new Multi-Stage Generating Resources, provided Scheduling Coordinators have previously followed the registration process requirements listed in Section 27.8.1. Subsequently, further changes to the attributes listed above in this Section 27.8.3 may not take effect until after the one hundred-and fifth (105th) day following the effective date of this Section, subject to the procedures described in Section 27.8.1. As of the one hundred-fifth (105th) day following the effective date of this Section, changes to these attributes may only be made every sixty (60) days after the day on which any such changes have taken effect.

27.9 [NOT USED]

27.10 Flexible Ramping Constraint

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

The CAISO may enforce a Flexible Ramping Constraint in the HASP, RTUC, STUC, and RTED. Any flexible Dispatch capacity constrained to be available as a result of the Flexible Ramping Constraint in RTUC will come from capacity that is not designated to provide Regulation or Operating Reserves, and will not offset the required procurement of those Regulation or Operating Reserves in RTUC. To the extent a resource incurs an opportunity cost for not providing Energy or Ancillary Services in the RTUC interval as a result of a binding Flexible Ramping Constraint, all resources resolving that Flexible Ramping Constraint will be compensated pursuant to Section 11.25. In RTD the resources identified as resolving the Flexible Ramping Constraint in the corresponding RTUC run will be the only resources used to resolve the Flexible Ramping Constraint enforced in RTD. The Flexible Ramping Constraint can be satisfied only by committed online dispatchable Generating Units and Proxy Demand Response resources with ramping capability for which a Scheduling Coordinator has submitted Economic Bids for Energy for the applicable Trading Hour. This constraint cannot be satisfied by System Resources. The quantity of the flexible ramping capacity for each applicable CAISO Market run will be determined by CAISO operators using tools that estimate the: 1) expected level of imbalance variability; 2) uncertainty due to forecast error; and 3) differences between the hourly, fifteen (15) minute average and historical five (5) minute Demand levels.

28. Inter-SC Trades

28.1 Inter-SC Trades Of Energy

28.1.1 Purpose

Scheduling Coordinators submit Inter-SC Trades of Energy consistent with the provisions in this Section 28.

28.1.2 Availability Of Inter-SC Trades Of Energy

The CAISO allows Inter-SC Trades of Energy at individual PNodes of Generating Units and unique Aggregated Pricing Nodes of Physical Scheduling Plants within the CAISO Balancing Authority Area and at Aggregated Pricing Nodes that are either defined Trading Hubs or Default LAPs. The CAISO does not allow Inter-SC Trades of Energy at Scheduling Points. The CAISO allows submission of Inter-SC Trades of Energy in the DAM and the HASP. Inter-SC Trades of Energy submitted for the DAM are settled at the hourly DAM LMP at the applicable Aggregated Pricing Nodes or PNodes. Inter-SC Trades of Energy

submitted in the HASP are settled hourly based on the simple average of the RTM Dispatch Interval LMPs at the applicable Aggregated Pricing Nodes or PNodes.

28.1.3 Submission Of Inter-SC Trades Of Energy

A Scheduling Coordinator may submit Inter-SC Trades of Energy that it intends to have settled based on DAM LMPs at any time during the Day-Ahead Inter-SC Trade Period and may submit Inter-SC Trades of Energy for a particular hour that it intends to have settled based on the simple average of the RTM Dispatch Interval LMPs during that hour at any time during the HASP Inter-SC Trade Period.

28.1.4 Information Requirements

An Inter-SC Trade of Energy must consist of trades from both Scheduling Coordinators and contain the following information: (i) the Scheduling Coordinator ID Code (SCID) of the Scheduling Coordinator from which the Energy is traded; (ii) the SCID of the Scheduling Coordinator to which the Energy is traded; (iii) the location of the Energy trade; (iv) the CAISO Market the trade is to be settled in; (v) the time period over which the bilateral Energy trade will take place, including the start-date and Trading Hour and the end-date and Trading Hour; and (vi) the quantity (MWh) of the Energy traded.

28.1.5 General Validation Rules For Inter-SC Trades

For all Inter-SC Trades of Energy the CAISO shall verify that the Scheduling Coordinators for the Inter-SC Trade of Energy mutually agree on the quantity, location, time period, and CAISO Market (for pricing purposes, i.e., DAM or RTM) for settling the Inter-SC Trade of Energy. Any individual Inter-SC Trade of Energy that is deemed invalid by the CAISO due to inconsistencies between the trading Scheduling Coordinators on these terms will be rejected. The CAISO will notify trading Scheduling Coordinators within a reasonable time if their Inter-SC Trades of Energy fail these general validation rules as described in the Business Practice Manuals.

28.1.6 Validation Procedures For Physical Trades

All Inter-SC Trades at PNodes and all Inter-SC Trades of Physical Scheduling Plants at their unique Aggregated Pricing Nodes will be subject to validation procedures as specified in this Section. Physical Trades can occur at any individual Generating Unit's PNode or a Physical Scheduling Plant's Aggregated Pricing Node provided the Physical Trade satisfies the CAISO's Physical Trades validation procedures described herein. The Scheduling Coordinators must demonstrate that the trade is supported (directly or

through an Inter-SC Trade of Energy with another Scheduling Coordinator) by a Day-Ahead Schedule or HASP Advisory Schedule for a Generating Unit or Physical Scheduling Plant at the same location for the Inter-SC Trade of Energy at a level greater than or equal to the amount of the Inter-SC Trade of Energy. The CAISO's validation procedures for Physical Trades include three components: (1) Physical Trade submittal screening, (2) Physical Trade pre-market validation, and (3) Physical Trade post-market confirmation.

28.1.6.1 Physical Trade Submittal Screening

The CAISO's Physical Trade validation procedures begin upon initial submission of a Physical Trade to the CAISO. The first stage of that process, Physical Trade submittal screening, validates that the submitted Physical Trade does not exceed the PMax of the identified Generating Unit or Physical Scheduling Plant. The CAISO will reject Physical Trades that exceed the PMax and notify the responsible Scheduling Coordinators.

28.1.6.2 Physical Trade Pre-Market Validation

The purpose of the pre-market validation is to determine whether the total MWh quantity of all submitted Physical Trades at a PNode of an individual Generating Unit or the Aggregated Pricing Node of a Physical Scheduling Plant exceeds the resource's Energy Bid MWh. Pre-market validation is performed on all Physical Trades that pass the submittal screening set forth in Section 28.1.6.1. Scheduling Coordinators are notified within a reasonable time of their Physical Trades status as the CAISO conducts the pre-market validation to indicate, at a minimum, whether the Physical Trade is currently "conditionally valid", "conditionally invalid", or "conditionally modified." These Physical Trade notices are preliminary and subject to change until the final pre-market validation at the close of the relevant Inter-SC Trade Period. A Physical Trade with a "conditionally valid" or "conditionally modified" status may be rendered "conditionally invalid" due to the actions of the Scheduling Coordinators to that Physical Trade or by other trading activities that are linked to the Generating Unit identified for the relevant Physical Trade whenever the quantities specified in the relevant Inter-SC Trades cannot be supported by the underlying Bid. Scheduling Coordinators can use these status notices to make modifications to complete or correct invalid Physical Trades. The CAISO also performs cyclic pre-market validation prior to the close of the relevant Inter-SC Trade Period. Physical Trades that are individually valid are concatenated (daisy

chained) with other supporting Physical Trades at the same PNode or Aggregated Pricing Node of the Generating Unit or Physical Scheduling Plant. Once that concatenation is complete, the CAISO will determine whether the concatenated Physical Trades are physically supported by either another Inter-SC Trade of Energy at that same location or the Bid submitted in the relevant CAISO Market on behalf of the resource for that Physical Trade, individually and in the aggregate. If a Physical Trade is not adequately physically supported, the quantities in the Physical Trades of that Scheduling Coordinator and its downstream trading counter-parties are reduced on a pro-rata basis until those Physical Trades are valid. In performing physical pre-market validation of Inter-SC Trades of Energy in HASP, the CAISO also considers final Inter-SC Trades of Energy for the DAM in determining whether the HASP Physical Trades are physically supported individually or in the aggregate. Specifically, the CAISO determines whether the resource's submitted Bid in HASP is greater than or equal to the sum of: (1) final Day-Ahead Inter-SC Trades of Energy at that location, (2) the additional Inter-SC Trades of Energy for the HASP at that location and (3) the sum of all upward Day-Ahead Ancillary Services Awards at that location. If the amounts are greater than the resource's submitted Bids in HASP, the CAISO will adjust down on a prorated basis the HASP Physical Trades. Final Day-Ahead Physical Trades are not adjusted in the HASP pre-market validation. The CAISO does not perform any Settlement on Physical Trade quantities (MWh) that are curtailed during Physical Trade pre-market validation.

28.1.6.3 Physical Trade Post-Market Confirmation

The CAISO conducts post-market confirmation of Physical Trades that pass pre-market validation in Section 28.1.6.2 after the Market Clearing and the market results are posted to ensure that the Generating Unit or Physical Scheduling Plant has a Schedule that can support all of the Physical Trades. During the post-market confirmation process, the MWh quantity of Physical Trades that passed the CAISO's pre-market validation process may be reduced if the resource supporting the Physical Trades has a Day-Ahead Schedule or HASP Advisory Schedule that is, on average, below the quantity of Physical Trades at that Location. The MWh quantities of Physical Trades that are reduced during the post-market confirmation process are settled at the Existing Zone Generation Trading Hub price for the Existing Zone associated with the resource identified in the Inter-SC Trade of Energy. The portion of

Physical Trades that remains intact will be settled at the relevant LMP for the identified PNode for the Generating Unit or Aggregated Pricing Node for the Physical Scheduling Plant.

28.1.6.4 Inter-SC Trades of Energy at Aggregated Pricing Nodes

Inter-SC Trades of Energy at Aggregated Pricing Nodes that are also defined Trading Hubs or Default LAPs are subject to the general validation procedures in Section 28.1.5 but are not subject to the three-stage physical validation procedures for Physical Trades described in Section 28.1.6 above.

28.2 Inter-SC Trades Of Ancillary Services

Inter-SC Trades of Ancillary Services enable a Scheduling Coordinator to transfer any fixed quantity of Ancillary Services (MW) to another Scheduling Coordinator. An Inter-SC Trade of AS shall consist of a quantity in MWs traded between two Scheduling Coordinators for a specific hour and for a specific Ancillary Service type. The Inter-SC Trade of AS is a financial trade. The CAISO shall charge and pay the two parties of the trade based on the quantity (MW) of the Ancillary Service Obligation traded times the user rate for the Ancillary Service trades for the Trading Hour. Scheduling Coordinators may submit Inter-SC Trades of Ancillary Services for Regulation Up, Regulation Down, Spinning and Non-Spinning Reserves.

28.2.1 Information Requirements

An Inter-SC Trade of Ancillary Services shall contain the following information: (i) the Scheduling Coordinator ID Code (SCID) for the Scheduling Coordinator from whom the MW amounts of Ancillary Service is traded; (ii) the SCID for the Scheduling Coordinator to whom the MW amounts of AS is traded; (iii) the type of AS being traded; (iv) the time period over which the trade will take place, including the start-date and time and the end-date and time; and the (v) quantity (MW) of the AS to be traded.

28.2.2 Validation

The CAISO's validation of Inter-SC Trades of AS will begin upon submission of an Inter-SC Trade of AS. The CAISO shall conduct a final validation for Inter-SC Trades of AS at the end of the HASP Inter-SC Trade Period. The CAISO will validate each submitted Inter-SC Trade of AS to verify that the contents of the submission match the submittal by the counter-party Scheduling Coordinator by type (Regulation Up, Regulation Down, Spinning Reserve and Non-Spinning Reserve), quantity (MW), and time period. The CAISO will inform the submitting Scheduling Coordinators regarding the validity of a submitted trade of an

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

AS and will allow the Scheduling Coordinator to resubmit the entire Inter-SC Trade of AS if it is not accepted. If only one of the two Scheduling Coordinators successfully submits an Inter-SC Trade of AS, the CAISO will notify both Scheduling Coordinators that the Inter-SC Trade of AS for the specific hour does not match the corresponding Inter-SC Trade of AS. If both Scheduling Coordinators successfully submit the Inter-SC Trade of AS, the CAISO will notify the Scheduling Coordinators that their Inter-SC Trade of AS for the specific hour has been accepted. An Inter-SC Trade of Ancillary Services submitted at a later time, but before the deadline for the submission of the trade for the Trading Hour, renders a previously submitted Inter-SC Trade of AS invalid if it applies to the same hour, same type of AS, and the same Scheduling Coordinators to whom and from whom the AS is traded.

28.2.3 Submission Of Inter-SC Trades Of Ancillary Services

Scheduling Coordinators may submit Inter-SC Trades of Ancillary Services at any time during the HASP Inter-SC Trade Period.

28.3 Inter-SC Trades Of IFM Load Uplift Obligation

Scheduling Coordinators may submit system-wide Inter-SC Trades of IFM Load Uplift Obligations from within the CAISO Balancing Authority Area. Inter-SC Trades of IFM Load Uplift Obligations enable a Scheduling Coordinator to transfer any amount of net IFM Load Uplift Obligation (MW) to another Scheduling Coordinator. An Inter-SC Trade of IFM Load Uplift Obligation shall consist of a quantity in MWs traded between two Scheduling Coordinators for a specific Trading Hour of the IFM.

28.3.1 Information Requirements

An Inter-SC Trade of IFM Load Uplift Obligation shall contain the following information: (i) the Scheduling Coordinator ID Code for the Scheduling Coordinator from whom the MW amounts of IFM Load Uplift Obligation is traded; (ii) the Scheduling Coordinator ID Code for the Scheduling Coordinator to whom the MW amounts of IFM Load Uplift Obligation is traded; (iii) the applicable Location of the Inter-SC Trade of IFM Load Uplift Obligation; (iv) the time period over which the trade will take place, including the start-date and time and the end-date and time; and (v) the quantity (MW) of the IFM Load Uplift Obligation to be traded.

28.3.2 Validation

The CAISO's validation of Inter-SC Trades of IFM Load Uplift Obligations will begin upon submission of an Inter-SC Trade of IFM Load Uplift Obligation. The CAISO shall conduct a final validation for Inter-SC Trades of IFM Load Uplift Obligations at the end of the HASP Inter-SC Trade Period. The CAISO will validate each submitted Inter-SC Trade of IFM Load Uplift Obligation to verify that the contents of the submission match the submittal by the counter-party Scheduling Coordinator in terms of quantity (MW), and time period. The CAISO will inform the submitting Scheduling Coordinators regarding the validity of a submitted Inter-SC Trade of IFM Load Uplift Obligation and will allow the Scheduling Coordinator to resubmit the entire Inter-SC Trade of IFM Load Uplift Obligation if it is not accepted. If only one of the two Scheduling Coordinators successfully submits an Inter-SC Trade of IFM Load Uplift Obligation, the CAISO will notify both Scheduling Coordinators that the Inter-SC Trade of IFM Load Uplift Obligation for the specific hour does not match the corresponding Inter-SC Trade of IFM Load Uplift Obligation. If both Scheduling Coordinators successfully submit the Inter-SC Trade of IFM Load Uplift Obligation, the CAISO will notify the Scheduling Coordinators that their Inter-SC Trade of IFM Load Uplift Obligations for the specific hour has been accepted. The CAISO will verify that an Inter-SC Trade of IFM Load Uplift Obligation is between different Scheduling Coordinators that are authorized to participate in the CAISO Markets during the time period covered by the trade and that the Trading Hour and the quantity of the trade must be greater than or equal to zero. An Inter-SC Trade of IFM Load Uplift Obligation submitted at a later time renders a previously submitted Inter-SC Trade of IFM Load Uplift Obligation invalid if it applies to the same hour and the same Scheduling Coordinators to whom and from whom the net IFM Load Uplift Obligation is traded.

28.3.3 Submission Of Inter-SC Trades Of IFM Load Uplift Obligation

Scheduling Coordinators may submit Inter-SC Trades of IFM Load Uplift Obligations at any time during the HASP Inter-SC Trade Period.

29. [NOT USED]

30. Bid And Self-Schedule Submission For All CAISO Markets

30.1 Bids, Including Self-Schedules

Scheduling Coordinators shall submit Bids to participate in the CAISO Markets, as well as any Self-Schedules, ETC Self-Schedules, TOR Self-Schedules, or Self-Provided Ancillary Services. Bidding rules for each type of resource are contained in this Section 30 and additional specifications regarding bidding practices are contained in the Business Practice Manuals posted on the CAISO Website. Bids will consist of various components described in this Section 30 through which the Scheduling Coordinator provides information regarding the parameters and conditions pursuant to which the Bid may be optimized by the CAISO Markets.

30.1.1 Day-Ahead Market

Bids submitted in the DAM apply to the twenty-four (24) hours of the next Trading Day (23 or 25 hours on the Daylight Savings transition days) and are used in both the IFM and RUC. Bids for the Regulation Up, Regulation Down, Spinning Reserve, and Non-Spinning Reserve service in the Day-Ahead Market must be received by Market Close for the Day-Ahead Market. The Bids shall include information for each of the twenty-four (24) Settlement Periods of the Trading Day. Failure to provide the information within the stated time frame shall result in the Bids being declared invalid by the CAISO. Scheduling Coordinators may submit Bids for the DAM as early as seven (7) days ahead of the targeted Trading Day.

30.1.2 HASP And Real-Time Market

Bids submitted in the HASP apply to a single Trading Hour and are used in the HASP and the RTM. The CAISO will require Scheduling Coordinators to honor their Day-Ahead Ancillary Services Awards when submitting Ancillary Services Bids in the HASP. Bids for Regulation Up, Regulation Down, Spinning Reserve, and Non-Spinning Reserve service for each Settlement Period must be received at least seventy-five minutes prior to the commencement of that Settlement Period. The Bids shall include information for only the relevant Settlement Period. Failure to provide the information within the stated time frame shall result in the Bids being declared invalid by the CAISO.

30.2 Bid Types

There are three types of Bids: Energy Bids (which include Virtual Bids), Ancillary Services Bids, and RUC Availability Bids. Each Bid type can be submitted as either an Economic Bid or a Self-Schedule (except for RUC Availability Bids and Virtual Bids, which cannot be self-scheduled). Economic Bids specify prices for MW amounts of capacity or MWh amounts of Energy. Self-Schedules do not have any prices associated for MW or MWh. Energy Bids, including both Economic Bids and Self-Schedules, may be either Supply Bids, Demand Bids, Virtual Supply Bids, or Virtual Demand Bids. Ancillary Services Bids and RUC Availability Bids are Supply Bids only. Ancillary Services may be self-provided by providing a Submission to Self-Provide an Ancillary Service and having that submission accepted by the CAISO. Rules for submitting the three types of Bids vary by the type of resource to which the Bid applies as described in Section 30.5 and as further required in each CAISO Markets process as specified in Sections 31, 33, and 34.

30.3 [NOT USED]

30.4 Election For Start-Up Costs And Minimum Load Costs

Scheduling Coordinators for Generating Units and Resource-Specific System Resources may elect on a thirty (30)-day basis either of the two options provided below (the Proxy Cost option or the Registered Cost option) for specifying their Start-Up Costs and Minimum Load Costs to be used for those resources in the CAISO Markets Processes. The elections are independent; that is, a Scheduling Coordinator electing either the Proxy Cost option or Registered Cost option for Start-Up Costs may make a different election for Minimum Load Costs. If a Scheduling Coordinator has not made an election, the CAISO will assume the Proxy Cost option as the default option. Scheduling Coordinators for Multi-Stage Generating Resources may also register with the CAISO their Transition Costs on a thirty (30)-day basis.

30.4.1 Start-Up and Minimum Load Costs

30.4.1.1 Proxy Cost Option

For natural gas fired resources, the Proxy Cost option uses fuel-cost adjusted formulas for Start-Up Costs and Minimum Load Costs based on the resource's actual unit-specific performance parameters. The Start-Up Costs and Minimum Load Costs values utilized in the CAISO Markets Processes will either be these formulaic values adjusted for fuel-cost variation on a daily basis as calculated pursuant to a

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Business Practice Manual, or values specified by Scheduling Coordinators pursuant to Sections 30.7.9 and 30.7.10. Start-Up Costs also include the cost of auxiliary power calculated using the unit-specific MWh quantity of auxiliary power used for Start-Up multiplied by a resource specific electricity price. Minimum Load Costs also includes operations and maintenance costs as provided in Section 39.7.1.1.2. For all other resources, this option shall be based on the relevant cost information of the particular resource, which will be provided to the CAISO by the Scheduling Coordinator and maintained in the Master File, or values specified by Scheduling Coordinators pursuant to Sections 30.7.9 and 30.7.10. In the event that the Scheduling Coordinator for a unit does not provide sufficient data for the CAISO to determine the unit's Proxy Costs, the CAISO will assume that the unit's Start-Up Costs and Minimum Load Costs are zero. If a Multi-Stage Generating Resource elects the Proxy Cost option, that election will apply to all the MSG Configurations for that resource. The Proxy Cost values for Multi-Stage Generating Resources will be calculated for each specific MSG Configuration.

30.4.1.2 Registered Cost Option

Under the Registered Cost option, the Scheduling Coordinator may register values of its choosing for Start-Up Costs and Minimum Load Costs in the Master File subject to the maximum limit specified in Section 39.6.1.6. For a resource to be eligible for the Registered Cost option there must be sufficient information in the Master File to calculate the Proxy Cost option for the specific Registered Cost option value. Any such values will be fixed for a minimum of 30 days in the Master File unless (a) the resource's costs, as calculated pursuant to the Proxy Cost option, exceed the Registered Cost option, in which case the Scheduling Coordinator may elect to switch to the Proxy Cost option for the balance of any 30-day period, or (b) any cost registered in the Master File exceeds the maximum limit specified in Section 39.6.1.6 after this minimum 30-day period, in which case the value will be lowered to the maximum limit specified in Section 39.6.1.6. If a Multi-Stage Generating Resource elects the Registered Cost option, that election will apply to all the MSG Configurations for that resource. The cap for the Registered Cost values for each MSG Configuration will be based on the Proxy Cost values calculated for each MSG Configuration, which are also subject to the maximum limit specified in Section 39.6.1.6.

30.4.2 Transition Costs

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Scheduling Coordinators may register and the CAISO will validate Transition Costs for Multi-Stage Generating Resources as described below. Once accepted by the CAISO, such Transition Costs will apply until modified and will apply for a minimum of thirty (30) days. Scheduling Coordinators may change their Transition Costs pursuant to the time line that applies to changes to the Master File. During the registration process, the Scheduling Coordinator shall submit a dollar value for each upward Transition Cost, including a Transition Costs multiplier which consists of the Transition Costs dollar value divided by the applicable monthly Thousand Thousand British Thermal Units (MMBtu) Gas Price Index on the day that the Scheduling Coordinator is registering the Transition costs value with the CAISO. At the time of registration, the CAISO will validate that the upward Transition Costs dollar value and the Transition Costs multiplier are consistent. The CAISO will further validate the upward Transition Costs dollar values using the two rules described below, and will include the validated values in the Master File. The Scheduling Coordinator shall also submit a fuel input value, which consists of a quantity of natural gas in MMBtu, for each downward MSG Transition such that the fuel input value accurately reflects the operating characteristics of the Multi-Stage Generating Resource, which the CAISO may reject if perceived to be inconsistent with such characteristics. Through the Bid validation process in the CAISO Markets, the CAISO will adjust both the downward and upward Transition Costs by the daily Gas Price Index when Scheduling Coordinators submit Bids into the CAISO Markets for Multi-Stage Generating Resources to calculate the Transition Costs per the submitted Bid. For the first thirty (30) days following the effective date of this provisions, if the CAISO is not able to validate the Transition Costs amounts submitted by the Scheduling Coordinator for a Multi-Stage Generating Resource prior to the effective date of this provision, the applicable Transition Costs for this first month shall be \$0.

Rule 1: The CAISO will constrain the Transition Costs along each of the feasible, unidirectional MSG Transition paths from Off to each MSG Configuration such that their sum is between one-hundred (100) percent and one-hundred twenty five (125) percent of the MSG Configuration's proxy Start-Up Cost value plus ten (10) percent; where the MSG Configuration's proxy Start-Up Cost value is determined using the same methodology provided in Section 30.4.1.1 except that the CAISO will use the monthly Gas Price Index as opposed to the daily value. If the Scheduling Coordinator flags an MSG Configuration as able to

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Start-Up as part of its registration requirements in Section 27.8, the CAISO will use a value of \$0 as the lower bound for the MSG Transition paths up to the MSG Configuration flagged as able to Start-Up.

Rule 2: The CAISO will validate that the sum of Transition Costs for incremental MSG Transitions along a feasible, unidirectional path between two MSG Configurations is between one-hundred (100) percent and one-hundred twenty five (125) percent of the Transition Cost associated with the direct transition to the target MSG Configuration.

30.5 Bidding Rules

30.5.1 General Bidding Rules

- (a) All Energy and Ancillary Services Bids of each Scheduling Coordinator submitted to the DAM for the following Trading Day shall be submitted at or prior to 10:00 a.m. on the day preceding the Trading Day, but no sooner than seven (7) days prior to the Trading Day. All Energy and Ancillary Services Bids of each Scheduling Coordinator submitted to the HASP for the following Trading Day shall be submitted starting from the time of publication, at 1:00 p.m. on the day preceding the Trading Day, of DAM results for the Trading Day, and ending seventy-five (75) minutes prior to each applicable Trading Hour in the RTM. The CAISO will not accept any Energy or Ancillary Services Bids for the following Trading Day between 10:00 a.m. on the day preceding the Trading Day and the publication, at 1:00 p.m. on the day preceding the Trading Day, of DAM results for the Trading Day;
- (b) Bid prices submitted by a Scheduling Coordinator for Energy accepted and cleared in the IFM and scheduled in the Day-Ahead Schedule may be increased or decreased in the HASP. Bid prices for Energy submitted but not scheduled in the Day-Ahead Schedule may be increased or decreased in the HASP. Incremental Bid prices for Energy associated with Day-Ahead AS or RUC Awards in Bids submitted to the HASP may be revised. Scheduling Coordinators may revise ETC Self-Schedules for Supply only in the HASP to the extent such a change is consistent with TRTC Instructions provided to the CAISO by the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Participating TO in accordance with Section 16. Scheduling Coordinators may revise TOR Self-Schedules for Supply only in the HASP to the extent such a change is consistent with TRTC Instructions provided to the CAISO by the Non-Participating TO in accordance with Section 17. Energy associated with awarded Ancillary Services capacity cannot be offered in the HASP or Real-Time Market separate and apart from the awarded Ancillary Services capacity;

- (c) Scheduling Coordinators may submit Energy, AS and RUC Bids in the DAM that are different for each Trading Hour of the Trading Day;
- (d) Bids for Energy or capacity that are submitted to one CAISO Market, but are not accepted in that market are no longer a binding commitment and Scheduling Coordinators may submit Bids in a subsequent CAISO Market at a different price;
- (e) The CAISO shall be entitled to take all reasonable measures to verify that Scheduling Coordinators meet the technical and financial criteria set forth in Section 4.5.1 and the accuracy of information submitted to the CAISO pursuant to this Section 30; and
- (f) In order to retain the priorities specified in Section 31.4 and 34.10 for scheduled amounts in the Day-Ahead Schedule associated with ETC and TOR Self-Schedules or Self-Schedules associated with Regulatory Must-Take Generation, a Scheduling Coordinator must submit to the HASP and Real-Time Market ETC or TOR Self-Schedules, or Self-Schedules associated with Regulatory Must-Take Generation, at or below the Day-Ahead Schedule quantities associated with the scheduled ETC, TOR or Regulatory Must-Take Generation Self-Schedules. If the Scheduling Coordinator fails to submit such HASP or Real-Time Market ETC, TOR or Regulatory Must-Take Generation Self-Schedules, the defined scheduling priorities of the ETC, TOR, or Regulatory Must-Take Generation Day-Ahead Schedule quantities may be subject to adjustment in the HASP and the Real-Time Market as further provided in Section 31.4 and 34.10 in order to meet operating conditions.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (g) For Multi-Stage Generating Resources that receive a Day-Ahead Schedule, are awarded a RUC Schedule, or receive an Ancillary Services Award the Scheduling Coordinator must submit an Energy Bid in the Real-Time Market for the same Trading Hour(s). If the Scheduling Coordinator submits an Economic Bid for such Trading Hour(s), the Economic Bid must be for either: the same MSG Configuration scheduled or awarded in the Integrated Forward Market, or the MSG Configuration committed in RUC. If the Scheduling Coordinator submits a Self-Schedule in the Real-Time Market for such Trading Hour(s), then the Energy Self-Schedule may be submitted in any registered MSG Configuration, including the MSG Configuration awarded in the Day-Ahead Market, that can support the awarded Ancillary Services (as further required by Section 8). Scheduling Coordinators for Multi-Stage Generating Resources may submit into the Real-Time Market bids from up to six (6) MSG Configurations in addition to the MSG Configuration scheduled or awarded in the Integrated Forward Market and Residual Unit Commitment, provided that the MSG Transitions between the MSG Configurations bid into the Real-Time Market are feasible and the transition from the previous Trading Hour are also feasible.
- (h) For the Trading Hours that Multi-Stage Generating Resources do not have a CAISO Schedule or award from a prior CAISO Market run, the Scheduling Coordinator can submit up to six (6) MSG Configurations into the RTM.
- (i) A Scheduling Coordinator cannot submit a Bid to the CAISO Markets for a MSG Configuration into which the Multi-Stage Generating Resource cannot transition due to lack of Bids for the specific Multi-Stage Generating Resource in other MSG Configurations that are required for the requisite MSG Transition.
- (j) In order for Multi-Stage Generating Resource to meet any Resource Adequacy must-offer obligations, the responsible Scheduling Coordinator must submit either an Economic Bid or Self-Schedule for at least one MSG Configuration into the Day-Ahead Market and Real-Time Market that is capable of fulfilling that

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Resource Adequacy obligation, as feasible. The Economic Bid shall cover the entire capacity range between the maximum bid-in Energy MW and the higher of Self-Scheduled Energy MW and the Multi-Stage Generating Resource plant-level PMin.

- (k) For any given Trading Hour, a Scheduling Coordinator may submit Self-Schedules and/or Submissions to Self-Provide Ancillary Services in only one MSG Configuration for each Generating Unit or Dynamic Resource-Specific System Resource.
- (l) In any given Trading Hour in which a Scheduling Coordinator has submitted a Self-Schedule for a Multi-Stage Generating Resource, the Scheduling Coordinator may also submit Bids for other MSG Configurations provided that they concurrently submit Bids that enable the applicable CAISO Market to transition the Multi-Stage Generating Resource to other MSG Configurations.
- (m) If in any given Trading Hour the Multi-Stage Generating Resource was awarded Regulation or Operating Reserves in the IFM, any Self-Schedules or Submissions to Self-Provide Ancillary Services the Scheduling Coordinator submits for that Multi-Stage Generating Resource in the RTM must be for the same MSG Configuration for which Regulation or Operating Reserve is Awarded in IFM for that Multi-Stage Generating Resource in that given Trading Hour.
- (n) If a Multi-Stage Generating Resource has received a binding RUC Start-Up Instruction as provided in Section 31, any Self-Schedule or Submission to Self-Provide Ancillary Services in the RTM must be in the same MSG Configuration committed in RUC.
- (o) If in any given Trading Hour the Multi-Stage Generating Resource is scheduled for Energy in the IFM, any Self-Schedules the Scheduling Coordinator submits for that Multi-Stage Generating Resource in the RTM must be for the same MSG Configuration for which Energy is scheduled in IFM for that Multi-Stage Generating Resource in that given Trading Hour.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (p) For a Multi-Stage Generating Resource, the Bid(s) submitted for the resource's configuration(s) shall collectively cover the entire capacity range between the maximum bid-in Energy MW and the higher of the Self-Scheduled Energy MW and the Multi-Stage Generating Resource plant-level PMin. This rule shall apply separately to the Day-Ahead Market and the Real-Time Market.

30.5.2 Supply Bids

30.5.2.1 Common Elements for Supply Bids

In addition to the resource-specific Bid requirements of this Section, all Supply Bids must contain the following components: Scheduling Coordinator ID Code; Resource Location or Resource ID, as appropriate; MSG Configuration ID, as applicable; Resource Location; PNode or Aggregated Pricing Node as applicable; Energy Bid Curve; Self-Schedule component; Ancillary Services Bid; RUC Availability Bid as applicable, the CAISO Market to which the Bid applies; Trading Day to which the Bid applies; Priority Type (if any). Supply Bids offered in the CAISO Markets must be monotonically increasing. Energy Bids in the RTM must also contain a Bid for Ancillary Services to the extent the resource is certified and capable of providing Ancillary Service in the RTM up to the registered certified capacity for that Ancillary Service less any Day-Ahead Ancillary Services Awards.

Scheduling Coordinators must submit the applicable Supply Bid components, including Self-Schedules, for the submitted MSG Configuration.

30.5.2.2 Supply Bids for Participating Generators

In addition to the common elements listed in Section 30.5.2.1, Supply Bids for Participating Generators shall contain the following components as applicable: Start-Up Bid, Minimum Load Bid, Ramp Rate, Minimum and Maximum Operating Limits; Energy Limit, Regulatory Must-Take/Must-Run Generation; Contingency Flag; and Contract Reference Number (if any). Scheduling Coordinators submitting these Bid components for a Multi-Stage Generating Resource must do so for the submitted MSG Configuration. A Scheduling Coordinator for a Physical Scheduling Plant or a System Unit may include Generation Distribution Factors as part of its Supply Bid. If the Scheduling Coordinator has not submitted the Generation Distribution Factors applicable for the Bid, the CAISO will use default Generation Distribution Factors stored in the Master File. All Generation Distribution Factors used by the CAISO will be

normalized based on Outage data that is available to the automated market systems. A Multi-Stage Generating Resource and its MSG Configurations are registered under a single Resource ID and Scheduling Coordinator for the Multi-Stage Generating Resource must submit all Bids for the resource's MSG Configurations under the same Resource ID. For a Multi-Stage Generating Resources Scheduling Coordinators may submit bid curves for up to ten individual MSG Configurations of their Multi-Stage Generating Resources into the Day-Ahead Market and up to three individual MSG Configurations into the Real-Time Market. Scheduling Coordinators for Multi-Stage Generating Resources must submit a single Operational Ramp Rate for each MSG Configuration for which it submits a supply Bid either in the Day-Ahead Market or Real-Time Market. For Multi-Stage Generating Resources the Scheduling Coordinator may submit the Transition Times, which cannot be greater than the maximum Transition Time registered in the Master File. To the extent the Scheduling Coordinator does not submit the Transition Time that is a registered feasible transition the CAISO will use the registered maximum Transition Time for that MSG Transition for the specific Multi-Stage Generating Resource.

30.5.2.3 Supply Bids for Participating Loads, Including Pumped-Storage Hydro Units and Aggregated Participating Loads

In addition to the common elements listed in Section 30.5.2.1, Scheduling Coordinators submitting Supply Bids for Participating Loads, which includes Pumping Load or Pumped-Storage Hydro Units, may include the following components: Pumping Level (MW), Minimum Load Bid (Generation mode only of a Pumped-Storage Hydro Unit), Load Distribution Factor, Ramp Rate, Energy Limit, Pumping Cost, and Pump Shut-Down Costs. If no values for Pumping Cost or Pump Shut-Down Costs are submitted, the CAISO will generate these Bid components based on values in the Master File. Scheduling Coordinators may only submit Supply Bids for Aggregated Participating Loads by using a Generating Unit or Physical Scheduling Plant Resource ID for the Demand reduction capacity represented by the Aggregated Participating Load as set forth in a Business Practice Manual. The CAISO will use Generation Distribution Factors provided by the Scheduling Coordinator for the Aggregated Participating Load.

30.5.2.4 Supply Bids for System Resources

In addition to the common elements listed in Section 30.5.2.1, Supply Bids for System Resources shall also contain: the relevant Ramp Rate; Start-Up Costs; and Minimum Load Costs. Resource-Specific System Resources may elect the Proxy Cost option or Registered Cost option for Start-Up Costs and

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Minimum Load Costs as provided in Section 30.4. Other System Resources are not eligible to recover Start-Up Costs and Minimum Load Costs. Resource-Specific System Resources are eligible to participate in the Day-Ahead Market on an equivalent basis as Generating Units and are not obligated to participate in RUC or the RTM if the resource did not receive a Day-Ahead Schedule unless the resource is a Resource Adequacy Resource. If the Resource-Specific System Resource is a Resource Adequacy Resource, the Scheduling Coordinator for the resource is obligated to make it available to the CAISO Market as prescribed by Section 40.6. Dynamic Resource-Specific System Resources are also eligible to participate in the HASP and RTM on an equivalent basis as Generating Units. Non-Dynamic Resource-Specific System Resources will be treated like other System Resources in the HASP and RTM. The quantity (in MWh) of Energy categorized as Interruptible Imports (non-firm imports) can only be submitted through Self-Schedules in the Day-Ahead Market and cannot be incrementally increased in the HASP or RTM. Bids submitted to the Day-Ahead Market for ELS Resources will be applicable for two days after they have been submitted and cannot be changed the day after they have been submitted.

30.5.2.4.1 Intertie Block Bids

Intertie Block Bids must contain the same energy Bid price for all hours of the period for which the Intertie Block Bid is submitted. Intertie Block Bids may only be submitted in the DAM.

30.5.2.5 Supply Bids for Metered Subsystems

Consistent with the bidding rules specified in this Section 30.5, Scheduling Coordinators that represent MSS Operators may submit Bids for Energy and Ancillary Services, including Self-Schedules and Submissions to Self-Provide an Ancillary Service, to the DAM. All Bids to supply Energy by MSS Operators must identify each Generating Unit on an individual unit basis. The CAISO will not accept aggregated Generation Bids without complying with the requirements of Section 4.9.12 of the CAISO Tariff. All Scheduling Coordinators that represent MSS Operators must submit Demand Bids at the relevant MSS LAP. Scheduling Coordinators that represent MSS Operators must comply with Section 4.9 of the CAISO Tariff. Scheduling Coordinators that represent MSS Operators that have opted out of RUC participation pursuant to Section 31.5 must Self-Schedule one hundred percent (100%) of the Demand Forecast for the MSS. For an MSS that elects Load following, the MSS Operator shall also self-schedule or bid Supply to match the Demand Forecast. All Bids for MSSs must be identify each Generating Unit

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

on an individual unit basis or a System Unit. For an MSS that elects Load following consistent with Section 4.9.13.2, the Scheduling Coordinator for the MSS Operator must include the following additional information with its Bids: the Generating Unit(s) that are Load following; the range of the Generating Unit(s) being reserved for Load following; whether the quantity of Load following capacity is either up or down; and, if there are multiple Generating Units in the MSS, the priority list or distribution factors among the Generating Units. The CAISO will not dispatch the resource within the range declared as Load following capacity, leaving that capacity entirely available for the MSS to dispatch. The CAISO uses this information in the IFM runs and the RUC to simulate MSS Load following. The Scheduling Coordinator for the MSS Operator may change these characteristics through the Bid submission process in the HASP. If the Load following resource is also an RMR Unit, the MSS Operator must not specify the Maximum Net Dependable Capacity specified in the RMR Contract as Load following up or down capacity to allow the CAISO to access such capacity for RMR Dispatch.

30.5.2.6 Ancillary Services Bids

There are four distinct Ancillary Services: Regulation Up, Regulation Down, Spinning Reserve and Non-Spinning Reserve. A resource shall be eligible to provide each Ancillary Service if it has complied with the CAISO's certification and testing requirements as contained in Appendix K and the CAISO's Operating Procedures. Scheduling Coordinators may use Dynamic System Resources to Self-Provide Ancillary Services as specified in Section 8. Scheduling Coordinators may not use Non-Dynamic System Resources to Self-Provide Ancillary Services. All System Resources, including Dynamic System Resources and Non-Dynamic System Resources, will be charged the Shadow Price as prescribed in Section 11.10, for any awarded Ancillary Services. A Scheduling Coordinator may submit Ancillary Services Bids for Regulation Up, Regulation Down, Spinning Reserve, and Non-Spinning Reserve for the same capacity by providing a separate price in \$/MW per hour as desired for each Ancillary Service. The Bid for each Ancillary Services is a single Bid segment. Only resources certified by the CAISO as capable of providing Ancillary Services are eligible to provide Ancillary Services and submit Ancillary Services Bids. In addition to the common elements listed in Section 30.5.2.1, all Ancillary Services Bid components of a Supply Bid must contain the following: (1) the type of Ancillary Service for which a Bid is being submitted; (2) Ramp Rate (Operating Reserve Ramp Rate and Regulation Ramp Rate, if

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

applicable); and (3) Distribution Curve for Physical Scheduling Plant or System Unit. A Scheduling Coordinator may only submit an Ancillary Services Bid or Submission to Self-Provide an Ancillary Service for Multi-Stage Generating Resources for the Ancillary Service for which the specific MSG Configurations are certified. For any such certified MSG Configurations the Scheduling Coordinator may submit only one Operating Reserve Ramp Rate and Regulation Ramp Rate. An Ancillary Services Bid submitted to the Day-Ahead Market when submitted to the Day-Ahead Market may be, but is not required to be, accompanied by an Energy Bid that covers the capacity offered for the Ancillary Service. Submissions to Self-Provide an Ancillary Services submitted to the Day-Ahead Market when submitted to the Day-Ahead Market may be, but are not required to be, accompanied by an Energy Bid that covers the capacity to be self-provided. If a Scheduling Coordinator's Submission to Self-Provide an Ancillary Service is qualified as specified in Section 8.6, the Scheduling Coordinator must submit an Energy Bid that covers the self-provided capacity prior to the close of the Real-Time Market for the day immediately following the Day-Ahead Market in which the Ancillary Service Bid was submitted. Except as provided below, the Self-Schedule for Energy need not include a Self-Schedule for Energy from the resource that will be self-providing the Ancillary Service. If a Scheduling Coordinator is self-providing an Ancillary Service from a Fast Start Unit, no Self-Schedule for Energy for that resource is required. If a Scheduling Coordinator proposes to self-provide Spinning Reserve, the Scheduling Coordinator is obligated to submit a Self-Schedule for Energy for that particular resource, unless as discussed above the particular resource is a Fast Start Unit. When submitting Ancillary Service Bids in the HASP and Real-Time Market, Scheduling Coordinators for resources that either have been awarded or self-provide Spinning Reserve or Non-Spinning Reserve capacity in the Day-Ahead Market must submit an Energy Bid for at least the awarded or self-provided Spinning Reserve or Non-Spinning Reserve capacity, otherwise the CAISO will apply the Bid validation rules described in Section 30.7.6.1.

As provided in Section 30.5.2.6.4, a Submission to Self-Provide an Ancillary Service shall contain all of the requirements of a Bid for Ancillary Services with the exception of Ancillary Service Bid price information. In addition, Scheduling Coordinators must comply with the Ancillary Services requirements of Section 8. Scheduling Coordinators submitting Ancillary Services Bids for System Resources in the HASP or Real-Time Market must also submit an Energy Bid for the associated Ancillary Services Bid

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

under the same Resource ID, otherwise the bid validation rules in Section 30.7.6.1 will apply to cover any portion of the Ancillary Services Bid not accompanied by an Energy Bid. As described in Section 33.7, if the resource is a Non-Dynamic System Resource, the CAISO will only use the Ancillary Services Bid in the HASP optimization and will not use the associated Energy Bid for the same Resource ID to schedule Energy from the Non-Dynamic System Resource in the HASP. Scheduling Coordinators must also comply with the bidding rules associated with the must offer requirements for Ancillary Services specified in Section 40.6.

30.5.2.6.1 Regulation Up or Regulation Down Bid Information

In the case of Regulation Up or Regulation Down, the Ancillary Services Bid or submission to self-provide must also contain: (a) the upward and downward range of generating capacity over which the resource is willing to provide Regulation within a range from a minimum of ten (10) minutes to a maximum of thirty (30) minutes; and (b) the Bid price of the capacity reservation, stated separately for Regulation Up and Regulation Down (\$/MW). In the case of Regulation Up or Regulation Down from Dynamic System Resources, the Ancillary Services Bid must also contain the Contract Reference Number, if applicable. Ancillary Services Bids submitted to the Day-Ahead or Real-Time Market for Regulation need not be accompanied by an Energy Supply Bid that covers the Ancillary Services capacity being offered. A Regulation Down Bid will be erased unless there is an Energy Supply Bid or Energy Self-Schedule at a level that would permit the resource to provide Regulation Down to its lower Regulation Limit. A submission to self-provide Regulation Down will be erased unless there is an Energy Self-Schedule at a level that would permit the resource to provide Regulation Down to its lower Regulation Limit. A Regulation Up Bid will be erased unless there is an Energy Supply Bid or Energy Self-Schedule at a level that would permit the resource to provide Regulation Up within its Regulation limit. A submission to self-provide Regulation Up will be erased unless there is an Energy Self-Schedule at a level that would permit the resource to provide Regulation Up within its Regulation Limit.

30.5.2.6.2 Spinning Reserve Capacity Bid Information

In the case of Spinning Reserve capacity, the Ancillary Services Bid must also contain: (a) MW of additional capability synchronized to the system, immediately responsive to system frequency, and available within ten (10) minutes; (b) Bid price of capacity reservation, and (c) an indication whether the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

capacity reserved would be available to supply Imbalance Energy only in the event of the occurrence of an unplanned Outage, a Contingency or an imminent or actual System Emergency (Contingency Flag). In the case of Spinning Reserve capacity from System Resources, the Ancillary Services Bid must also contain: (a) Interchange ID code of the selling entity, (b) Schedule ID (NERC ID number, and (c) a Contract Reference Number, if applicable. Ancillary Services Bids and Submissions to Self-Provide an Ancillary Services submitted to the Real-Time Market for Spinning Reserves must also submit an Energy Bid that covers the Ancillary Services capacity being offered into the Real-Time Market.

30.5.2.6.3 Non-Spinning Reserve Capacity

In the case of Non-Spinning Reserve, the Ancillary Service Bid must also contain: (a) the MW capability available within ten (10) minutes; (b) the Bid price of the capacity reservation; (c) time of synchronization following notification (minutes); and (d) an indication whether the capacity reserved would be available to supply Imbalance Energy only in the event of the occurrence of an unplanned Outage, a Contingency or an imminent or actual System Emergency (Contingency Flag). In the case of Non-Spinning Reserve Capacity from System Resources, the Ancillary Services Bid must also contain: (a) Interchange ID code of the selling entity, (b) Schedule ID (NERC ID number); and (c) a Contract Reference Number, if applicable. In the case of Non-Spinning Reserve Capacity from Participating Load within the CAISO Balancing Authority Area, the Ancillary Service Bid must also contain: (a) a Load identification name and Location Code, (b) Demand reduction available within ten (10) minutes, (c) time to interruption following notification (minutes), and (d) maximum allowable curtailment duration (hour). In the case of Aggregated Participating Load, and Proxy Demand Resources, Scheduling Coordinators must submit Bids using a Generating Unit, Physical Scheduling Plant Resource ID, or Resource ID for the Proxy Demand Resource for the Demand reduction capacity of the Aggregated Participating Load through a Bid to provide Non-Spinning Reserve or a Submission to Self-Provide an Ancillary Service for Non-Spinning Reserve. Ancillary Services Bids and Submissions to Self-Provide an Ancillary Services submitted to the Real-Time Market for Non-Spinning Reserves must also submit an Energy Bid that covers the Ancillary Services capacity being offered into the Real-Time Market.

30.5.2.6.4 Additional Rules For Self-Provided Ancillary Services

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Scheduling Coordinators electing to self-provide Ancillary Services shall supply the information referred to in this Section 30.5 in relation to each Ancillary Service to be self-provided, excluding the capacity price information, but including the name of the trading Scheduling Coordinator in the case of Inter-Scheduling Coordinator Ancillary Service Trades. The portion of the Energy Bid that corresponds to the high end of the resource's operating range, shall be allocated to any awarded or Self-Provided Ancillary Services in the following order from higher to lower capacity: (a) Regulation Up; (b) Spinning Reserve; and (c) Non-Spinning Reserve. For resources providing Regulation Up, the upper regulating limit shall be used if it is lower than the highest operating limit. The remaining portion of the Energy Bid (i.e. that portion not associated with capacity committed to provide Ancillary Services) shall constitute a Bid to provide Energy.

30.5.2.7 RUC Availability Bids

Scheduling Coordinators may submit RUC Availability Bids for specific Generating Units capacity that is not Resource Adequacy Capacity or CPM Capacity of in the DAM. Scheduling Coordinators for Resource Adequacy Capacity or CPM Capacity must participate in RUC to the extent that such capacity is not reflected in an IFM Schedule but need not submit RUC Availability Bids, Resource Adequacy Capacity participating in RUC will be optimized using a zero dollar (\$0/MW-hour) RUC Availability Bid. For Multi-Stage Generating Resources, the RUC Availability Bids shall be submitted at the MSG Configuration. Capacity that does not have Bids for Supply of Energy in the IFM will not be eligible to participate in the RUC process. The RUC Availability Bid component is MW-quantity of non-Resource Adequacy Capacity in \$/MW per hour.

30.5.3 Demand Bids

Each Scheduling Coordinator representing Demand, including Non-Participating Load and Aggregated Participating Load, shall submit Bids indicating the hourly quantity of Energy in MWh that it intends to purchase in the IFM for each Trading Hour of the Trading Day. Scheduling Coordinators must submit Demand Bids, including Self Schedules, for CAISO Demand at Load Aggregation Points except as provided in Section 30.5.3.2.

30.5.3.1 Demand Bids Components

Demand Bids must have the following components: Scheduling Coordinator ID Code; a Demand Bid curve that is a monotonically decreasing staircase function of no more than ten (10) segments defined by

eleven (11) ordered pairs of MW and \$/MWh; Location Code for the LAP, Custom LAP or PNode, as applicable; and hourly scheduled MWh within the range of the Bid curve, including any zero values, for each Settlement Period of the Trading Day.

30.5.3.2 Exceptions to Requirement for Submission of Demand Bids and Settlement at the LAP

The following are exceptions to the requirement that Demand Bids be submitted and settled at the LAP:

- (a) ETC or TOR Self-Schedules submitted consistent with the submitted TRTC Instructions;
- (b) Participating Load and Aggregated Participating Load Bids for Supply and Demand may be submitted and settled at a PNode or Custom LAP, as appropriate; and
- (c) Export Bids are submitted and settled at Scheduling Points, which do not constitute a LAP.

30.5.4 Wheeling Through Transactions

A Wheeling Through transaction consists of an Export Bid and an Import Bid with the same Wheeling reference (a unique identifier for each Wheeling Through transaction). If the Wheeling reference does not match at the time the relevant market closes, the Wheeling Through transaction will be erased; this includes any Energy Bid or Self-Schedule for the resource for that Trading Hour. Wheeling Through transactions with matching Wheeling references will be kept balanced in the IFM and in the HASP and RTM; that is, to the extent an Export Bid or Import Bid or Self-Schedule specify different quantities, only that matching quantity will clear the CAISO Markets.

30.6 Bidding and Scheduling of Proxy Demand Resources

30.6.1 Bidding and Scheduling Generally

30.6.2 [NOT USED]

30.6.3 Net Benefits Test for Scheduling of PDRs

The CAISO will apply a net benefits test to determine whether Bids for Proxy Demand Resources qualify as a Schedule as set forth in Section 31.

30.6.3.1 Supply Curve Used in Applying the Net Benefits Test

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

The CAISO will generate one (1) on-peak supply curve and one (1) off-peak supply curve for each month that depicts the system-wide aggregated power supplies at different offer prices in the CAISO Markets within that month. The CAISO will generate these two supply curves for each month, using the following sequential methodology:

- (i) The CAISO will collect supply curve data for the month that is twelve (12) months prior to the month for which the CAISO is generating the supply curves (the reference month), using all mitigated Bids in the Real-Time Market from any Generating Unit that is either committed or uncommitted and excluding Import Bids and Export Bids.
- (ii) The CAISO will adjust the supply curve data to reflect differences in resource availability and fuel prices between the target month and the reference month. Significant changes in resource availability will be determined using the averages of the hourly supply curves over the entire reference month, with the supply quantities being averaged for every price level. Significant changes in fuel prices will be determined using the simple average of the Pacific Gas and Electric Company citygate price and the Southern California Edison Company citygate price, or, if those prices are unavailable, using the Henry Hub price. For every supply quantity, the corresponding price will be scaled using a scaling factor defined as the forward gas price for the Trading Month divided by the historical average gas price for the reference month. These adjustments will result in two representative supply curves for the target month, one (1) on-peak and one (1) off-peak.
- (iii) The CAISO will smooth the representative supply curves to twice differentiable using an exponential form function and applying a price window that is likely to contain the threshold Market Clearing Price. The price window may need to be adjusted in the process until the smoothed supply curves fit the representative supply curves closely.

Using the smoothed supply curves, the CAISO will determine a candidate threshold Market Clearing Price for the on-peak and a threshold Market Clearing Price for the off-peak corresponding to the point on each supply curve beyond which (i) the product of the amount of supplied Power (prior to the dispatch of Proxy Demand Resources) and the reduction in Market Clearing Price that results from the dispatch of Proxy Demand Resources exceeds (ii) the product of the Market Clearing Price (prior to the dispatch of Proxy

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Demand Resources) and the reduction in the amount of supplied Power that results from the dispatch of Proxy Demand Resources. If the candidate threshold Market Clearing Price is outside the corresponding price window being used, the price window needs to be adjusted and this process will be repeated until the price window contains the candidate threshold Market Clearing Price and thus makes it the final threshold Market Clearing Price. If multiple candidate threshold Market Clearing Prices exist, the candidate threshold Market Clearing Price that is concave on the supply curve (a supply function of price) will be the final threshold Market Clearing Price.

30.6.3.2 Information Posted on CAISO Website

The net benefits test will be posted on the CAISO website, along with supporting documentation and the threshold Market Clearing Prices that were in effect in the previous twelve (12) months, and any updated supply curve analysis. The CAISO will post the threshold Market Clearing Prices determined for each month on the CAISO Website by the fifteenth (15th) day of the immediately preceding month.

30.7 Bid Validation

The CAISO shall validate submitted Bids pursuant to the procedures set forth in this Section 30.7 and the rules set forth in the Business Practice Manuals.

30.7.1 Scheduling Coordinator Access

Each Scheduling Coordinator will be provided access to the CAISO's secure communication system to submit, modify and cancel Bids prior to the close of both the DAM and HASP, as specified in Section 30.5.1. The CAISO shall provide information regarding submitted Bids including, but not be limited to, the following: (i) notification of acceptance; (ii) notification of validation; (iii) notification of rejection; (iv) notification of status; (v) notification of submission error(s); and (vi) default modification or generation of Bids as further provided below, if any, on behalf of Scheduling Coordinators.

30.7.2 Timing Of CAISO Validation

Once a Bid is submitted to the CAISO Markets, the Bid is available for validation, which is conducted in multiple steps. Clean Bids will be generated after Market Close.

30.7.3 DAM Validation

30.7.3.1 Validation Prior to Market Close and Master File Update

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

The CAISO conducts Bid validation in three steps as described below. For a Multi-Stage Generating Resource the validation described herein is done for each submitted MSG Configuration.

Step 1: The CAISO will validate all Bids after submission of the Bid for content validation which determines that the Bid adheres to the structural rules required of all Bids as further described in the Business Practices Manuals. If the Bid fails any of the content level rules the CAISO shall assign it a rejected status and the Scheduling Coordinator must correct and resubmit the Bid.

Step 2: After the Bids are successfully validated for content, but prior to the Market Close of the DAM, the Bids will continue through the second level of validation rules to verify that the Bid adheres to the applicable CAISO Market rules and if applicable, limits based on Master File data. If the Bid fails any level two validation rules, the CAISO shall assign the Bid as invalid and the Scheduling Coordinator must either correct or resubmit the Bid.

Step 3: If the Bid successfully passes validation in Step 2, it will continue through the third level of validation where the Bid will be analyzed based on its contents to identify any missing Bid components that must be either present for the Bid to be valid consistent with the market rules contained in Article III of this CAISO Tariff and as reflected in the Business Practice Manuals. At this stage the Bid will either be automatically modified for correctness and assigned a status of conditionally modified or modified, or if it can be accepted as is, the Bid will be assigned a status of conditionally valid, or valid. A Bid will be automatically modified and assigned a status of modified or conditionally modified Bid, whenever the CAISO inserts or modifies a Bid component. The CAISO will insert or modify a Bid component whenever (1) a Self-Schedule quantity is less than the lowest quantity specified as an Economic Bid for either an Energy Bid or Demand Bid, in which case the CAISO extends the Self-Schedule to cover the gap; (2) for non-Resource Adequacy Resources, the CAISO will extend the Energy Bid Curve using Proxy Costs to cover any capacity in a RUC Bid component, if necessary; and (3) for a Resource Adequacy Resource that is not a Use-Limited Resource, the CAISO will extend the Energy Bid Curve using Proxy Costs to cover any capacity in a RUC Bid component and, if necessary, up to the full registered Resource Adequacy Capacity. The CAISO will generate a Proxy Bid or extend an Energy Bid or Self-Schedule to cover any RUC Award or Day-Ahead Schedule in the absence of any Self-Schedule or Economic Bid components, or to fill in any gaps between any Self-Schedule Bid and any Economic Bid components to

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

cover a RUC Award or Day-Ahead Schedule. To the extent that an Energy Bid to the HASP/RTM is not accompanied by an Ancillary Services Bid, the CAISO will insert a Spinning Reserve and Non-Spinning Reserve Ancillary Services Bid at \$ 0/MW for any certified Operating Reserve capacity. The CAISO will also generate a Self-Schedule Bid for any Generating Unit that has a Day-Ahead Schedule but has not submitted Bids in HASP/RTM, up to the quantity in the Day-Ahead Schedule. Throughout the Bid evaluation process, the Scheduling Coordinator shall have the ability to view the Bid and may choose to cancel the Bid, modify and re-submit the Bid, or leave the modified, conditionally modified or valid, conditionally valid Bid as is to be processed in the designated CAISO Market. The CAISO will not insert or extend any Bid for Regulation Up or Regulation Down in the Real-Time Market for a Use-Limited Resource except as provided in Section 40.6.8. The CAISO will not insert or extend a Spinning Reserve or Non-Spinning Reserve Ancillary Service Bid at \$0 in the Real-Time Market for any certified Operating Reserve capacity of a resource unless that resource submits an Energy Bid and fails to submit an Ancillary Service Bid in the Real-Time Market.

30.7.3.2 Master File Data Update

Except as otherwise prescribed in this tariff, and unless the CAISO has issued a temporary suspension, once a day the Master File data is updated with changes to the Master File that were submitted between at least five (5) and up to eleven (11) Business Days in advance, after which all conditional Bids must be re-validated prior to the trading period when the Bid will take effect. After this re-validation takes place, the status of all conditionally modified and conditionally valid Bids may be changed to modified or valid, if the Bid period is for the next relevant DAM.

30.7.3.3 Validation Prior to Market Close and After Master File Update

Prior to the Market Close of the DAM, after the Master File data has been updated, all Bids must be re-validated using the same process as described in Section 30.7.3.1 to produce either valid Bids or modified Bids. Throughout this process the Scheduling Coordinator shall have the ability to view the Bid and may choose to re-submit (at which point the Bid would undergo the Bid validation process described in this Section 30.7 again), cancel, or modify the Bid. Valid or modified Bids that are not re-submitted or cancelled become Clean Bids after the Market Close of the DAM. Modified Bids for Resource Adequacy Resources will reflect the full capability of the resource as defined in the Master File.

30.7.3.4 Validation after Market Close

To the extent that Scheduling Coordinators fail to enter a Bid for resource that is required to submit Bids in the full range of available capacity consistent with the Resource Adequacy provisions of Section 40, the CAISO will create a Bid for the Scheduling Coordinator, which is referred to as the Generated Bid. This does not apply to Load-following MSSs. The Generated Bid will be created only after the Market Close for the DAM and will be based on data registered in the Master File, and, if applicable, published natural gas pricing data. The Scheduling Coordinator may view Generated Bids, but may not modify such Bids. The CAISO will provide notice to the Scheduling Coordinator of the use of a Generated Bid prior to Market Clearing of the IFM. In addition validation of export priority pursuant to Sections 31.4 and 34.10.1 and Wheeling Through transactions pursuant to Section 30.5.4 occur after the Market Close for the DAM.

30.7.3.5 Bid Validation Rules for Multi-Stage Generating Resources

If a Scheduling Coordinator does not submit a Bid in the Day-Ahead Market or Real-Time Market for a Multi-Stage Generating Resource with a Resource Adequacy must-offer obligation at a MSG Configuration that can meet the applicable Resource Adequacy must-offer obligation, the CAISO will create a Generated Bid for the default Resource Adequacy MSG Configuration. If the Multi-Stage Generating Resource is not capable of Start-Up in the default Resource Adequacy MSG Configuration, the CAISO will create a Generated Bid for every MSG Configuration in the registered Default Resource Adequacy Path. In the event that the Scheduling Coordinator does not submit a Bid in compliance with section 30.5.1(p), the CAISO will create a Generated Bid for all of the capacity not bid into the CAISO Market between the maximum bid-in Energy MW and the higher of Self-Scheduled Energy MW and the Multi-Stage Generating Resource plant-level PMin. If the Scheduling Coordinator submits a Bid for the Multi-Stage Generating Resource, the CAISO will create this Generated Bid for the registered MSG Configurations before the Market Close, and if it does not submit such a Bid the CAISO will create this Generated Bid after the Market Close. Any Generated Bid created by the CAISO for the default Resource Adequacy MSG Configuration will be in addition to the MSG Configurations bid into the Real-Time Market by the responsible Scheduling Coordinator. If the Scheduling Coordinator submits a Bid in the Day-Ahead Market or Real-Time Market for a MSG Configuration that is not the default Resource Adequacy MSG Configuration and that does not cover the full amount of the resource's Resource

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Adequacy requirements, the CAISO will create a Generated Bid for the full Resource Adequacy Capacity. Before the market closes, if a Scheduling Coordinator submits a Bid in the Day-Ahead Market or Real-Time Market for the default Resource Adequacy MSG Configuration of a Multi-Stage Generating Resource that only meets part of the resource's Resource Adequacy must-offer obligation, the CAISO will extend the last segment of the Energy Bid curve in the submitted Bid for the Multi-Stage Generating Resource up to the Multi-Stage Generating Resource's Resource Adequacy must-offer obligation. After the market closes, to the extent that no Bid is submitted into the Real-Time Market for a Multi-Stage Generating Resource scheduled in the Integrated Forward Market as required in Section 30.5 the CAISO will create a Self-Schedule for MSG Configuration equal to the Day-Ahead Schedule for that resource for the MSG Configuration scheduled in the IFM. To the extent a Multi-Stage Generating Resource is awarded Operating Reserves in the Day-Ahead Market and no Economic Energy Bids is submitted for that resource in the Real-Time Market, the CAISO will insert Proxy Energy Bid in the MSG Configuration that was awarded in the Day-Ahead Market to cover the awarded Operating Reserves. To the extent that a Multi-Stage Generating Resources RUC Schedule is greater than its Day-Ahead Schedule, if the Scheduling Coordinator does not submit an Energy Bid in the RTM to cover the difference, then the CAISO will either create a Bid in the MSG Configuration awarded in RUC, or extend the Bid submitted by the Scheduling Coordinator before the Market Close. After the Market Close, the CAISO will create a Generated Bid if there is no Bid submitted for the resource for this difference. The CAISO will validate that the combination of the Day-Ahead Ancillary Services Awards and Submissions to Self-Provide Ancillary Services are feasible with respect to the physical operating characteristics of the applicable MSG Configuration. The CAISO will reject Ancillary Services Bids or Submissions to Self-Provide Ancillary Services for MSG Configurations that are not certified Ancillary Services. For any given Multi-Stage Generating Resource, for any given CAISO Market and Trading Hour if one MSG Configuration's Bid fails the bid validation process, all other Bids for all other MSG Configurations are also invalidated.

30.7.3.6 Additional Bid Validation Rules for Virtual Bids

In addition to the validation rules described in Section 30.7.3.1, Virtual Bids will be subject to the following additional validation rules.

30.7.3.6.1 Scheduling Coordinator Validation

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

The CAISO will validate that the SCID associated with a Virtual Bid is submitted from a Scheduling Coordinator authorized to submit Virtual Bids and that the Virtual Bid is submitted at an Eligible PNode or Eligible Aggregated PNode. The CAISO will reject Virtual Bids that do not satisfy these requirements.

30.7.3.6.2 Credit Requirement

Virtual Bids must satisfy the credit requirements of Section 12.8. The Scheduling Coordinator will be notified if Virtual Bids fail to satisfy the credit requirements. If the Scheduling Coordinator fails to resubmit Virtual Bids that satisfy the credit requirements or to provide adequate additional Financial Security, the CAISO will reject the Scheduling Coordinator's Virtual Bids on a last-in, first-out basis.

30.7.3.6.3 Position Limits

For each Convergence Bidding Entity, the CAISO will reject all Virtual Bids submitted by its Scheduling Coordinator at any Eligible PNode or Eligible Aggregated PNode (other than a Default LAP or Trading Hub), that exceed the position limits specified in this Section 30.7.3.6.3. If the Scheduling Coordinator uses multiple SCIDs on behalf of a Convergence Bidding Entity, the position limits will apply to the sum of those Virtual Bids submitted at the Eligible PNode or Eligible Aggregated PNode (other than a Default LAP or Trading Hub). The CAISO will perform all position limit calculations based on the highest Virtual Bid segment MW point submitted in the Virtual Bid Curve. The CAISO will not net Virtual Supply Bids and Virtual Demand Bids in performing the position limit calculations. The affected Scheduling Coordinator will be provided notice that position limits have been violated. If the Scheduling Coordinator does not resubmit Virtual Bids within the position limits, the CAISO will reject Virtual Bids for all hours at each Eligible PNode or Eligible Aggregated PNode (other than a Default LAP or Trading Hub) where the position limits are violated. Position limits only apply to Eligible PNodes or Eligible Aggregated PNodes (other than Default LAPs or Trading Hubs).

30.7.3.6.3.1 Position Limits at Eligible PNodes and Eligible Aggregated PNodes

For an Eligible PNode associated with a single physical supply resource, the CAISO will publish a locational limit that will be equal to the PMax of the physical supply resource. For an Eligible PNode or Eligible Aggregated PNode (other than a Default LAP or Trading Hub) associated with more than one physical supply resource, the CAISO will publish a locational limit that will be equal to the sum of the PMaxes of the physical supply resources. For an Eligible PNode associated with a single physical

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

demand resource, the CAISO will publish a locational limit that will be equal to the forecast of the maximum MW consumption of the physical demand resource. For an Eligible PNode or Eligible Aggregated PNode (other than a Default LAP or Trading Hub) associated with more than one physical demand resource, the CAISO will publish a locational limit that will be equal to the forecast of the maximum MW consumption of the physical demand resources. The percentages used to calculate the position limits for each Convergence Bidding Entity at Eligible PNodes and Eligible Aggregated PNodes (other than Default LAPs or Trading Hubs) will be the following percentages of the published locational limits:

- (a) Position limits of ten (10) percent will apply during the time period beginning as of the effective date of this tariff provision through the last day of the eighth month following the effective date of this tariff provision.
- (b) Position limits of fifty (50) percent will apply during the time period beginning as of the first day of the ninth month following the effective date of this tariff provision through the last day of the twelfth month following the effective date of this tariff provision.
- (c) Position limits will cease to apply beginning on the first day of the month as of the first anniversary of the effective date of this tariff provision.

The CAISO will enforce the position limits for Eligible PNodes and Eligible Aggregated PNodes (other than Default LAPs or Trading Hubs) at the time of Virtual Bid submission. It is possible for the enforcement of position limits on a later-submitted Virtual Bid to cause a previously approved Virtual Bid to be rejected, if both of those Virtual Bids are submitted by a Scheduling Coordinator on behalf of the same Convergence Bidding Entity at the same Eligible PNode or Eligible Aggregated PNode (other than a Default LAP or Trading Hub). The CAISO will timely publish the locational limits for Eligible PNodes and Eligible Aggregated PNodes (other than Default LAPs or Trading Hubs).

30.7.4 HASP And RTM Validation

The HASP and RTM Bids will include the same validation process implemented in the DAM except that the CAISO will not validate the Bid before and again after the Master File Data update. HASP and RTM Bids are only validated based on the current Master File Data on the relevant Trading Day.

30.7.5 Validation Of ETC Self-Schedules

ETC Self-Schedules shall be validated pursuant to the procedures set forth in Section 16.6.

30.7.6 Validation And Treatment Of Ancillary Services Bids

30.7.6.1 Validation of Ancillary Services Bids

Throughout the validation process described in Section 30.7, the CAISO will verify that each Ancillary Services Bid conforms to the content, format and syntax specified for the relevant Ancillary Service. If the Ancillary Services Bid does not so conform, the CAISO will send a notification to the Scheduling Coordinator notifying the Scheduling Coordinator of the errors in the Bids as described in Section 30.7. When the Bids are submitted, a technical validation will be performed to verify that the bid quantity of Regulation, Spinning Reserve, or Non-Spinning Reserve does not exceed the certified Ancillary Services capacity for Regulation, or Operating Reserves on the Generating Units, System Units, Participating Loads, Proxy Demand Resources, and external imports/exports bid. The Scheduling Coordinator will be notified within a reasonable time of any validation errors. For each error detected, an error message will be generated by the CAISO in the Scheduling Coordinator's notification screen, which will specify the nature of the error. The Scheduling Coordinator can then look at the notification messages to review the detailed list of errors, make changes, and resubmit if it is still within the CAISO's timing requirements. The Scheduling Coordinator is also notified of successful validation. If a resource is awarded or has qualified Self-Provided Ancillary Services in the Day-Ahead Market, the following rules will apply: (1) if no Energy Self-Schedule is submitted to support a Submission to Self-Provide an Ancillary Service for Regulation, the Submission to Self-Provide an Ancillary Service will be invalidated: (2) if no Energy Supply Bid is submitted to cover the awarded or Self-Provided Ancillary Services for Spinning Reserve or Non-Spinning Reserve by the Market Close of HASP and the RTM, the CAISO will generate or extend an Energy Supply Bid as necessary to cover the awarded or Self-Provided Ancillary Services capacity using the registered values in the Master File and relevant fuel prices as described in the Business Practice Manuals for use in the HASP and IFM. If an AS Bid or Submission to Self-Provide an AS is submitted in the Real-Time Market for Spinning Reserve or Non-Spinning Reserve without an accompanying Energy Supply Bid at all, the AS Bid or Submission to Self-Provide an Ancillary Service will be erased. If an AS Bid is submitted in the HASP or Real-Time Market for Spinning Reserve and Non-Spinning Reserve with

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

only a partial Energy Supply Bid for the AS capacity, the CAISO will generate an Energy Supply Bid for the uncovered portions. If a Submission to Self-Provide an Ancillary Service is submitted in the HASP or Real-Time Market for Spinning Reserve and Non-Spinning Reserve with only a partial Energy Supply Bid for the AS capacity bid in, the CAISO will not generate or extend an Energy Supply Bid for the uncovered portions. For Generating Units with certified Regulation capacity, if there no Bid for Regulation in the Real-Time Market, but there is a Day-Ahead award for Regulation Up or Regulation Down or a submission to self-provide Regulation Up or Regulation Down, respectively, the CAISO will generate a Regulation Up or Regulation Down Bid at the default Ancillary Service Bid price of \$0 up to the certified Regulation capacity for the Generating Unit minus any Regulation awarded or self-provided in the Day-Ahead. If there is a Bid for Regulation Up or Regulation Down in the Real-Time Market, the CAISO will increase the respective Bid up to the certified Regulation capacity for the Generating Unit minus any Regulation awarded or self-provided in the Day-Ahead. If a Self-Schedule amount is greater than the Regulation Limit for Regulation Up, the Regulation Up Bid will be erased.

Notwithstanding any of the provisions of Section 30.7.6.1 set forth above, the CAISO will not insert or extend any Bid for Regulation Up or Regulation Down for a Use-Limited Resource of a Load Following MSS Operator. The CAISO will not insert a Spinning Reserve and Non-Spinning Reserve Ancillary Service Bid at \$0 in the Real-Time Market for any certified Operating Reserve capacity of a resource unless that resource submits an Energy Supply Bid but fails to submit an Ancillary Service Bid in the Real-Time Market.

30.7.6.2 Treatment of Ancillary Services Bids

When Scheduling Coordinators bid into the Regulation Up, Regulation Down, Spinning Reserve, and Non-Spinning Reserve markets, they may submit Bids for the same capacity into as many of these markets as desired at the same time by providing the appropriate Bid information to the CAISO. The CAISO optimization will evaluate AS Bids simultaneously with Energy Bids. A Scheduling Coordinator may specify that its Bid applies only the markets it desires. A Scheduling Coordinator shall also have the ability to specify different capacity prices for the Spinning Reserve, Non-Spinning Reserve, and Regulation markets. A Scheduling Coordinator providing one or more Regulation Up, Regulation Down, Spinning Reserve or Non-Spinning Reserve services may not change the identification of the Generating

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Units or Proxy Demand Resources offered in the Day-Ahead Market or in the Real-Time Market for such services unless specifically approved by the CAISO (except with respect to System Units, if any, in which case Scheduling Coordinators are required to identify and disclose the resource specific information for all Generating Units, Participating Loads, and Proxy Demand Resources constituting the System Unit for which Bids and Submissions to Self-Provide Ancillary Services are submitted into the CAISO's Day-Ahead Market and Real-Time Market).

The following principles will apply in the treatment of Ancillary Services Bids in the CAISO Markets:

- (a) not differentiate between bidders for Ancillary Services and Energy other than through cost, price, effectiveness, and capability to provide the Ancillary Service or Energy, and the required locational mix of Ancillary Services;
- (b) select the bidders with most cost effective Bids for Ancillary Service capacity which meet its technical requirements, including location and operating capability to minimize the costs to users of the CAISO Controlled Grid;
- (c) evaluate the Day-Ahead Bids over the twenty-four (24) Settlement Periods of the following Trading Day along with Energy, taking into account Transmission Constraints and AS Regional Limits;
- (d) evaluate Import Bids along with Bids from internal resources (which includes Pseudo-Ties of Generating Units to the CAISO Balancing Authority Area);
- (e) establish Real-Time Ancillary Service Awards through RTUC from imports and resources internal to the CAISO Balancing Authority Area (which includes Pseudo-Ties of Generating Units to the CAISO Balancing Authority Area) at fifteen (15) minutes intervals to the hour of operation; and
- (f) procure sufficient Ancillary Services in the Day-Ahead and Real-Time Markets to meet its forecasted requirements.

30.7.7 Format And Validation Of Operational Ramp Rates

The submitted Operational Ramp Rate expressed in megawatts per minute (MW/min) as a function of the operating level, expressed in megawatts (MW), must be a staircase function with up to four segments.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

There is no monotonicity requirement for the Operational Ramp Rate. The submitted Operational Ramp Rate shall be validated as follows:

- (a) The range of the submitted Operational Ramp Rate must cover the entire capacity of the resource, from the minimum to the maximum operating capacity, as registered in the Master File for the relevant resource.
- (b) The operating level entries must match exactly (in number, sequence, and value) the corresponding minimum and maximum Operational Ramp Rate breakpoints, as registered in the Master File for the relevant resource.
- (c) If a Scheduling Coordinator does not submit an Operational Ramp Rate for a generating unit for a day, the CAISO shall use the maximum Ramp Rate for each operating range set forth in the Master File as the Ramp Rate for that unit for that same operating range for the Trading Day.
- (d) The last Ramp Rate entry shall be equal to the previous Ramp Rate entry and represent the maximum operating capacity of the resource as registered in the Master File. The resulting Operational Ramp Rate segments must lie between the minimum and maximum Operational Ramp Rates, as registered in the Master File.
- (e) The submitted Operational Ramp Rate must be the same for each hour of the Trading Day, i.e., the Operational Ramp Rate submitted for a given Trading Hour must be the same with the one(s) submitted earlier for previous Trading Hours in the same Trading Day.
- (f) Outages that affect the submitted Operational Ramp Rate must be due to physical constraints, reported in SLIC and are subject to CAISO approval. All approved changes to the submitted Operational Ramp Rate will be used in determination of Dispatch Instructions for the shorter period of the balance of the Trading Day or duration of reported Outage.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (g) Operational Ramp Rate derates in SLIC may be declared for any operational segment established in the Master File. Ramping capability through Forbidden Operating Regions are not affected by derates entered in SLIC.
- (h) The amount of change in Ramp Rates from one operating range to a subsequent operating range must not exceed a 10 to 1 ratio, and any Ramp Rate change in excess will be adjusted to achieve the 10 to 1 ratio. This adjustment will also include the implicit ramp rate in the Forbidden Operating Region.
- (i) For all CAISO Dispatch Instructions of Reliability Must-Run Units the Operational Ramp Rate will be the Ramp Rate declared in the Reliability Must Run Contract Schedule A.

30.7.8 Format And Validation Of Start-Up And Shut-Down Times

For a Generating Unit or a Resource-Specific System Resource, the submitted Start-Up Time expressed in minutes (min) as a function of down time expressed in minutes (min) must be a staircase function with up to three (3) segments defined by a set of 1 to 4 down time and Start-Up Time pairs. The Start-Up Time is the time required to start the resource if it is offline longer than the corresponding down time. The CAISO shall model Start-Up Times for Multi-Stage Generating Resource at the MSG Configuration level and Transition Times are validated based on the Transition Matrix submitted as provided in Section 27.8. The last segment will represent the time to start the unit from a cold start and will extend to infinity. The submitted Start-Up Time function shall be validated as follows:

- (a) The first down time must be zero (0) min.
- (b) The down time entries must match exactly (in number, sequence, and value) the corresponding down time breakpoints of the maximum Start-Up Time function, as registered in the Master File for the relevant resource.
- (c) The Start-Up Time for each segment must not exceed the Start-Up Time of the corresponding segment of the maximum Start-Up Time function, as registered in the Master File for the relevant resource.
- (d) The Start-Up Time function must be strictly monotonically increasing, i.e., the Start-Up Time must increase as down time increases.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

For Participating Load and for a Proxy Demand Resource, a single Shut-Down time in minutes is the time required for the resource to Shut-Down after receiving a Dispatch Instruction. For Multi-Stage Generating Resources, the Scheduling Coordinator must provide Start-Up Costs for each MSG Configuration into which the resource can be started.

30.7.9 Format And Validation Of Start-Up Costs And Shut-Down Costs

For a Generating Unit or a Resource-Specific System Resource, the submitted Start-Up Cost expressed in dollars (\$) as a function of down time expressed in minutes must be a staircase function with up to three (3) segments defined by a set of 1 to 4 down time and Start-Up Cost pairs. The Start-Up Cost is the cost incurred to start the resource if it is offline longer than the corresponding down time. The last segment will represent the cost to start the resource from cold Start-Up and will extend to infinity. The submitted Start-Up Cost function shall be validated as follows:

- (a) The first down time must be zero (0) min.
- (b) The down time entries must match exactly (in number, sequence, and value) the corresponding down time breakpoints of the Start-Up Cost function, as registered in the Master File for the relevant resource as either the Proxy Cost or Registered Cost.
- (c) The Start-Up Cost for each segment must not be negative and must be equal to the Start-Up Cost of the corresponding segment of the Start-Up Cost function, as registered in the Master File for the relevant resource. In addition, if the Proxy Cost option pursuant to Section 30.4 applies to the resource, the Scheduling Coordinator for that resource may submit a daily Bid for the Start-Up Cost that must not be negative but may be less than or equal to the Proxy Cost. For a resource that has elected the Registered Cost option pursuant to Section 30.4, if a value is submitted in a Bid for the Start-Up Cost, it will be overwritten by the Registered Cost reflected in the Master File. If no value for Start-Up Cost is submitted in a Bid, the CAISO will insert the Master File value, as either the Proxy Cost or Registered Cost based on the option elected pursuant to Section 30.4.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (d) The Start-Up Cost function must be strictly monotonically increasing, i.e., the Start-Up Cost must increase as down time increases.

For Participating Loads and Proxy Demand Resources, a single Shut-Down Cost in dollars (\$) is the cost incurred to Shut-Down the resource after receiving a Dispatch Instruction. The submitted Shut-Down Cost must not be negative. For Multi-Stage Generating Resources, the Scheduling Coordinator must provide Start-Up Costs for each MSG Configuration into which the resource can be started.

30.7.10 Format And Validation Of Minimum Load Costs

For a Generating Unit or a Resource-Specific System Resource, the submitted Minimum Load Cost expressed in dollars per hour (\$/hr) is the cost incurred for operating the unit at Minimum Load. The submitted Minimum Load Cost must not be negative. In addition, if the Proxy Cost option pursuant to Section 30.4 applies to the resource, the Scheduling Coordinator for that resource may submit a daily Bid for the Minimum Load Cost that must not be negative but may be less than or equal to the Proxy Cost value. For a resource that has elected the Registered Cost option pursuant to Section 30.4, any submitted Minimum Load Cost must be equal to the Minimum Load Cost as registered in the Master File. For Participating Loads, the submitted Minimum Load Cost (\$/hr) is the cost incurred while operating the resource at reduced consumption after receiving a Dispatch Instruction. The submitted Minimum Load Cost must not be negative.

30.8 Bids On Out-Of-Service Paths At Scheduling Points Prohibited

Scheduling Coordinators shall not submit any Bids or ETC Self-Schedules at Scheduling Points using a transmission path for any Settlement Period for which the Operating Transfer Capability for that path is zero (0) MW. The CAISO shall reject Bids or ETC Self-Schedules submitted at Scheduling Points where the Operating Transfer Capability on the transmission path is zero (0) MW. If the Operating Transfer Capability of a transmission path at the relevant Scheduling Point is reduced to zero (0) after Day-Ahead Schedules have been issued, then, if time permits, the CAISO shall direct the responsible Scheduling Coordinators to reduce all MWh associated with the Bids on such zero-rated transmission paths to zero (0) in the HASP. As necessary to comply with Applicable Reliability Criteria, the CAISO shall reduce any non-zero (0) HASP Bids across zero-rated transmission paths to zero after the Market Close for the HASP.

30.9 Virtual Bids

Virtual Bids are Energy Bids that may be submitted only in the Day-Ahead Market, at Eligible PNodes or Eligible Aggregated PNodes, where virtual bidding is permitted, by Scheduling Coordinators representing Convergence Bidding Entities. Virtual Bids are either Virtual Supply Bids or Virtual Demand Bids. A Virtual Bid submitted in the Day-Ahead Market and cleared in the IFM represents a commitment to liquidate a Day-Ahead award in the Real-Time Market at the price determined for the applicable Eligible PNode or Eligible Aggregated PNode as set forth in Section 11.3. For each SCID associated with a Convergence Bidding Entity, there may be only one Virtual Supply Bid and one Virtual Demand Bid per each Eligible PNode or Eligible Aggregated PNode in the Day-Ahead Market. The minimum size of a segment of a Virtual Bid is one (1) MW.

30.9.1 Virtual Bid Components

Each Virtual Bid must have the following components: an indicator that identifies the Virtual Bid as a Virtual Supply Bid or a Virtual Demand Bid; Scheduling Coordinator ID Code; Eligible PNode or Eligible Aggregated PNode as applicable; Virtual Bid Curve; and the Trading Hour or Trading Day to which the Virtual Bid applies. Virtual Bids do not include Start-Up Costs or Minimum Load Costs.

30.10 Use of AC Solution and Nodal MW Constraints

The CAISO will achieve an alternating current (AC) solution in the Day-Ahead Market to the extent practicable. If and when it is impracticable to achieve an AC power flow solution without the initial enforcement of nodal MW limit constraints, the CAISO will apply nodal MW constraints to Eligible PNodes (except for Eligible PNodes established for Interties, which are addressed through the process described in Section 31.8). The CAISO will determine whether to apply such nodal MW constraints as follows:

- (i) The CAISO will calculate a MW limit for each Eligible PNode other than an Eligible PNode established for an Intertie. For an Eligible PNode associated with physical supply resource, the MW limit will be equal to a factor multiplied by the PMax of the physical supply resource. For an Eligible PNode associated with a physical demand resource, the MW limit will be equal to a factor multiplied by the nodal load forecast of the Eligible PNode calculated as the MW portion of the System Demand Forecast that is distributed to the Eligible PNode according to

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

the corresponding system Load Distribution Factor associated with the Eligible PNode. The factors used in these calculations will be determined in accordance with a process set forth in the Business Practice Manuals.

- (ii) For each of the Eligible PNodes or group of Eligible PNodes, the CAISO will calculate the percentage by which the sum of the MW amounts of all Energy Supply Bids, Demand Bids, and Virtual Bids exceeds the MW limit calculated pursuant to Section 30.10(i).
- (iii) Starting with the Eligible PNodes or group of Eligible PNodes at which the MW limits would be exceeded by the largest percentages, and working in descending order of the Eligible PNodes or group of Eligible PNodes that would exceed their MW limits ranked by the extent to which the corresponding MW limits would be exceeded, the CAISO will apply the MW limits to all Energy Supply Bids, Demand Bids, and Virtual Bids at the applicable Eligible PNodes or group of Eligible PNodes and run iterations of the IFM until the CAISO Markets can achieve an AC solution. The application of the MW limit will be enforced by means of a MW limit constraint on the sum of the nodal Energy Supply Bids, Demand Bids, and Virtual Bids as well as the portions of the aggregate Energy Supply Bids, Demand Bids, and Virtual Bids that are applicable to the Eligible PNodes or group of Eligible PNodes. The MW limit constraints will be enforced in the IFM optimization engine to curtail the Bids at the Eligible PNodes or group of Eligible PNodes that have been identified as candidates for causing AC convergence issues. The IFM optimization engine will use the economic criteria based on Bid prices and effectiveness of Bids to mitigate the violation of the MW limit at the Eligible PNode or group of Eligible PNodes.

31. Day-Ahead Market

The DAM consists of the following functions performed in sequence: the MPM-RRD, IFM, and RUC.

Scheduling Coordinators may submit Bids for Energy, Ancillary Services and RUC Capacity for an

applicable Trading Day. The CAISO shall issue Schedules for all Supply and Demand, including Participating Load and Proxy Demand Resources, pursuant to their Bids as provided in this Section 31.

31.1 Bid Submission And Validation In The Day-Ahead Market

Bids, including Self-Schedules and Ancillary Services Bids, and Submissions to Self-Provide an Ancillary Service shall be submitted pursuant to the submission rules specified in Section 30. There is a single Bid submission in which Scheduling Coordinators' Bids are used for purposes of the DAM, which includes the MPM-RRD, the IFM and RUC. Scheduling Coordinators may submit Bids for the DAM as early as seven (7) days prior to the applicable Trading Day up to Market Close of the DAM for the applicable Trading Day. The CAISO will validate all Bids submitted to the DAM pursuant to the procedures set forth in Section 30.7. Scheduling Coordinators must submit Bids for participation in the IFM for Resource Adequacy Capacity as required in Section 40.

31.2 Day-Ahead MPM Process

After the Market Close of the DAM, and after the CAISO has validated the Bids pursuant to Section 30.7, the CAISO will perform the MPM process, which is a single market run that occurs prior to the IFM Market Clearing run. The Day-Ahead MPM process determines which Bids need to be mitigated in the IFM and when RMR Proxy Bids should be considered in the IFM for RMR Units. The Day-Ahead MPM process optimizes resources to meet Demand reflected in Demand Bids, including Export Bids and Virtual Demand Bids, and to procure one hundred (100) percent of Ancillary Services requirements based on Supply Bids submitted to the DAM. Virtual Bids and Bids from Demand Response Resources are considered in the MPM process, but are not subject to Bid mitigation. Bids from Participating Load resources that are not subject to Bid mitigation will also be considered in the MPM process. The mitigated or unmitigated Bids and RMR Proxy Bids identified in the MPM process for all resources that cleared in the MPM are then passed to the IFM. The CAISO performs the MPM process for the DAM for the twenty-four (24) hours of the targeted Trading Day.

31.2.1 The Market Power Mitigation Process

The MPM process enforces all Transmission Constraints that are expected to be enforced in the relevant market and produces dispatch levels for all resources with submitted Bids and LMPs for all Locations.

Bid mitigation is determined by decomposing the Congestion component of each LMP determined in the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

MPM process into competitive Congestion and non-competitive Congestion components. The competitive Congestion component of each LMP is calculated as the sum of the product of the shift factor and the Shadow Price for all competitive Transmission Constraints and the non-competitive Congestion component of each LMP is calculated as the sum of the product of the shift factor and the Shadow Price for all non-competitive Transmission Constraints. The Reference Bus used in the MPM process will be either: (1) the Midway 500kV bus if Path 26 flow is from north to south; or (2) the Vincent 500kV bus if Path 26 flow is from south to north. The treatment of a particular Transmission Constraint as competitive or non-competitive for purposes of the MPM process is determined pursuant to Section 39.7.2.

31.2.2 Bid Mitigation for RMR Units

For purposes of the MPM process, Condition 1 RMR Units will be treated like non-RMR Units with respect to any capacity in excess of the Maximum Net Dependable Capacity specified in the RMR Contract. For up to the Maximum Net Dependable Capacity specified in the RMR Contract for Condition 1 RMR Units, the portion of the market Bid at and below the Competitive LMP at the RMR Unit's Location will be retained in the IFM. To the extent that the non-competitive Congestion component of an LMP calculated in the MPM process is greater than zero (0), and that MPM process dispatches a Condition 1 RMR Unit at a level such that some portion of its market Bid exceeds the Competitive LMP at the RMR Unit's Location, those Bid prices above the Competitive LMP will be set to the higher of the RMR Proxy Bid or the Competitive LMP. If any Bid prices are set to the level of the RMR Proxy Bid through this process, any incremental dispatch of the resource based on the RMR Proxy Bid will be flagged as an RMR Dispatch in the Day-Ahead Schedule and the resource shall be considered to have received a Dispatch Notice pursuant to the RMR Contract. Condition 1 RMR Units that have not submitted Bids and Condition 2 RMR Units will not be considered in the MPM unless the CAISO issues a manual RMR Dispatch, in which case the dispatch level specified in the manual RMR Dispatch will be protected in the MPM. If a Condition 2 RMR Unit is issued a Manual RMR Dispatch by the CAISO, then RMR Proxy Bids for all of the unit's Maximum Net Dependable Capacity under the RMR Contract will be considered in the MPM. Any incremental dispatch based on RMR Proxy Bids will be flagged as an RMR Dispatch in the Day-Ahead Schedule and the resource shall be considered to have received a Dispatch Notice pursuant to the RMR Contract. For a Condition 1 RMR Unit that has submitted Bids and has not been issued a Manual

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

RMR Dispatch, to the extent that the non-competitive Congestion component of an LMP calculated in the MPM process is greater than zero (0), and that MPM process dispatches a Condition 1 RMR Unit at a level such that some portion of its market Bid exceeds the Competitive LMP at the RMR Unit's Location, the resource will be flagged as an RMR dispatch in the Day-Ahead Market if the resource has a Day-Ahead Schedule at a level higher than the dispatch level determined by the Competitive LMP

31.2.3 Bid Mitigation for Non-RMR Units

If the non-competitive Congestion component of an LMP calculated in an MPM process is greater than zero, then any resource at that Location that is dispatched in that MPM process is subject to Local Market Power Mitigation. Bids on behalf of any such resource, to the extent that they exceed the Competitive LMP at the resource's Location, will be mitigated to the higher of the resource's Default Energy Bid, as specified in Section 39, or the Competitive LMP at the resource's Location. To the extent a Multi-Stage Generating Resource is dispatched in the MPM process and the non-competitive Congestion component of the LMP calculated at the Multi-Stage Generating Resource's Location is greater than zero (0), for purposes of mitigation, all the MSG Configurations will be mitigated similarly and the CAISO will evaluate all submitted Energy Bids for all MSG Configurations based on the relevant Default Energy Bids for the applicable MSG Configuration. The CAISO will calculate the Default Energy Bids for Multi-Stage Generating Resources by submitted MSG Configuration. Any market Bids equal to or less than the Competitive LMP will be retained in the IFM.

31.3 Integrated Forward Market

After the MPM-RRD and prior to RUC, the CAISO shall perform the IFM. The IFM (1) performs Unit Commitment and Congestion Management (2) clears mitigated or unmitigated Bids cleared in the MPM-RRD as well as Bids that were not cleared in the MPM-RRD process against bid-in Demand, taking into account transmission limits and honoring technical and inter-temporal operating constraints, such as Minimum Run Times (3) and procures Ancillary Services to meet one hundred (100) percent of the CAISO Forecast of CAISO Demand requirements. The IFM utilizes a set of integrated programs that: (1) determine Day-Ahead Schedules and AS Awards, and related LMPs and ASMPs; and (2) optimally commits resources that are bid in to the DAM. The IFM utilizes a SCUC algorithm that optimizes Start-Up Costs, Minimum Load Costs, Transition Costs, and Energy Bids along with any Bids for Ancillary Services

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

as well as Self-Schedules submitted by Scheduling Coordinators. The IFM selects the optimal MSG Configuration from a maximum of ten MSG Configurations of each Multi-Stage Generating Resource as mutually exclusive resources. If a Scheduling Coordinator submits a Self-Schedule or a Submission to Self-Provide Ancillary Services for a given MSG Configuration in a given Trading Hour, the IFM will consider the Start-Up Cost, Minimum Load Cost, and Transition Cost associated with any Economic Bids for other MSG Configurations as incremental costs between the other MSG Configurations and the self-scheduled MSG Configuration. In such cases, incremental costs are the additional costs incurred to transition or operate in an MSG Configuration in addition to the costs associated with the self-scheduled MSG Configuration. The IFM also provides for the optimal management of Use-Limited Resources. The ELS Resources committed through the ELC Process conducted two days before the day the IFM process is conducted for the next Trading Day as described in Section 31.7 are binding.

31.3.1 Market Clearing And Price Determination

31.3.1.1 Integrated Forward Market Output

The IFM produces: (1) a set of hourly Day-Ahead Schedules, AS Awards, and AS Schedules for all participating Scheduling Coordinators that cover each Trading Hour of the next Trading Day; and (2) the hourly LMPs for Energy and the ASMPs for Ancillary Services to be used for settlement of the IFM. For a Multi-Stage Generating Resource, the IFM produces a Day-Ahead Schedule for no more than one MSG Configuration per Trading Hour. In addition, the IFM will produce the MSG Transition and the MSG Configuration indicators for the Multi-Stage Generating Resource, which would establish the expected MSG Configuration in which the Multi-Stage Generating Resource will operate. During a transition, the committed MSG Configuration is considered to be the “from” MSG Configuration. The CAISO will publish the LMPs at each PNode as calculated in the IFM. In determining Day-Ahead Schedules, AS Awards, and AS Schedules the IFM optimization will minimize total Bid Costs based on submitted and mitigated Bids while respecting the operating characteristics of resources, the operating limits of transmission facilities, and a set of scheduling priorities that are described in Section 31.4. In performing its optimization, the IFM first tries to complete its required functions utilizing Effective Economic Bids without adjusting Self-Schedules, and skips Ineffective Economic Bids and adjusts Self-Schedules only if it is not possible to balance Supply and Demand and manage Congestion in an operationally prudent manner

with available Effective Economic Bids. The process and criteria by which the IFM adjusts Self-Schedules and other Non-priced Quantities are described in Sections 27.4.3, 31.3.1.3 and 31.4. The Day-Ahead Schedules are binding commitments, including the commitment to Start-Up, if necessary, to comply with the Day-Ahead Schedules. The CAISO will not issue separate Start-Up Instructions for Day-Ahead commitments. A resource's status, however, can be modified as a result of additional market processes occurring in the HASP and RTM.

31.3.1.2 Treatment of Ancillary Services Bids in IFM

As provided in Section 30.7.6.2 the CAISO shall co-optimize the Energy and Ancillary Services Bids in clearing the IFM. To the extent that capacity subject to an Ancillary Services Bid submitted in the Day-Ahead Market is not associated with an Energy Bid, there is no co-optimization, and therefore, no opportunity cost associated with that resource for that Bid for the purposes of calculating the Ancillary Services Marginal Price as specified in Section 27.1.2.2. When the capacity associated with the Energy Bid overlaps with the quantity submitted in the Ancillary Services Bid, then the Energy Bid will be used to determine the opportunity cost, if any, in the co-optimization to the extent of the overlap. Therefore, the capacity that will be considered when co-optimizing the procurement of Energy and Ancillary Services from Bids in the IFM will consider capacity up to the total capacity of the resource as reflected in the Ancillary Services Bid as derated through SLIC, if at all. In the case of Regulation, the capacity that will be considered is the lower of the capacity of the resource offered in the Ancillary Services Bid or the upper Regulation limit of the highest Regulating Range as contained in the Master File. For any Trading Hour within the period in which the Multi-Stage Generating Resource is transitioning from one MSG Configuration to another, the IFM will not award Ancillary Services and any Submission to Self-Provide Ancillary Services will be disqualified. Any Ancillary Services Awards in the IFM to Multi-Stage Generating Resources will carry through to the Real-Time Market in the same MSG Configuration that the Multi-Stage Generating Resource is awarded in the IFM.

31.3.1.3 Reduction of Self-Scheduled LAP Demand

In the IFM, to the extent the market software cannot resolve a non-competitive Transmission Constraint utilizing Effective Economic Bids such that self-scheduled Load at the LAP level would otherwise be reduced to relieve the Transmission Constraint, the CAISO Market software will adjust Non-priced

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Quantities in accordance with the process and criteria described in Section 27.4.3. For this purpose the priority sequence, starting with the first type of Non-priced Quantity to be adjusted, will be: (a) Schedule the Energy from Self-Provided Ancillary Service Bids from capacity that is obligated to offer an Energy Bid under a must-offer obligation such as from an RMR Unit or a Resource Adequacy Resource. Consistent with Section 8.6.2, the CAISO Market software could also utilize the Energy from Self-Provided Ancillary Service Bids from capacity that is not under a must-offer obligation such as from an RMR Unit or a Resource Adequacy Resource, to the extent the Scheduling Coordinator has submitted an Energy Bid for such capacity. The associated Energy Bid prices will be those resulting from the MPM-RRD process.(b) Relax the constraint consistent with Section 27.4.3.1, and establish prices consistent with Section 27.4.3.2. No constraints, including Transmission Constraints, on Interties with adjacent Balancing Authority Areas will be relaxed in this procedure.

31.3.1.4 Eligibility to Set the Day-Ahead LMP

All Generating Units, Participating Loads, non-Participating Loads, Proxy Demand Resources, System Resources, System Units, or Constrained Output Generators subject to the provisions in Section 27.7, with Bids, including Generated Bids, that are unconstrained due to Ramp Rates, MSG Transitions, Forbidden Operating Regions, or other temporal constraints are eligible to set the LMP, provided that (a) the Schedule for the Generating Unit or Resource-Specific System Resource is between its Minimum Operating Limit and the highest MW value in its Economic Bid or Generated Bid, or (b) the Schedule for the Participating Load, non-Participating Load, Proxy Demand Resources, non-Resource-Specific System Resource, or System Unit is between zero (0) MW and the highest MW value in its Economic Bid or Generated Bid. If (a) a resource's Schedule is constrained by its Minimum Operating Limit or the highest MW value in its Economic Bid or Generated Bid, (b) the CAISO enforces a resource-specific constraint on the resource due to an RMR or Exceptional Dispatch, (c) the resource is constrained by a boundary of a Forbidden Operating Region or is Ramping through a Forbidden Operating Region, or (d) the resource's full Ramping capability is constraining its inter-hour change in Schedule, the resource cannot be marginal and thus is not eligible to set the LMP. Resources identified as MSS Load following resources are not eligible to set the LMP. A Constrained Output Generator will be eligible to set the hourly LMP if any portion of its Energy is necessary to serve Demand.

31.3.2 Congestion And Transmission Losses Cost Determination

Except for those transactions exempt from such charges as specified in Section 11.2.1.5, Scheduling Coordinators will be responsible for MCC and MCL as specified in Section 27.1. The CAISO will determine the Marginal Losses surplus it has collected and will allocate such revenues to Scheduling Coordinators as described in Section 11.2.1.6.

31.3.3 Metered Subsystems

In clearing the IFM, the CAISO will not enforce Transmission Constraints within each MSS. The Full Network Model (FNM) includes a full model of MSS transmission networks used for power flow calculations and Transmission Constraint management in the IFM and RTM. Transmission Constraints (i.e. circuit ratings, thermal ratings, etc.) within the MSS, or at its boundaries, that are modeled in the FNM shall be monitored but not enforced in the operation of the CAISO Markets. If overloads are observed in the forward markets that are internal to the MSS or at the MSS boundaries and are attributable to MSS operations, the CAISO shall communicate such events to the Scheduling Coordinator for the MSS and coordinate any manual Re-dispatch required in Real-Time. If, independent of the CAISO, the Scheduling Coordinator for the MSS is unable to resolve Congestion internal to the MSS or at the MSS boundaries in Real-Time, the CAISO will use Exceptional Dispatch Instructions on resources that have been bid into the HASP and RTM to resolve the Congestion. Such costs will be allocated pursuant to the provisions specified in Section 11.5.6.2.5.2. The CAISO and MSS Operator shall develop specific procedures for each MSS to determine how Transmission Constraints will be handled. Costs associated with internal Congestion and Transmission Losses in the MSS will be the responsibility of the MSS Operator. The Scheduling Coordinator for the MSS shall be responsible for payment of Marginal Losses for transactions at any points of interconnection between the MSS and the CAISO Controlled Grid, and for the delivery of Energy to the MSS or from the MSS in accordance with the CAISO Tariff. For MSS Operators that elect Load following, the CAISO shall exclude the effect of Transmission Losses in the relevant MSS in the CAISO's calculation of loss sensitivity factors used to calculate LMPs.

31.4 CAISO Market Adjustments To Non-Priced Quantities In The IFM

All Self-Schedules are respected by SCUC to the maximum extent possible and are protected from curtailment in the Congestion Management process to the extent that there are Effective Economic Bids

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

that can relieve Congestion. If all Effective Economic Bids in the IFM are exhausted, resource Self-Schedules between the resource's Minimum Load and the first Energy level of the first Energy Bid point will be subject to adjustments by the CAISO Market optimization based on the scheduling priorities listed below. This functionality of the optimization software is implemented through the setting of scheduling parameters as described in Section 27.4.3 and specified in Section 27.4.3.1 and the Business Practice Manuals. Through this process, imports and exports may be reduced to zero, Demand Bids may be reduced to zero, Price Taker Demand (LAP load) may be reduced, and Generation may be reduced to a lower operating limit (or Regulation Limit) (or to a lower Regulation Limit plus any qualified Regulation Down award or Self-Provided Ancillary Services, if applicable). Any Self-Schedules below the Minimum Load level are treated as fixed Self-Schedules and are not subject to these adjustments for Congestion Management. The provisions of this section shall apply only to the extent they do not conflict with any MSS Agreement. In accordance with Section 27.4.3.5 the resources submitted in valid TOR, ETC or Converted Right Self-Schedules shall not be adjusted in the IFM in response to an insufficiency of Effective Economic Bids. Thus the adjustment sequence for the IFM from highest priority (last to be adjusted) to lowest priority (first to be adjusted), is as follows:

- (a) Reliability Must Run (RMR) Generation pre-dispatch reduction;
- (b) Day-Ahead TOR Self-Schedules reduction (balanced demand and supply reduction);
- (c) Day-Ahead ETC and Converted Rights Self-Schedules reduction; different ETC priority levels will be observed based upon global ETC priorities provided to the CAISO by the Responsible PTOs;
- (d) Internal Transmission Constraint relaxation for the IFM pursuant to Section 27.4.3.1;
- (e) Other Self-Schedules of CAISO Demand reduction subject to Section 31.3.1.3, exports explicitly identified in a Resource Adequacy Plan to be served by Resource Adequacy Capacity explicitly identified and linked in a Supply Plan to the exports, and Self-Schedules of exports at Scheduling Points explicitly sourced by non-Resource Adequacy Capacity;

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (f) Self-Schedules of exports at Scheduling Points not explicitly sourced by non-Resource Adequacy Capacity, except those exports explicitly identified in a Resource Adequacy Plan to be served by Resource Adequacy Capacity explicitly identified and linked in a Supply Plan to the exports as set forth in Section 31.4(d);
- (g) Day-Ahead Regulatory Must-Run Generation and Regulatory Must-Take Generation reduction;
- (h) Other Self-Schedules of Supply reduction.

31.5 Residual Unit Commitment

The CAISO shall perform the RUC process after the IFM. In the event that the IFM did not commit sufficient resources to meet the CAISO Forecast of CAISO Demand and account for other factors such as Demand Forecast error, as described in the Business Practice Manuals, the RUC shall commit additional resources and identify additional RUC Capacity to ensure sufficient on-line resources to meet Demand for each hour of the next Trading Day. RUC Capacity is selected by a SCUC optimization that uses the same Base Market Model used in the IFM adjusted as described in Section 27.5.1 and 27.5.6 to help ensure the deliverability of Energy from the RUC Capacity. In the case of Multi-Stage Generating Resources, the RUC will optimize Transition Costs in addition to the Start-Up and Minimum Load Costs. If a Scheduling Coordinator submits a Self-Schedule or a Submission to Self-Provide Ancillary Services for a given MSG Configuration in a given Trading Hour, the RUC will consider the Start-Up Cost, Minimum Load Cost, and Transition Cost associated with any Economic Bids for other MSG Configurations as incremental costs between the other MSG Configurations and the self-scheduled MSG Configuration. In such cases, incremental costs are the additional costs incurred to transition or operate in an MSG Configuration in addition to the costs associated with the self-scheduled MSG Configuration.

31.5.1 RUC Participation

31.5.1.1 Capacity Eligible for RUC Participation

RUC participation is voluntary for capacity that has not been designated as Resource Adequacy Capacity. Scheduling Coordinators may make such capacity available for participation in RUC by submitting a RUC Availability Bid, provided the Scheduling Coordinator has also submitted an Energy Bid

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

(other than a Virtual Bid) for such capacity into the IFM. Virtual Bids are not eligible to participate in RUC. Capacity from Non-Dynamic System Resources that has not been designated Resource Adequacy Capacity is not eligible to participate in RUC. Capacity from resources including System Resources that has been designated as qualified Resource Adequacy Capacity must participate in RUC. RUC participation is required for Resource Adequacy Capacity to the extent that Resource Adequacy Capacity is not committed following the IFM. System Resources eligible to participate in RUC will be considered on an hourly basis; that is, RUC will not observe any multi-hour block constraints. In RUC the CAISO may commit a Multi-Stage Generating Resource with a Resource Adequacy must-offer obligation at any MSG Configuration with capacity equal to or greater than the MSG Configuration committed in the Integrated Forward Market. RUC will observe the Energy Limits that may have been submitted in conjunction with Energy Bids to the IFM. RMR Unit capacity will be considered in RUC in accordance with Section 31.5.1.3. MSS resources may participate in RUC in accordance with Section 31.5.2.3. COG resources are accounted for in RUC, but may not submit or be paid RUC Availability Payments. The ELS Resources committed through the ELC Process conducted two (2) days before the day the RUC process is conducted for the next Trading Day as described in Section 31.7 are binding.

31.5.1.2 RUC Availability Bids

Scheduling Coordinators may only submit RUC Availability Bids for capacity (above the Minimum Load) for which they are also submitting an Energy Bid (other than a Virtual Bid) to participate in the IFM. Any available Resource Adequacy Capacity and CPM Capacity will be optimized at \$0/MW in RUC. For Multi-Stage Generating Resources that fail to submit a \$0/MW per hour for the Resource Adequacy Capacity, the CAISO will insert the \$0/MW per hour for the resource's Resource Adequacy Capacity at the MSG Configuration level up to the minimum of the Resource Adequacy Capacity or the PMax of the MSG Configuration. Scheduling Coordinators may submit non-zero RUC Availability Bids for the portion of a resource's capacity that is not Resource Adequacy Capacity or CPM Capacity.

31.5.1.3 RMR Generation Resources

If a resource is determined to have an RMR Generation requirement for any Trading Hour of the next day, either by the MPM-RRD process or by the CAISO through a manual RMR Dispatch Notice, and if any

portion of the RMR Generation requirement has not been cleared in the IFM, the entire portion of the RMR Generation requirement will be represented as a RMR Generation Self-Schedule in the RUC.

31.5.1.4 Eligibility to Set the RUC Price

All resources that are eligible for RUC participation as described in Section 31.5.1.1 with RUC Bids that are unconstrained due to Ramp Rates or other temporal constraints, including MSG Transitions, are eligible to set the RUC Price, provided that (a) the RUC Schedule for the Generating Unit or Resource-Specific System Resource is between its Minimum Operating Limit and the highest MW value in its Economic Bid or Generated Bid, or (b) the Schedule for the eligible resource other than a Generating Unit or Resource-Specific System Resource is between zero (0) MW and the highest MW value in its Economic Bid or Generated Bid. If (a) a resource's Schedule is constrained by its Minimum Operating Limit or the highest MW value in its Economic Bid or Generated Bid, (b) the CAISO enforces a resource-specific constraint on the resource due to an RMR or Exceptional Dispatch or (c) the resource's full Ramping capability is constraining its inter-hour change in Schedule, the resource cannot be marginal and thus is not eligible to set the RUC Price. Resources identified as MSS Load following resources are not eligible to set the RUC Price.

31.5.2 Metered Subsystem RUC Obligation

MSS Operators are permitted to make an annual election to opt-in or opt-out of RUC participation. MSS Operators that elect to Load follow are automatically considered to opt-out of the RUC participation. Prior to the deadline for the annual CRR Allocation and CRR Auction process, as specified in Section 36, an MSS Operator that has selected not to Load follow shall notify the CAISO of its RUC participation option for the following CRR cycle.

31.5.2.1 MSS Operator Opts-In to RUC Procurement

If the MSS Operator opts-in to the RUC procurement process, the Scheduling Coordinator for the MSS will be treated like any other Scheduling Coordinator that submits a Bid in the DAM with respect to RUC procurement by the CAISO and allocation of RUC costs. The CAISO will consider the CAISO Demand Forecast of the MSS Demand in setting the RUC procurement target, and the Scheduling Coordinator for the MSS will be responsible for any applicable allocation of costs related to the Bid Cost Recovery for RUC as provided in Section 11.8.

31.5.2.2 MSS Operator Opts-out of RUC Procurement

If an MSS Operator opts out of the RUC procurement process, the CAISO shall not consider the CAISO Demand Forecast of the MSS Demand in setting the RUC procurement target, and will not commit resources in RUC to serve the MSS Demand. The MSS Operator shall be responsible for meeting the Supply requirements for serving its Demand in accordance with this Section 31.5.2.2, and it will be exempt from the allocation of costs related to the Bid Cost Recovery for RUC as provided in Section 11.8. The MSS that opts out of the CAISO's RUC procurement will have two options for meeting the Supply requirements for serving its Demand, which it will select on an hourly basis depending on how it submits Self-Schedules for its Demand in the DAM.

31.5.2.2.1 Based on CAISO Demand Forecast

If the Scheduling Coordinator for the MSS submits Hourly Demand Self-Schedules in the DAM that are greater than or equal to the CAISO Demand Forecast for the MSS Demand, the Scheduling Coordinator will have met its Supply requirement for such hours and will be exempt from the allocation of costs related to the Bid Cost Recovery for RUC as provided in Section 11.8.

31.5.2.2.2 Not Based on CAISO Demand Forecast

If the Scheduling Coordinator for the MSS submits Hourly Demand Self-Schedules in the DAM that are less than the CAISO Demand Forecast for the MSS Demand, the Scheduling Coordinator will be exempt from the RUC cost allocation but will be monitored for its compliance with the Supply requirement based on the following performance criteria. If the MSS Demand Self-Schedule in the IFM for a given Trading Hour is less than the CAISO Demand Forecast for the MSS Demand and less than the actual metered Demand of the MSS for that Trading Hour, then penalty points will be accrued as follows: (i) if the difference between the actual metered Demand and the IFM Self-Schedule in any hour is greater than the lesser of two percent (2%) of the CAISO Demand Forecast for the MSS or five (5) MW, but less than the lesser of five percent (5%) or ten (10) MW, then the Scheduling Coordinator for the MSS will have one (1) penalty point against it for each occurrence; (ii) if the difference in any hour is more than the lesser of five percent (5%) or ten (10) MW, but less than the lesser of ten percent (10%) or twenty (20) MW, then the Scheduling Coordinator for the MSS will have two (2) penalty points against it for each occurrence; (iii) if the difference in any hour is more than the lesser of ten percent (10%) or twenty (20) MW, then the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Scheduling Coordinator for the MSS will have five (5) penalty points against it for each occurrence. The maximum penalty points that can be accrued during a single Trading Day for each MSS will be five (5). A total of more than twenty (20) penalty points within twelve (12) consecutive months will require the MSS to opt-in to RUC for the remainder of the CRR Annual Cycle and for the following CRR Annual Cycle. The provisions in this Section 31.5.2.2.2 do not apply to an MSS Operator that has elected to Load follow, and only apply to non-Load following MSS Operators.

31.5.2.3 MSS Option to Bid RUC Capacity

The Scheduling Coordinator for the MSS Operator may submit RUC Availability Bids for the capacity of MSS resources and receive RUC Availability Payments and other RUC Compensation for such capacity selected in RUC, subject to the same bidding and operational requirements as any other resources providing RUC Capacity. This capability is not affected by the MSS Operator's decision to opt-in to or opt-out of RUC per Sections 31.5.2.1 and 31.5.2.2.

31.5.3 RUC Procurement Target

The procurement target for RUC in any given Trading Hour will be determined based on the next day's hourly CAISO Forecast of CAISO Demand less the Energy scheduled in the Day-Ahead Schedule, and accounting for other factors, as appropriate, such as Demand Forecast error and estimated incremental HASP Bids including those from Participating Intermittent Resources. The adjustments listed in Sections 31.5.3.1 to 31.5.3.6 will be made to the CAISO Forecast of CAISO Demand to account for the conditions as provided therein. Adjustments may be made on a RUC Zone basis to ensure that RUC results in adequate local capacity procurement. The RUC procurement target-setting procedure is designed to meet the requirements of reliable grid operation without unnecessary over-procurement of RUC Capacity or over-commitment of resources. Additional detail on the process for setting the RUC procurement target is specified in the Business Practice Manuals.

31.5.3.1 CAISO Operator Review & Adjustment

The CAISO Operator reviews the CAISO Forecast of CAISO Demand and all calculated adjustments as provided in Sections 31.5.3.2 through 31.5.3.6. The CAISO Operator shall accept, modify, or reject such adjustments based on Good Utility Practice. If the CAISO Operator determines it must modify or reject

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

adjustments, the CAISO Operator shall log sufficient information as to reason, Operating Hour, and specific modification(s) made to the calculated adjustments.

31.5.3.2 Demand Response Adjustments.

The CAISO shall account for Demand response that is clearly communicated to the CAISO as certain to be curtailed for the next Trading Day only for the two following types of Demand response: 1) Demand response triggered by a staged System Emergency event; and 2) Demand response that is triggered by a price or an event known in advance. If an LSE informs the CAISO of anticipated Demand response prior to Market Close of the DAM, the CAISO Forecast of CAISO Demand used as the RUC procurement target will be reduced accordingly.

31.5.3.3 MSS Adjustment

As specified in section 31.5.2.1, MSS Operators are permitted to make an annual election to opt-in or opt-out of RUC participation. If the MSS Operator opts-in to the RUC procurement process, the CAISO considers the CAISO's Demand Forecast of the MSS Demand in setting the RUC procurement target. If an MSS Operator opts-out of the RUC procurement process, the CAISO does not consider the CAISO's Demand Forecast of the MSS Demand in setting the RUC procurement target. An MSS Operator that has elected to opt-out of RUC, or has elected to Load follow and therefore has also elected to opt-out of RUC, is required to provide sufficient resources in the Day-Ahead Market, and in the case of a Load following MSS Operator, follow its Load within the MSS Deviation Band. To reflect these options and to prevent committing additional capacity or resources for any differences between the CAISO Demand Forecast for the MSS and the MSS Self-Scheduled quantities in the IFM, the CAISO replaces the CAISO Demand Forecast for such MSS with the quantity of Demand in Self-Schedules submitted by the Scheduling Coordinator for the MSS in the IFM.

31.5.3.4 Eligible Intermittent Resource Adjustment

Scheduling Coordinators for Eligible Intermittent Resources may submit Bids, including Self-Schedules, in the Day-Ahead Market and the quantity ultimately scheduled from Eligible Intermittent Resources may differ from the CAISO forecasted deliveries from the Eligible Intermittent Resources. The CAISO may adjust the forecasted Demand either up or down for such differences by RUC Zone in which the Eligible Intermittent Resource resides. To the extent the scheduled quantity for an Eligible Intermittent Resource

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

in the IFM is less than the quantity forecasted by CAISO, the CAISO makes a Supply side adjustment in RUC by using the CAISO forecasted quantity for the Eligible Intermittent Resource as the expected delivered quantity. To the extent the scheduled quantity for an Eligible Intermittent Resource in the IFM is greater than the quantity forecasted by the CAISO, the CAISO makes a Demand side adjustment to the RUC Zone Demand equal to the difference between the Day-Ahead Schedule and the CAISO forecasted quantity.

31.5.3.5 Real-Time Expected Incremental Supply Self-Schedule Adjustment

In order to avoid over procurement of RUC, the CAISO shall, using a similar-day approach, estimate the HASP Self-Schedules for resources that usually submit HASP Self-Schedules that are greater than their Day-Ahead Schedules. The CAISO Operator may set the length of the Self-Schedule moving average window. Initially this moving average window shall be set by default to seven (7) days; in which case the weekday estimate is based on the average of five (5) most recent weekdays and the weekend estimate is based on the average of the two (2) most recent weekend days. To the extent weather conditions differ significantly from the historical days, additional adjustment may be necessary. After determining the estimate of Real-Time Self-Schedules, using a similar day forecasting approach, the CAISO adjusts the CAISO Forecast of CAISO Demand of a RUC Zone based on the forecasted quantity changes in Supply as a result of Self-Schedules submitted in the RTM. This adjustment for forecasted Real-Time Self-Schedules may result in positive or negative adjustments. Demand adjustments to the CAISO Forecast of CAISO Demand result when there is a net forecast decrease in Real-Time Self-Schedule Supply relative to the Day-Ahead Schedule Supply. Supply adjustments to the individual resources occur when there is a net forecast increase in Real-Time Self-Schedule Supply relative to the Day-Ahead Schedule Supply of the individual resource.

31.5.3.6 Day-Ahead Ancillary Service Procurement Deficiency Adjustment

While the CAISO intends to procure one hundred percent (100%) of its forecasted Operating Reserve requirement in the IFM based on the CAISO Forecast of CAISO Demand as specified in Section 8.3.1, the CAISO shall make adjustments to the CAISO Forecast of CAISO Demand used in RUC to ensure sufficient capacity is available or resources committed in cases that the CAISO is unable to procure one hundred percent (100%) of its forecasted Operating Reserve requirement in the IFM; provided, however,

that the CAISO shall not procure specific Ancillary Services products in RUC, nor will the RUC optimization consider AS-related performance requirements of available capacity.

31.5.3.7 RUC Zones

31.5.3.7.1 Use of RUC Zones

The CAISO shall adjust the CAISO Forecast of CAISO Demand by RUC Zone for the conditions described in Sections 31.5.3.2 through 31.5.3.6. If any adjustments are made throughout the affected RUC Zone, such adjustments will be made consistent with the subset of system LDFs for the Nodes that define the RUC Zone(s). The CAISO will adjust the CAISO Forecast of CAISO Demand of each affected RUC Zone, preserving the LDFs within each RUC Zone, but the relative weighting of the LDFs across the system will deviate from the original LDFs. RUC costs will be pooled together to establish the RUC Compensation Costs. As described in Section 11.6.1, Settlement of RUC Compensation Costs will not be on a RUC Zone basis.

31.5.3.7.2 Designation of RUC Zones

The CAISO shall define RUC Zones as areas that represent UDC or MSS Service Areas, Local Capacity Areas, or any other collection of Nodes. RUC Zones will be designated by the CAISO as necessary and to the extent that the CAISO has developed sufficient data on historical CAISO Demand and weather conditions to allow it to perform Demand Forecasts. Once the CAISO has established RUC zones, the mapping of RUC Zones to Nodes shall be static data and shall be maintained in the Master File. The CAISO may add new Nodes to a RUC Zone if new Nodes are added to the FNM. The status of each RUC Zone shall remain active for as long as the CAISO maintains regional forecasting capabilities, but once a RUC Zone is designated the CAISO will only adjust the CAISO Forecast of CAISO Demand as necessary to address RUC procurement constraints and not as a normal course for all CAISO Market functions. The actual RUC Zones used by the CAISO in its operation of RUC are posted on the CAISO Website.

31.5.4 RUC Procurement Constraints

In addition to the resource constraints and Transmission Constraints employed by SCUC as discussed in Section 27.4.1, the CAISO shall employ the following three constraints in RUC:

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (a) To ensure that sufficient RUC Capacity is procured to meet the CAISO Forecast of CAISO Demand, the CAISO will enforce the power balance between the total Supply, which includes Day-Ahead Schedules and RUC Capacity, and the total Demand, which includes the CAISO Forecast of CAISO Demand and IFM export Schedules. The CAISO may adjust the CAISO Forecast of CAISO Demand to increase the RUC procurement target if there is AS Bid insufficiency in the IFM.
- (b) To ensure that RUC will neither commit an excessive amount of Minimum Load Energy nor procure an excessive amount of RUC Capacity from Scheduling Points the CAISO will verify that the sum of Day-Ahead Schedules, Schedules of Generating Units, net imports, Participating Loads, and Proxy Demand Resources plus the Minimum Load Energy committed by RUC is not greater than a configurable percentage of the system CAISO Forecast of CAISO Demand.
- (c) The CAISO can limit the amount of RUC Capacity it will procure from resources that could otherwise be started during the Operating Day based on operational factors such as: (1) historical confidence that a Short Start Unit actually starts when needed based on the assessment of the CAISO Operators of the historical performance of Short Start Units; (2) need to conserve the number of run-hours and number of starts per year for critical loading periods; and (3) seasonal constraints such as Overgeneration. The CAISO will verify that the total Day-Ahead Schedules and RUC Capacity from such resources is not greater than a configurable percentage of the total available capacity of all such resources.

31.5.5 Selection And Commitment Of RUC Capacity

Capacity that is not already scheduled in the IFM may be selected as RUC Capacity through the RUC process of the DAM. The RUC optimization will select RUC Capacity and produce nodal RUC Prices by minimizing total Bid cost based on RUC Availability Bids and Start-Up, Minimum Load Bids and Transition Costs. RUC will not consider Start-Up, Minimum Load Bids, or Transition Costs for resources already committed in the IFM. The RUC Capacity of a resource is the incremental amount of capacity selected in RUC above the resource's Day-Ahead Schedule. The resource's Day-Ahead Schedule plus its RUC

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Capacity comprise the resource's RUC Schedule. The CAISO will only issue RUC Start-Up Instructions to resources committed in RUC that must receive a Start-Up Instruction in the Day-Ahead in order to be available to meet Real-Time Demand. RUC Schedules will be provided to Scheduling Coordinators even if a RUC Start-Up Instruction is not issued at that time. RUC shall not Shut Down resources scheduled through the IFM and RUC will not commit a Multi-Stage Generating Resource to a lower MSG Configuration that is unable to support the Energy scheduled in the IFM. If the RUC process cannot find a feasible solution given the resources committed in the IFM, the RUC process will adjust constraints as described in Section 31.5.4 to arrive at a feasible solution that accommodates all the resources committed in the IFM, and any necessary de-commitment of IFM committed units shall be effectuated through an Exceptional Dispatch.

31.5.6 Eligibility For RUC Compensation

All RUC Capacity is eligible for the RUC Availability Payment except for: (i) RUC Capacity from RMR Units that has been designated as RMR Dispatch and included in RUC as a Self-Schedule; (ii) Resource Adequacy Capacity; and (iii) RUC Capacity that corresponds to the resource's Minimum Load, which is compensated through the Bid Cost Recovery as described in Section 11.8. Resources not committed in the IFM that are committed in RUC, including RMR Units that were not designated for RMR Dispatches and Resource Adequacy Resources, are also eligible for RUC Cost Compensation, which includes Start-Up, Transition Costs, and Minimum Load Cost compensation, and Bid Cost Recovery, subject to the resource actually following its Dispatch Instructions as verified by the CAISO pursuant to procedures set forth in the Business Practice Manuals.

31.5.7 Rescission Of Payments For RUC Capacity

If capacity committed in RUC provided from a Generating Unit, Participating Load, Proxy Demand Resource, System Unit or System Resource is Undispatchable Capacity or Undelivered Capacity during the relevant Settlement Interval, then payments will be rescinded as described in this Section 31.5.7 and settled in accordance with Section 11.2.2.2. If the CAISO determines that non-compliance of a Participating Load, Proxy Demand Resource, Generating Unit, System Unit or System Resource with an operating order or Dispatch Instruction from the CAISO, or with any other applicable technical standard under the CAISO Tariff, causes or exacerbates system conditions for which the WECC imposes a penalty

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

on the CAISO, then the Scheduling Coordinator of such Participating Load, Proxy Demand Resource, Generating Unit, System Unit or System Resource shall be assigned that portion of the WECC penalty which the CAISO reasonably determines is attributable to such non-compliance, in addition to any other penalties or sanctions applicable under the CAISO Tariff. The rescission of payments in this Section 31.5.7 shall not apply to a capacity payment for any particular RUC Capacity if the RUC Availability Payment is less than or equal to zero (0).

31.5.7.1 Rescission of Payments for Undispatchable RUC Capacity

The CAISO shall calculate the Real-Time ability of each Generating Unit, Participating Load, Proxy Demand Resource, System Unit or System Resource to deliver Energy from or capacity committed in RUC for each Settlement Interval based on its maximum operating capability, actual telemetered output (or, in the case of Proxy Demand Resources, an estimate of actual output), and Operational Ramp Rate as described in Section 30.10, which for a Multi-Stage Generating Resource is evaluated by MSG Configuration. If the Undispatchable Capacity is capacity committed in RUC and is from a Generating Unit, System Unit or System Resource that is a Resource Adequacy Resource, there is no payment obligation to the CAISO for the Undispatchable Capacity. The CAISO will report the instance of non-compliance by the Resource Adequacy Resource to the appropriate Local Regulatory Authority.

31.5.7.2 Rescission of Payments for Undelivered RUC Capacity

For each Settlement Interval in which a Generating Unit, Participating Load, Proxy Demand Resource, System Unit or System Resource fails to supply Energy from capacity committed in RUC in accordance with a Dispatch Instruction, or supplies only a portion of the Energy specified in the Dispatch Instruction, the RUC Availability Payment will be reduced to the extent of the deficiency, in accordance with the provisions of Section 11.2.2.2.2, which for a Multi-Stage Generating Resource is evaluated for the Generating Unit or Dynamic Resource-Specific System Resource and not by the MSG Configuration.

31.6 Timing Of Day-Ahead Scheduling

31.6.1 Criteria For Temporary Waiver Of Timing Requirements

The CAISO may at its sole discretion implement any temporary variation or waiver of the timing requirements of this Section 31 and Section 6.5.3 (including the omission of any step) if any of the following criteria are met:

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (i) such waiver or variation of timing requirements is reasonably necessary to preserve System Reliability, prevent an imminent or threatened System Emergency or to retain Operational Control over the CAISO Controlled Grid during an actual System Emergency.
- (ii) because of error or delay, the CAISO requires additional time to fulfill its responsibilities;
- (iii) problems with data or the processing of data cause a delay in receiving or issuing Bids or publishing information on the CAISO's secure communication system;
- (iv) problems with telecommunications or computing infrastructure cause a delay in receiving or issuing Day-Ahead Schedules or publishing information on the CAISO's secure communication system.

31.6.2 Information To Be Published On Secure Communication System

If the CAISO temporarily implements a waiver or variation of such timing requirements, the CAISO will publish the following information on the CAISO's secure communication system as soon as practicable:

- (i) the exact timing requirements affected;
- (ii) details of any substituted timing requirements;
- (iii) an estimate of the period for which this waiver or variation will apply; and
- (iv) reasons for the temporary waiver or variation.

31.6.3 Conditions Permitting CAISO To Abort Day-Ahead Market

If, despite the variation of any time requirement or the omission of any step, the CAISO either fails to receive sufficient Bids or fails to clear the Day-Ahead Market, the CAISO may abort the Day-Ahead Market and require all Bids to be submitted in the HASP and RTM

31.6.4 [NOT USED]

31.7 Extremely Long-Start Commitment Process

The CAISO shall perform the Extremely Long-Start Commitment Process (ELC Process) after the regular DAM results are posted. ELS Resources are flagged in the Master File and are the only resources eligible to be committed in the ELC Process. Each day after the DAM results are posted, the CAISO shall

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

conduct the ELC Process to determine commitment of ELS Resources to be available to the CAISO Markets in the second day out. The CAISO will use the latest CAISO Forecast of CAISO Demand available to the CAISO for the Trading Day two days ahead of the current day that the ELC Process is executed. For commitment purposes for a resource whose Start-Up time would exceed the definition of an ELS Resource based on the resource's initial condition and cooling time, the CAISO will consider DAM Bids from ELS Resources as Bids for the Trading Day two days ahead of the current day that the ELC Process is executed. The CAISO Operator shall use its operator judgment consistent with Good Utility Practice to determine whether ELS Resources for the second day in the 48-hour time period should be committed. The ELC Process does not dispatch Energy for the 48-hour time period and therefore the commitment instructions will not include megawatts schedules greater than the Minimum Load. ELS Resources receiving a commitment instruction are obligated to resubmit the same Bid in the next day's Day-Ahead Market. The CAISO Commitment Period or Self-Commitment Period determination for the ELS Resources depends on the DAM results and the Clean and Generated Bids, following the same rules that apply to other resources. All Commitment Intervals for the ELS Resources will be classified as CAISO Commitment Periods, unless there is a Self-Schedule or Self-Provided AS for that interval.

31.8 [NOT USED]

32. [NOT USED]

33 Hour-Ahead Scheduling Process (HASP)

The HASP is the hour-ahead process during the Real-Time which consists of the following activities. The HASP includes a special hourly run of the Real-Time Unit Commitment (RTUC), which is also one of the component processes of the RTM. The RTUC utilizes a SCUC optimization and runs every fifteen (15) minutes, as fully described in Section 34. This Section 33 describes the special features of the specific hourly HASP run of the RTUC. The HASP combines provisions for the CAISO to issue hourly pre-dispatch instructions to System Resources that submit Energy Bids to the RTM and for the procurement of Ancillary Services on an hourly basis from System Resources, with provisions for Scheduling Coordinators to self-schedule changes to their Day-Ahead Schedules as provided in Section 33.1, and submit Bids to export Energy at Scheduling Points. The HASP also performs the MPM procedure with

respect to the Bids that will be used in the HASP optimization and in the RTM processes for the same Trading Hour.

33.1 Submission Of Bids For The HASP And RTM

Scheduling Coordinators may submit Bids, including Self-Schedules, for Supply that will be used for the HASP and the RTM processes starting from the time Day-Ahead Schedules have been posted until seventy-five (75) minutes prior to each applicable Trading Hour in the Real-Time. This includes Self-Schedules by Participating Load that is modeled using the Pumped-Storage Hydro Unit. Scheduling Coordinators may not submit Bids, including Self-Schedules, for CAISO Demand in the HASP and RTM. Scheduling Coordinators may submit Bids, including Self-Schedules, for exports at Scheduling Points in the HASP and RTM. The rules for submitted Bids specified in Section 30 apply to Bids submitted to the HASP and RTM. After the Market Close of the HASP and the RTM the CAISO performs a validation process consistent with the provisions set forth in Section 30.7 and the following additional rules. The CAISO will generate a Self-Schedule to cover any RUC Award or Day-Ahead Schedule in the absence of any Self-Schedule or Economic Bid components, or to fill in any gaps between any Self-Schedule Bid and any Economic Bid components to cover a RUC Award or Day-Ahead Schedule. Bids submitted to the HASP and the RTM to supply Energy and Ancillary Services will be considered in the various HASP and RTM processes, including the MPM process, the HASP optimization, the STUC, the RTUC and the RTD.

33.2 The HASP Optimization

After the Market Close for the HASP and RTM for the relevant Trading Hour, the Bids have been validated and the MPM process has been performed, the HASP optimization determines feasible but non-binding HASP Advisory Schedules for Generating Units for each fifteen-minute interval of the Trading Hour, as well as binding hourly HASP Intertie Schedules and binding hourly HASP AS Awards from Non-Dynamic System Resources for that Trading Hour. The HASP may also commit resources whose Start-Up Times are within the immediately following Trading Hour. The HASP, like the other runs of the RTUC, utilizes the same SCUC optimization and Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6 as the IFM, with the Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6 updated to reflect changes in system conditions as appropriate, to ensure that HASP Intertie Schedules are feasible. Instead of clearing against Demand Bids as in the IFM, the HASP clears Supply against the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

CAISO Forecast of CAISO Demand plus submitted Export Bids, to the extent the Export Bids are selected in the MPM process. The HASP optimization also factors in forecasted unscheduled flow at the Interties. The HASP optimization produces Settlement prices for hourly imports and exports to and from the CAISO Balancing Authority Area reflected in the HASP Intertie Schedule and for the HASP AS Awards for System Resources.

33.3 Treatment Of Self-Schedules In HASP

The HASP optimization clears Bids, including Self-Schedules, while preserving all priorities in this process consistent with Section 34.10. The HASP optimization does not adjust submitted Self-Schedules unless it is not possible to balance Supply and the CAISO Forecast of CAISO Demand plus Export Bids and manage Congestion using the available Economic Bids, in which case the HASP performs non-economic adjustments to Self-Schedules. The MWh quantities of Self-Schedules of Supply that clear in the HASP constitute a feasible Dispatch for the RTM at the time HASP is run, but the HASP results do not constitute a final Schedule for Generating Units because these resources may be adjusted non-economically in the RTD if necessary to manage Congestion and clear Supply and Demand. Self-Schedules submitted for Generating Units that clear in the HASP will be issued HASP Advisory Schedules. Scheduling Coordinators representing Participating Intermittent Resources whose output is being used to satisfy a resource adequacy requirement must submit Self-Schedules in HASP in accordance with the forecast provided by the independent forecast service provider. The submission of a change to an ETC Self-Schedule beyond the deadline specified in Section 16.9.1, that is permitted pursuant to the terms of the applicable ETC, shall not be deemed to be an unbalanced ETC Self-Schedule for the purposes of Settlement, consistent with the ETC and TOR Self-Schedule Settlement treatment described in Section 11.5.7.

33.4 MPM-RRD For The HASP And The RTM

After the Market Close of the HASP and RTM, after the CAISO has validated the Bids pursuant to section 30.7, and prior to running the HASP optimization, the CAISO conducts the MPM-RRD process, the results of which will be utilized in the HASP optimization and all RTM processes for the Trading Hour. Bids on Demand Response Resources are not considered in the MPM process but are not subject to Bid mitigation. The MPM process for the HASP and RTM produces results for each fifteen (15) minute

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

interval of the Trading Hour and thus may produce up to four mitigated Bids for any given resource for the Trading Hour. The determination as to whether a Bid is mitigated in the HASP and RTM is made based on the non-competitive Congestion component of each LMP for each fifteen (15) minute interval of the applicable Trading Hour, using the methodology set forth in Sections 31.2.2 and 31.2.3 above. If a Bid is mitigated in any of the four fifteen (15) minute intervals comprising a Trading Hour during the MPM process for the HASP and RTM, then that Bid will be treated as mitigated for the entire Trading Hour for purposes of the HASP optimization and all RTM processes. A single mitigated Bid for the entire Trading Hour is calculated using the minimum Bid price of the four mitigated Bid curves at each Bid quantity level. For a Condition 1 RMR Unit, the use of RMR Proxy Bids is determined based on the non-competitive Congestion component of each LMP for each fifteen (15) minute interval of the applicable Trading Hour, using the methodology set forth in Section 31.2.2 above. If a Condition 2 RMR Unit is issued a Manual RMR Dispatch by the CAISO, then RMR Proxy Bids for all of the unit's Maximum Net Dependable Capacity will be considered in the MPM process. For both Condition 1 and Condition 2 RMR Units, when mitigation is triggered, a single RMR Proxy Bid for the entire Trading Hour is calculated using the same methodology described above for non-RMR Units. For a Condition 1 RMR Unit that has submitted Bids and has not been issued a Manual RMR Dispatch, to the extent that the non-competitive Congestion component of an LMP calculated in the MPM process is greater than zero, and that MPM process dispatches a Condition 1 RMR Unit at a level such that some portion of its market Bid exceeds the Competitive LMP at the RMR Unit's Location, the resource will be flagged as an RMR dispatch if it is dispatched at a level higher than the dispatch level determined by the Competitive LMP. Both Condition 1 and Condition 2 RMR Units may be issued manual RMR dispatches at any time to address local reliability needs or to resolve non-competitive constraints.

33.5 [NOT USED]

33.6 HASP Results

The CAISO publishes the binding HASP Intertie Schedules and HASP AS Awards for System Resources, as well as HASP Advisory Schedules and HASP AS Awards for internal Generating Units (which includes Pseudo-Ties of Generating Units to the CAISO Balancing Authority Area) no later than forty-five (45) minutes prior to the Trading Hour.

33.7 Ancillary Services in the HASP

After establishing the Day-Ahead Ancillary Services Awards, the CAISO will procure additional Ancillary Services needed to meet Reliability Criteria to maintain required Ancillary Services arising from changes in forecasts of Demand and resource Outages. The CAISO utilizes the HASP (for Spinning and Non-Spinning Reserve) and the RTUC to procure additional Ancillary Services needed for this purpose for the next Trading Hour. The HASP optimization will consider the optimal mix of Ancillary Services from System Resources and from Generating Units, but only the Ancillary Service from Non-Dynamic System Resources awarded in HASP are binding. These binding Ancillary Services Awards are for the full Trading Hour for which the given HASP run applies. Generating Units and Dynamic System Resources designated in the HASP to provide Ancillary Services for the same Trading Hour receive non-binding advisory Ancillary Services awards because the CAISO will re-optimize the use of these Generating Units and Dynamic System Resources to provide Ancillary Services in a subsequent RTUC run, as described in Section 34.2. The CAISO settles the HASP Ancillary Services Awards for Non-Dynamic System Resources as provided in Section 11.10.1.2. All Operating Reserves procured in HASP are Contingency Only Operating Reserves, as described in Section 30.5.2.6. Scheduling Coordinators submitting Ancillary Services Bids for Non-Dynamic System Resources in the HASP must also submit an Energy Bid under the same Resource ID for the associated Ancillary Services Bid. For these Non-Dynamic System Resources, the CAISO will only use the Ancillary Services Bid in the HASP optimization and will not Schedule Energy in HASP from the Energy Bid provided under the same Resource ID as the Ancillary Services Bid. The CAISO may dispatch Energy from the Contingency Only Operating Reserves awarded to Non-Dynamic System Resources in HASP through the Real-Time Contingency Dispatch as described in Section 34.3.2.

33.8 HASP Prices For HASP Intertie Schedules

The RTUC will produce fifteen (15) minute LMPs for the four (4) fifteen (15) minute RTUC intervals for the applicable Trading Hour. The fifteen (15) minute LMPs corresponding to the Scheduling Points are then used to derive a simple average hourly price for the Settlement of hourly Intertie Schedules at each Scheduling Point. The RTUC also produces fifteen (15) minute ASMPs for the four (4) fifteen (15) minute intervals for the next Trading Hour. The CAISO uses these fifteen (15) minute ASMPs to derive a simple

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

average hourly price for the Settlement of hourly HASP AS Awards. The RTUC run will also produce fifteen (15) minute Shadow Prices for each of the Intertie constraint for the four (4) fifteen (15) minute intervals for the applicable Trading Hour. These fifteen (15) minute Shadow Prices are then used to derive a simple average hourly price for charging hourly Intertie AS Awards providers for Congestion at the applicable intertie. HASP Intertie Schedules and HASP AS Awards are settled in accordance with Section 11.4 and 11.10.1.2, respectively.

33.8.1 Eligibility To Set The HASP Intertie LMP

All Generating Units, Participating Loads, System Resources, System Units, or COGs subject to the provisions in Section 27.7 with Bids, including Generated Bids, that are unconstrained due to Ramp Rates or other temporal constraints are eligible to set the HASP Intertie LMP, provided that (a) the Generating Unit or Resource-Specific System Resource is Dispatched between its Minimum Operating Limit and the highest MW value in its Economic Bid or Generated Bid, or (b) the Participating Load, non-Resource-Specific System Resource, or System Unit is Dispatched between zero (0) MW and the highest MW value in its Economic Bid or Generated Bid. If (a) a resource's Dispatch is constrained by its Minimum Operating Limit or the highest MW value in its Economic Bid or Generated Bid, (b) the CAISO enforces a resource-specific constraint on the resource due to an RMR or Exceptional Dispatch, or (c) the resource's full Ramping capability is constraining its Dispatch for additional Energy in a target interval, the resource cannot be marginal and thus is not eligible to set the HASP Intertie LMP. Resources identified as MSS Load following resources are not eligible to set the HASP Intertie LMP. A Constrained Output Generator that has the ability to be committed or shut off within the immediately following Trading Hour in which a specific HASP run is conducted will be eligible to set the Dispatch Interval LMP if any portion of its Energy is necessary to serve Demand. Dispatches of Regulation resources to a Dispatch Operating Point by SCED will be eligible to set the HASP Intertie LMP.

33.9 Cessation Of The HASP

If, despite the variation of any time requirement or omission of any step, the CAISO is unable to operate the HASP, the CAISO may abort the HASP and perform all required functions through the RTM processes.

34. Real-Time Market

The RTM is the market conducted by the CAISO during any given Operating Day in which Scheduling Coordinators may provide Real-Time Imbalance Energy and Ancillary Services. The Real-Time Market consists of the Real-Time Unit Commitment (RTUC), the Short-Term Unit Commitment (STUC) and the Real-Time Dispatch (RTD) processes. The Short-Term Unit Commitment (STUC) runs once per hour near the top of the hour and utilizes the SCUC optimization to commit Medium Start, Short Start and Fast Start Units to meet the CAISO Demand Forecast. The CAISO shall dispatch all resources, including Participating Load and Proxy Demand Resource, pursuant to submitted Bids or pursuant to the provisions below on Exceptional Dispatch. In Real-Time, resources are required to follow Real-Time Dispatch Instructions. In any given Trading Hour, the STUC may commit resources for the third fifteen-minute interval of the current Trading Hour and extending into the next four (4) Trading Hours. The RTUC runs every fifteen (15) minutes and utilizes the SCUC optimization to commit Fast Start and some Short Start Units and to procure any needed AS on a fifteen-minute basis. In any given Trading Hour, the RTUC may commit resources in the four to seven subsequent fifteen-minute intervals, depending on when during the hour the run occurs. Not all resources committed in a given STUC or RTUC run will necessarily receive CAISO commitment instructions immediately, because during the Trading Day the CAISO may issue a commitment instruction to a resource only at the latest possible time that allows the resource to be ready to provide Energy when it is expected to be needed. The RTD uses a Security Constrained Economic Dispatch (SCED) algorithm every five minutes throughout the Trading Hour to determine optimal Dispatch Instructions to balance Supply and Demand. Updates to the Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6 used in the RTM optimization include current estimates of real-time unscheduled flow at the Interties. In any given five-minute interval, the RTD optimization looks ahead over multiple five-minute intervals, but the CAISO issues Dispatch Instructions only for the next target five-minute interval. The RTUC, STUC and RTD processes of the RTM use the same Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6 used in the DAM and the HASP, subject to any necessary updates of the Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6 pursuant to changes in grid conditions after the DAM has run. In the case of Multi-Stage Generating Resources, the RTM procedures will optimize Transition Costs in addition to the Start-

Up and Minimum Load Costs. If a Scheduling Coordinator submits a Self-Schedule or a Submission to Self-Provide Ancillary Services for a given MSG Configuration in a given Trading Hour, all of the RTM processes will consider the Start-Up Cost, Minimum Load Cost, and Transition Cost associated with any Economic Bids for other MSG Configurations as incremental costs between the other MSG Configurations and the self-scheduled MSG Configuration. In such cases, incremental costs are the additional costs incurred to transition or operate in an MSG Configuration in addition to the costs associated with the self-scheduled MSG Configuration.

34.1 Inputs To The Real-Time Market

The RTM utilizes results produced by the DAM and HASP for each Trading Hour of the Trading Day, including the combined commitments contained in the Day-Ahead Schedules, Day Ahead AS Awards, RUC Awards, HASP Intertie Schedules, HASP Self-Schedules, HASP Intertie AS Awards and the MPM that is run as part of the HASP to determine mitigated bids for each relevant Trading Hour. Virtual Bids and Virtual Awards are not used in the Real-Time Market. These results, plus the short-term Demand Forecast, Real-Time Energy Bids, Real-Time Ancillary Service Bids, updated Base Market Model adjusted as described in Sections 27.5.1 and 27.5.6, State Estimator output, resource outage and de-rate information constitute the inputs to the RTM processes. Bids submitted in HASP for all Generating Units and Participating Load shall be used in the Real-Time Market.

34.2 Real-Time Unit Commitment

The Real-Time Unit Commitment (RTUC) process uses SCUC and is run every fifteen (15) minutes to: (1) make commitment decisions for Fast Start and Short Start Units having Start-Up Times within the applicable time periods described below in this section, and (2) procure required additional Ancillary Services and calculate ASMP used for settling procured Ancillary Service capacity for the next fifteen-minute Real-Time Ancillary Service interval. In any fifteen (15) minute RTUC interval that falls within a time period in which a Multi-Stage Generating Resource is transitioning from one MSG Configuration to another MSG Configuration, the CAISO: (1) will not award any incremental Ancillary Services; (2) will disqualify any Day-Ahead Ancillary Services Awards; (3) will disqualify Day-Ahead qualified Submissions to Self-Provide Ancillary Services Award, and (4) will disqualify Submissions to Self-Provide Ancillary Services in RTM. For Multi-Stage Generating Resources the RTUC will issue a binding Transition

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Instruction separately from the binding Start-Up or Shut Down instructions. The RTUC can also be run with the Contingency Flag activated, in which case the RTUC can commit Contingency Only Operating Reserves. If RTUC is run without the Contingency Flag activated, it cannot commit Contingency Only Operating Reserves. RTUC is run at the following time intervals: (1) at approximately 7.5 minutes prior to the next Trading Hour, in conjunction with the HASP run, for T-45 minutes to T+60 minutes; (2) at approximately 7.5 minutes into the current hour for T-30 minutes to T+60 minutes; (3) at approximately 22.5 minutes into the current hour for T-15 minutes to T+60 minutes; and (4) at approximately 37.5 minutes into the current hour for T to T+60 minutes where T is the beginning of the next Trade Hour. The HASP, described in Section 33, is a special RTUC run that is performed at approximately 7.5 minutes before each hour and has the additional responsibility of: (1) pre-dispatching Energy and awarding Ancillary Services for hourly dispatched System Resources for the Trading Hour that begins 67.5 minutes later, and (2) performing the necessary MPM for that Trading Hour. A Day-Ahead Schedule or RUC Schedule for an MSG Configuration that is later impacted by the resource's derate or outages, will be reconsidered in the RTUC process taking into consideration the impacts of the derate or outage on the available MSG Configurations.

34.2.1 Commitment Of Fast Start And Short Start Resources

RTUC produces binding and advisory Start-Up and Shut-Down Dispatch Instructions for Fast Start and Short Start Units that have Start-Up Times that would allow the resource to be committed prior to the end of the relevant time period of the RTUC run as described in Section 34.2. A Start-Up Dispatch Instruction is considered binding in any given RTUC run if the Start-Up Time of the resource is such that there would not be sufficient time for a subsequent RTUC run to Start-Up the resource. A Start-Up Instruction is considered advisory if it is not binding, such that the resource could achieve its target Start-Up Time as determined in the current RTUC run in a subsequent RTUC run based on its Start-Up Time. A Shut-Down Instruction is considered binding if the resource could achieve the target Shut-Down Time as determined in the current RTUC in a subsequent RTUC run. A Shut-Down Dispatch Instruction is considered advisory if the resource Shut-Down Instruction is not binding such that the resource could achieve its target Shut-Down time as determined in the current RTUC run in a subsequent RTUC run. A binding Dispatch Instruction that results in a change in Commitment Status will be issued, in accordance

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

with Section 6.3, after review and acceptance of the Start-Up Instruction by the CAISO Operator. An advisory Dispatch Instruction changing the Commitment Status of a resource may be modified by the CAISO Operator to a binding Dispatch Instruction and communicated in accordance with Section 6.3 after review and acceptance by the CAISO Operator. Only binding and not advisory Dispatch Instructions will be issued by the CAISO. For Multi-Stage Generating Resources the CAISO will also issue binding Transition Instructions when the Multi-Stage Generating Resource must change from one MSG Configuration to another. A Transition Instruction is considered binding in any given RTUC run if the Transition Time for the Multi-Stage Generating Resource is such that there would not be sufficient time for a subsequent RTUC run to transition the resource.

34.2.2 Real-Time Ancillary Services Procurement

If the CAISO determines that additional Ancillary Services are required, other than those procured in the IFM, HASP, the RTUC will procure Ancillary Services on a fifteen (15) minute basis as necessary to meet reliability requirements and will determine Real-Time Ancillary Service interval ASMPs for such AS for the next Commitment Period. All Operating Reserves procured in the RTM are considered Contingency Only Operating Reserves. Any Ancillary Service awarded in RTUC will be taken as fixed for the three (3) five (5) minute RTD intervals of its target fifteen (15) minute interval. In the RTUC, all resources certified and capable of providing Operating Reserves that have submitted Real-Time Energy Bids shall also submit applicable Spinning or Non-Spinning Reserves Bids, respectively, depending on whether the resource is online or offline. The CAISO will utilize the RTUC to procure Operating Reserves to restore its Operating Reserve requirements in cases when: (1) Operating Reserves awarded in IFM, HASP or RTUC have been dispatched to provide Energy, (2) resource(s) awarded to provide Operating Reserves in the IFM, HASP or RTUC are no longer capable of providing such awarded Operating Reserves, or (3) the Operator determines that additional Operating Reserves are necessary to maintain Operating Reserves within NERC and WECC reliability standards, including any requirements of the NRC. The CAISO will utilize the RTUC to procure additional Regulation capacity in Real-Time in cases when: (1) resource(s) awarded to provide Regulation in the IFM, HASP or RTUC are no longer capable of providing such awarded Regulation, or (2) the Operator determines that additional Regulation is necessary to maintain sufficient control consistent with NERC and WECC reliability standards, including any requirements of the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

NRC and Good Utility Practice. The RTUC will produce fifteen (15) minute ASMPs for the four (4) binding fifteen (15) minute intervals for the applicable Trading Hour. These fifteen (15) minute ASMPs are then used for the Settlement of the fifteen (15) minute AS Awards. The RTUC run will also produce fifteen (15) minute Shadow Prices for each of the Interties for the four (4) fifteen (15) minute intervals for the applicable Trading Hour. These fifteen (15) minute Shadow Prices are then used to charge for Intertie Real-Time AS Award providers for Congestion on the Interties. RTUC AS Awards are settled in accordance with 11.10.1.3.

34.3 Real-Time Dispatch

The RTD can operate in three modes: RTED, RTCD and RTMD. The RTED uses a Security Constrained Economic Dispatch (SCED) algorithm every five (5) minutes throughout the Trading Hour to determine optimal Dispatch Instructions to balance Supply and Demand. The CAISO will use the Real-Time Economic Dispatch (RTED) under most circumstances to optimally dispatch resources based on their Bids. The RTED can be used to Dispatch Contingency Only Operating Reserves, pursuant to Section 34.8, when needed to avoid an imminent System Emergency. The Real-Time Contingency Dispatch (RTCD) can be invoked in place of the RTED when a transmission or generation contingency occurs and will include all Contingency Only Operating Reserves in the optimization. If the CAISO awards a Non-Dynamic System Resource Ancillary Services in the IFM or HASP and issues a Dispatch Instruction in the middle of the Trading Hour for Energy associated with its Ancillary Services (Operating Reserve) capacity, the CAISO will Dispatch the Non-Dynamic System Resource to operate at a constant level until the end of the Trading Hour. If the CAISO dispatches a Non-Dynamic System Resource such that the binding interval of the Dispatch is in the next Trading Hour, the CAISO will dispatch Energy from the Non-Dynamic System Resource at a constant level until the end of the next Trading Hour. The dispatched Energy will not exceed the awarded Operating Reserve capacity for the next Trading Hour and will be at a constant level for the entire next Trading Hour. The Real Time Manual Dispatch (RTMD) will be invoked as a fall-back mechanism only when the RTED or RTCD fails to provide a feasible Dispatch. These three (3) modes of the RTD are described in Sections 34.3.1 to 34.3.3.

34.3.1 Real-Time Economic Dispatch

RTED mode of operation for RTD normally runs every five (5) minutes starting at approximately 7.5 minutes prior to the start of the next Dispatch Interval and produces binding Dispatch Instructions for Energy for the next Dispatch Interval and advisory Dispatch Instructions for multiple future Dispatch Intervals through at least the next Trading Hour. After being reviewed by the CAISO Operator, only binding Dispatch Instructions are communicated for the next Dispatch Interval in accordance with Section 6.3. RTED will produce a Dispatch Interval LMP for each PNode for the Dispatch Interval associated with the binding Dispatch Instructions. The RTED Dispatch target is the middle of the interval between five (5) minutes boundary points.

34.3.2 Real-Time Contingency Dispatch

RTCD mode of operation for RTD is run in response to a significant Contingency event, such that waiting until the next normal RTD run is not adequate and/or Operating Reserve identified as Contingency Only need to be activated in response to the event. The CAISO Operator may activate the Operating Reserve identified as Contingency Only either on a resource specific basis or for all such resources. When activating Contingency Only reserves in RTCD, the original Energy Bids associated with the resources providing Operating Reserve will be used for the RTCD. RTCD uses SCED to produce an optimized set of binding Dispatch Instructions for a single ten-minute Dispatch Interval instead of a normal five-minute Dispatch Interval. After being reviewed by the CAISO Operator, only binding Dispatch Instructions are communicated for the next Dispatch Interval in accordance with Section 6.3. When activating a RTCD and returning to normal RTED run after a RTCD run, five-minute Dispatch Interval LMPs will be produced for each PNode be based on the last available price from either the RTCD or normal RTED run relative to a five-minute target Dispatch Interval.

34.3.3 Real-Time Manual Dispatch

RTMD mode of operation for RTD is a merit-order run activated upon CAISO Operator request as a backup process in case the normal RTED process fails to converge. The RTMD run will provide the CAISO Operator a list of resources and quantity of MW available for Dispatch in merit-order based on Operational Ramp Rate but otherwise ignores Transmission Losses and Transmission Constraints. The CAISO Operator may dispatch resources from the list by identifying the quantity of Imbalance Energy that

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

is required for the system and/or directly selecting resources from the merit order taking into consideration actual operating conditions. After Dispatches have been selected, reviewed and accepted by the CAISO Operator, Dispatch Instructions will be communicated in accordance with Section 6.3. While the RTMD mode is being used for Dispatch a uniform five-minute MCP will be produced for all PNodes based on the merit order Dispatch. Until RTMD is actually run and RTMD-based Dispatch Instructions are issued after RTED fails to converge, all five-minute Dispatch Interval LMPs will be set to the last LMP at each Node produced by the last RTED run that converged.

34.4 Short-Term Unit Commitment

At the top of each Trading Hour, immediately after the RTUC run is completed, the CAISO performs an approximately five (5) hour Short-Term Unit Commitment (STUC) run using SCUC and the CAISO Forecast of CAISO Demand to commit Medium Start Units and Short Start Units with Start-Up Times greater than the time period covered by the RTUC described in Section 34.2. The STUC looks ahead over a period of at least three (3) hours beyond the Trading Hour for which the RTUC optimization was run, and will utilize Bids available from other CAISO Markets for that Trading Hour for these additional hours. The CAISO revises these replicated Bids each time the hourly STUC is run, to utilize the most recently available Bids. A Start-Up Instruction produced by STUC is considered binding if the resource could not achieve the target Start-Up Time as determined in the current STUC run in a subsequent RTUC or STUC run as a result of the Start-Up Time of the resource. A Start-Up Instruction produced by STUC is considered advisory if it is not binding, such that the resource could achieve its target start time as determined in the current RTUC run in a subsequent STUC or RTUC run based on its Start-Up Time. A binding Dispatch Instruction produced by STUC that results in a change in Commitment Status will be issued, in accordance with Section 6.3, after review and acceptance of the Start-Up Instruction by the CAISO Operator. The STUC will only decommit a resource to the extent that resource's physical characteristics allow it to be cycled in the same approximately five (5) hour look-ahead time period for which it was previously committed. STUC does not produce Locational Marginal Prices for Settlement. A Day-Ahead Schedule or RUC Schedule for an MSG Configuration that is later impacted by the resource's derate or outages, will be reconsidered in the STUC process taking into consideration the impacts of the derate or outage on the available MSG Configurations.

34.5 General Dispatch Principles

The CAISO shall conduct all Dispatch activities consistent with the following principles:

- (1) The CAISO shall issue AGC instructions electronically as often as every four (4) seconds from its Energy Management System (EMS) to resources providing Regulation and on Automatic Generation Control to meet NERC and WECC performance requirements;
- (2) In each run of the RTED or RTCD the objective will be to meet the projected Energy requirements over the applicable forward-looking time period of that run, subject to transmission and resource operational constraints, taking into account the short term CAISO Forecast of CAISO Demand adjusted as necessary by the CAISO Operator to reflect scheduled changes to Interchange and non-dispatchable resources in subsequent Dispatch Intervals;
- (3) Dispatch Instructions will be based on Energy Bids for those resources that are capable of intra-hour adjustments and will be determined through the use of SCED except when the CAISO must utilize the RTMD;
- (4) When dispatching Energy from awarded Ancillary Service capacity the CAISO will not differentiate between Ancillary Services procured by the CAISO and Submissions to Self-Provide an Ancillary Service;
- (5) The Dispatch Instructions of a resource for a subsequent Dispatch Interval shall take as a point of reference the actual output obtained from either the State Estimator solution or the last valid telemetry measurement and the resource's operational ramping capability. For Multi-Stage Generating Resources the determination of the point of reference is further affected by the MSG Configuration and the information contained in the Transition Matrix;
- (6) In determining the Dispatch Instructions for a target Dispatch Interval while at the same time achieving the objective to minimize Dispatch costs to meet the forecasted conditions of the entire forward-looking time period, the Dispatch for the target Dispatch Interval will be affected by: (a) Dispatch Instructions in prior

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

intervals, (b) actual output of the resource, (c) forecasted conditions in subsequent intervals within the forward-looking time period of the optimization, and (d) operational constraints of the resource, such that a resource may be dispatched in a direction for the immediate target Dispatch Interval that is different than the direction of change in Energy needs from the current Dispatch Interval to the next immediate Dispatch Interval, considering the applicable MSG Configuration;

- (7) Through Start-Up Instructions the CAISO may instruct resources to start up or shut down, or may reduce Load for Participating Loads and Proxy Demand Resources, over the forward-looking time period for the RTM based on submitted Bids, Start-Up Costs and Minimum Load Costs, Pumping Costs and Pump Shut-Down Costs, as appropriate for the resource, or for Multi-Stage Generating Resource as appropriate for the applicable MSG Configuration, consistent with operating characteristics of the resources that the SCED is able to enforce. In making Start-Up or Shut-Down decisions in the RTM, the CAISO may factor in limitations on number of run hours or Start-Ups of a resource to avoid exhausting its maximum number of run hours or Start-Ups during periods other than peak loading conditions;
- (8) The CAISO shall only start up resources that can start within the applicable time periods of the various CAISO Markets Processes that comprise the RTM;
- (9) The RTM optimization may result in resources being shut down consistent with their Bids and operating characteristics provided that: (a) the resource does not need to be on-line to provide Energy, (b) the resource is able to start up within the applicable time periods of the processes that comprise the RTM, (c) the Generating Unit is not providing Regulation or Spinning Reserve, and (d) Generating Units online providing Non-Spinning Reserve may be shut down if they can be brought up within ten (10) minutes as such resources are needed to be online to provide Non-Spinning Reserves;

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (10) For resources that are both providing Regulation and have submitted Energy Bids for the RTM, Dispatch Instructions will be based on the Regulation Ramp Rate of the resource rather than the Operational Ramp Rate if the Dispatch Operating Point remains within the Regulating Range. The Regulating Range will limit the Ramping of Dispatch Instructions issued to resources that are providing Regulation;
- (11) For Multi-Stage Generating Resources the CAISO will issue Dispatch Instructions by Resource ID and Configuration ID;
- (12) The CAISO may issue Transition Instructions to instruct resources to transition from one MSG Configuration to another over the forward-looking time period for the RTM based on submitted Bids, Transition Costs and Minimum Load Costs, as appropriate for the MSG Configurations involved in the MSG Transition, consistent with Transition Matrix and operating characteristics of these MSG Configurations. The RTM optimization will factor in limitations on Minimum Up Time and Minimum Down Time defined for each MSG configuration and Minimum Up Time and Minimum Down Time at the Generating Unit or Dynamic Resource-Specific System Resource.

34.6 Dispatch of Dispatch to Units, Participating Loads, and PDR

The CAISO may issue Dispatch Instructions covering:

- (a) Ancillary Services;
- (b) Energy, which may be used for:
 - (i) Congestion relief;
 - (ii) provision of Imbalance Energy; or
 - (iii) replacement of an Ancillary Service;
- (c) agency operation of Generating Units, Participating Loads, Proxy Demand Resources, or Interconnection schedules, for example:
 - (i) output or Demand that can be Dispatched to meet Applicable Reliability Criteria;

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (ii) Generating Units that can be Dispatched for Black Start;
- (iii) Generating Units that can be Dispatched to maintain governor control regardless of their Energy schedules;
- (d) the operation of voltage control equipment applied on Generating Units as described in this CAISO Tariff;
- (e) MSS Load following instructions provided to the CAISO, which the CAISO incorporates to create their Dispatch Instructions;
- (f) necessary to respond to a System Emergency or imminent emergency; or
- (g) Transition Instructions.

34.7 Utilization Of The Energy Bids

The CAISO uses Energy Bids for the following purposes: (i) satisfying Real-Time Energy needs; (ii) mitigating Congestion; (iii) maintaining aggregate Regulation reserve capability in Real-Time; (iv) allowing recovery of Operating Reserves utilized in Real-Time operations; (v) procuring Voltage Support required from resources beyond their power factor ranges in Real-Time; (vi) establishing LMPs; (vii) as the basis for Bid Cost Recovery; and (viii) to the extent a Real-Time Energy Bid Curve is submitted starting at minimum operating level for a Short Start Unit that is scheduled to be on-line, the RTM may Dispatch such a resource down to its minimum operating level and may issue a Shut-Down Instruction to the resource based on its Minimum Load Energy costs.

34.8 Dispatch Of Energy From Ancillary Services

The CAISO may issue Dispatch Instructions to Participating Generators, Participating Loads, Proxy Demand Resources, (via communication with the Scheduling Coordinators of Demand Response Providers) System Units and System Resources contracted to provide Ancillary Services (either procured through the CAISO Markets, Self-Provided by Scheduling Coordinators, or dispatched in accordance with the RMR Contract) for the Supply of Energy. During normal operating conditions, the CAISO shall Dispatch those Participating Generators, Participating Loads, Proxy Demand Resources, System Units and System Resources that have contracted to provide Spinning and Non-Spinning Reserve, except for those reserves designated as Contingency Only, in conjunction with the normal Dispatch of Energy. Contingency Only reserves are Operating Reserve capacity that have been designated, either by the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Scheduling Coordinator or the CAISO, as available to supply Energy in the Real-Time only in the event of the occurrence of an unplanned Outage, a Contingency or an imminent or actual System Emergency. The CAISO may designate any reserve not previously identified as Contingency Only by Scheduling Coordinator as Contingency Only reserves, as necessary to maintain NERC and WECC reliability standards, including any requirements of the NRC. In the event of an unplanned Outage, a Contingency or a threatened or actual System Emergency, the CAISO may dispatch Contingency Only reserves. If Contingency Only reserves are dispatched through the RTCD, which as described in Section 34.3.2, only Dispatches in the event of a Contingency. Such Dispatch and pricing will be based on the original Energy Bids. If Contingency Only reserves are dispatched in response to a System Emergency that has occurred because the CAISO has run out of Economic Bids when no Contingency event has occurred, the RTED will Dispatch such Contingency Only reserves using maximum Bid prices as provided in Section 39.6.1 as the Energy Bids for such reserves and will set prices accordingly. If a Participating Generator, Participating Load, System Unit or System Resource that is supplying Operating Reserve is dispatched to provide Energy, the CAISO shall replace the Operating Reserve as necessary to maintain NERC and WECC reliability standards, including any requirements of the NRC. If the CAISO uses Operating Reserve to meet Real-Time Energy requirements, and if the CAISO needs Operating Reserves to satisfy NERC and WECC reliability standards, including any requirements of the NRC, the CAISO shall restore the Operating Reserves to the extent necessary to meet NERC and WECC reliability standards, including any requirements of the NRC through either the procurement of additional Operating Reserve in the RTM or the Dispatch of other Energy Bids in SCED to allow the resources that were providing Energy from the Operating Reserve to return to their Dispatch Operating Point. The Energy Bid Curve is not used by the AGC system when Dispatching Energy from Regulation. For Regulation Up capacity, the upper portion of the resource capacity from its Regulation Limit is allocated to Regulation regardless of its Energy Bid Curve. For a resource providing Regulation Up or Operating Reserves the remaining Energy Bid Curve shall be allocated to any RTM AS Awards in the following order from higher to lower capacity where applicable: (a) Spinning Reserve; and (b) Non-Spinning Reserve. For resources providing Regulation Up, the applicable upper Regulation Limit shall be used as the basis of allocation if it is lower than the upper portion of the Energy Bid Curve. The remaining portion of the Energy Bid Curve, if there is

any, shall constitute a Bid for RTM Energy. For Regulation Down capacity, the lower portion of the resource capacity from its applicable Regulation Limit is allocated to Regulation regardless of its Energy Bid Curve.

34.9 Exceptional Dispatch

The CAISO may issue Exceptional Dispatches for the circumstances described in this Section 34.9, which may require the issuance of forced Shut-Downs, forced Start-Ups, or forced MSG Transitions and shall be consistent with Good Utility Practice. Dispatch Instructions issued pursuant to Exceptional Dispatches shall be entered manually by the CAISO Operator into the Day-Ahead or RTM optimization software so that they will be accounted for and included in the communication of Day-Ahead Schedules and Dispatch Instructions to Scheduling Coordinators. Exceptional Dispatches are not derived through the use of the IFM or RTM optimization software and are not used to establish the LMP at the applicable PNode. The CAISO will record the circumstances that have led to the Exceptional Dispatch. Except as provided in this Section 34.9, the CAISO shall consider the effectiveness of the resource along with Start-Up Costs, Transition Costs, and Minimum Load Costs when issuing Exceptional Dispatches to commit a resource to operate at Minimum Load. When the CAISO issues Exceptional Dispatches for Energy, the CAISO shall also consider Energy Bids, if available and as appropriate. In accordance with Good Utility Practice, the CAISO shall make designations of Eligible Capacity for an Exceptional Dispatch CPM by applying the following additional criteria in the order listed:

- (1) the effectiveness of the Eligible Capacity at meeting the designation criteria specified in Section 43.2;
- (2) the capacity costs associated with the Eligible Capacity;
- (3) the quantity of a resource's available Eligible Capacity, based on a resource's PMin, relative to the remaining amount of capacity needed;
- (4) the operating characteristics of the resource, such as dispatchability, Ramp Rate, and load-following capability; and
- (5) whether the resource is subject to restrictions as a Use-Limited Resource.

In applying these selection criteria, the goal of the CAISO will be to issue Exceptional Dispatches on a least-cost basis to resources that will be effective in meeting the reliability needs underlying the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Exceptional Dispatches. In making this determination, the CAISO will apply the first criterion to identify the effective Eligible Capacity by considering the effectiveness of the resources at meeting the designation criteria for the Exceptional Dispatch and at resolving the underlying reliability need, The CAISO will apply the second criterion by considering the cost of the effective Eligible Capacity. The CAISO will endeavor to Exceptionally Dispatch a resource at the CPM Capacity price determined in accordance with Section 43.6.1 before selecting a resource with a higher unit-specific CPM Capacity price specified under Section 43.6.2. The CAISO will endeavor to Exceptionally Dispatch resources that have specified a capacity price before designating resources that have not specified a CPM Capacity price under Section 43.6.2.1. The CAISO will apply the third criterion by considering the quantity of a resource's Eligible Capacity. The CAISO will endeavor to select a resource that has a PMin at or below the capacity that is needed to meet the reliability need before selecting a resource that has a PMin that would result in over-procurement. The CAISO will apply the fourth criterion by considering specific operating characteristics of a resource, such as dispatchability, ramp rate, and load-following capability to the extent that such characteristics are an important factor in resolving the reliability need. The CAISO will apply the fifth criterion by considering whether a resource is use-limited and whether that status may restrict its ability to be available to the CAISO in the Day-Ahead Market and Real-Time Market throughout the period for which it is being procured. To the extent that use-limited resources are capable of performing the required service for the duration of the Exceptional Dispatch, the CAISO will not unduly discriminate in favor of non-Use Limited resources when applying the selection criteria. Imbalance Energy delivered or consumed pursuant to the various types of Exceptional Dispatch is settled according to the provisions in Section 11.5.6.

34.9.1 System Reliability Exceptional Dispatches

The CAISO may issue a manual Exceptional Dispatch for Generating Units, System Units, Participating Loads, Proxy Demand Resources, Dynamic System Resources, and Condition 2 RMR Units pursuant to Section 41.9, in addition to or instead of resources with a Day-Ahead Schedule dispatched by RTM optimization software during a System Emergency, or to prevent an imminent System Emergency or a situation that threatens System Reliability and cannot be addressed by the RTM optimization and system modeling. To the extent possible, the CAISO shall utilize available and effective Bids from resources

before dispatching resources without Bids. To deal with any threats to System Reliability, the CAISO may also issue a manual Exceptional Dispatch in the Real-Time for Non-Dynamic System Resources that have not been or would not be selected by the RTM for Dispatch, but for which the relevant Scheduling Coordinator has submitted a Bid into the HASP.

34.9.2 Other Exceptional Dispatch

The CAISO may also issue manual Exceptional Dispatches for resources in addition to or instead of resources with a Day-Ahead Schedule or dispatched by the RTM optimization software to: (1) perform Ancillary Services testing; (2) perform pre-commercial operation testing for Generating Units; (3) perform periodic testing of Generating Units, including PMax testing; (4) mitigate for Overgeneration; (5) provide for Black Start; (6) provide for Voltage Support; (7) accommodate TOR or ETC Self-Schedule changes after the Market Close of the HASP; (8) reverse a commitment instruction issued through the IFM that is no longer optimal as determined through RUC; or (9) in the event of a Market Disruption, to prevent a Market Disruption, or to minimize the extent of a Market Disruption; or (10) reverse the operating mode of a Pumped-Storage Hydro Unit. The CAISO will not consider Start-Up Costs, Minimum Load Costs, or Energy Bids in connection with the issuance of Exceptional Dispatches to perform Ancillary Services testing, to perform PMax testing, or to perform pre-commercial operation testing for Generating Units.

34.9.3 Transmission-Related Modeling Limitations

The CAISO may also manually Dispatch resources in addition to or instead of resources with a Day-Ahead Schedule or dispatched by the RTM optimization software, during or prior to the Real-Time as appropriate, to address transmission-related modeling limitations in the Full Network Model.

Transmission-related modeling limitations for the purposes of Exceptional Dispatch, including for settlement of such Exceptional Dispatch as described in Section 11.5.6, shall consist of any FNM modeling limitations that arise from transmission maintenance, lack of Voltage Support at proper levels as well as incomplete or incorrect information about the transmission network, for which the Participating TOs have primary responsibility. The CAISO shall also manually Dispatch resources under this Section 34.9.3 in response to system conditions including threatened or imminent reliability conditions for which the timing of the Real-Time Market optimization and system modeling are either too slow or incapable of

bringing the CAISO Controlled Grid back to reliable operations in an appropriate time-frame based on the timing and physical characteristics of available resources to the CAISO.

34.9.4 Reporting Requirements

On the fifteenth day of each month, the CAISO shall file with the Commission and post to the CAISO Website an initial report concerning the Exceptional Dispatches that occurred in the month two months prior to the month in which the report is filed. The report shall identify the frequency, volume, costs, causes, and degree of mitigation of Exceptional Dispatches during such period to the extent such data are available. On the thirtieth day of the month following the month in which the initial report is filed, the CAISO shall file with the Commission and post to the CAISO Website a revised and updated report for the same period.

34.10 CAISO Market Adjustment To Non-Priced Quantities In The RTM

All Self-Schedules are respected by the SCED and SCUC to the maximum extent possible and are protected from curtailment in the Congestion Management process to the extent that there are effective Economic Bids that can relieve Congestion. If all Effective Economic Bids for the RTM are exhausted, all Self-Schedules between the Minimum Load and the lowest Energy level of the first Energy Bid point will be subject to uneconomic adjustments based on assigned scheduling priorities. This functionality of the optimization software is implemented through the setting of scheduling parameters as described in Section 27.4.3 and specified in Section 27.4.3.1 and the BPMs. Through this process, imports and exports may be reduced to zero, Demand may be reduced to zero, and Generation may be reduced to a lower operating limit (or Regulation Limit) (or to a lower Regulation Limit plus any qualified Regulation Down Award or Self-Provided Ancillary Services, if applicable). Any Self-Schedules below the Minimum Load level are treated as fixed Self-Schedules and are not subject to uneconomic adjustments for Congestion Management but may be subject to decommitment via an Exceptional Dispatch if necessary as a last resort to relieve Congestion that could not otherwise be managed.

34.10.1 Increasing Supply

The scheduling priorities as defined in the RTM optimization to meet the need for increasing Supply as reflected from higher to lower priority are as follows:

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (a) Non-Participating Load reduction, exports explicitly identified in a Resource Adequacy Plan to be served by Resource Adequacy Capacity explicitly identified and linked in a Supply Plan to the exports, or Self-Schedules for exports at Scheduling Points in HASP served by Generation from non-Resource Adequacy Capacity or from non-RUC Capacity;
- (b) Self-Schedules for exports at Scheduling Points in HASP not offered by Generation from non-Resource Adequacy Capacity or not offered by Generation from non-RUC Capacity, except those exports explicitly identified in a Resource Adequacy Plan to be served by Resource Adequacy Capacity explicitly identified and linked in a Supply Plan to the exports as set forth in Section 34.10.1(a); and
- (c) Contingency Only Operating Reserve if activated by Operator to provide Energy (as indicated by the Contingency Flag and the Contingency condition);

34.10.2 Decreasing Supply

The scheduling priorities as defined in the RTM optimization to meet the need for decreasing Supply as reflected from higher to lower priority are as follows:

- (a) Non-Participating Load increase;
- (b) Reliability Must Run (RMR) Schedule (Day-Ahead manual pre-dispatch or Manual RMR Dispatches or Dispatches that are flagged as RMR Dispatches following the MPM-RRD process);
- (c) Transmission Ownership Right (TOR) Self-Schedule;
- (d) Existing Rights (ETC) Self-Schedule;
- (f) Regulatory Must-Run and Regulatory Must-Take (RMT) Self-Schedule;
- (g) Participating Load increase;
- (h) Day-Ahead Supply Schedule; and
- (i) Self-Schedule submitted in HASP.

These dispatch priorities as defined in the RTM optimization may be superseded by operator actions and procedures as necessary to ensure reliable operations.

34.11 Means Of Dispatch Communication

The CAISO dispatches Regulation by AGC to Participating Generators and, for Dynamic System Resources, through dedicated communication links that satisfy the CAISO's standards for external imports of Regulation. The CAISO communicates all other Dispatch Instructions electronically, except that, at the CAISO's discretion, the CAISO may communicate Dispatch Instructions by telephone, or facsimile. Scheduling Coordinators shall confirm the Dispatch Instructions that are communicated orally by repeating them to the CAISO employee providing the Dispatch Instruction. Except in the case of deteriorating system conditions or an actual or threatened System Emergency, and except for Dispatch Instructions for Regulation, the CAISO sends all Dispatch Instructions to the Scheduling Coordinator. The recipient Scheduling Coordinator shall immediately communicate the Dispatch Instruction to the operator of the resource. The CAISO may, with the prior permission of the applicable Scheduling Coordinator, communicate with and give Dispatch Instructions to the operators of the resource directly without having to communicate through their Scheduling Coordinator. The CAISO shall record the communications between the CAISO and Scheduling Coordinators relating to Dispatch Instructions in a manner that permits auditing of the Dispatch Instructions, and of the response of the resources, as applicable. In situations of deteriorating system conditions or System Emergency, the CAISO reserves the right to communicate directly with the resource(s) as required to ensure System Reliability. Scheduling Coordinators are required to advise the CAISO immediately of any change in resource availability that prevents the recipient of a Dispatch Instruction from performing in accordance with that Dispatch Instruction.

34.11.1 Response Required By Resources To Dispatch Instructions

Resources must:

- (a) unless otherwise stated in the Dispatch Instruction, comply with a Dispatch Instruction immediately upon receipt;
- (b) respond to all Dispatch Instructions in accordance with Good Utility Practice;
- (c) meet voltage criteria in accordance with the provisions in the CAISO Tariff;
- (d) meet any applicable Operational Ramp Rates;

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (e) respond to Dispatch Instructions for Ancillary Services within the required time periods and (in the case of Participating Generators providing Regulation) respond to AGC from the EMS; and
- (f) if a time frame is stated in a Dispatch Instruction, respond to a Dispatch Instruction within the stated time frame.

34.11.2 Failure To Conform To Dispatch Instructions

In the event that, in carrying out the Dispatch Instruction, an unforeseen problem arises (relating to plant operations or equipment, personnel or the public safety), the recipient of the Dispatch Instruction must notify the CAISO or, in the case of a Generator, the relevant Scheduling Coordinator immediately. The relevant Scheduling Coordinator shall notify the CAISO of the problem immediately. If a resource is unavailable or incapable of responding to a Dispatch Instruction, or fails to respond to a Dispatch Instruction in accordance with its terms, the resource shall be considered to be non-conforming to the Dispatch Instruction unless the resource has notified the CAISO of an event that prevents it from performing its obligations within thirty (30) minutes of the onset of such event through a SLIC log entry. Notification of non-compliance via the Automated Dispatch System (ADS) will not supplant nor serve as the official notification mechanism to the CAISO. If the resource is considered to be non-conforming as described above, the Scheduling Coordinator for the resource concerned shall be subject to Uninstructed Imbalance Energy as specified in Section 11.5.2 and Uninstructed Deviation Penalties as specified in Section 11.23. This applies whether any Ancillary Services concerned are contracted or Self-Provided. For a Non-Dynamic System Resource Dispatch Instruction prior to the Trading Hour, the Scheduling Coordinator shall inform the CAISO of its ability to conform to a Dispatch Instruction via ADS. The Non-Dynamic System Resource has the option to accept, partially accept, or decline the Dispatch Instruction, but in any case must respond within the timeframe specified in a Business Practice Manual. The Non-Dynamic System Resource can change its response within the indicated timeframe. If a Non-Dynamic System Resource does not respond within the indicated timeframe, the Dispatch Instruction will be considered declined. A decline of such a Non-Dynamic System Resource for a Dispatch Instruction received at least forty (40) minutes prior to the Trading Hour will be subject to Uninstructed Deviation Penalties as specific in Section 11.23. A decline of such a Non-Dynamic System Resource for a Dispatch

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Instruction received less than forty (40) minutes prior to the Trading Hour will not be subject to Uninstructed Deviation Penalties. A Non-Dynamic System Resource that only partially accepts a Dispatch Instruction is subject to Uninstructed Deviation Penalties for the portion of the Dispatch Instruction that is declined.

When a resource demonstrates that it is not following Dispatch Instructions, the RTM will no longer assume that the resource will ramp from its current output level. The RTM assumes the resource to be "non-compliant" if it is deviating its five (5)-minute Ramping capability for more than N intervals by a magnitude determined by the CAISO based on its determination that it is necessary to improve the calculation of the expected Imbalance Energy as further defined in the BPM. When a resource is identified as "non-compliant," RTM will set the Dispatch operating target for that resource equal to its actual output in the Market Clearing software such that the persistent error does not cause excessive AGC action and consequently require CAISO to take additional action to comply with reliability requirements. Such a resource will be considered to have returned to compliance when the resource's State Estimator or telemetry value (whichever is applicable) is within the above specified criteria. During the time when the resource is "non-compliant", the last applicable Dispatch target shall be communicated to the Scheduling Coordinator as the Dispatch operating target. The last applicable Dispatch target may be (i) the last Dispatch operating target within the current Trading Hour that was instructed prior to the resource becoming "non-compliant," or (ii) the Day-Ahead Schedule, or (iii) the HASP Self-Schedule depending on whether the resource submitted a Bid and the length of time the resource was "non-compliant," or (iv) for a Dynamic System Resource or a Pseudo-Tie Generating Unit that is an Eligible Intermittent Resource, the most recently available telemetry for the actual output.

34.12 Metered Subsystems

Scheduling Coordinators that represent MSSs may submit Bids for Supply of Energy to the RTM, irrespective of whether the MSS is a Load following MSS. All Bids submitted for MSS generating resources for the RTM and all Dispatch Instructions shall be generating resource-specific. MSS non-Load following resources are responsible for following Dispatch Instructions. Load following MSS Operators shall provide the CAISO with an estimate of the number of MWs the applicable generating resource(s) will be generating over the next two hours in five-minute interval resolution. The Dispatch

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Instructions for Load following resources are incorporated with Generation estimates provided by MSS Operators. Such MSS Load following resources can deviate from the Dispatch Instructions in Real-Time to facilitate the following of Load without being subject to the Uninstructed Deviation Penalty as further described in Section 11.23. The State Estimator will estimate all MSS Load in Real-Time and the CAISO will incorporate the information provided by the Load following MSS Operator for utilization in clearing the RTM and its Dispatch Instructions.

34.13 Treatment Of Resource Adequacy Capacity In The RTM

Resource Adequacy Resources required to offer their Resource Adequacy Capacity in accordance with Section 40 shall be required to submit Energy Bids for: (1) all such Resource Adequacy Capacity and (2) any Ancillary Services capacity awarded or self-provided in the IFM, HASP, or Real-Time Market. In the absence of submitted Bids, as part of the validation described in 30.7, Generated Bids will be used for Resource Adequacy Resources required to offer their Resource Adequacy Capacity in accordance with Section 40. For any capacity from a Resource Adequacy Resource not required to offer Resource Adequacy Capacity in accordance with Section 40 that was awarded or is self-providing Operating Reserves capacity in the IFM, Scheduling Coordinators must submit an Energy Bid for no less than the amount of awarded or self-provided Operating Reserves capacity above their Day-Ahead Schedule. Resource Adequacy Resources that are not required to offer their Resource Adequacy Capacity in accordance with Section 40 may voluntarily submit Energy Bids or Ancillary Services Bids. Submitted Energy Bids shall be subject to the maximum and minimum Bid requirements and Mitigation Measures as set forth in Section 39.

34.14 Real-Time Activities In The Hour Prior To Settlement Period

34.14.1 Confirm Interchange Transaction Schedules (ITSs)

Also in the hour prior to the beginning of the Operating Hour the CAISO will:

- (a) adjust Interchange transaction schedules (ITSs) as required under Existing Contracts in accordance with the procedures in the CAISO Tariff for the management of Existing Contracts;
- (b) adjust ITSs as required by changes in transfer capability of transmission paths occurring after Market Close of the HASP; and

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (c) agree on ITS changes with adjacent Balancing Authorities.

34.15 Rules For Real-Time Dispatch Of Imbalance Energy Resources

34.15.1 Resource Constraints

The SCED shall enforce the following resource physical constraints:

- (a) Minimum and maximum operating resource limits. Outages and limitations due to transmission clearances shall be reflected in these limits. The more restrictive operating or regulating limit shall be used for resources providing Regulation so that the SCED shall not Dispatch them outside their Regulating Range.
- (b) Forbidden Operating Regions. When ramping in the Forbidden Operating Region, the implicit ramp rate will be used as determined based on the time it takes for the resource to cross its Forbidden Operating Region. A resource can only be ramped through a Forbidden Operating Region after being dispatched into a Forbidden Operation Region. The CAISO will not Dispatch a resource within its Forbidden Operating Regions in the Real-Time Market, except that the CAISO may Dispatch the resource through the Forbidden Operating Region in the direction that the resource entered the Forbidden Operating Region at the maximum applicable Ramp Rate over consecutive Dispatch Intervals. A resource with a Forbidden Operating Region cannot provide Ancillary Services in a particular fifteen (15) minute Dispatch Interval unless that resource can complete its transit through the relevant Forbidden Operating Region within that particular Dispatch Interval.
- (c) Operational Ramp Rates and Start-Up Times. The submitted Operational Ramp Rate for resources shall be used as the basis for all Dispatch Instructions, provided that the Dispatch Operating Point for resources that are providing Regulation remains within their applicable Regulating Range. The Regulating Range will limit the Ramping of Dispatch Instructions issued to resources that are providing Regulation. The Ramp Rate for Non-Dynamic System Resources cleared in the HASP will not be observed. Rather, the ramp of the Non-Dynamic System Resource will respect inter-Balancing Authority Area Ramping conventions established by WECC. Ramp Rates for Dynamic System

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Resources will be observed like Participating Generators in the RTD. Each Energy Bid shall be Dispatched only up to the amount of Imbalance Energy that can be provided within the Dispatch Interval based on the applicable Operational Ramp Rate. The Dispatch Instruction shall consider the relevant Start-Up Time as, if the resource is off-line, the relevant Operational Ramp Rate function, and any other resource constraints or prior commitments such as Schedule changes across hours and previous Dispatch Instructions. The Start-Up Time shall be determined from the Start-Up Time function and when the resource was last shut down. The Start-Up Time shall not apply if the corresponding resource is on-line or expected to start.

- (d) Maximum number of daily Start-Ups. The SCED shall not cause a resource to exceed its daily maximum number of Start-Ups.
- (e) Minimum Run Time and Down Time. The SCED shall not start up off-line resources before their Minimum Down Time expires and shall not shut down on-line resources before their Minimum Run Time expires. For Multi-Stage Generating Resources these requirements shall be observed both for the Generating Unit or Dynamic Resource-Specific System Resource and MSG Configuration.
- (f) Operating (Spinning and Non-Spinning) Reserve. The SCED shall Dispatch Spinning and Non-Spinning Reserve subject to the limitations set forth in Section 34.16.3.
- (g) Non-Dynamic System Resources. If Dispatched, each Non-Dynamic System Resource flagged for hourly pre-dispatch in the next Trading Hour shall be Dispatched to operate at a constant level over the entire Trading Hour. The HASP shall perform the hourly pre-dispatch for each Trading Hour once prior to the Operating Hour. The hourly pre-dispatch shall not subsequently be revised by the SCED and the resulting HASP Intertie Schedules are financially binding and are settled pursuant to Section 11.4.
- (h) Daily Energy use limitation to the extent that Energy limitation is expressed in a resource's Bid. If the Energy Limits are violated for purposes of Exceptional Dispatches for System Reliability, the Bid will be settled as provided in Section 11.5.6.1.

34.15.2 Calculation Of Dispatch Operating Points After Instructions

The RTED process shall calculate Dispatch Operating Points as follows:

- (a) After RTUC issues a Start-Up Instruction, RTED moves the Dispatch Operating Point of a resource immediately from zero (0) MW to the PMin, as defined in the Master File or as modified via SLIC, of a Generating Unit at the start of the Dispatch Interval pertaining to the Start-Up Instruction. The Dispatch Operating Point shall then be determined using the resource's applicable Operational Ramp Rate as further described in Sections 34.15.4, 34.15.5, and 34.15.6.
- (b) After RTUC issues a Shut-Down Instruction, RTED shall first ramp the Dispatch Operating Point down to the PMin, as defined in the Master File or as modified via SLIC, of a Generating Unit at the end of the Dispatch Interval pertaining to the Shut-Down Instruction, using the resource's applicable Operational Ramp Rate. The Dispatch Operating Point shall then be set immediately to zero (0) MW.
- (c) After RTUC issues a Transition Instruction: (1) for MSG Configurations where the operating ranges of the two MSG Configurations do not overlap, the RTD will move the Dispatch Operating Point of the resource immediately from the boundary of the "from" MSG Configuration to the boundary of the "to" MSG Configuration, as defined in the Master File or as modified via the CAISO's outages reporting mechanism, of a Multi-Stage Generating Resource; and (2) for MSG Configurations for which the operating ranges of the two MSG Configurations do overlap, RTD will move the Dispatch Operating Point of the resource within the overlapping operating range of the MSG Configuration until the MSG Transition is complete.

34.15.3 [NOT USED]

34.15.4 Inter-Hour Dispatch Of Resources With Real-Time Energy Bids

Dispatch Instructions associated with the ramp between the Real-Time Market Bid in one hour and the Real-Time Market Bid in the immediately succeeding Trading Hour shall be determined optimally by the SCED if the CAISO has Bids for either or both relevant Operating Hours. For any Operating Hour(s) for

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

which Bids have been submitted Dispatch Instructions will be optimized such that the Dispatch Operating Point is within the Bid range(s). For any Operating Hour without submitted Bids, Dispatch Instructions will be optimized such that the Dispatch Operating Point conforms to the Schedule within the Operating Hour. Energy resulting from the Standard Ramp shall be deemed Standard Ramping Energy and will be settled in accordance with Section 11.5.1. Energy resulting from any ramp extending beyond the Standard Ramp will be deemed Ramping Energy Deviation and will be settled in accordance with Section 11.5.1. Energy delivered or consumed as a result of CAISO Dispatch of a resource's Energy Bid in one Operating Hour to a Dispatch Operating Point such that the resource cannot return to its successive Operating Hour Schedule or to an infra-marginal operating point by the beginning of the next Operating Hour is Residual Imbalance Energy and shall be settled as Instructed Imbalance Energy as provided for in Section 11.5.1 and also may be eligible for recovery of its applicable Energy Bid Costs in accordance with Section 11.8. Similarly, Energy delivered or consumed as a result of CAISO Dispatch of a resource's Energy Bid in a future Operating Hour to a Dispatch Operating Point different from its current Operating Point prior to the end of the current Operating Hour is also considered Residual Imbalance Energy and shall be settled as Instructed Imbalance Energy as provided for in Section 11.5.1 and also may be eligible for recovery of its applicable Energy Bid Costs in accordance with Section 11.8. When Ramping Energy Deviation and Residual Imbalance Energy coexist within a given Dispatch Interval, the Ramping Energy Deviation shall be the portion of Instructed Imbalance Energy that is produced or consumed within the Schedule-change band defined by the accepted HASP Bids of the two consecutive Settlement Periods; the Residual Imbalance Energy shall be the portion of Instructed Imbalance Energy that is produced or consumed outside the Schedule-change band.

34.15.5 Inter-Hour Resources Dispatch Without Real-Time Energy Bids

Dispatch Instructions shall be issued for each Dispatch Interval as needed to prescribe the ramp between a resource's accepted Self-Schedule in one Trading Hour and its accepted Self-Schedule in the immediately succeeding Trading Hour. Such Dispatch Instructions shall be based on the lesser of: (1) the applicable Operational Ramp Rate as provided for in Section 30.7.7 and (2) the Ramp Rate associated with the Standard Ramp. The Dispatch Instructions for Ramping of Generating Units without Real-Time Energy Bids in both Operating Hours shall ramp the resource between hourly Schedules symmetrically to

the extent possible subject to the Regulation Ramping limitations across hourly boundaries in twenty (20) to sixty (60) minutes assuming Congestion can be resolved utilizing Economic Bids. The minimum twenty (20)-minute ramp is required for smooth hourly Schedule changes and is consistent with Intertie.

scheduling agreements between Balancing Authority Areas. Energy resulting from the Standard Ramp shall be deemed Standard Ramping Energy and will be settled in accordance with Section 11.5.1.

Energy resulting from any ramp extending beyond the Standard Ramp will be deemed Ramping Energy Deviation and will be settled in accordance with Section 11.5.1.

34.15.6 Intra-Hour Exceptional Dispatches

For the special case where an Exceptional Dispatch begins in the new hour and the rules above would result in the violation of the resource's inter-temporal constraint(s), the following rules are applied and the Energy is settled as Exceptional Dispatch Energy as described in Section 11.5.6.

- (a) If the ramp time is greater than one hour or greater than what can be achieved when RTM receives the constraint, RTM starts the ramp at the earliest possible time and continues Ramping the resource in the new Trading Hour.
- (b) If the ramp time results in starting the ramp less than ten (10) minutes before the start of the hour, RTM instead starts the ramp at ten (10) minutes before the start of the hour and ramps the resource at a uniform rate so that it meets the constraint by the start time of the Exceptional Dispatch.
- (c) If the new hour's Day-Ahead Schedule is beyond the Exceptional Dispatch constraint, RTM resumes the basic Ramping rules after the Exceptional Dispatch constraint is met, but limits the Ramp Rate as necessary to ensure that the resource does not complete its ramp before ten (10) minutes after the hour.

34.16 Ancillary Services In The Real-Time Market

34.16.1 [NOT USED]

34.16.2 Dispatch Of Self-Provided Ancillary Services

Where a Scheduling Coordinator has chosen to self-provide the whole of the additional Operating Reserve required to cover any Interruptible Imports which it has submitted through Self-Schedules in the Day-Ahead Market and has identified specific Generating Units, Participating Loads, System Units or

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

System Resources as the providers of the additional Operating Reserve concerned, the CAISO shall Dispatch only the designated Generating Units, Participating Loads, System Units or System Resources in the event of the CAISO being notified that the on demand obligation is being curtailed. The Scheduling Coordinator scheduling an Interruptible Import will be responsible for Operating Reserves associated with the Interruptible Import, regardless of whether the Scheduling Coordinator is an LSE or not. For all other Submissions to Self-Provide an Ancillary Service, the Energy Bid shall be used to determine the Dispatch, subject to the limitation on the Dispatch of Spinning Reserve and Non-Spinning Reserve set forth in Section 34.10.

34.16.3 Ancillary Services Requirements For RTM Dispatch

The following requirements apply to the Dispatch of Ancillary Services in the RTM:

34.16.3.1 Regulation

- (a) Regulation provided from Generating Units or System Resources must meet the standards specified in this CAISO Tariff and Part A of Appendix K;
- (b) The CAISO will Dispatch Regulation through the EMS, which Dispatch of Regulation by EMS does not set the RTM LMP;
- (c) In the event of an unscheduled increase in system Demand or a shortfall in Generation output and Regulation margin drops, the CAISO will use Dispatch Energy in the RTM or Dispatch Operating Reserve to restore Regulation margin; and
- (d) When scheduled Operating Reserve is used for restoration of Regulation reserve, the CAISO shall arrange for the replacement of that Operating Reserve.

34.16.3.2 Operating Reserve

- (a) Spinning Reserve:
 - (i) Spinning Reserve provided from Generating Units and System Resources must meet the standards specified in Part B of Appendix K;
 - (ii) The CAISO will Dispatch Spinning Reserve as may be required to meet the Applicable Reliability Criteria;

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (iii) The CAISO may Dispatch Spinning Reserve as balancing Energy to return Regulation Generating Units to their Set Points and restore full Regulation margin; and
 - (iv) The CAISO will Dispatch Spinning Reserve as determined by the SCED, subject to Sections 34.3 and 34.8.
- (b) Non-Spinning Reserve:
- (i) Non-Spinning Reserve provided from Generating Units, Demands, and System Resources must meet the standards specified in Part C of Appendix K;
 - (ii) The CAISO may Dispatch Non-Spinning Reserve in place of Spinning Reserve to meet Applicable Reliability Criteria;
 - (iii) The CAISO will Dispatch Non-Spinning Reserve as determined by the SCED, subject to Sections 34.3 and 34.8; and
 - (iv) The CAISO may Dispatch Non-Spinning Reserve to replace Spinning Reserve if there is a shortfall in Spinning Reserve because of a deficiency of balancing Energy.

34.16.3.3 Replacement of Operating Reserve

If Operating Reserve is used for Energy, the CAISO may replace such Operating Reserve through Dispatch of additional Energy available from Energy Bids submitted in the HASP for the RTM or through procurement of additional reserves based on optimization of a resource's RTM Ancillary Service Bid and its Energy Bid.

34.16.3.4 Voltage Support

- (a) Voltage Support provided from Generating Units shall meet the standards specified in this CAISO Tariff and Part E of Appendix K.
- (b) The CAISO may Dispatch Generating Units to increase or decrease MVar output within power factor limits established pursuant to Section 8.2.3.3 (or within other limits specified by the CAISO in any exemption granted pursuant to Section 8.2.3.3) at no cost to the CAISO when required for System Reliability.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (c) The CAISO may Dispatch each Generating Unit to increase or decrease MVar output outside of established power factor limits, but within the range of the Generating Unit's capability curve, at a price calculated in accordance with the CAISO Tariff.
- (d) If Voltage Support is required in addition to that provided pursuant to Section 34.16.3.4 (b) and (c), the CAISO will reduce output of Participating Generators certified in accordance with Appendix K . The CAISO will select Participating Generators in the vicinity where such additional Voltage Support is required.
- (e) The CAISO will monitor voltage levels at Interconnections to maintain them in accordance with the applicable inter-Balancing Authority Area agreements.

34.17 Dispatch Information And Instructions

34.17.1 Dispatch Information To Be Supplied By The CAISO

Communication of Dispatch information provided by the CAISO shall be in accordance with Section 6.3.

34.17.2 Dispatch Information To Be Supplied By SC

Each Scheduling Coordinator shall be responsible for the submission of Bids and Dispatch of Generation and Demand in accordance with its Day-Ahead Schedule. Each Scheduling Coordinator shall keep the CAISO apprised of any change or potential change in the current status of all Generating Units and Intertie Schedules. This will include any changes in Generating Unit capacity that could affect planned Dispatch and conditions that could affect the reliability of a Generating Unit. Each Scheduling Coordinator shall immediately pass to the CAISO any information which it receives from a Generator which the Generator provides to the Scheduling Coordinator pursuant to Sections 34.11.1 and 34.11.2. Each Scheduling Coordinator shall immediately pass to the CAISO any information it receives from a MSS Operator which the MSS Operator provides to the Scheduling Coordinator regarding any change or potential change in the current status of all Generating Units, System Units and Intertie Schedules. This information includes any changes in MSS System Units and Generating Unit capacity that could affect planned Dispatch and conditions that could affect the reliability of the System Unit or Generating Unit.

34.17.3 Dispatch Information To Be Supplied By UDCs

Each UDC shall keep the CAISO informed of any change or potential change in the status of its transmission lines and station equipment at the point of Interconnection with the CAISO Controlled Grid.

Each UDC shall keep the CAISO informed as to any event or circumstance in the UDC's service territory that could affect the reliability of the CAISO Controlled Grid. This would include adverse weather conditions, fires, bomb threats, etc.

34.17.4 Dispatch Information To Be Supplied By PTOs

Each PTO shall report any change or potential change in equipment status of the PTO's transmission assets turned over to the control of the CAISO or in equipment that affects transmission assets turned over to the control of the CAISO immediately to the CAISO (this will include line and station equipment, line protection, Remedial Action Schemes and communication problems, etc.). Each PTO shall also keep the CAISO immediately informed as to any change or potential change in the PTO's transmission system that could affect the reliability of the CAISO Controlled Grid. This would include adverse weather conditions, fires, bomb threats, etc.

Each PTO shall schedule all Outages of its lines and station equipment which are under the Operational Control of the CAISO in accordance with the appropriate procedures in Section 9.3. Each PTO shall coordinate any requests for or responses to Forced Outages on its transmission lines or station equipment which are under the Operational Control of the CAISO directly with the appropriate CAISO Control Center as defined in Section 7.1.

34.17.5 Dispatch Information To Be Supplied By Balancing Authorities

The CAISO and each adjacent Balancing Authority shall keep each other informed of any change or potential change in the status of the Interconnection and any changes in the Interconnection's TTC. The CAISO and each adjacent Balancing Authority shall keep each other informed of situations such as adverse weather conditions, fires, etc., that could affect the reliability of any Interconnection.

The CAISO and each adjacent Balancing Authority shall follow all applicable NERC and WECC scheduling procedures. This will include checking the Interconnection schedules for the next Settlement Period prior to the start of the Energy ramp going into that hour. The CAISO and each adjacent Balancing Authority shall check and agree on actual MWh net Interchange after the hour for the previous

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Settlement Period. One Balancing Authority Area shall change its actual number to reflect that of the other Balancing Authority Area in accordance with WECC standard procedures.

The CAISO and each adjacent Balancing Authority shall exchange MW, MVar, terminal and bus voltage data with each other on a four second update basis. MWh data for the previous hour shall be exchanged once per hour. All MW and MWh data for both the CAISO Balancing Authority Area and the adjacent Balancing Authority Areas must originate from the same metering equipment. All provisions in Sections 4.6.1.1(i) and 4.6.1.1 (ii) refer to information and data obtained from metering used for Balancing Authority Area operations and not metering used for billing and Settlement.

34.18 [NOT USED]

34.19 Pricing Imbalance Energy

34.19.1 General Principles

Instructed and Uninstructed Imbalance Energy shall be paid or charged the applicable Resource-Specific Settlement Interval LMP except for hourly pre-dispatched Instructed Imbalance Energy, which shall be settled as set forth in Section 11.5.2. These prices are determined using the Dispatch Interval LMPs. The Dispatch Interval LMPs shall be based on the Bid of the marginal Generating Units, System Units, Participating Loads, and Proxy Demand Resources dispatched by the CAISO to increase or reduce Demand or Energy output in each Dispatch Interval as provided in Section 34.19.2.1.

The CAISO will respond to the Dispatch Instructions issued by the SCED to the extent practical in the time available and acting in accordance with Good Utility Practice. The CAISO will record the reasons for any variation from the Dispatch Instructions issued by the SCED.

34.19.2 Determining Real-Time LMPs

34.19.2.1 Dispatch Interval Real-Time LMPs

34.19.2.2 Computation

For each Dispatch Interval, the CAISO will compute updated Imbalance Energy needs and will Dispatch Generating Units, System Units, Dynamic System Resources, Participating Load, and Proxy Demand Resources according to the CAISO's SCED during that time period to meet Imbalance Energy requirements. The RTM transactions will be settled at the Dispatch Interval LMPs in accordance with Section 11.5.

34.19.2.3 Eligibility to Set the Real-Time LMP

All Generating Units, Participating Loads, Proxy Demand Resources, Dynamic System Resources, System Units, or COGs subject to the provisions in Section 27.7, with Bids, including Generated Bids, that are unconstrained due to Ramp Rates or other temporal constraints are eligible to set the LMP, provided that (a) a Generating Unit or a Dynamic Resource-Specific System Resource is Dispatched between its Minimum Operating Limit and the highest MW value in its Economic Bid or Generated Bid, or (b) a Participating Load, a Proxy Demand Resource, a Dynamic System Resource that is not a Resource-Specific System Resource, or a System Unit is Dispatched between zero (0) MW and the highest MW value within its submitted Economic Bid range or Generated Bid. If a resource is Dispatched below its Minimum Operating Limit or above the highest MW value in its Economic Bid range or Generated Bid, or the CAISO enforces a resource-specific constraint on the resource due to an RMR or Exceptional Dispatch, the resource will not be eligible to set the LMP. Resources identified as MSS Load following resources are not eligible to set the LMP. A resource constrained at an upper or lower operating limit or dispatched for a quantity of Energy such that its full Ramping capability is constraining the ability of the resource to be dispatched for additional Energy in target interval, cannot be marginal (i.e., it is constrained by the Ramping capability) and thus is not eligible to set the Dispatch Interval LMP. Non-Dynamic System Resources are not eligible to set the Dispatch Interval LMP. Dynamic System Resources are eligible to set the Dispatch Interval LMP. A Constrained Output Generator that has the ability to be committed or shut off within applicable time periods that comprise the RTM will be eligible to set the Dispatch Interval LMP if any portion of its Energy is necessary to serve Demand. Dispatches of Regulation resources by EMS in response to AGC will not set the RTM LMP. Dispatches of Regulation resources to a Dispatch Operating Point by RTM SCED will be eligible to set the RTM LMP.

34.19.2.4 [NOT USED]

34.19.2.5 Price for Uninstructed Deviations for Participating Intermittent Resources

Deviations associated with each Participating Intermittent Resource in a Scheduling Coordinator's portfolio shall be settled as provided in Section 11.12 at the monthly weighted average Dispatch Interval LMP, as calculated in accordance with Section 11.5.4.1 at each Pnode associated with the Participating

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Intermittent Resource, and using the monthly weighted average with weights equal to total Real-Time Generation.

35. Market Validation And Price Correction

35.1 Market Validation

The CAISO shall monitor the Market Clearing software solutions for the Day-Ahead Market, the RUC process, the Hour-Ahead Scheduling Process, and the Real-Time Market for all market intervals to determine whether prices are calculated accurately, consistent with the provisions of the CAISO Tariff. To the extent reasonably practicable, the CAISO shall correct erroneous prices identified through such monitoring and re-run the relevant CAISO Markets prior to publication of prices on its Open Access Same-Time Information System (OASIS) or provision of prices directly to Market Participants, if applicable.

35.2 Timing Of The Price Correction Process

All prices for each Trading Day shall become subject to the CAISO's price correction process once the CAISO publishes them on its OASIS or provides them directly to Market Participants, if applicable. For all prices, the price correction process for each Trading Day shall end no later than the end of the fifth calendar day following that Trading Day. The CAISO may complete the price correction process for any Trading Day earlier than the end-time established in this Section 35 . The CAISO shall provide notification on the CAISO Website when it has completed the price correction process for each Trading Day. If the CAISO does not provide such notification, the price correction process will be deemed complete at the end of the fifth calendar day following that Trading Day.

35.3 Finality Of Prices Subject To The Price Correction Process

All prices shall be considered provisional until the CAISO has completed the price correction process regarding them. All prices for each Trading Day shall be considered final for purposes of this Section 35 once the price correction process for that Trading Day has ended and the CAISO will not make price corrections or change published prices after the price correction process time period has expired except as further discussed in this Section 35.3. The CAISO will not make price corrections after the price correction process time period specified in Section 35.2 has expired, except as otherwise directed by the Federal Energy Regulatory Commission. In addition, for intervals in which the CAISO experiences a

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

problem with the processing or publication of prices, the CAISO will make changes to the affected prices to remedy the processing or publication problems within the time period following the applicable Trading Day as specified in the Business Practice Manual, except as otherwise directed by the Federal Energy Regulatory Commission. After the after expiration of the applicable time horizon for addressing processing and publication issues, as specified in the Business Practice Manual, in the case of a price discrepancy between prices posted on the CAISO's OASIS and prices provided to Scheduling Coordinators through other means, the CAISO will use the price posted on OASIS for Settlement purposes.

35.4 Scope Of Price Corrections

The CAISO may correct all financially binding prices, including all prices released pursuant to Section 6, whenever the CAISO identifies an invalid market solution or invalid prices in an otherwise valid market solution. The circumstances in which the CAISO may determine that an invalid market solution or invalid prices exist include the following: the occurrence of data input failure; the occurrence of hardware or software failure; or a result that is inconsistent with the CAISO Tariff. The reposting of prices to remedy processing or publication issue as discussed in Section 35.3 does not constitute a price correction.

35.5 Price Correction Methodology

The CAISO shall correct prices to conform with the relevant provisions of the CAISO Tariff to the extent such correction is practicable. To the extent such correction is not practicable, the CAISO shall correct prices so that they are as close as reasonably possible to the prices that should have resulted under the relevant provisions of the CAISO Tariff, using the most accurate data available, and in a manner that is consistent with the prevalent system conditions existing at that time. The CAISO shall correct prices using the first applicable and practicable correction method of the following:

- (a) The CAISO shall selectively recalculate incorrect financially binding prices when the invalid prices are isolated and can be corrected such that no other financially binding prices are affected by the correction.
- (b) If the correction method in Section 35.5(a) is not applicable and practicable, the CAISO shall recalculate prices for the invalidated market interval when all market inputs applicable to the market interval to be recalculated are either (i) preserved

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

from the original market run, for data that was not the cause of the invalidated price, (ii) corrected, in the case of invalid initial data in the initial Market Clearing, or (iii) recreated or replicated data using the best available alternate data sources, in the case of missing data in the initial Market Clearing.

- (c) If the correction methods in Sections 35.5(a) and 35.5(b) are not applicable and practicable, the CAISO shall use, in place of prices for the binding interval of an invalidated market solution, replicated prices from binding or advisory intervals from the validated market solution in which the market conditions were most similar to the market conditions in the invalidated market solution, for the affected interval. In no case will an invalidated Day-Ahead Market solution be replaced with a valid Day-Ahead Market solution from a previous Trading Day. The method set forth in this Section 35.5(c) shall apply in the Day-Ahead Market only when some but not all hourly market intervals within a valid market run are deemed to be invalid and prices are not recalculated pursuant to the method set forth in Section 35.5(b), above.

The CAISO shall include details concerning the CAISO's price correction methodology in the applicable Business Practice Manual.

35.6 Weekly Price Correction Report

The CAISO shall summarize all price corrections that occur within a week in a report that shall be posted on the CAISO Website by the seventh day of the following week. For all price corrections that occur during each week, the price correction report shall specify: (a) which market intervals were affected, (b) which price locations were affected, (c) a brief description of the reason for the price correction, and (d) the method of price corrective action undertaken.