| e | California I | SO | 202 | 24 Telemetry Exemptions | | |
|----------|-----------------|------------|------------|------------------------------|--|---|
| Status | Resource ID | Start Date | End Date | Site Name | Exemption | Rejection Reason |
| Granted | DIABLO_7_UNIT 1 | 2/8/2022 | 10/2/2024 | . DIABLO CANYON POWER PLANT | Other | |
| Granted | DIABLO_7_UNIT 2 | 2/8/2022 | 9/26/2025 | . DIABLO CANYON POWER PLANT | Other | |
| Granted | TX-ELK_6_SOLAR1 | 1/12/2024 | 10/31/2024 | CASTOR | Other | |
| Granted | RTEDDY_2_SC1SR3 | 3/4/2024 | 8/29/2024 | GOLDEN FIELDS SOLAR III LLC | RIG points not in current model build | |
| Granted | RTEDDY_2_SEBSR3 | 3/4/2024 | 8/29/2024 | GOLDEN FIELDS SOLAR III LLC | RIG points not in current model build | |
| Granted | RTEDDY_2_SEBSR4 | 3/4/2024 | 8/29/2024 | GOLDEN FIELDS SOLAR III LLC | RIG points not in current model build | |
| Granted | RTEDDY_2_SPASR4 | 3/4/2024 | 8/29/2024 | GOLDEN FIELDS SOLAR III LLC | RIG points not in current model build | |
| Granted | RTEDDY_2_SRXSR4 | 3/4/2024 | 8/29/2024 | GOLDEN FIELDS SOLAR III LLC | RIG points not in current model build | |
| Granted | VESTAL_2_UNIT1 | 3/12/2024 | 9/1/2024 | CALGREN-PIXLEY | Intermittent connection (communication dropping) | |
| Granted | CALFTN_2_CFSBT1 | 3/21/2024 | 7/31/2024 | CAL FLATS BESS | Various analog and digital points are down | |
| Granted | CALFTN_2_SOLAR | 3/21/2024 | 7/31/2024 | CAL FLATS NORTH | Various analog and digital points are down | |
| Granted | RTEDDY_2_SOLAR1 | 3/7/2024 | 6/30/2024 | ROSAMOND 1 | RIG points not in current model build | |
| Granted | RTEDDY_2_SOLAR2 | 3/7/2024 | 6/30/2024 | ROSAMOND 2 | RIG points not in current model build | |
| Granted | CALFTS_2_CFSSR1 | 4/2/2024 | 9/1/2024 | CA FLATS SOUTH | RIG points not in current model build | |
| Granted | GRNLF2_1_UNIT | 4/2/2024 | 8/31/2024 | GREENLEAF ENERGY UNIT 2, LLC | Intermittent connection (communication dropping) | |
| Granted | ESCO_6_GLMQF | 4/4/2024 | 7/31/2024 | GOAL LINE 5912232 | RIG failure | |
| Granted | BGSKYN_2_ASSR1B | 2/28/2024 | 8/20/2024 | ANTELOPE EXPANSION 1B | RIG points not in current model build | |
| Rejected | MSTANG_2_MTGBT1 | 4/11/2024 | 8/27/2024 | MUSTANG BESS | All communication with resource is down | Continue working towards resolution and provide status updates. If applicable, ensure the proper status and generation changes are communicated by your SC to our Generation Desk. If communication cannot be restored by exemption end date you must submit an exemption renewal request and provide additional information. |
| Granted | HOLSTR_1_SOLAR | 4/23/2024 | 6/30/2024 | SAN BENITO SMART PARK | Other | |
| Granted | VICTOR_1_CREST | 4/29/2024 | 9/2/2024 | VICTOR_1_CREST | Other | |
| Granted | BKRFLD_2_SOLAR1 | 4/29/2024 | 6/30/2024 | BAKERSFIELD 111 | All communication with resource is down | |
| Granted | SAMPSN_6_KELCO1 | 4/3/2024 | 7/12/2024 | CP KELCO | RIG failure | |
| Granted | GUERNS_6_SOLAR | 4/10/2024 | 6/30/2024 | GUERNSEY SOLAR | Some weather station points are down | |
| Granted | MIDWD_2_WIND2 | 4/9/2024 | 6/30/2024 | CORAM WIND | Invalid or inaccurate data | |
| Granted | DRACKR_2_D4SR4B | 5/2/2024 | 6/30/2024 | BLYTHE 4 B (PV SOLAR) | Various analog and digital points are down | |
| Granted | DRACKR 2 DS4SR4 | 5/3/2024 | 6/30/2024 | BLYTHE 4 A SOLAR | Invalid or inaccurate data | |

| Status | Resource ID | Start Date | End Date | Site Name | Exemption | Rejection Reason |
|----------|-------------------|------------|------------|-----------------------------------|--|------------------|
| Granted | DRACKR_2_DS3SR3 | 5/4/2024 | 6/30/2024 | BLYTHE 3 SOLAR | Invalid or inaccurate data | |
| Granted | WNDSTR_2_WIND | 5/13/2024 | 8/30/2024 | WINDSTAR | All communication with resource is down | |
| Granted | USWPJR_2_UNITS | 5/11/2024 | 8/30/2024 | VASCO | Invalid or inaccurate data | |
| Granted | OASIS_6_SOLAR3 | 3/6/2024 | 7/31/2024 | OASIS_6_SOLAR3 | All communication with resource is down | |
| Granted | REDMAN_2_SOLAR | 5/14/2024 | 7/31/2024 | REDMAN_2_SOLAR | All communication with resource is down | |
| Rejected | MIDWD_2_WIND2 | 4/9/2024 | 8/30/2024 | CORAM WIND | Invalid or inaccurate data | |
| Voided | MDFKRL_2_PROJCT | 4/30/2024 | 9/16/2024 | MIDDLE FORK & RALSTON POWERHOUSE | Various analog and digital points are down | |
| Granted | BANKPP_2_NSPIN | 2/15/2024 | 8/30/2024 | BANKPP_2_NSPIN | Various analog and digital points are down | |
| Granted | SNCLRA_2_HOWLNG | 5/17/2024 | 7/16/2024 | GLASS HOUSE CAMARILLO CULTIVATION | Other | |
| Granted | CRWCKS_1_SOLAR1 | 5/17/2024 | 7/18/2024 | FRONTIER SOLAR | All communication with resource is down | |
| Granted | OASIS_6_LPPSR1 | 5/18/2024 | 7/18/2024 | FRONTIER SOLAR | All communication with resource is down | |
| Granted | EEKTMN_6_SOLAR1 | 5/21/2024 | 7/18/2024 | KETTLEMAN SOLAR | All communication with resource is down | |
| Granted | RECTOR_2_CREST | 5/25/2023 | 12/31/2024 | RECTOR_2_CREST | Other | |
| Granted | DELAMO_2_SOLRC1 | 9/28/2023 | 6/28/2024 | GOLDEN SPRINGS BUILDINGS C1 & D | Some weather station points are down | |
| Granted | DELAMO_2_SOLRD | 9/28/2023 | 6/28/2024 | GOLDEN SPRINGS BUILDINGS C1 & D | Some weather station points are down | |
| Granted | DSFLWR_2_WS2SR1 | 5/28/2024 | 6/28/2024 | WILLOW SPRINGS | All communication with resource is down | |
| Granted | MRCHNT_2_PL1X3 | 5/24/2024 | 7/26/2024 | DESERT STAR | RIG failure | |
| Granted | LNCSTR_6_SOLAR2 | 4/24/2024 | 7/22/2024 | SEPV SIERRA | Some metering points are down | |
| Granted | ALT6DN_2_WIND7 | 4/25/2024 | 6/29/2024 | ALTA WIND 7 | All weather station points are down | |
| Granted | ALTWD_2_COAWD1 | 12/15/2023 | 6/29/2024 | COACHELLA 1 | All weather station points are down | |
| Granted | BLM W_2_COSBT1 | 3/8/2024 | 6/28/2024 | COSO BESS | Intermittent connection (communication dropping) | |
| Granted | DELAMO_2_SOLRC1 | 5/29/2024 | 6/28/2024 | GOLDEN SPRINGS BUILDINGS C1 & D | All communication with resource is down | |
| Granted | DELAMO_2_SOLRD | 5/29/2024 | 6/28/2024 | GOLDEN SPRINGS BUILDINGS C1 & D | All communication with resource is down | |
| Granted | GARNET_1_SOLAR2 | 3/25/2024 | 6/30/2024 | GARNET | Site network failure | |
| Granted | MARTIN_1_SUNSET | 5/1/2024 | 6/28/2024 | SUNSET SOLAR | Intermittent connection (communication dropping) | |
| Granted | WHTWTR_1_WINDA1 | 1/10/2024 | 6/29/2024 | WHITEWATER | All weather station points are down | |
| Granted | DELAMO_2_SOLAR6 | 5/29/2024 | 6/28/2024 | GOLDEN SPRINGS BUILDING FREEWAY | Intermittent connection (communication dropping) | |
| Granted | RUSSELL_2_SOLANO1 | 3/8/2024 | 7/31/2024 | SMUD SOLANO WIND PROJECT | Invalid or inaccurate data | |
| Granted | ARLNTN_2_ASUSR1 | 1/12/2024 | 7/31/2024 | ARLINGTON 1 SOLAR | Invalid or inaccurate data | |
| Granted | BLKCRK_2_SOLAR1 | 5/31/2024 | 7/31/2024 | MCCOY SOLAR | Various analog and digital points are down | |
| Granted | DRACKR_2_D4SR4B | 4/2/2024 | 7/31/2024 | BLYTHE 4 B SOLAR | Invalid or inaccurate data | |
| Granted | DRACKR_2_DS3SR3 | 11/13/2023 | 7/31/2024 | BLYTHE 3 SOLAR | Invalid or inaccurate data | |
| Granted | DRACKR_2_DS4SR4 | 11/13/2023 | 7/31/2024 | BLYTHE 4 A SOLAR | Invalid or inaccurate data | |

| Status | Resource ID | Start Date | End Date | Site Name | Exemption | Rejection Reason |
|---------|-----------------|------------|-----------|--------------------------|--|------------------|
| Granted | DRACKR_2_SOLAR1 | 11/13/2023 | 7/31/2024 | BLYTHE 1 SOLAR | Invalid or inaccurate data | |
| Granted | DRACKR_2_SOLAR2 | 11/13/2023 | 7/31/2024 | BLYTHE 2 SOLAR | Invalid or inaccurate data | |
| Granted | GARLND_2_GASLRA | 6/4/2024 | 7/2/2024 | GARLND_2_GASLRA | Some digital points are down | |
| Granted | GILRPP_1_PL3X4 | 5/31/2024 | 6/30/2024 | GILROY ENERGY CENTER | Various analog and digital points are down | |
| Granted | PAIGES_6_SOLAR | 5/31/2024 | 7/31/2024 | WESTSIDE SOLAR | Invalid or inaccurate data | |
| Granted | RSMSLR_6_SOLAR2 | 5/31/2024 | 6/28/2024 | ROSAMOND 2 | Intermittent connection (communication dropping) | |
| Granted | STROUD_6_WWHSR1 | 4/30/2024 | 6/30/2024 | WINTER WHEAT | Some weather station points are down | |
| Granted | SUNSHN_2_LNDFL | 4/26/2024 | 6/30/2024 | SUNSHINE | Network circuit is down | |
| Granted | BEARMT_1_UNIT | 5/31/2024 | 6/28/2024 | BEAR MOUNTAIN LTD. | All communication with resource is down | |
| Granted | VESTAL_6_QF | 5/31/2024 | 6/28/2024 | ISABELLA HYDRO DAM | Other | |
| Granted | VICTOR_1_SOLAR1 | 3/29/2024 | 6/28/2024 | VICTOR PHELAN | Some weather station points are down | |
| Granted | HARBGN_7_UNITS | 6/1/2024 | 6/28/2024 | HARBOR COGENERATION | Network circuit is down | |
| Granted | AVENAL_6_AVPARK | 6/1/2024 | 6/30/2024 | AVENAL PARK | All communication with resource is down | |
| Granted | AVENAL_6_AVPARK | 6/1/2024 | 9/30/2024 | AVENAL PARK | All communication with resource is down | |
| Granted | BRDSLD_2_MTZUMA | 6/1/2024 | 7/31/2024 | MONTEZUMA 1 | Invalid or inaccurate data | |
| Granted | CLOVDL_1_SOLAR | 6/1/2024 | 6/28/2024 | CLOVDL_1_SOLAR | Other | |
| Granted | GARLND_2_GASLRA | 6/4/2024 | 7/2/2024 | GARLND_2_GASLRA | Some digital points are down | |
| Granted | GASKW1_2_GW2BT1 | 6/1/2024 | 6/30/2024 | GASKELL WEST 2 BESS | Intermittent connection (communication dropping) | |
| Granted | GASKW1_2_GW2SR1 | 6/1/2024 | 6/30/2024 | GASKELL WEST 2A | Intermittent connection (communication dropping) | |
| Granted | GASKW1_2_GW2SR2 | 6/1/2024 | 6/30/2024 | GASKELL WEST 2B | Intermittent connection (communication dropping) | |
| Granted | GASKW1_2_GW3SR1 | 6/1/2024 | 6/30/2024 | GASKELL WEST 3 | Intermittent connection (communication dropping) | |
| Granted | GASKW1_2_GW4SR1 | 6/1/2024 | 6/30/2024 | GASKELL WEST 4 | Intermittent connection (communication dropping) | |
| Granted | GASKW1_2_GW5SR1 | 6/1/2024 | 6/30/2024 | GASKELL WEST 5 | Intermittent connection (communication dropping) | |
| Granted | LARKSP_6_UNIT 1 | 6/1/2024 | 7/1/2024 | LARKSPUR ENERGY LLC | Other | |
| Granted | LARKSP_6_UNIT 2 | 6/1/2024 | 6/30/2024 | LARKSPUR ENERGY LLC | Other | |
| Granted | SHUTLE_6_RUISR3 | 6/1/2024 | 6/30/2024 | SCE-RUTAN III | All communication with resource is down | |
| Granted | SUNCAT_2_A2BSR2 | 6/1/2024 | 7/31/2024 | ARLINGTON 2B SOLAR | Invalid or inaccurate data | |
| Granted | BEARMT_1_UNIT | 6/1/2024 | 6/28/2024 | BEAR MOUNTAIN LTD. | All communication with resource is down | |
| Granted | PRIMM_2_SOLAR1 | 2/15/2024 | 7/31/2024 | SILVER STATE SOLAR | Invalid or inaccurate data | |
| Granted | CENTPD_2_BMSSX2 | 6/5/2024 | 6/30/2024 | BLYTHE MESA SOLAR 2 | Some metering points are down | |
| Granted | CENTPD_2_BMSX2 | 6/5/2024 | 6/30/2024 | BLYTHE MESA SOLAR 2 BESS | Some metering points are down | |
| Granted | MNDOTA_1_SOLAR1 | 6/5/2024 | 6/30/2024 | NORTHSTAR SOLAR | Various analog and digital points are down | |
| Granted | ALT6DN_2_WIND7 | 6/6/2024 | 7/5/2024 | ALTA WIND 7 | All communication with resource is down | |

| Status | Resource ID | Start Date | End Date | Site Name | Exemption | Rejection Reason |
|---------|-----------------|------------|-----------|---------------------------------|--|------------------|
| Granted | ALT6DS_2_WIND9 | 6/6/2024 | 7/5/2024 | ALTA WIND 9 | All communication with resource is down | |
| Granted | GARNET_1_SOLAR2 | 6/6/2024 | 7/5/2024 | GARNET | RIG failure | |
| Granted | GARNET_1_WIND | 6/6/2024 | 7/5/2024 | GARNET WIND | All communication with resource is down | |
| Granted | VLCNTR_6_VCSLR1 | 6/6/2024 | 7/5/2024 | VALLEY CENTER | Some metering points are down | |
| Granted | SUNSHN_2_LNDFL | 6/7/2024 | 6/30/2024 | SUNSHINE | All metering data points are down | |
| Granted | ALT6DS_2_WIND9 | 6/7/2024 | 7/6/2024 | ALTA WIND 9 | All weather station points are down | |
| Granted | ETIWND_2_SOLAR5 | 6/8/2024 | 7/8/2024 | GOLDEN SPRINGS BUILDING DULLES | Various analog and digital points are down | |
| Granted | CRELMN_6_RAMSR3 | 6/10/2024 | 7/10/2024 | RAMONA SOLAR | Some metering points are down | |
| Granted | JANCRK_6_RCABT1 | 6/9/2024 | 8/1/2024 | REDWOOD COAST AIRPORT MICROGRID | Other | |
| Granted | ALTA3A_2_CPCE4 | 6/11/2024 | 6/30/2024 | ALTA 4 | Some weather station points are down | |
| Granted | CRWCKS_1_SOLAR1 | 6/11/2024 | 7/11/2024 | FRONTIER | Intermittent connection (communication dropping) | |
| Granted | ENERSJ_2_WIND | 6/11/2024 | 7/10/2024 | ESJ WIND ENERGY | Network circuit is down | |
| Granted | ENERSJ_5_ESJWD2 | 6/11/2024 | 7/10/2024 | ENERGIA SIERRA JUAREZ WIND 2 | Network circuit is down | |
| Granted | KANSAS_6_SOLAR | 6/11/2024 | 6/30/2024 | KANSAS SOUTH | Some metering points are down | |
| Granted | BRODIE_2_WIND | 6/11/2024 | 7/30/2024 | CORAM BRODIE WIND | RIG failure | |
| Granted | FLOWD2_2_FPLWND | 6/12/2024 | 7/11/2024 | DIABLO WIND | All communication with resource is down | |
| Granted | TWISSL_6_SOLAR | 6/12/2024 | 7/5/2024 | NICKEL 1 ("NLH1") | Other | |
| Granted | ETIWND_2_UNIT1 | 6/13/2024 | 7/1/2024 | ONTARIO COGENERATION | RIG failure | |
| Granted | HENRTA_6_HDEBT1 | 6/13/2024 | 7/15/2024 | HENRIETTA D ENERGY STORAGE | Invalid or inaccurate data | |
| Granted | SLRMS3_2_SRMSR1 | 6/13/2024 | 7/12/2024 | MOUNT SIGNAL 3 | Intermittent connection (communication dropping) | |
| Granted | VLCNTR_6_VCSLR2 | 6/13/2024 | 7/12/2024 | VALLEY CENTER | RIG failure | |
| Granted | HAMLIN_1_BLDSB1 | 5/10/2024 | 6/28/2024 | BALDY MESA | Invalid or inaccurate data | |
| Granted | LEPRFD_1_KANSAS | 6/14/2024 | 6/30/2024 | KANSAS SOLAR | All weather station points are down | |
| Granted | KNTSTH_6_SOLAR | 6/14/2024 | 6/30/2024 | KENT SOUTH SOLAR | Intermittent connection (communication dropping) | |
| Granted | OLDRV1_6_SOLAR | 6/14/2024 | 6/30/2024 | OLD RIVER ONE SOLAR | Intermittent connection (communication dropping) | |
| Granted | GARNET_2_WIND5 | 6/14/2024 | 7/13/2024 | YAVI-EASTWIND | All communication with resource is down | |
| Granted | RATSKE_2_NROSR1 | 6/14/2024 | 7/13/2024 | NORTH ROSAMOND SOLAR | Some metering points are down | |
| Granted | LIVEOK_6_SOLAR | 9/14/2023 | 7/15/2024 | HARRIS 2127 | RIG failure | |
| Granted | CPVERD_2_SOLAR | 6/15/2024 | 6/30/2024 | CAMPO VERDE | Intermittent connection (communication dropping) | |
| Granted | CPVERD_2_SOLAR | 6/15/2024 | 7/15/2024 | CAMPO VERDE | Some weather station points are down | |
| Granted | MSTANG_2_SOLAR | 6/15/2024 | 6/30/2024 | MUSTANG SOLAR | Some weather station points are down | |
| Granted | MSTANG_2_SOLAR4 | 6/15/2024 | 6/30/2024 | MUSTANG SOLAR 4 | Some weather station points are down | |
| Granted | PMPJCK_1_SOLAR1 | 6/15/2024 | 7/14/2024 | PUMPJACK SOLAR | Some weather station points are down | |

| Status | Resource ID | Start Date | End Date | Site Name | Exemption | Rejection Reason |
|---------|-----------------|------------|-----------|----------------------------------|--|------------------|
| Granted | WLDWD_1_SOLAR1 | 6/16/2024 | 7/16/2024 | WILDWOOD SOLAR 1 | Some metering points are down | |
| Granted | GOLETA_6_ELLWOD | 6/15/2024 | 6/28/2024 | ELLWOOD | Various analog and digital points are down | |
| Granted | DYLAN_2_BMTBT1 | 6/15/2024 | 7/14/2024 | BEAUMONT BESS | All communication with resource is down | |
| Granted | GARNET_2_COAWD2 | 6/15/2024 | 7/14/2024 | COACHELLA 2 | All communication with resource is down | |
| Granted | VENWD_1_WIND3 | 6/18/2024 | 7/17/2024 | PAINTED HILLS | All communication with resource is down | |
| Granted | VESTAL_2_WELLHD | 6/15/2024 | 8/15/2024 | WELLHEAD POWER DELANO | Some metering points are down | |
| Granted | WISTRA_2_WRSSR1 | 6/15/2024 | 7/15/2024 | WISTARIA RANCH SOLAR | Intermittent connection (communication dropping) | |
| Granted | ANZA_6_SOLAR1 | 6/18/2024 | 7/17/2024 | SEVILLE SOLAR ONE | Some metering points are down | |
| Granted | DELAMO_2_SOLAR3 | 6/20/2024 | 7/20/2024 | GOLDEN SPRINGS BUILDINGS F, G, L | Various analog and digital points are down | |
| Granted | DELAMO_2_SOLAR4 | 6/20/2024 | 7/20/2024 | GOLDEN SPRINGS BUILDINGS F, G, L | Various analog and digital points are down | |
| Granted | DELAMO_2_SOLAR5 | 6/20/2024 | 7/20/2024 | GOLDEN SPRINGS BUILDINGS F, G, L | Various analog and digital points are down | |
| Granted | DELAMO_2_SOLAR6 | 6/20/2024 | 7/20/2024 | GOLDEN SPRINGS BUILDING FREEWAY | Various analog and digital points are down | |
| Granted | DELSUR_6_SOLAR4 | 6/19/2024 | 7/2/2024 | RADIANCE 4 | Intermittent connection (communication dropping) | |
| Granted | DELSUR_6_SOLAR5 | 6/19/2024 | 7/2/2024 | RADIANCE 5 | Intermittent connection (communication dropping) | |
| Granted | DREWSR_2_BHSSR1 | 6/19/2024 | 6/30/2024 | DREW SOLAR | All communication with resource is down | |
| Granted | GARNET_2_WIND3 | 6/20/2024 | 7/20/2024 | PHOENIX AGGREGATE | Various analog and digital points are down | |
| Granted | KNGBRG_1_KBSLR1 | 6/19/2024 | 7/19/2024 | KNGBRG_1_KBSLR1 | Network circuit is down | |
| Granted | KNGBRG_1_KBSLR2 | 6/19/2024 | 7/19/2024 | KNGBRG_1_KBSLR2 | Network circuit is down | |
| Granted | MCARTH_6_FRIVRB | 6/19/2024 | 7/12/2024 | SHASTA B | Invalid or inaccurate data | |
| Granted | ORMOND_7_UNIT 1 | 6/18/2024 | 6/28/2024 | ORMOND BEACH | Various analog and digital points are down | |
| Granted | PIT1_6_FRIVRA | 6/19/2024 | 7/12/2024 | SHASTA A | Intermittent connection (communication dropping) | |
| Granted | REEDLY_6_SOLAR | 6/18/2024 | 7/15/2024 | TERZIAN 2081 | RIG failure | |
| Granted | SPRGVL_2_PORTPV | 6/19/2024 | 7/19/2024 | SPRGVL_2_PORTPV | Some digital points are down | |
| Granted | SUMWHT_6_SWSSR1 | 6/19/2024 | 7/18/2024 | SUMMER WHEAT | All metering data points are down | |
| Granted | TEHAPI_2_PW1WD1 | 6/19/2024 | 7/18/2024 | POINT WIND I | All communication with resource is down | |
| Granted | TEHAPI_2_PW2WD2 | 6/19/2024 | 7/18/2024 | POINT WIND II | All communication with resource is down | |
| Granted | TOPAZ_2_SOLAR | 6/19/2024 | 7/12/2024 | TOPAZ SOLAR | Some metering points are down | |
| Granted | TWISSL_6_SOLAR1 | 6/20/2024 | 7/20/2024 | LOST HILLS | All communication with resource is down | |
| Granted | ETIWND_2_SOLAR5 | 6/18/2024 | 7/17/2024 | GOLDEN SPRINGS BUILDING DULLES | All communication with resource is down | |
| Granted | BAHIA_2_LKHSR1 | 5/24/2024 | 7/5/2024 | RCPA SOLAR 4 (LAKE HERMAN) | Intermittent connection (communication dropping) | |
| Granted | CUYAMS_6_CUYSR1 | 6/21/2024 | 7/5/2024 | CUYAMA | All communication with resource is down | |
| Granted | SEARLS_7_ARGUS | 6/21/2024 | 7/22/2024 | ARGUS COGEN | All communication with resource is down | |
| Granted | SPRGVL_2_EXETPV | 6/21/2024 | 7/1/2024 | SPRGVL_2_EXETPV | Network circuit is down | |

| Status | Resource ID | Start Date | End Date | Site Name | Exemption | Rejection Reason |
|---------|-----------------|------------|-----------|---------------------------------|--|------------------|
| Granted | TORTLA_1_SOLAR | 4/26/2024 | 7/12/2024 | LONGBOAT SOLAR | All metering data points are down | |
| Granted | TRNSWD_1_QF | 6/20/2024 | 7/22/2024 | CABAZON WIND FARM | Some weather station points are down | |
| Granted | GASKW1_2_GW1SR1 | 6/24/2024 | 7/29/2024 | GASKW1_2_GW1SR1 | Some weather station points are down | |
| Granted | TWISSL_6_SOLAR1 | 6/25/2024 | 7/25/2024 | LOST HILLS | All weather station points are down | |
| Granted | DSFLWR_2_WS2SR1 | 6/23/2024 | 6/28/2024 | WILLOW SPRINGS | Invalid or inaccurate data | |
| Granted | CRWCKS_1_SOLAR1 | 6/22/2024 | 8/15/2024 | FRONTIER | All metering data points are down | |
| Granted | CRWCKS_1_SOLAR1 | 6/22/2024 | 8/15/2024 | FRONTIER | All metering data points are down | |
| Granted | BREGGO_6_DEGRSL | 5/24/2024 | 7/24/2024 | DESERT GREEN SOLAR FARM LLC | All communication with resource is down | |
| Granted | DELAMO_2_SOLRC1 | 6/28/2024 | 7/27/2024 | GOLDEN SPRINGS BUILDINGS C1 & D | All communication with resource is down | |
| Granted | DELAMO_2_SOLRC1 | 6/28/2024 | 7/28/2024 | GOLDEN SPRINGS BUILDINGS C1 & D | Some weather station points are down | |
| Granted | DELAMO_2_SOLRD | 6/28/2024 | 7/27/2024 | GOLDEN SPRINGS BUILDINGS C1 & D | All communication with resource is down | |
| Granted | DELAMO_2_SOLRD | 6/28/2024 | 7/28/2024 | GOLDEN SPRINGS BUILDINGS C1 & D | Some weather station points are down | |
| Granted | DEVERS_1_SEPV05 | 6/25/2024 | 7/24/2024 | SEPV2 | Intermittent connection (communication dropping) | |
| Granted | DSRTSL_2_SOLAR1 | 6/25/2024 | 7/24/2024 | STATELINE | Some digital points are down | |
| Granted | GARNET_1_SOLAR2 | 6/25/2024 | 7/24/2024 | GARNET | RIG failure | |
| Granted | HAMLIN_1_BLDSB1 | 5/10/2024 | 7/2/2024 | BALDY MESA | Invalid or inaccurate data | |
| Granted | HOLSTR_1_SOLAR | 6/25/2024 | 8/30/2024 | SAN BENITO SMART PARK | Other | |
| Granted | LCKHT1_2_LH1SR1 | 6/25/2024 | 7/24/2024 | LOCKHART 1 & 2 | Various analog and digital points are down | |
| Granted | LCKHT1_2_LH1SR2 | 6/25/2024 | 7/24/2024 | LOCKHART 1 & 2 | Various analog and digital points are down | |
| Granted | LEPRFD_1_KANSAS | 6/25/2024 | 7/1/2024 | KANSAS SOLAR | Some metering points are down | |
| Granted | PIUTE_6_GNBSR1 | 6/25/2024 | 7/18/2024 | GREEN BEANWORKS B | Intermittent connection (communication dropping) | |
| Granted | PNCHVS_2_SOLAR | 6/26/2024 | 7/15/2024 | PANOCHE VALLEY SOLAR | Intermittent connection (communication dropping) | |
| Granted | VESTAL_6_QF | 6/28/2024 | 7/31/2024 | ISABELLA HYDRO DAM | Other | |
| Granted | WFRESN_1_SOLAR | 6/25/2024 | 7/24/2024 | LA JOYA DEL SOL | Intermittent connection (communication dropping) | |
| Granted | WISTRA_2_WRSSR1 | 6/25/2024 | 7/5/2024 | WISTARIA RANCH SOLAR | Intermittent connection (communication dropping) | |
| Granted | VOYAGR_2_VOAWD5 | 6/25/2024 | 7/24/2024 | OASIS ALTA | All communication with resource is down | |
| Granted | ETIWND_2_UNIT1 | 6/12/2024 | 7/12/2024 | ONTARIO COGENERATION | RIG failure | |
| Granted | BLM W_2_COSBT1 | 6/28/2024 | 7/29/2024 | COSO BESS | Intermittent connection (communication dropping) | |
| Granted | RECTOR_2_IVANPV | 6/27/2024 | 7/8/2024 | RECTOR_2_IVANPV | Network circuit is down | |
| Pending | SLRMS3_2_SRMSR1 | 6/27/2024 | 7/26/2024 | MOUNT SIGNAL 3 | All weather station points are down | |
| Granted | SPRGVL_2_LINDPV | 6/27/2024 | 7/8/2024 | SPRGVL_2_LINDPV | Network circuit is down | |
| Pending | FLOWD2_2_FPLWND | 6/11/2024 | 8/9/2024 | DIABLO WIND | All communication with resource is down | |
| Pending | RECTOR_2_VISSR1 | 6/27/2024 | 7/11/2024 | VISALIA CSG LLC | All communication with resource is down | |