

## Wind and Solar Curtailment January 31, 2017

This report is produced daily to provide a detailed accounting of the wind and solar renewable generation that was curtailed and the reasons why¹. This report should be read in the context of the Renewables Watch report for a more complete understanding of both renewable curtailment and generation².

Wind and solar curtailments are grouped into the following categories:

- 1. Economic Local: Market dispatch of generators with economic bids to mitigate local congestion<sup>3</sup>.
- 2. Economic System: Market dispatch of generators with economic bids to mitigate systemwide oversupply<sup>4</sup>.
- 3. SelfSchCut Local: Market dispatch of self-schedules to mitigate local congestion.
- 4. SelfSchCut System: Market dispatch of self-schedules to mitigate system-wide oversupply.
- 5. ExDispatch Local: Exceptional dispatch to mitigate local congestion.
- 6. ExDispatch System: Exceptional dispatch to mitigate system-wide oversupply.

Note: Amounts smaller than 1 MW are filtered out for simplicity. Such small curtailments are occasionally observed when forecasts are lower than Pmin when market will de-commit the unit and send the 0 MW dispatch.

CAISO/HZ 1 January 31, 2017

<sup>&</sup>lt;sup>1</sup>Only wind and solar resources can be reported in this manner because these resources have a forecast. Curtailment is defined as the difference between actual production and the forecast when actual production is less than the forecast.


<sup>&</sup>lt;sup>2</sup>The Renewables Watch report provides daily actual renewable production within the ISO grid. It is available at: <a href="http://www.caiso.com/green/renewableswatch.html">http://www.caiso.com/green/renewableswatch.html</a>.


<sup>&</sup>lt;sup>3</sup>Congestion occurs when available, least-cost energy cannot be delivered to some loads because transmission facilities do not have sufficient capacity to deliver the energy.


<sup>&</sup>lt;sup>4</sup>For more information on oversupply conditions, please see: https://www.caiso.com/Documents/FlexibleResourcesHelpRenewables FastFacts.pdf




The following charts show the daily and 7-day rolling wind and solar curtailment by category, if any.









CAISO/HZ 2 January 31, 2017



Data used to produce hourly charts



DATE	HOUR	CURT TYPE	REASON	FUEL TYPE	CURTAILED MWH	CURTAILED MW
01/31	1	Economic	Local	WIND	94	159
01/31	2	Economic	Local	WIND	78	159
01/31	3	Economic	Local	WIND	50	78
01/31	4	Economic	Local	WIND	44	56
01/31	5	Economic	Local	WIND	21	44
01/31	6	Economic	Local	WIND	55	105
01/31	7	Economic	Local	WIND	5	56
01/31	9	Economic	Local	SOLR	2	
01/31	9	Economic	System	SOLR	292	1041
01/31	9	Economic	System	WIND	1	8
01/31	10	Economic	Local	SOLR	10	15
01/31	10	Economic	System	SOLR	124	520
01/31	10	Economic	System	WIND	0	1
01/31	11	Economic	Local	SOLR	9	2
01/31	11	Economic	System	SOLR	12	144
01/31	11	Economic	System	WIND	0	1
01/31	12	Economic	Local	SOLR	21	
01/31	12	Economic	Local	WIND	0	
01/31	12	Economic	System	SOLR	112	567
01/31	12	Economic	System	WIND	0	1
01/31	13	Economic	Local	SOLR	0	
01/31	13	Economic	System	SOLR	5	52
01/31	13	Economic	System	WIND	0	1
01/31	14	Economic	Local	SOLR	9	79
01/31	14	Economic	Local	WIND	0	1
01/31	14	Economic	System	SOLR	9	47
01/31	14	Economic	System	WIND	0	0
01/31	15	Economic	Local	SOLR	0	
01/31	15	Economic	System	SOLR	83	363
01/31	15	Economic	System	WIND	0	1
01/31	16	Economic	System	SOLR	39	262
01/31	16	Economic	System	WIND	0	1
01/31	17	Economic	System	SOLR	0	2



The information contained in this report is preliminary and subject to change without notice. No inference, decision or conclusion should be made based on the information in this report or any series of these reports. All values are hourly average unless otherwise stated. Questions about this report should be directed to Hong Zhou at hzhou@caiso.com.

CAISO/HZ 5 January 31, 2017