

## Wind and Solar Curtailment May 02, 2024

This report is produced daily to provide a detailed accounting of the wind and solar renewable generation that was curtailed and the reasons why<sup>1</sup>. This report should be read in the context of the Renewables Watch report for a more complete understanding of both renewable curtailment and generation<sup>2</sup>.

Wind and solar curtailments are grouped into the following categories:

- 1. Economic Local: Market dispatch of generators with economic bids to mitigate local congestion<sup>3</sup>.
- 2. Economic System: Market dispatch of generators with economic bids to mitigate systemwide oversupply.
- 3. SelfSchCut Local: Market dispatch of self-schedules to mitigate local congestion.
- 4. SelfSchCut System: Market dispatch of self-schedules to mitigate system-wide oversupply.
- 5. ExDispatch Local: Exceptional dispatch to mitigate local congestion.
- 6. ExDispatch System: Exceptional dispatch to mitigate system-wide oversupply.

Note: Amounts smaller than 1 MW are filtered out for simplicity. Such small curtailments are occasionally observed when forecasts are lower than Pmin when market will de-commit the unit and send the 0 MW dispatch.

<sup>1</sup>Only wind and solar resources can be reported in this manner because these resources have a forecast. Curtailment is defined as the difference between actual production and the forecast when actual production is less than the forecast.


<sup>2</sup>The Renewables Watch report provides daily actual renewable production within the ISO grid. It is available at: <u>http://www.caiso.com/green/renewableswatch.html</u>.


<sup>3</sup>Congestion occurs when available, least-cost energy cannot be delivered to some loads because transmission facilities do not have sufficient capacity to deliver the energy.


For more information on oversupply conditions, please see: <u>https://www.caiso.com/Documents/FlexibleResourcesHelpRenewables\_FastFacts.pdf</u>




The following charts show the daily and 7-day wind and solar curtailment by category, if any.








 Maximum generation curtailment in MW for any one of the twelve real-time dispatch intervals in a particular day on a 7-day basis. - 5/2/2024






The following charts show hourly year to date wind and solar curtailment by category, if any.



The following charts show monthly year to date wind and solar curtailment by category, if any.



TYPE	YTD CURTAILED MWH - 5/2/2024
LocalEconomic	1,866,427
LocalSelfSchCut	1,219
SystemEconomic	63,153
TOTAL	1,930,798



## Data used to produce hourly chart

DATE	HOU R	CURT TYPE	REASON	FUEL TYPE	CURTAILED MWH	CURTAILED MW
05/02	8	Economic	Local	SOLR	65	236
05/02	9	Economic	Local	SOLR	542	609
05/02	9	SelfSchCut	Local	SOLR	2	
05/02	10	Economic	Local	SOLR	690	799
05/02	10	Economic	Local	WIND	0	
05/02	10	SelfSchCut	Local	SOLR	6	11
05/02	11	Economic	Local	SOLR	783	842
05/02	11	SelfSchCut	Local	SOLR	7	
05/02	12	Economic	Local	SOLR	818	855
05/02	12	SelfSchCut	Local	SOLR	12	12
05/02	13	Economic	Local	SOLR	1025	1062
05/02	13	SelfSchCut	Local	SOLR	9	19
05/02	14	Economic	Local	SOLR	676	752
05/02	14	SelfSchCut	Local	SOLR	15	21
05/02	15	Economic	Local	SOLR	1281	1726
05/02	15	Economic	Local	WIND	84	241
05/02	15	SelfSchCut	Local	SOLR	11	9
05/02	16	Economic	Local	SOLR	1649	2001
05/02	16	Economic	Local	WIND	172	242
05/02	16	SelfSchCut	Local	SOLR	7	
05/02	17	Economic	Local	SOLR	1850	2481
05/02	17	Economic	Local	WIND	180	303
05/02	17	SelfSchCut	Local	SOLR	1	2
05/02	18	Economic	Local	SOLR	881	1667
05/02	18	Economic	Local	WIND	49	120
05/02	19	Economic	Local	SOLR	69	337

The information contained in this report is preliminary and subject to change without notice. No inference, decision or conclusion should be made based on the information in this report or any series of these reports. All values are hourly average unless otherwise stated. Questions about this report should be directed to Short-Term Forecasting at ShortTermForecasting@caiso.com.

