

## Comments on CAISO 2024 and 2028 Local Capacity Technical Study Base Cases

Submitted by	Company	Date Submitted
Mohan Niroula	California Department of Water Resources	Jan 30, 2023

CDWR has reviewed the published data and recommends following changes to the SOCAL base cases:

Plant	Existing data in the 2024 and 2028 base cases, MW	CDWR proposed change, MW
Edmonston pumping plant	-271.2 MW	-360 MW
Pearblossom pumping plant	-39.1 MW	-60 MW
Oso pumps	0	-30 MW
Delta pumps	-268 MW	-220 MW

Thanks,

Mohan Niroula