



Phase I Powerflow Study Results

Presentation for STEP Group 11/4/2003

**Johan Galleberg
Grid Planning
California ISO**



Short Term Upgrades

- Base upgrades
 - Miguel 500/230 kV No. 2 transformer
 - Imperial Valley – Miguel 500 kV series capacitor upgrade
 - Miguel – Mission No. 2 230 kV line
- Phase 1 upgrades
 - Devers 500/230 kV No. 2 transformer
 - West of Devers upgrade
 - Series capacitor upgrades
 - Hassayampa – North Gila – Imperial Valley 500 kV
 - Palo Verde – Devers 500 kV
 - Navajo – Crystal and Moenkopi – Eldorado 500 kV



CALIFORNIA ISO Objective

California Independent
System Operator

- Develop a “realistic” powerflow case including the Phase I upgrades with high EOR and high dispatch of new generation
- Not a Path Rating Study

Created By: Johan Galleberg


LST UPDT: 10/31/2003



CALIFORNIA ISO

Load duration curve “Old Units” Oct. 1 2002 to May. 31, 2003
(sorted, net output)

California Independent
System Operator



Created By: Johan Galleberg


LST UPDT: 10/31/2003



CALIFORNIA ISO

California Independent
System Operator

Load duration curve Devers 230/115 kV bank Oct.1 2002 to Sept. 30, 2003
(positive flow is from the 115 kV system to the 230 kV system)



Created By: Johan Galleberg

LST UPDT: 10/31/2003



CALIFORNIA ISO

California Independent
System Operator

Limitations Phase I case


- West of Devers flow, maximum 2200 MW
- Flow on Palo Verde – Devers 500 kV line, maximum 2100-2200 MW
- Normal and N-1 overload on El Centro 230/161 kV transformer
- Miguel Import, maximum 2000 MW
- Voltage support Eastern LA Basin
- EOR, maximum 8300 MW
- SCIT/EOR relationship

Created By: Johan Galleberg


LST UPDT: 10/31/2003



West of Devers



West of Devers flow 10/1/2002 to 9/30/2003, sorted






CALIFORNIA ISO

West of Devers flow and limitations

California Independent System Operator



Created By: Johan Galleberg

LST UPDT: 10/31/2003



CALIFORNIA ISO

Flow on Palo Verde - Devers

California Independent System Operator

- Too high flow on the line can overload underlying system if the line trips (N-1)
- Loading on the underlying system depends on generation dispatch, loadlevel and EOR flow
- Potential overloads:
 - Avenue 58 – Banister 161 kV line
 - Gene – Parker 230 kV line
 - Blythe – Eagle Mountain 161 kV line
 - Perkins – Mead (series capacitors and phase shifters, if not bypassed)
- Without SPS, flow cannot exceed 2100-2200 MW under most conditions (at Palo Verde)

Created By: Johan Galleberg

LST UPDT: 10/31/2003



CALIFORNIA ISO

California Independent
System Operator

El Centro 230/161 kV transformer

- Loading on the transformer depends on generation from the Imperial Valley and Blythe area, IID load and generation, and EOR flow
- High Imperial Valley generation, low Blythe generation and low IID generation (or high IID load):
 - Potential normal overload on El Centro bank (225 MVA limit)
- High North Gila – Imperial Valley 500 kV line flow:
 - Potential N-1 overload on El Centro bank (258 MVA limit) for loss of North Gila – Imperial Valley 500 kV line

Created By: Johan Galleberg

LST UPDT: 10/31/2003



CALIFORNIA ISO

California Independent
System Operator

Miguel Import

- Too high import can overload underlying system (138 and 69 kV) under contingency conditions
- Import level depends on SDG&E generation and load, in particular the generation from the Southbay units
 - Low Southbay generation: N-2 of Miguel – Mission No.1&2 overloads Miguel 230/138 kV transformer and 138 kV lines between Miguel and Southbay
 - High Southbay generation: N-2 of Miguel – Mission No.1&2 overloads Mission – Southbay 138 kV line
- Import limit at about 2000 MW has been identified in previous studies
- Implementation of SPS for double line 230 kV contingencies North of Miguel may allow for an increase in import limit

Created By: Johan Galleberg

LST UPDT: 10/31/2003



CALIFORNIA ISO

California Independent
System Operator

Voltage support Eastern LA Basin

- Area with high load and very little generation
- Voltage dip at Devers is a current limitation in the import level into Southern California
- The most critical single line outage is Hassayampa - North Gila 500 kV line
- Higher import to Devers Substation requires additional dynamic voltage support to meet transient stability criteria

Created By:Johan Galleberg

LST UPDT: 10/31/2003



CALIFORNIA ISO

California Independent
System Operator

Sensitivities

- 1) **New Southern California Generation**
 - Otay Mesa (SDG&E, 510 MW)
 - Palomar (SDG&E, 540 MW)
 - Mountainview (SCE, 1000 MW)
 - Replaced older Southern California generation:
 - Encina 4&5, Southbay 4, Huntington Beach 2, Alamitos 1, Redondo Beach 6, El Segundo 3
 - Replaced 400 MW of generation in PG&E's area
 - Mountainview increases the West of Devers rating and reduces the need for voltages support around Devers
 - Only local impacts identified

Created By:Johan Galleberg

LST UPDT: 10/31/2003



CALIFORNIA ISO Sensitivities

California Independent
System Operator

2) Mohave units online (1560 MW)

- Replaced older Southern California generation:
 - Encina 4, Huntington Beach 2, Alamitos 4, Redondo Beach 6
- Replaced 650 MW of generation in PG&E's area
- Increase in WOR, both Mohave – Lugo and Eldorado – Lugo 500 kV lines loaded close to normal rating of series capacitors

Created By: Johan Galleberg

LST UPDT: 10/31/2003



CALIFORNIA ISO Sensitivities

California Independent
System Operator

3) Blythe II online (520 MW)

- Replaced older Southern California generation:
 - Huntington Beach 2 and Alamitos 4
- Blythe II connected radially to Palo Verde – Devers 500 kV line
- About 420 MW increase in West of Devers flow, need for West of Devers upgrades increases substantially

Created By: Johan Galleberg

LST UPDT: 10/31/2003



CALIFORNIA ISO

Sensitivities

California Independent System Operator

4) Navajo South

- Step 1: 500 MW coal plant connected to Four Corners 345 kV. 250 MW scheduled to SCE (250 MW), the rest scheduled to the north and south
- Step 2: Step 1 + 1000 MW coal plant connected to Shiprock 500 kV station. New 500 kV line between Shiprock – Moenkopi - Marketplace. 500 MW scheduled to PG&E and 500 MW scheduled to SCE
- Some local impacts in the Four Corners area

Created By: Johan Galleberg


LST UPDT: 10/31/2003



CALIFORNIA ISO

Projected flow on Navajo-Crystal 500 kV line

California Independent System Operator



Created By: Johan Galleberg


LST UPDT: 10/31/2003



CALIFORNIA ISO

Projected flow on Eldorado - Moenkopi 500 kV line

California Independent System Operator



Created By: Johan Galleberg

LST UPDT: 10/31/2003