



STEP Dynamic Stability Study Results

Short-term Upgrades

Sensitivities and Development of a Replacement for the SCIT Nomogram

**Irina Green
Grid Planning
California ISO**




CALIFORNIA ISO OVERVIEW

California Independent
System Operator

- DYNAMIC STABILITY STUDY RESULTS
- PROBLEMS DISCOVERED AND MITIGATION MEASURES
- DYNAMIC REACTIVE SUPPORT
- SENSITIVITY STUDIES, IMPACT OF DIFFERENT FACTORS
- CONCEPTUAL ARIZONA-SOUTHERN CALIFORNIA TRANSFER NOMOGRAM



WECC TRANSIENT STABILITY STANDARDS VOLTAGE PERFORMANCE PARAMETERS





DYNAMIC STABILITY STUDIES

- **TO IDENTIFY CRITERIA VIOLATIONS AND ADDITIONAL DYNAMIC REACTIVE SUPPORT**
- **BASE CASES**
 - PEAK CASE
 - OFF-PEAK with 8075 MW EOR flow
 - OFF-PEAK with 8750 MW EOR flow (James Hsu option)
- **OUTAGES WITH 3-PHASE FAULTS**
 - PEAK CASE – ALL 500 KV SINGLE AND SELECTED DOUBLE OUTAGES
 - OFF-PEAK CASES - SINGLE OUTAGES
 - PALO VERDE-DEVERS AND HASSYAMPA-NORTH GILA
- **GE COMPUTER PROGRAM FOR DYNAMIC STABILITY ANALYSIS AND A PROGRAM TO IDENTIFY CRITERIA VIOLATIONS AND BUSES WITH HIGHEST VOLTAGE DIPS AND LOWEST FREQUENCIES WAS USED**



STUDY RESULTS. PEAK CASE

No violations, except for the Imperial Valley-Miguel outage with cross-tripping of La Rosita-Imperial Valley 230 kV line

Frequency violations in Cerro Prieto area of CFE

LOWEST FREQUENCY

AREA	BUS NAME	BUS KV	TYPE	MaxDip	@time
20	CPU-161	161	fbul	59.592	2.342
20	CPT-161	161	fbus	59.59	2.342
20	CPT-U3	13.8	fbug	59.568	2.342



STUDY RESULTS. OFF-PEAK CASE

- Palo Verde- Devers outage

HIGHEST VOLTAGE DIP

AREA	BUS NAME	BUS KV	TYPE	Initial	MaxDip	Prct	@time
26	WLMNTNLD	138	vbul	1.033	0.794	23.2	0.7
26	HARB	138	vbus	1.034	0.794	23.2	0.7
26	ADELSVC	500	vbug	1.05	0.815	22.5	0.663

Local Frequency Violations. Frequency lower than 59.6 HZ for more than 6 cycles


AREA	BUS NAME	BUS KV	TYPE	Cycles	From	To
21	DELRANCH	14.4	fbug	13.5	1.563	1.788
21	JJELMORE	14.4	fbug	13.5	1.563	1.788
21	LEATHERS	14.4	fbug	13.5	1.563	1.788



CALIFORNIA ISO

PALO VERDE-DEVERS OUTAGE

frequency





HASSAYAMPA-NORTH GILA OUTAGE

Voltage violations on 31 load buses

Highest Voltage dip:


AREA	BUS NAME	BUS KV	TYPE	Initial	MaxDip	Prct	@time
24	VALLEY-S	115	vbul	1.004	0.748	25.4	0.738
24	VALLEYSC	500	vbus	1.04	0.784	24.6	0.738
24	DEVERS	500	vbug	1.025	0.751	26.8	0.7

Lowest frequency:

AREA	BUS NAME	BUS KV	TYPE	MaxDip	@time
54	AURORA 8	69	fbul	59.672	3.737
54	SYNC_D08	69	fbus	59.675	3.737
54	SYNC_G19	13.2	fbug	59.655	3.775



CALIFORNIA ISO HASSAYAMPA-NORTH GILA OUTAGE voltage





CALIFORNIA ISO VOLTAGE VIOLATIONS MITIGATION HASSAYAMPA-NORTH GILA OUTAGE

California Independent
System Operator

200 MVAR STATCOM at Devers 500 kV

No violations. Voltage dip reduced by 4.5%

HIGHEST VOLTAGE DIP

AREA	BUS NAME	BUS KV	TYPE		Initial	MaxDip	Prct	@time
24	VALLEY-S	115	vbul		1.004	0.79	21.3	0.7
26	VICTORVL	287	vbus		1.049	0.831	20.8	0.738
24	DEVERS	500	vbug		1.025	0.797	22.3	0.625

LOWEST FREQUENCY

AREA	BUS NAME	BUS KV	TYPE		MaxDip	@time
20	PAR-230	230	fbul		59.695	1.863
20	CPD-230	230	fbus		59.693	1.863
20	CPD-U1	13.8	fbug		59.676	1.863

Minimum STATCOM size

140 MVAR – one violation

160 MVAR - no violations



CALIFORNIA ISO

VOLTAGE VIOLATIONS MITIGATION

California Independent
System Operator

HASSAYAMPA-NORTH GILA OUTAGE

200 MVAR SVC

No violations

HIGHEST VOLTAGE DIP

AREA	BUS NAME	BUS KV	TYPE		Initial	MaxDip	Prct	@time
24	VALLEY-S	115	vbul		1.004	0.78	22.3	0.7
24	VALLEYSC	500	vbus		1.04	0.816	21.6	0.7
24	DEVERS	500	vbug		1.025	0.786	23.4	0.663

LOWEST FREQUENCY

AREA	BUS NAME	BUS KV	TYPE		MaxDip	@time
20	PAR-230	230	fbul		59.694	1.863
20	CPD-230	230	fbus		59.692	1.863
20	CPD-U1	13.8	fbug		59.675	1.863

Minimum SVC size

180 MVAR – one violation, equivalent to 140
MVAR STATCOM



SENSITIVITY 1. MORE INDUCTION MOTORS (50% in the desert areas)

- Multiple voltage violations both with 200 MVAR STATCOM and 20 ohm TCSC
- TSC more effective : 33.3% voltage dip with STATCOM and 27.9% with TCSC



CALIFORNIA ISO

SENSITIVITY 2. NO MOUNTAIN VIEW (1000 MW)

California Independent
System Operator

- Mountain View generation replaced by Alamitos, Huntington Beach, Redondo Beach
- Southern California inertia slightly higher without Mountain View
- Voltage violations both with 200 MVAR STATCOM and 20 ohm TCSC
- TSC showed better performance than STATCOM (voltage dip 26.3% with STATCOM, 25.2% with TSC)



SENSITIVITY 3. INERTIA AT HASSYAMPA/ GILA

Total generation at Hassyampa and Gila, EOR and other flows approximately the same

- Higher inertia : 33 units, 42861 MWsec versus 20 units and 26437 MWsec in the base case
- No reactive support required

HIGHEST VOLTAGE DIP


AREA	BUS NAME	BUS KV	TYPE	Initial	MaxDip	Prct	@time
24	VALLEY-S	115	vbul	1.004	0.849	15.4	0.625
24	VALLEYSC	500	vbus	1.04	0.884	15	0.625
24	DEVERS	500	vbug	1.025	0.851	17	0.588

- Lower inertia - 18 units, 24274 MWsec versus 20 units and 26437 MWsec in the base case
- EOR flow lower (8056 MW versus 8075 MW in the base case)
- More voltage violations



CALIFORNIA ISO BASE CASE AND CASES WITH HIGH AND LOW INERTIA

California Independent
System Operator



a,b- base case

e,f- low inertia

c,d- high inertia



SENSITIVITY 4. WHERE TO INSTALL TCSC

ON PALO VERDE – DEVERS 500 KV LINE

- 60 miles from Devers
- 60 miles from Palo Verde
- At Devers substation

- Almost no difference in the results



STUDIES OF FACTORS WHICH MAY IMPACT DYNAMIC STABILITY PERFORMANCE


- INERTIA IN ARIZONA AND SOUTHERN CALIFORNIA
- SOUTHERN CALIFORNIA GENERATION AND LOAD
- BULK POWER TRANSFERS
 - a. Palo Verde to Southern California (Palo Verde West)
 - b. Las Vegas to Southern California transfers (Northern WOR)
 - c. Northern California to Southern California transfers (Path 26)
 - d. Pacific DC Intertie to Southern California transfers (Path 65)
- Arizona to Nevada transfers (Northern EOR)
- Other transfers



CALIFORNIA ISO INERTIA SENSITIVITIES

California Independent
System Operator

Fig.3.1. IMPACT OF ARIZONA INERTIA ON THE REQUIRED
REACTIVE SUPPORT. PV WEST FLOW 3430 MW, SCIT 12245





CALIFORNIA ISO INERTIA IMPACT

California Independent
System Operator

- At Hassayampa, Gila River and Palo Verde - significant impact. The higher the inertia, the lower the required reactive support.
- The rest of Arizona - approximately half of the impact of the Palo Verde, Hassayampa and Gila River generation inertia.
- Southern California inertia - no impact




CALIFORNIA ISO

SOUTHERN CALIFORNIA GENERATION SENSITIVITIES

California Independent System Operator


Fig. 4.1. REQUIRED REACTIVE SUPPORT VS HASSAYAMPA INERTIA
EOR 8075 MW, PV WEST 3420 MW, SCIT 12245 MW.
IMPACT OF S.CAL GENERATION OUTAGES





GENERATION IMPACT DEPENDS ON MODELING

Fig. 4.2. REQUIRED REACTIVE SUPPORT VS HASSAYAMPA INERTIA
EOR 8075 MW, PV WEST 3420 MW. IMPACT OF MTN.VIEW GENERATION





CALIFORNIA ISO SOUTHERN CALIFORNIA GENERATION IMPACT

California Independent
System Operator


Southern California generation impacts the reactive support requirement. However, the results depend on how the sensitivity case is modeled and on flows on the major paths to Southern California.



CALIFORNIA ISO SOUTHERN CALIFORNIA LOAD SENSITIVITIES

California Independent
System Operator

Fig. 5.2 REQUIRED REACTIVE SUPPORT VERSUS PALO VERDE WEST FLOW.
ONLY HASSAYAMPA GENERATION VARIES, NEVADA GENERATION CONSTANT






SOUTHERN CALIFORNIA LOAD IMPACT

- **Lower Southern California load results in higher reactive power support requirements if the flows between Southern California and Arizona held constant.**
- **The amount of required reactive support depends significantly on how the change in load is compensated, thus on the flow on the major paths.**
- **For changes in the amount of local load at Valley and Devers, the impact was no different than for an equivalent change across Southern California's entire load.**




TRANSFER SENSITIVITIES. PALO VERDE WEST AND PALO VERDE EAST

Fig.6.2. REQUIRED REACTIVE SUPPORT VS. PALO VERDE WEST FLOW
HASSAYAMPA INERTIA (26437 MWsec), NORTH EOR (4655 MW), SCE LOAD HELD CONSTANT. PV EAST FLOW CONSTANT FOR EACH CURVE





TRANSFER SENSITIVITIES. PALO VERDE WEST AND NORTH EOR






CALIFORNIA ISO TRANSFER SENSITIVITIES. NORTHERN WOR

California Independent
System Operator

Fig.6.6. REQUIRED REACTIVE SUPPORT VS. NORTH WOR FLOW
HASSAYAMPA INERTIA (26437 MWsec), PV WEST (3420 MW), PV EAST (3947
MW) AND SCE LOAD (13650 MW) HELD CONSTANT






CALIFORNIA ISO TRANSFER SENSITIVITIES. PATH 26

California Independent
System Operator

Fig.6.7. REQUIRED REACTIVE SUPPORT VS. PATH 26 FLOW
HASSAYAMPA INERTIA (26437 MWsec), PV WEST (3420 MW), SCE LOAD HELD
CONSTANT





CALIFORNIA ISO

IMPACT OF MAJOR PATH FLOWS

California Independent
System Operator


- **Palo Verde West highest impact**
- **Palo Verde East some impact, depends on which other flows are held constant.**
- **Impacts of the North WOR, North EOR and Path 26 flows depend on the modeling assumptions, should not be considered alone.**
- **Factors for the new Arizona-Southern California transfer nomogram: flow on the Palo Verde West lines, combined flow to the Southern California from the North (North SCIT) and the Palo Verde East flow.**



CALIFORNIA ISO CONCEPTUAL NOMOGRAM

California Independent
System Operator

Fig.8.4 NOMOGRAM PALO VERDE WEST/ NORTH SCIT
HASSAYAMPA INERTIA (26437 MWsec) CONSTANT






CALIFORNIA ISO CONCEPTUAL NOMOGRAM

California Independent
System Operator

Fig.8.3. NOMOGRAM PALO VERDE WEST/ PV EAST
HASSAYAMPA INERTIA (26437 MWsec) CONSTANT






CALIFORNIA ISO CONCEPTUAL NOMOGRAM

California Independent
System Operator

Fig.8.5 NOMOGRAM PALO VERDE WEST-EAST/ NORTH SCIT
HASSAYAMPA INERTIA (26437 MWsec) CONSTANT





CALIFORNIA ISO CONCEPTUAL NOMOGRAM

California Independent
System Operator

SCIT north/PV West/PV East Nomogram

