

# Briefing on the California Independent System Operator Renewable Integration Study



Clyde Loutan  
Sr. Regional Transmission Engineer



**California ISO**  
Your Link to Power

Board of Governors Meeting  
General Session  
October 17, 2007

California enacted a RPS requiring each LSE to procure 20% of its energy from renewables.

- State Law requires LSEs to meet the 20% RPS
- The focus of the CAISO study is on wind
- Existing and expected wind resources

	<i>Tehachapi (MW)</i>	<i>System wide (MW)</i>
Existing	722	2,648
Addition	3,540	4,040
<b>Total</b>	<b>4,262</b>	<b>6,688</b>

- Goal – Identify Transmission and Operational challenges
- Scope – Engineering Analysis
- 20% RPS target can be met, without adverse Transmission or Operational impacts

# The study builds on the CEC's intermittency analysis for the 2007 Integrated Energy Policy Report

## **Infrastructure Analysis**

- Grid stability and voltage performance
- Characteristics of Wind Turbine Generator models
- Required voltage support

## **Operational Analysis**

- Modeled operating practice and timelines
- Multi-hour ramps
- Load Following/Regulation Capacity Requirements
- Over-generation Issues and Potential Solutions

## Transmission studies focused on a high concentration of wind resources in the Tehachapi Area.

### **Focused on stability performance following contingencies**

- WECC requirements for new wind plants
- FERC Order 661


### **Study Methodology**

### **Conclusions**


- Tehachapi Transmission Project must be built to accommodate the new wind resources
- 4,200 MW of wind generation can be integrated in the Tehachapi area
- Both transient stability and system damping are satisfactory
- Dynamic reactive capability at wind plants is required
- New wind Plants should be of Type 3 or Type 4 design
- Adequate reactive margins exist following critical contingencies

# Wind energy production is very difficult to predict in the Day Ahead or a few hours ahead.

Tehachapi – April 2005




# Wind production levels are typically low on hot days.



# Wind generation tends to be inversely correlated to daily load curve, creating ramping impacts.

CAISO Load -- Summer 2006



## Multi – Hour Ramps

### HE8 to HE10

2006 ~ 10,000 MW  
Change in Wind ~ 580 MW


20% RPS ~ 12,600 MW  
Change in Wind ~ 2,100 MW

### HE22 to HE24

2006 ~ 10,500 MW  
Change in Wind ~ 400 MW

20% RPS ~ 12,000 MW  
Change in Wind ~ 800 MW

Total Wind -- Summer 2006



# Load Following is necessary to maintain stable operations.

## MRTU will help with wind integration

- The Real Time Market balances Load and Generation on a forward looking basis
- Short Term Unit Commitment looks ahead 5 hours
- Real Time Unit Commitment looks out up to 105 minute
- Real Time Economic Dispatch software runs every 5-minutes
- Generation is dispatched based on economics/ramping capability

## Conclusions

- Load following Capacity requirements will increase



700 - 800 MW



500 - 900 MW

Existing generation fleet can meet the increased requirements



## Regulating resources are dispatched through Automatic Generation Control every four-seconds to meet real time fluctuations in the system.

- 🌐 Regulation is required to maintain frequency and maintain interchange schedules
- 🌐 Regulation is not dispatched based on economics
- 🌐 Today, the CAISO procures  $\pm 350$  MW of regulation on an hourly basis

### 🌐 Conclusions

- Regulation capacity requirements may double certain hours



170 - 250 MW



100 - 500 MW

- Additional regulation requirements are significant but manageable

## Recommendations



### **Advanced Information Needs**

- 4-second wind generation data
- Graphical displays for real-time operators
- Ramp forecasting tool
- State-of-the-art (DA, HA, RT) wind forecasting service
- solar power variability



### **Software Enhancements**

- Incorporate wind forecasts into scheduling processes
- Integrate wind forecast into MRTU dispatching applications

## Recommendations (cont.)

### **Generation Fleet Improvements**

- Additional generation with faster ramping capabilities
- Additional quick start units
- Resources with lower minimum operating levels
- Conventional generation impacts due to additional cycling, wear-and-tear and environmental constraints
- Evaluate wider-area ACE sharing with BPA

### **Policy Enhancements**

- Encourage the development of new energy storage technology
- Develop a procedure to allow pro-rata cuts in wind energy production
- Develop a policy for Imports/Exports of Renewables
- Critical to align with other policy considerations – GHG, once-through cooling, increased RPS