

DP 8.7.2

Operating Reserve

- (a) Spinning Reserve:
 - (i) Spinning Reserve provided from Generating Units and Interconnection schedules (~~for self providers of ancillary services~~) must meet the standards specified in the ASRP;
 - (ii) the ISO will dispatch Spinning Reserve as may be required to meet the Applicable Reliability Criteria;
 - (iii) the ISO may dispatch Spinning Reserve as balancing Energy to return Regulation Generating Units to their Set Points and restore full Regulation margin; and
 - (iv) the ISO will dispatch Spinning Reserve in merit order of Energy bid prices as determined by BEEP;
- (b) Non-Spinning Reserve:
 - (i) Non-Spinning Reserve provided from Generating Units ~~and~~ Demands, ~~and external imports of System Resources~~ must meet the standards specified in the ASRP;
 - (ii) the ISO may dispatch Non-Spinning Reserve in place of Spinning Reserve to meet Applicable Reliability Criteria;
 - (iii) the ISO will dispatch Non-Spinning Reserve in merit order of Energy bid prices as determined by BEEP; and
 - (iv) the ISO may dispatch Non-Spinning Reserve to replace Spinning Reserve if there is a shortfall in Spinning Reserve because of a deficiency of balancing Energy;

DP 9.1.1

Range of ISO Authority

The ISO has full authority to:

- (a) direct the physical operation of the ISO Controlled Grid, including (without limitation) circuit breakers, switches, voltage control equipment, protective relays, metering and Load Shedding equipment;
- (b) commit Reliability Must-Run Generation;
- (c) order a change in operating status of voltage control equipment;
- (d) take required action to prevent against uncontrolled losses of load or Generation;
- (e) control the output of Generating Units and Interconnection schedules (~~for self-providers of Ancillary Services~~) scheduled to provide Ancillary Services or offering Supplemental Energy;
- (f) dispatch Curtailable Demand which has been scheduled to provide Non-Spinning Reserve or Replacement Reserve; and
- (g) require the operation of resources which are at the ISO's disposal in a System Emergency, as described in DP 10.