

A	B	C	D	E	F	G	H	I	J	K	L
DG Node		DG in Base Portfolio	WDAT/Rule 21 non-NEM DG		Existing non-NEM DG		2015 Unassigned PDGD	Total Additional DG Modeled	Total DG Deliverable	2015-16 PDGD	Notes
Substation Name	Transmission Level kV		EO	FC	EO	FC					
VALLEY	115	23.99	20.32	555.64	5.33	62.52	0.00	0.00	0.00	0.00	WOD constraint
ANTELOPE	66	5.35	11.89	191.41	58.5	76.5	93.89	93.89	93.89	93.89	
BAILEY	66	0.00	0	1.5	0.45	25.6	0.45	0.45	0.45	0.45	
BARRE	230	3.56	0	170	0.1	47.2	149.65	149.65	149.65	149.65	
CHINO	230	0.00	0	50	6.49	101.3	3.50	6.49	6.49	6.49	
EAGLROCK	230	2.86	3.03	0	7.5	0	54.65	54.65	54.65	54.65	
ELLIS	230	76.52	0	0	0	18.51	0.00	76.52	76.52	76.52	
ETIWANDA	230	1.00	10.45	3.86	4.49	127.88	22.34	22.34	22.34	22.34	
GOLETA	230	0.00	0	101.5	1.04	115.6	1.04	1.04	1.04	1.04	
HINSON	230	0.00	0	0	1.37	68.91	0.00	1.37	1.37	1.37	
JOHANNA	230	74.23	0	241.8	2	0.3	0.00	2.00	2.00	2.00	
LA FRESA	230	0.00	1.8	0	0	1.45	0.00	1.80	1.80	1.80	
LAGUBELL	230	5.00	0	0	0	163	0.00	10.00	10.00	10.00	
LEWIS	230	20.00	0	4	0	240.41	0.00	20.00	20.00	20.00	
LITEHIPE	230	0.00	0	0	7.57	53	7.57	7.57	7.57	7.57	
MIRALOMA	230	0.00	1.76	1.5	3.99	142.25	5.75	5.75	5.75	5.75	
PADUA	230	46.12	0.43	0	3.32	42.97	8.60	49.44	49.44	49.44	
PARDEE	230	0.00	6.5	0	11.9	123.67	18.40	18.40	18.40	18.40	
S.CLARA	230	5.08	0	72	13.95	316.31	13.95	13.95	13.95	13.95	
SANTIAGO	230	98.90	13.38	29.6	0	9.99	0.00	69.30	69.30	69.30	
VILLA PK	230	15.55	0	87	0	9.2	3.56	3.56	3.56	3.56	
VSTA	230	22.20	0	0	11.27	716.13	10.77	45.47	45.47	45.47	
WINDHUB	230	14.02	8	100	0	543.1	0.00	14.02	14.02	14.02	
KRAMER	115	2.47	0	148.7	2	48.2	0.00	2.00	2.00	2.00	Conditional on participation in North of Lugo SPS
RECTOR	230	72.96	6.43	0	9.6	29.9	88.96	88.96	88.96	88.96	Conditional on participation in San Joaquin/Big Creek RAS
SPRINGVL	230	31.35	0	0	15.15	11.2	0.00	46.50	46.50	46.50	Conditional on participation in San Joaquin/Big Creek RAS
VESTAL	230	29.68	85.93	180	10.05	198.4	85.98	95.98	95.98	95.98	Conditional on participation in San Joaquin/Big Creek RAS
VICTOR	115	0.00	32.16	0	136.52	7.13	223.67	223.67	223.67	223.67	Conditional on participation in North of Lugo SPS

A	B	C	D	E	F	G	H	I	J	K	L
DG Node		DG in Base Portfolio	WDAT/Rule 21 non-NEM DG		Existing non-NEM DG		2015 Unassigned PDGD	Total Additional DG Modeled	Total DG Deliverable	2015-16 PDGD	Notes
Substation Name	Transmission Level kV		EO	FC	EO	FC					
VISTA	138	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	