

A	B	C	D	E	F	G	H	I	J	K	L	
DG Node		DG in Base Portfolio	WDAT/Rule 21 non-NEM DG		Existing non-NEM DG		2017 Unassigned PDGD	Total Additional DG Modeled	Total DG Deliverable	2017-18 PDGD	Notes	
Substation Name	Transmission Level KV		EO	FC	EO	FC						
ALMITOSW	66	7.04	0.00	0.00	0.00	0.00	7.04	17.94	17.94	7.04	PDGD = base portfolio	
ANTELOPE	66	5.35	0.15	225.61	65.34	152.31	172.09	172.09	0.00	172.09	PDGD = 2017 unassigned; Antelope A bank and AA bank overloads	
BAILEY	66	0.00	0.05	1.95	0.00	25.60	0.05	0.05	0.00	0.05	PDGD = 2017 unassigned; Pastoria - Pardee - Warne 230kV line overload	
BARRE	66	3.56	1.50	419.10	3.00	47.20	3.56	4.50	4.50	4.50	PDGD = existing EO + EO in queue	
CENTER	66	0.00	1.42	2.77	0.90	77.91	21.90	78.74	78.74	21.90	PDGD = 2017 unassigned	
CHINO	66	0.00	4.26	150.00	26.05	93.93	0.00	30.31	30.31	30.31	PDGD = existing EO + EO in queue	
DELA MO	66	0.00	0.00	130.00	2.41	8.83	2.41	2.41	2.41	2.41	PDGD = existing EO + EO in queue	
DEVERS	115	0.00	121.62	20.00	63.27	678.86	0.00	184.89	184.89	184.89	PDGD = existing EO + EO in queue	
EAGLROCK	66	2.86	0.00	0.00	0.00	0.00	7.50	26.59	26.59	7.50	PDGD = 2017 unassigned	
EL NIDO	66	0.00	0.80	0.00	0.00	22.68	0.00	22.61	41.44	41.44	23.48	PDGD = existing EO + EO in queue
ELLIS	66	76.52	0.06	0.00	3.25	12.00	74.52	79.77	79.77	79.77	PDGD = base portfolio	
ETIWANDA	66	0.59	31.60	5.35	8.79	144.34	32.44	79.93	79.93	40.39	PDGD = existing EO + EO in queue	
GOLETA	66	0.00	0.00	301.80	3.31	115.60	1.04	1.04	0.00	1.04	PDGD = 2017 unassigned; Pardee - Sylmar overloads	
HINSON	66	0.00	0.00	0.00	1.00	64.60	1.37	1.37	1.37	1.37	PDGD = 2017 unassigned	
JOHANNA	66	74.23	65.00	100.00	4.28	0.01	4.00	69.28	69.28	69.28	PDGD = existing EO + EO in queue	
LA FRESA	66	0.00	0.00	80.00	0.35	0.00	0.35	0.35	0.35	0.35	PDGD = existing EO + EO in queue	
LCIENEGA	66	0.01	0.00	0.00	0.00	9.95	2.76	23.02	23.02	2.76	PDGD = 2017 unassigned	
LITEHIPE	66	0.00	0.00	0.00	7.50	53.00	7.50	25.84	25.84	7.50	PDGD = existing EO + EO in queue	
MESA CAL	66	0.00	0.00	0.00	0.01	2.90	0.20	78.00	78.00	0.20	PDGD = 2017 unassigned	
MIRALOMA	66	10.00	0.75	0.00	2.50	154.35	15.99	41.54	41.54	15.99	PDGD = 2017 unassigned	
OLINDA	66	0.00	0.00	0.00	0.12	36.53	0.12	82.24	82.24	0.12	PDGD = existing EO + EO in queue	
PADUA	66	46.12	0.00	0.00	0.00	0.00	49.44	49.44	49.44	49.44	PDGD = 2017 unassigned	
RIOHONDO	66	46.06	0.00	0.00	0.00	13.10	46.06	102.01	102.01	46.06	PDGD = base portfolio	
S.CLARA	66	5.08	0.00	26.00	14.00	203.02	9.03	9.03	0.00	9.03	PDGD = 2017 unassigned; Pardee - Sylmar overloads	
SANTIAGO	66	98.90	0.00	21.60	0.00	28.36	75.30	77.30	77.30	77.30	PDGD = deliverable MW	
SAUGUS	66	0.00	0.00	0.00	3.50	20.00	5.07	5.07	0.00	5.07	PDGD = 2017 unassigned; Pardee - Sylmar overloads	
VALLEY	115	23.99	13.22	0.00	11.52	82.74	0.00	35.51	35.51	35.51	PDGD = base portfolio + existing EO	
VILLA PK	66	15.55	0.00	0.00	1.87	9.20	15.55	104.48	104.48	17.42	PDGD = base portfolio + existing EO	
VSTA	115	0.00	3.75	0.00	38.87	646.16	2.95	42.62	42.62	42.62	PDGD = existing EO + EO in queue	
WALNUT	66	8.76	0.00	0.00	1.83	61.00	10.36	105.10	105.10	10.59	PDGD = base portfolio + existing EO	
WINDHUB	66	8.00	3.00	84.00	9.40	469.23	36.00	36.00	0.00	36.00	PDGD = 2017 unassigned	
KRAMER	115	2.47	48.57	38.00	5.49	76.00	10.20	10.20	0.00	10.20	PDGD = 2017 unassigned; South of Kramer TPD fully allocated; conditional on participation in Mojave Desert RAS and HDPP RAS	
RECTOR	66	72.96	0.80	0.00	13.05	27.40	80.96	80.96	0.00	80.96	PDGD = 2017 unassigned; Pastoria - Pardee - Warne 230kV line overload; conditional on participation in Big Creek/San Joaquin Valley RAS	
SPRINGVL	66	31.35	0.80	20.00	14.85	2.68	46.20	46.20	0.00	46.20	PDGD = 2017 unassigned; Pastoria - Pardee - Warne 230kV line overload; conditional on participation in Big Creek/San Joaquin Valley RAS	

A	B	C	D	E	F	G	H	I	J	K	L
DG Node		DG in Base Portfolio	WDAT/Rule 21 non-NEM DG		Existing non-NEM DG		2017 Unassigned PDGD	Total Additional DG Modeled	Total DG Deliverable	2017-18 PDGD	Notes
Substation Name	Transmission Level KV		EO	FC	EO	FC					
VESTAL	66	29.68	0.00	106.00	88.94	214.58	173.94	173.94	0.00	173.94	PDGD = 2017 unassigned; Pastoria - Pardee - Warne 230kV line overload; conditional on participation in Big Creek/San Joaquin Valley RAS
VICTOR	115	0.00	3.00	30.00	108.37	34.50	144.49	144.49	0.00	144.49	PDGD = 2017 unassigned; Kramer-Victor overloads; Conditional on participation in HDPP RAS;