

A	B	C	D	E	F	G	H	I	J	K	L
DG Node		DG in Base Portfolio	WDAT/Rule 21 non-NEM DG		Existing non-NEM DG		2018 Unassigned PDGD	Total Additional DG Modeled	Total DG Deliverable	2018-19 PDGD	Notes
Substation Name	Transmission Level kV		EO	FC	EO	FC					
AVOCADO	69	16.66	40.00	2.00				40.00	0.00	0.00	Constrained by overload(s)
BORDER	12	6.00	5.33					9.70	0.00	0.00	Constrained by overload(s)
BORREGO	69	6.50				6.50		6.50	0.00	0.00	Constrained by overload(s)
BOULEVRD EAST	12	2.00	2.00	10.00				2.00	0.00	0.00	Constrained by overload(s)
CAPSTRNO	138	9.00	1.82	8.00				1.82	1.82	1.82	PDGD = Queued EO
CHCARITA	138	2.00			4.73			9.22	0.00	0.00	Constrained by overload(s)
CORONADO	69	3.00						4.00	0.00	0.00	Constrained by overload(s)
CREELMAN	69	16.00		2.00		10.46		14.00	0.00	0.00	Constrained by overload(s)
EASTGATE	69	0.20			1.60			1.80	0.00	0.00	Constrained by overload(s)
EL CAJON	69	7.50				7.50		7.50	0.00	0.00	Constrained by overload(s)
ESCNDIDO	69	30.00	1.50	6.50		30.00		23.50	0.00	0.00	Constrained by overload(s)
LILAC	12	2.00		2.00		3.00		0.00	0.00	0.00	Constrained by overload(s)
LOSE COCHES	12	3.00	3.00					3.00	0.00	0.00	Constrained by overload(s)
MARGARTA	138	0.00	1.05				0.89	1.05	1.05	1.05	PDGD = Queued EO
MELROSE	69	3.50	4.43	42.00				4.43	0.00	0.00	Constrained by overload(s)
MISSION	69	0.70						0.70	0.00	0.00	Constrained by overload(s)
MONSRATE	69	2.00	0.72	2.00				0.72	0.00	0.00	Constrained by overload(s)
OLD TOWN	69	5.40						5.40	0.00	0.00	Constrained by overload(s)
OMWD	69	7.20						7.20	0.00	0.00	Constrained by overload(s)
OTAY	69	8.20			3.20			11.40	0.00	0.00	Constrained by overload(s)
PICO	138	0.00					0.42	0.42	0.42	0.42	PDGD = 2018 unassigned
POMERADO	12	3.00	9.00					9.00	0.00	0.00	Constrained by overload(s)
PRCTRVLY	138	2.30			3.00			5.30	0.00	0.00	Constrained by overload(s)
RINCON	12	1.50	1.50					1.50	0.00	0.00	Constrained by overload(s)
SAN MARCOS	12	1.50	1.73					1.73	0.00	0.00	Constrained by overload(s)
STREAMVIEW	12	2.30	6.25					6.25	0.00	0.00	Constrained by overload(s)
VALLEY CENTER	12	1.00				9.83		1.00	0.00	0.00	Constrained by overload(s)
WARNERS	69	1.50						1.50	0.00	0.00	Constrained by overload(s)