

A	B	C	D	E	F	G	H	I	J	K	L
DG Node		DG in Base	WDAT/Rule 21 non-NEM DG		Existing non-NEM DG		2020	Total Additional DG Modeled	Total DG Deliverable	2020-2021 PDGD	Notes
Substation Name	Transmission Level kV	Portfolio/ POU Forecast	EO	FC	EO	FC	Unassigned PDGD				
APPLE HILL	115.00	0.00	0.00	0.00	0.00	0.00	0.00	24.00	13.50	13.50	Partially Constrained by Eight Mile-Stagg 230 kV line and other overloads
BONNIE NOOK	60.00	0.00	0.00	0.00	0.00	0.00	0.00	1.80	0.00	0.00	Constrained by Drum-Dutch Flats 115 kV line and other overloads
BRUNSWICK	115.00	0.00	0.00	0.00	0.00	0.00	0.00	60.26	0.00	0.00	Constrained by Vaca-Dixon-Tesla 500 kV line and other overloads
CALISTOGA	60.00	0.00	0.00	0.00	0.00	0.00	0.00	4.00	0.00	0.00	Constrained by Birdslanding-Contra Costa 230 kV line and other overloads
CEDAR CREEK	60.00	0.00	0.00	0.00	0.00	0.00	0.00	1.40	0.00	0.00	Constrained by Cortina-Vaca Dixon 230 kV line and other overloads
CHALLENGE	60.00	0.00	0.00	0.00	0.00	0.00	0.00	2.60	0.00	0.00	Constrained by Vaca-Dixon-Tesla 500 kV line and other overloads
CLARK ROAD	60.00	0.00	0.00	0.00	0.00	0.00	0.00	6.79	0.00	0.00	Constrained by Vaca-Dixon-Tesla 500 kV line and other overloads
CLEAR LAKE	60.00	0.00	0.00	0.00	0.00	0.00	0.00	14.10	0.00	0.00	Constrained by Cortina-Vaca Dixon 230 kV line and other overloads
CLOVERDALE	115.00	0.00	0.00	0.00	0.00	0.00	0.00	16.50	0.00	0.00	Constrained by Cortina-Vaca Dixon 230 kV line and other overloads
COLUMBIA HILL	60.00	0.00	0.00	0.00	0.00	0.00	0.00	2.50	0.00	0.00	Constrained by Vaca-Dixon-Tesla 500 kV line and other overloads
DOBBINS	60.00	0.00	0.00	0.00	0.00	0.00	0.00	2.00	0.00	0.00	Constrained by Vaca-Dixon-Tesla 500 kV line and other overloads
EL DORADO PH	115.00	0.00	0.00	0.00	0.00	0.00	0.00	10.77	6.04	6.04	Partially Constrained by Eight Mile-Stagg 230 kV line and other overloads
ELECTRA	13.80	0.00	0.00	0.00	0.00	0.00	0.00	9.90	9.90	9.90	
FORESTHILL	60.00	0.00	0.00	0.00	0.00	0.00	0.00	8.50	0.00	0.00	Constrained by Spaulding-Cisco 60 kV line and other overloads
FRENCH GULCH	60.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	0.00	0.00	Constrained by Humboldt-Bridgeville 115 kV line and other overloads
HARTLEY	60.00	0.00	0.00	0.00	0.00	0.00	0.00	14.60	0.00	0.00	Constrained by Cortina-Vaca Dixon 230 kV line and other overloads
HOOPA	60.00	0.00	0.00	0.00	0.00	0.00	0.00	3.70	0.00	0.00	Constrained by Humboldt-Bridgeville 115 kV line and other overloads
KANAKA	115.00	0.00	0.00	0.00	0.00	0.00	0.00	1.40	0.00	0.00	Constrained by Vaca-Dixon-Tesla 500 kV line and other overloads
KONOCTI	60.00	0.00	0.00	0.00	0.00	0.00	0.00	14.50	0.00	0.00	Constrained by Cortina-Vaca Dixon 230 kV line and other overloads
LOW GAP	115.00	0.00	0.00	0.00	0.00	0.00	0.00	1.10	0.00	0.00	Constrained by Humboldt-Trinity 115 kV line and other overloads
OAKLAND L	115.00	0.00	0.00	0.00	0.00	0.00	0.00	7.00	0.00	0.00	Constrained by Vaca-Dixon-Tesla 500 kV line and other overloads
PIKE CITY	60.00	0.00	0.00	0.00	0.00	0.00	0.00	0.70	0.00	0.00	Constrained by Vaca-Dixon-Tesla 500 kV line and other overloads
PINE GROVE	60.00	0.00	0.00	0.00	0.00	0.00	0.00	18.40	18.40	18.40	
PLAINFIELD	60.00	0.00	0.00	0.00	0.00	0.00	0.00	22.70	0.00	0.00	Constrained by Birdslanding-Contra Costa 230 kV line and other overloads
POINT MORETTI	60.00	0.00	0.00	0.00	0.00	0.00	0.00	3.10	3.10	3.10	
SHADY GLEN	60.00	0.00	0.00	0.00	0.00	0.00	0.00	7.60	0.00	0.00	Constrained by Drum-Dutch Flats 115 kV line and other overloads
WEIMAR	60.00	0.00	0.00	0.00	0.00	0.00	0.00	7.20	0.00	0.00	Constrained by Drum-Dutch Flats 115 kV line and other overloads
WHITMORE	60.00	0.00	0.00	0.00	0.00	0.00	0.00	1.30	0.00	0.00	Constrained by Delevan-Cortina 230 kV line and other overloads
WILLOW CREEK	60.00	0.00	0.00	0.00	0.00	0.00	0.00	5.90	0.00	0.00	Constrained by Humboldt-Bridgeville 115 kV line and other overloads