

A	B	C	D	E	F	G	H	I	J	K	L
DG Node		DG in Base Portfolio/ POU forecast	WDAT/Rule 21 non-NEM DG		Existing non-NEM DG		2022 Unassigned PDGD	Total Additional DG Modeled	Total DG Deliverable	2022-2023 PDGD	Notes
Substation Name	Transmission Level KV		EO	FC	EO	FC					
Victor	230	7							0	0	Victor to Lugo Area Constraint; 0 MW of TPD available
Valley	500	1.25							0	0	Serrano-Alberhill-Valley Area Constraint; 0 MW of TPD available
Etiwanda	230	0.59							0	0	Serrano-Alberhill-Valley Area Constraint; 0 MW of TPD available
Vista	220	10							0	0	Serrano-Alberhill-Valley Area Constraint; 0 MW of TPD available
Laguna Bell	220	10					10	0	10	10	Del Amo to Barre Area Constraint: more than 10 MW of TPD available