

**CALIFORNIA INDEPENDENT SYSTEM OPERATOR CORPORATION
FINAL 2014 FLEXIBLE CAPACITY
NEEDS ASSESSMENT**

**ADDENDUM
MAY 5, 2012**

The ISO’s Final Flexible Capacity Needs Assessment, dated May 1, 2014, is available on the ISO’s website at

<http://www.aiso.com/informed/Pages/StakeholderProcesses/FlexibleCapacityRequirements.aspx>

Figure 8 in that assessment showed the calculation of the CPUC jurisdictional load serving entities’ contribution to the base flexible capacity need using 74 percent for all months.

In accordance with methodology discussed in Section 6.3 of the Final Flexible Capacity Needs Assessment, the CPUC jurisdictional load serving entities’ contribution to the flexible capacity need should have been calculated by applying a seasonal factor of 74 percent for the non-summer months (January through April and October through December) and 68 percent for summer months (May through September).

The ISO is issuing this Addendum to the Final Flexible Capacity Needs Assessment to revise Figure 8. Revised Figure 8 contains the corrected summer the base and peak flexible capacity needs, as highlighted for the months of May through September.

**Revised Figure 8:
CPUC Flexible Capacity Need in Each Category for 2015**

