

UNITED STATES OF AMERICA  
BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION

Turlock Irrigation District and )  
Modesto Irrigation District )  
 ) Docket No. EL99-93-000  
California Independent System )  
Operator Corporation )

ANSWERING TESTIMONY OF  
DEANE LYON  
ON BEHALF OF THE  
CALIFORNIA INDEPENDENT SYSTEM  
OPERATOR CORPORATION

1 **Q. PLEASE STATE YOUR NAME, TITLE AND BUSINESS ADDRESS.**

2 A. My name is Deane Lyon. I am Director of Operations Support and  
3 Training (“OSAT”) for the California Independent System Operator (“ISO”).  
4 My business address is 151 Blue Ravine Road, Folsom, CA 95630.

5

6 **Q. WHAT IS YOUR EDUCATIONAL BACKGROUND?**

7 A. I am certified by the California Apprenticeship Council, the Western  
8 System Coordinating Council (“WSCC”) and the North American Electric  
9 Reliability Council (“NERC”) as a System Operator. I attended Ohlone  
10 Junior College, Fremont, California in 1976, taking business law, business  
11 administration and electronics courses. Since being employed first with  
12 Pacific Gas and Electric Company (“PG&E”) from December 1976 through  
13 September 1997 and from October 1997 with the California ISO, I have  
14 completed several system operations, supervisory and management  
15 courses.

16

17 **Q. PLEASE DESCRIBE YOUR WORK EXPERIENCE PRIOR TO THE**  
18 **WORK YOU ARE DOING TODAY.**

19 A. I began my professional career with PG&E in 1976 as a System Operator.  
20 Through the course of my PG&E career, I worked as a System Operator  
21 at both the distribution and transmission switching center levels, and  
22 supervised or managed distribution and transmission switching centers,  
23 regional transmission departments and a regional operator training

1 program. I was an instructor at the PG&E System Operator Training  
2 Center and Power System simulator. The last seven years of my career  
3 with PG&E were spent in their Energy Control Center as a Transmission  
4 Dispatcher, Interchange Scheduler, Generation Dispatcher and Senior  
5 Operations Supervisor, in that order. As Senior Operations Supervisor, or  
6 Shift Supervisor, I was responsible for the safe and reliable operation of  
7 the PG&E Control Area grid which, prior to its incorporation into the ISO  
8 Control Area, spanned from Bakersfield in the south to the California-  
9 Oregon border in the north, and from the California coast to the California-  
10 Nevada border in the east.

11

12 I joined the California ISO in October 1997 as a Shift Manager, assuming  
13 the same responsibilities as I had at PG&E, however with a considerably  
14 larger Control Area that includes most of the state of California, and with  
15 the added market component. I moved from Grid Operations to the OSAT  
16 Department in late 1999 as an Operations Trainer. I became manager of  
17 Operations Support in June 2000, and recently have accepted the position  
18 of Director, Operations Support and Training.

19

20 **Q. WHAT ARE YOUR CURRENT RESPONSIBILITIES AT THE ISO?**

21 A. I am currently Director of the OSAT Department at the ISO. Personnel  
22 that report directly to me include managers for the following groups:  
23 Operations Support, Operations Training, and Operations Applications

1 Support. The primary role of OSAT is to provide support to all  
2 departments within the Operations Division, including the development of  
3 training programs, real-time operations support and development of tools  
4 for operations. OSAT provides training and support to all groups within  
5 the Operations Division, to other departments within the ISO, and to  
6 Market Participants, to ensure and enhance system reliability as well as to  
7 facilitate and expand workably competitive markets.

8  
9 As the Director of OSAT, I am responsible for overseeing preparation and  
10 administration of training across all operations groups, other groups in the  
11 ISO, and Market Participants; providing support for ISO efforts to interface  
12 with and incorporate markets and deregulation from an operations  
13 perspective as they develop inside and outside the ISO; updating, creating  
14 and maintaining all ISO Operating Procedures; implementing emergency  
15 response programs and procedures within the ISO and in coordination  
16 with state and federal agencies; providing presentation development and  
17 support for the Operations organization; and reviewing ISO Tariff changes,  
18 legislation, and regional and national operating organization policies from  
19 an operations feasibility point-of-view.

20

1 **Q. HAVE YOU PREVIOUSLY PROVIDED TESTIMONY IN A**  
2 **REGULATORY PROCEEDING?**

3 A. Yes. I have submitted testimony in Docket No. Docket No. ER01-  
4 313-000, *et al.* regarding the ISO's position with regard to certain billing  
5 determinants for the ISO's Grid Management Charge.

6

7 **Q. AS YOU TESTIFY, WILL YOU BE USING ANY SPECIALIZED TERMS?**

8 A. Yes, I will use capitalized terms as defined in the Master Definitions  
9 Supplement, Appendix A of the ISO Tariff. I would note, however, that the  
10 definitions of Load, Generation, Generating Units, and certain other terms  
11 refer specifically to the ISO Control Area or the ISO Controlled Grid. In  
12 addition, operators often use the term "load" as a shorthand for Demand  
13 from Load, and "resources" as a shorthand for Generation from  
14 Resources, as in the concept of balancing load and resources. I will  
15 therefore be using a number of these terms, without capitalization, in their  
16 more general meaning.

17

18 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS**  
19 **PROCEEDING?**

20 A. The purpose of this testimony is to respond to portions of the Direct  
21 Testimony of Paul G. Scheuerman (Exh. No. TID-1). In particular, I  
22 respond to Mr. Scheuerman's assertions that the requirement that TID  
23 enter a Participating Generator Agreement ("PGA") in order to participate

1 in the ISO's markets is discriminatory because the ISO does not impose a  
2 similar requirement on System Resources – i.e., generating units outside  
3 the ISO Control Area that can participate in the ISO's markets.

4

5 **Q. WHAT IS THE ISO CONTROL AREA?**

6 A. The WSCC Minimum Operating Reliability Criteria ("MORC") include the  
7 following requirement:

8 **Inclusion in control area.** Each entity operating transmission,  
9 generation, or distribution facilities shall either operate a control  
10 area or make arrangements to be included in a control area  
11 operated by another entity. All generation, transmission, and load  
12 operating within the Western Interconnection shall be included  
13 within the metered boundaries of a WSCC control area. Control  
14 areas are ultimately responsible for ensuring that the total  
15 generation is properly matched to total load in the Interconnection.

16

17 The ISO Control Area is the territory for which the ISO is the WSCC  
18 designated Control Area operator. It constitutes the former Control Areas  
19 of the Participating Transmission Owners – PG&E, Southern California  
20 Edison Company, and San Diego Gas & Electric Company – and includes  
21 the TID service territory. The ISO is ultimately responsible for ensuring  
22 the safety and reliability of the ISO Control Area, fulfilling our responsibility  
23 as Control Area operator to the Western Interconnection, and for  
24 compliance with WSCC MORC and NERC operating policies.

25

1 **Q. WHAT ARE THE ISO'S CONTROL AREA RESPONSIBILITIES?**

2 A. These responsibilities are significant. The manner in which a Control Area  
3 operator carries out these responsibilities will have an impact not only on  
4 its own Control Area, but also on the Western Interconnection as a whole.

5 They include, but are not limited to the following:

- 6 • System security analyses
- 7
- 8 • Setting transmission maintenance standards
- 9
- 10 • System planning to ensure overall reliability
- 11
- 12 • Integration with other Control Areas
- 13
- 14 • Emergency management
- 15
- 16 • Transmission line, equipment and Generator Unit outage coordination
- 17
- 18 • Energy scheduling for Generating Units, imports, exports, and
- 19 Wheeling in the Day-Ahead and Hour-Ahead of actual operations and
- 20 reconciling those Schedules after-the-fact
- 21
- 22 • Conducting annual and multi-year studies to determine the need for
- 23 Reliability Must-Run Generation contracts
- 24
- 25 • Performing operational studies
- 26
- 27 • Real-time frequency control, i.e., the continuous balancing of load and
- 28 resources
- 29
- 30 • Monitoring time error and, as WSCC time error monitor, initiating and
- 31 terminating manual time error corrections for the entire Western
- 32 Interconnection
- 33
- 34 • Compliance with WSCC MORC, including: generation control and
- 35 performance; transmission operation; interchange scheduling; system
- 36 coordination; emergency operations; operations planning;
- 37 telecommunications; and operating personnel and training
- 38
- 39 • Compliance with NERC policies and NERC Standards compliance
- 40 reporting

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

- Compliance with WSCC Reliability Management System (RMS) monitoring and reporting criteria
- Managing unscheduled flow through the ISO Control Area, including initiating, terminating and complying with requests of other Control Areas to participate in the WSCC Unscheduled Flow Reduction procedure
- Managing inadvertent interchange and reporting status to the WSCC

The WSCC and NERC set the standards for Control Areas.

**Q. MR. SCHEUERMAN NOTES THAT SYSTEM RESOURCES ARE NOT REQUIRED TO SIGN A PGA OR “YIELD CONTROL” OF THE GENERATING UNITS TO THE ISO. WHY IS THIS NOT DISCRIMINATORY?**

A. Due to the fact that TID’s Generating Units are within the ISO Control Area, they are not similarly situated to System Resources, and in fact are significantly different. Mr. Scheuerman’s argument to the contrary disregards the function of Control Areas, which are the entities through which the reliability of the interconnected electric grid is maintained, and the manner in which the ISO and other Control Area operators fulfill that responsibility. The ISO must match resources and load in its Control Area within the small tolerances specified under WSCC reliability criteria at all times. In order to do so, the ISO must have the ability to direct, as system conditions and operating circumstances require, the operations, including real-time production, start-up and shut-down, of Generating Units within its



1 Control Area and must acquire real-time data on these Generating Units.  
2 The ISO simply does not require that degree of control or that level of data  
3 detail with respect to external resources, i.e., System Resources, since  
4 these resources and associated load responsibility are the responsibility of  
5 other Control Area operators. The adjacent Control Area operator's  
6 responsibility with regard to System Resources is simply to maintain  
7 interchange schedules with the ISO across specific interconnection points.  
8 It is not required to match those utilities' loads and resources on a minute-  
9 to-minute basis or to associate specific interchange schedules with  
10 specific resources.

11  
12 To expand further, a System Resource is a firm Energy schedule to the  
13 ISO from an adjacent Control Area. It is essentially a contract obligating  
14 that Control Area operator to supply the scheduled Energy even though a  
15 generator associated with the schedule experiences a curtailment or an  
16 outage. By the nature of the schedule being firm, the adjacent Control  
17 Area operator is obligated to provide operating reserve associated with  
18 that schedule on a 1 MW-for-1 MW basis, thereby ensuring the delivery of  
19 that schedule across the agreed upon point of interchange.

20  
21 Moreover, just as resources within the ISO Control Area are subject to the  
22 limited control exercised by the ISO, resources in other Control Areas are  
23 subject to the operational control requirements of the operators of those

1 Control Areas – and necessarily cannot be under any type of control by  
2 the ISO. For the ISO to exercise any control over resources located in  
3 other Control Areas would be a hindrance to the reliable operation of that  
4 Control Area and, in fact, to the Western Interconnection.

5  
6 **Q. MR. SCHEUERMAN ASSERTS THAT TID IS IDENTICAL TO A**  
7 **SYSTEM RESOURCE FROM A SCHEDULING AND METERING**  
8 **STANDPOINT, AND THAT THE DATA REQUIREMENTS THAT THE**  
9 **ISO TARIFF WOULD IMPOSE ON TID THROUGH THE PGA ARE**  
10 **THEREFORE DISCRIMINATORY. WHY DOES THE ISO TREAT**  
11 **SYSTEM RESOURCES DIFFERENTLY IN THIS REGARD?**

12 A. The ISO has fundamentally different needs for data from Generating Units  
13 and Loads in its Control Area than from generating units and loads located  
14 outside of the Control Area. As I noted, the ISO must maintain a constant  
15 real-time balance between Generation and load in its Control Area. The  
16 ISO needs information on Generating Units within the Control Area in  
17 order to calculate system load in real-time and maintain the required level  
18 of Operating Reserves, and to balance Generation and load by  
19 dispatching Imbalance Energy from bids in the Supplemental Energy  
20 market and Energy bids associated with Spinning and Non-Spinning  
21 Reserve capacity. Because the ISO is not responsible for maintaining  
22 Operating Reserves for load outside of the Control Area other than for on-

1 demand obligations to other Control Areas as noted above, it does not  
2 require the information from System Resources.

3

4

5 **Q. WHY DOES THE ISO REQUIRE TELEMETRY DATA FROM TID IN**  
6 **ORDER TO MAINTAIN BALANCE BETWEEN GENERATION AND**  
7 **LOAD?**

8 A. TID is part of the ISO Control Area. Thus, if TID were to experience a loss  
9 of Generation, it is the ISO, as Control Area operator, who is responsible  
10 to replace that loss. The ISO's Area Control Error ("ACE") would reflect  
11 that Generation shortage, and the ISO would be responsible to return  
12 Control Area load and Generation into balance. In order for the ISO to  
13 properly perform this function, the ISO is required to maintain a supply of  
14 unloaded operating capacity, i.e., Operating Reserve, to be used to  
15 respond to a loss of Generation or other real-time Energy disturbance.  
16 The ISO must know the amount and the location of Operating Reserves  
17 within the Control Area. The WSCC MORC Section 1.A.7, Operating  
18 Reserve Distribution, states the following:

19 Prudent operating judgment shall be exercised in distributing  
20 operating reserve, taking into account effective use of capacity in  
21 an emergency, time required to be effective, transmission  
22 limitations, and local area requirements.

23

24 Further, NERC Policy One, Generation Control and Performance, states:

25 OPERATING RESERVE shall be dispersed throughout the system  
26 and shall consider the effective use of capacity in an emergency,

1 time required to be effective, transmission limitations, and local  
2 area requirements. Spinning reserve should be distributed to  
3 maximize the effectiveness of governor action.  
4

5 Moreover, there is currently language in a proposed and widely accepted  
6 revision to WSCC Operating Reserve criteria, which states:

7  
8 The Control Area Operator shall have sufficient knowledge at all  
9 times of the amount and location of the operating reserve that is in  
10 place to meet his or her Control Area's/Reserve Sharing Group's  
11 requirements and to operate within OTCs.  
12

13 Implicit in the above quoted statements is the responsibility for the Control  
14 Area operator to have knowledge, at all times, of the amount and location  
15 of Operating Reserve so that when dispatched, the effect on transmission  
16 line and equipment flows can be anticipated. A lack of such information  
17 would complicate efforts to comply with the requirement under the WSCC  
18 MORC to calculate Operating Reserve that can be fully activated within  
19 ten minutes. Thus the ISO must have telemetry data from TID's  
20 Generating Units and all other Generating Units in the ISO Control Area in  
21 order to comply with WSCC MORC and to be able to detect and respond  
22 appropriately to a loss of Generation or other Energy disturbance.  
23

24 **Q. COULD YOU PROVIDE AN EXAMPLE?**

25 A. A very simple and credible example is the following: if a TID Generating  
26 Unit with an output of 50 MW were to suddenly disconnect from the grid as  
27 the result of generator or auxiliary equipment trouble, an ISO ACE of -50  
28 MW would result, assuming a zero ACE prior to the event. A -50 MW

1 ACE is indicative of a 50 MW imbalance between ISO Control Area load  
2 and resources, and the ISO is responsible for the dispatching of  
3 Imbalance Energy from Operating Reserves or the Supplemental Energy  
4 market to regain that balance. This sudden loss of a 50 MW Generating  
5 Unit would also result in a system frequency deviation that would be  
6 observed over the entire Western Interconnection until the ISO has  
7 regained the load-resource balance. In addition, transmission line and  
8 equipment MW flows in the area of the Generating Unit disconnection  
9 would change. The ISO, as Control Area operator, must monitor these  
10 changes and be prepared to mitigate any resulting Congestion, again by  
11 dispatching Imbalance Energy from Operating Reserve or Supplemental  
12 Energy bids. These bids must be dispatched in the proper amount and  
13 from the proper location in order to mitigate, not to increase the  
14 Congestion or compound other problems resulting from the Generating  
15 Unit disconnection.

16  
17 **Q. HOW DOES THE ISO'S NEED TO MAINTAIN ADEQUATE OPERATING**  
18 **RESERVES CREATE THE NEED FOR TELEMETRY DATA?**

19 A. Under WSCC Criteria, the ISO's load responsibility is the basis for  
20 accurately calculating and adequately maintaining Operating Reserve.  
21 The WSCC defines load responsibility as "Control Area firm load demand  
22 plus those firm sales minus those firm purchases for which reserve  
23 capacity is provided by the supplier." Thus, in order to determine load

1 responsibility, the ISO must be able to accurately calculate ISO Control  
2 Area firm load demand. Because it would be impractical to obtain real  
3 time data from all Loads, Control Area firm load demand is measured as  
4 the sum of internal Generation plus net interchange. Load responsibility is  
5 that sum minus firm Energy imports (the portion of the ISO load for which  
6 another Control Area is, based on the type of interchange schedule,  
7 providing operating reserve) plus firm energy Exports (the portion of  
8 another Control Area's load for which the ISO is, based on the type of  
9 interchange schedule, providing Energy and/or Operating Reserve). The  
10 ISO therefore cannot meet its obligation to the WSCC without real-time  
11 telemetered information on Generation; neither can it relinquish or be  
12 excused from these obligations.

13  
14 Inadequate load calculations and inaccurate or inadequate knowledge of  
15 the amount and the location of reserves threaten reliability. Without such  
16 knowledge, it becomes difficult to protect the system against credible  
17 contingencies. As I have described, during such contingencies, the ISO  
18 as Control Area operator must have sufficient unloaded capacity, i.e.,  
19 Operating Reserve, in the proper location to respond to a sudden loss in  
20 capacity or Generation. Hence, without accurate calculations of  
21 Generation and load, the ISO's Control Area responsibilities are  
22 compromised, as is the reliability of the Control Area and the Western

1 Interconnection. Indeed, continuity of service to load is the primary  
2 objective of the WSCC MORC.

3

4 As the WSCC MORC states regarding Operating Reserve:

5 The reliable operation of the interconnected power system requires  
6 that adequate generating capacity be available at all times to maintain  
7 schedule frequency and avoid loss of firm load following transmission  
8 or generation contingencies. This generating capacity is needed to:

9

- 10 • Supply requirements for load variations.
- 11
- 12 • Replace generating capacity and energy lost due to forced outages  
13 of generation or transmission equipment
- 14
- 15 • Meet on-demand obligations
- 16
- 17 • Replace energy lost due to curtailment of interruptible imports.
- 18

18

19 Mr. Scheuerman would have us ignore these operating requirements.

20

21 In contrast, the ISO is *not* responsible for maintaining adequate reserves  
22 for external demands, other than those scheduled as firm Energy or  
23 capacity exports, even when the supplier schedules transactions on the  
24 ISO Controlled Grid. The ISO only requires accurate data regarding  
25 interchange schedules.

26

27 **Q. WHY IS TID'S INTERCONNECTION AGREEMENT WITH PG&E NOT**  
28 **SUFFICIENT TO ALLOW THE ISO TO ENSURE THE RELIABILITY OF**  
29 **THE CONTROL AREA?**

1 A. Under its Interconnection Agreement with PG&E, as Mr. Scheuerman  
2 explains it, TID provides PG&E with net scheduling information and  
3 provides its own Spinning and Non-Spinning Reserves. I have already  
4 explained why the net scheduling information is inadequate for the ISO's  
5 performance of its responsibilities. In addition, the ISO cannot simply rely  
6 upon TID's commitment to provide reserves. As the Control Area  
7 operator, the ISO must have data available to ensure that the reserves are  
8 available when needed. Unlike PG&E, the ISO does not own Generating  
9 Units, from which it can "make up the difference" if TID fails to live up to  
10 that commitment; it must rely on resource owners, like TID, to make that  
11 Generation available. If the ISO did not insist on the ability to verify that  
12 TID in fact was providing the reserves that it committed to provide, it could  
13 not insist on that ability with respect to other Generating Unit owners in its  
14 Control Area, and its ability to maintain reliability would be fatally  
15 compromised. Experience has shown that the ISO cannot simply take  
16 Market Participants at their word, hoping that they will live up to  
17 commitments to supply Generation. In a competitive environment,  
18 Generators seek every advantage and cost savings. The ISO has had to  
19 remain vigilant to enforce Market Participants' obligations to supply  
20 reserves and follow dispatch instructions. To do otherwise would show  
21 blatant disregard for WSCC MORC and NERC Operating policies.

22



1           Moreover, as Mr. Scheuerman admits, TID does not provide its own  
2           Regulation. Although he asserts that TID “buys” that Regulation from  
3           PG&E, the fact is that PG&E is no longer responsible for using Regulation  
4           to constantly maintain system balance. It is the ISO that must maintain  
5           the constant communication with Generating Units providing Regulation  
6           and it is the ISO’s system that responds immediately when a Generating  
7           Unit in the Control Area fails or a Load suddenly changes.

8  
9           It is perfectly appropriate for TID to contract with PG&E to provide  
10          Regulation on TID’s behalf. The Regulation provided by PG&E, however,  
11          must be controlled by the ISO if it is to be used to ensure System  
12          Reliability. The fact that TID purchases Regulation from PG&E does not  
13          substitute for the services provided by the ISO.

14  
15          Of course, if TID really believes that it is self-sufficient, and does not  
16          impose reliability burdens on the ISO, TID could seek designation as its  
17          own Control Area. Under such circumstances, TID would truly be a  
18          System Resource, and would not need to enter into a PGA with the ISO.

19

20   **Q.    THERE AREA NO FURTHER QUESTIONS.**

21

22