

Record ID	Utility	Shikoh Name	Description	Type	KV	Units	From	To	Owner	Operator	Rating	Duration	Rating	Duration	Rating	Duration	Rating	Duration	Rating	Duration	Rating	Duration	Change Reason	
397158			CIMA ELDORADO PISGAH NO 1	TL	230	AMPS	PST 00 00 1998	5/21 Mar 21	SCE	SCE	75.0													
397198			CIMA ELDORADO PISGAH NO 2	TL	230	AMPS	PST 00 00 1998	5/21 Mar 21	SCE	SCE	72.5													
400464			ELDORADO MEAD NO 1	TL	230	AMPS	PST 11 05 2000	11 Jul 13	SCE	SCE	72.5													REMOVED WAVE TRAP 0020 OTHER CAUSES NOT THAT LIMITED CAPACITY COVERED IN ABOVE LISTING
400588			ELDORADO MEAD NO 2	TL	230	AMPS	PST 06 09 47 1999	11 Dec 09	SCE	SCE	748.0	2850.0	3.150	1										
415154			DEVERS PALOVERDE (1 SEE SCIT AND CASI MONOGRAMS) LAUGHLIN MOHAVE (1 SCE PORTION 2 LIMITED TO 800A BY SYSTEM PROTECTION)	TL	500	AMPS	PST 00 00 1998	19 Mar 19	SCE	SCE	1900.0		2430	0.5										
415283			ELDORADO LUGO (SEE SCIT MONOGRAM)	TL	500	AMPS	PST 13 34 13 2000	15 Nov 15	SCE	SCE	800.0													
415555			ELDORADO MOENKOP (SCE PORTION) (SEE SCIT AND CASI MONOGRAMS)	TL	500	AMPS	PST 00 00 1997	19 Dec 19	SCE	SCE	1600.0		2400	0.5										0007 REPAIR ACED EXISTING EQUIPMENT
415783			ELDORADO MOHAVE (SEE SCIT MONOGRAMS)	TL	500	AMPS	PST 00 00 1998	19 Mar 19	SCE	SCE	1900.0	2150	24	0.5										0008 CORRECTED A DATA INPUT ERROR 0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY) 0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
415881			ELDORADO MOHAVE	TL	500	AMPS	PST 00 00 1998	17 Aug 17	SCE	SCE	3000.0		3270	1										0008 CORRECTED A DATA INPUT ERROR 0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY) 0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
416433			LUGO MOHAVE (SEE SCIT MONOGRAM)	TL	500	AMPS	PST 08 12 31 2000	17 Aug 17	SCE	SCE	1600.0		2140	0.5										0008 CORRECTED RATING
2434818			ELDORADO-MCCULLOUGH	TL	500	AMPS	PST 09 03 18 2000	18 Jan 26	SCE	SCE	1620.0													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
2942527			ELDORADO MERCHANT	TL	230	AMPS	PST 13 45 2001	26 Jan 26	SCE	SCE	1620.0													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)

Record ID	Update	Station Name	Description	Type	KV	Uses	From	Owner	Operator	N	Duration	A	Rating	B	Duration	C	Rating	D	Duration	E	Duration	F	Duration	Non-ISO	Equipment	Change Category	Change Reason	
1720148		ELDRADO	CIRCUIT BREAKER 4012	CB	230	AMPS	Fri May 28 09 16 15 2000 P01	SCE	SCE	3000	C		5400	5400												0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)		
397230		ELDRADO	CIRCUIT BREAKER 4092	CB	230	AMPS	Fri May 28 09 50 43 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
397170		ELDRADO	CIRCUIT BREAKER 4102	CB	230	AMPS	Mon Sep 24 09 57 21 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
1720014		ELDRADO	CIRCUIT BREAKER 4112	CB	230	AMPS	Fri May 28 09 18 15 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
2942144		ELDRADO	CIRCUIT BREAKER 5012	CB	230	AMPS	Fri May 28 13 45 11 2001 P01	SCE	SCE	3000	C		5400	5400													0007 REPLACED EXISTING EQUIPMENT	
397166		ELDRADO	CIRCUIT BREAKER 5092	CB	230	AMPS	Fri May 28 09 50 44 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
397206		ELDRADO	CIRCUIT BREAKER 5102	CB	230	AMPS	Fri May 28 09 50 46 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
2942209		ELDRADO	CIRCUIT BREAKER 6012	CB	230	AMPS	Fri May 28 13 45 27 2001 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
1720031		ELDRADO	CIRCUIT BREAKER 6012	CB	230	AMPS	Fri May 28 09 16 15 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
397208		ELDRADO	CIRCUIT BREAKER 6092	CB	230	AMPS	Fri May 28 09 50 44 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
397246		ELDRADO	CIRCUIT BREAKER 8102	CB	230	AMPS	Fri May 28 09 50 46 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
1720037		ELDRADO	CIRCUIT BREAKER 8112	CB	230	AMPS	Fri May 28 09 16 15 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
2434164		ELDRADO	CIRCUIT BREAKER 712	CB	500	AMPS	Mon Dec 18 09 00 06 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
413391		ELDRADO	CIRCUIT BREAKER 782	CB	500	AMPS	Fri May 28 09 50 51 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
413811		ELDRADO	CIRCUIT BREAKER 882	CB	500	AMPS	Fri May 28 09 50 52 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
413813		ELDRADO	CIRCUIT BREAKER 912	CB	500	AMPS	Fri May 28 09 50 54 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
413807		ELDRADO	CIRCUIT BREAKER 982	CB	500	AMPS	Fri May 28 09 50 52 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
2434797		ELDRADO	CIRCUIT BREAKER 952	CB	500	AMPS	Wed Dec 18 09 00 13 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
413881		ELDRADO	CIRCUIT BREAKER 962	CB	500	AMPS	Fri May 28 09 50 53 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
413853		ELDRADO	CIRCUIT BREAKER 972	CB	500	AMPS	Fri May 28 09 50 54 2000 P01	SCE	SCE	3000	C		5400	5400													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
423481		ELDRADO	CIRCUIT BREAKER BAYER- COOL WATER DRAIN SINKING- HWT PASS 115 VV/CB	CB	115	AMPS	Fri May 28 09 19 23 2000 P01	SCE	SCE	1,200	C		2,160	2,160													0004 TRANSMISSION LINE/FACILITY RECONFIGURED (PHYSICALLY CHANGED)	
1721176		ELDRADO	BANK LEADS, 1,405 MCM (BANK 1A)	COND	230	AMPS	Fri May 28 09 16 26 2000 P01	SCE	SCE	825	C		960	1,100													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
1721404		ELDRADO	BANK LEADS, 2,2156 MCM (BANK 3A)	COND	230	AMPS	Fri May 28 09 16 35 2000 P01	SCE	SCE	3100	C		4260	5000													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	
1721496		ELDRADO	BANK LEADS, 2,2156 MCM (BANK 3A)	COND	500	AMPS	Fri May 26 09 16 36 2000 P01	SCE	SCE	3700	C		4260	5000													0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	

1721456	ELDORADO	BREAKER TO DISCONNECT LEADS 2 2156 MCM 6112 TO	COND	230 AMPS	Fri May 26 09 16 35	2000 PDT	3700 C	4260 C	3700 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	5000 C	4260 C	5000 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
2434767	ELDORADO	BREAKER TO DISCONNECT LEADS 2 2156 MCM, 782 TO	COND	500 AMPS	Mon Dec 18 09 03 07	2000 PST	3700 C	4260 C	3700 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	5000 C	4260 C	5000 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415555	ELDORADO	BREAKER TO DISCONNECT LEADS 2 2156 MCM, 782 TO	COND	500 AMPS	Fri May 26 09 35 44	2000 PDT	3700 C	4260 C	3700 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	5000 C	4260 C	5000 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415815	ELDORADO	BREAKER TO DISCONNECT LEADS 2 2156 MCM, 862 TO	COND	500 AMPS	Fri May 26 09 35 46	2000 PDT	3700 C	4260 C	3700 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	5000 C	4260 C	5000 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415917	ELDORADO	BREAKER TO DISCONNECT LEADS 2 2156 MCM, 812 TO	COND	500 AMPS	Fri May 26 09 35 50	2000 PDT	3700 C	4260 C	3700 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	5000 C	4260 C	5000 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415641	ELDORADO	BREAKER TO DISCONNECT LEADS 2 2156 MCM, 862 TO	COND	500 AMPS	Tue Aug 15 11 34 36	2000 PDT	3700 C	4260 C	3700 C	SCE	SCE	SCE	0006 CORRECTED A DATA INPUT ERROR	5000 C	4260 C	5000 C	DESCRIPTION ERROR
415665	ELDORADO	BREAKER TO DISCONNECT LEADS 2 2156 MCM, 862 TO	COND	500 AMPS	Fri May 26 09 35 49	2000 PDT	3700 C	4260 C	3700 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	5000 C	4260 C	5000 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415218	ELDORADO	BREAKER TO DISCONNECT LEADS 2 2156 MCM, 812 TO	COND	500 AMPS	Fri May 26 09 35 43	2000 PDT	3700 C	4260 C	3700 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	5000 C	4260 C	5000 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
1719381	ELDORADO	MCM SOUTH BUS CONDUCTORS 3-2156	COND	230 AMPS	Fri May 26 09 16 06	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	7500 C	6390 C	7500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
425465	ELDORADO	BUS CONDUCTORS, 1 1033 MCM 1A BANK BUS	COND	115 AMPS	Tue Oct 03 07 54 06	2000 PDT	1150 C	1325 C	1150 C	SCE	SCE	SCE	0008 CORRECTED A DATA INPUT ERROR	1575 C	1325 C	1575 C	DESCRIPTION ERROR
397216	ELDORADO	MCM 1A BANK BUS CONDUCTORS 3-2156	COND	230 AMPS	Fri May 26 09 21 39	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	7500 C	6390 C	7500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415575	ELDORADO	MCM, NORTH BUS CONDUCTORS 3-2156	COND	500 AMPS	Fri May 26 09 21 41	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	7500 C	6390 C	7500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415231	ELDORADO	MCM, SOUTH BUS CONDUCTORS, 3-2156	COND	500 AMPS	Fri May 26 09 21 41	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	7500 C	6390 C	7500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415578	ELDORADO	2156 MCM NORTH BUS TO 781	COND	500 AMPS	Fri May 26 09 42 46	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	7500 C	6390 C	7500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
425468	ELDORADO	BUS TO DISCONNECT LEADS, 1A BANK 115 HV ISOLATING	COND	115 AMPS	Tue Oct 03 07 54 07	2000 PDT	1150 C	1325 C	1150 C	SCE	SCE	SCE	0008 CORRECTED A DATA INPUT ERROR	1575 C	1325 C	1575 C	PHYSICALLY UNCHANGED)
1721464	ELDORADO	BUS TO DISCONNECT LEADS, 1256 MCM, NORTH BUS TO DISCONNECT (BANK 1A)	COND	230 AMPS	Fri May 26 09 16 35	2000 PDT	1850 C	2130 C	1850 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	2500 C	2130 C	2500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
2942433	ELDORADO	BUS TO DISCONNECT LEADS 2 2156 MCM, NORTH BUS TO	COND	230 AMPS	Fri Jan 28 13 45 05	2001 PST	3700 C	4260 C	3700 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	5000 C	4260 C	5000 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
1721384	ELDORADO	BUS TO DISCONNECT LEADS 2 2156 MCM, NORTH BUS TO	COND	230 AMPS	Fri May 26 09 16 34	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	7500 C	6390 C	7500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
400480	ELDORADO	BUS TO DISCONNECT LEADS 2 2156 MCM, NORTH BUS TO	COND	230 AMPS	Fri May 26 09 42 43	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	7500 C	6390 C	7500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
400604	ELDORADO	3-2156 MCM NORTH BUS TO BUS TO DISCONNECT LEADS,	COND	230 AMPS	Fri May 26 09 42 45	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	7500 C	6390 C	7500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
1721424	ELDORADO	BUS TO DISCONNECT LEADS, 2 2156 MCM, NORTH BUS TO	COND	230 AMPS	Fri May 26 09 16 35	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	7500 C	6390 C	7500 C	PHYSICALLY UNCHANGED)
1721498	ELDORADO	BUS TO DISCONNECT LEADS, 2 2156 MCM, NORTH BUS TO	COND	500 AMPS	Fri May 26 09 16 36	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	7500 C	6390 C	7500 C	PHYSICALLY UNCHANGED)
2434753	ELDORADO	BUS TO DISCONNECT LEADS, 3-2156 MCM, NORTH BUS TO	COND	500 AMPS	Mon Dec 18 09 03 04	2000 PST	5550 C	6390 C	5550 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	7500 C	6390 C	7500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415798	ELDORADO	BUS TO DISCONNECT LEADS, 2 2156 MCM, NORTH BUS TO	COND	500 AMPS	Tue Aug 15 11 34 38	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0008 CORRECTED A DATA INPUT ERROR	7500 C	6390 C	7500 C	DESCRIPTION ERROR
415901	ELDORADO	BUS TO DISCONNECT LEADS, 2 2156 MCM, NORTH BUS TO	COND	500 AMPS	Tue Aug 15 11 34 41	2000 PDT	5550 C	6390 C	5550 C	SCE	SCE	SCE	0008 CORRECTED A DATA INPUT ERROR	7500 C	6390 C	7500 C	DESCRIPTION ERROR
1721488	ELDORADO	DISCONNECT TO BANK RISER LEADS, 1-2156 MCM (BANK1A)	COND	230 AMPS	Fri May 26 09 16 35	2000 PDT	1850 C	2130 C	1850 C	SCE	SCE	SCE	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	2500 C	2130 C	2500 C	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)

1721396	ELDORADO	DISCONNECT TO BANK RISER LEADS 2 2156 MCM 4073 TO 4073/6071 BANK RISER	COND	230	AMPS	Fri May 26 09 16 34 2000 PDT	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
1721436	ELDORADO	DISCONNECT TO BANK RISER LEADS 2 2156 MCM 4113 TO 4113/6111 BANK RISER	COND	230	AMPS	Fri May 26 09 16 35 2000 PDT	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
1721500	ELDORADO	DISCONNECT TO BANK RISER LEADS 2 2156 MCM 741 TO BANK RISER	COND	500	AMPS	Fri May 26 09 16 36 2000 PDT	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
425477	ELDORADO	DISCONNECT TO BREAKER LEADS 1-1003 MCM 1A BANK 115 KV ISOLATING DISC TO BANK RISER	COND	115	AMPS	Tue Oct 03 07 54 09 2000 PDT	1150	1325	1575	0008 CORRECTED A DATA INPUT ERROR (REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
1721308	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 4071 TO 4072	COND	230	AMPS	Fri May 26 09 16 34 2000 PDT	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
1721428	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 4111 TO 4112	COND	230	AMPS	Fri May 26 09 16 35 2000 PDT	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
2042440	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 4011 TO 4012	COND	230	AMPS	Fri Jan 26 13 45 09 2000 PDT	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
400524	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 5001 TO 5002	COND	230	AMPS	Fri May 26 09 35 34 2000 PDT	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
400546	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 6011 TO 6012	COND	230	AMPS	Fri May 26 09 35 40 2000 PDT	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
1721412	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 6071 TO 6072	COND	230	AMPS	Fri May 26 09 16 35 2000 PDT	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
400564	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 6091 TO 6092	COND	230	AMPS	Fri May 26 09 35 36 2000 PDT	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
400608	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 6101 TO 6102	COND	230	AMPS	Fri May 26 09 35 42 2000 PDT	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
1721452	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 6111 TO 6112	COND	230	AMPS	Fri May 26 09 16 35 2000 PDT	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
2434760	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 751 TO 752	COND	500	AMPS	Tue Aug 15 11 34 40 2000 PST	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
415907	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 761 TO 762	COND	500	AMPS	Tue Aug 15 11 34 43 2000 PDT	3700	4260	5000	0008 CORRECTED A DATA INPUT ERROR (REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
415908	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 771 TO 772	COND	500	AMPS	Tue Aug 15 11 34 43 2000 PDT	3700	4260	5000	0008 CORRECTED A DATA INPUT ERROR (REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
415957	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 781 TO 782	COND	500	AMPS	Fri May 26 09 35 43 2000 PDT	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
415958	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 791 TO 792	COND	500	AMPS	Fri May 26 09 35 45 2000 PDT	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
2434793	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 881 TO 882	COND	500	AMPS	Mon Dec 18 09 03 12 2000 PST	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
415957	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 961 TO 962	COND	500	AMPS	Fri May 26 09 35 48 2000 PDT	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED
415958	ELDORADO	DISCONNECT TO BREAKER LEADS 2 2156 MCM 971 TO 972	COND	500	AMPS	Fri May 26 09 35 51 2000 PDT	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	PHYSICALLY UNCHANGED	PHYSICALLY UNCHANGED

2042490	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 6013 TO SOUTH 2001 PST	230	AMPS	Fri Jan 26 13 45 32	SCE	SCE	3700	C	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
1121470	ELDORADO	DISCONNECT TO BUS LEADS, BUS 3 2156 MCM 8073 TO SOUTH 2000 PDT	230	AMPS	Fri May 26 09 16 35	SCE	SCE	5550	C	6390	7500	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
400580	ELDORADO	DISCONNECT TO BUS LEADS, BUS 1 2156 MCM 8093 TO SOUTH 2000 PDT	230	AMPS	Fri May 26 09 42 44	SCE	SCE	5550	C	6390	7500	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
400704	ELDORADO	DISCONNECT TO BUS LEADS, BUS 3 2156 MCM 8103 TO SOUTH 2000 PDT	230	AMPS	Fri May 26 09 42 45	SCE	SCE	5550	C	6390	7500	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
1121460	ELDORADO	DISCONNECT TO BUS LEADS, BUS 3 2156 MCM 6113 TO SOUTH 2000 PDT	230	AMPS	Fri May 26 09 16 35	SCE	SCE	5550	C	6390	7500	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
1121492	ELDORADO	DISCONNECT TO BUS LEADS, BUS 3 2156 MCM 933 TO SOUTH 2000 PDT	500	AMPS	Fri May 26 09 16 36	SCE	SCE	5550	C	6390	7500	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
2434807	ELDORADO	DISCONNECT TO BUS LEADS, BUS 3 2156 MCM 933 TO SOUTH 2000 PDT	500	AMPS	Mon Dec 18 09 03 15	SCE	SCE	5550	C	6390	7500	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
415973	ELDORADO	DISCONNECT TO BUS LEADS, BUS 3 2156 MCM 863 TO SOUTH 2000 PDT	500	AMPS	Fri May 26 09 42 48	SCE	SCE	5550	C	6390	7500	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
415227	ELDORADO	DISCONNECT TO BUS LEADS, BUS 3 2156 MCM 873 TO SOUTH 2000 PDT	500	AMPS	Fri May 26 09 42 48	SCE	SCE	5550	C	6390	7500	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415448	ELDORADO	DISCONNECT TO BUS LEADS, BUS 3 2156 MCM 883 TO SOUTH 2000 PDT	500	AMPS	Tue Aug 15 11 34 37	SCE	SCE	5550	C	6390	7500	0008 CORRECTED A DATA INPUT ERROR DESCRIPTION ERROR
425483	ELDORADO	DISCONNECT TO BUS LEADS, BUS 3 2156 MCM 893 TO SOUTH 2000 PDT	115	AMPS	Fri May 26 09 19 26	SCE	SCE	1150	C	1325	1575	0004 TRANSMISSION LINE FACILITY RECONFIGURED (PHYSICALLY CHANGED)
400504	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 4093 TO 2000 PDT	230	AMPS	Fri May 26 09 35 33	SCE	SCE	3700	C	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
400828	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 4103 TO 2000 PDT	230	AMPS	Fri May 26 09 35 39	SCE	SCE	3700	C	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
400540	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 5093 TO 2000 PDT	230	AMPS	Wed Sep 07 07 55 29	SCE	SCE	3700	C	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
397278	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 5093 TO 2000 PDT	230	AMPS	Fri May 26 09 35 26	SCE	SCE	3700	C	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
400664	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 5103 TO 2000 PDT	230	AMPS	Wed Sep 06 07 55 32	SCE	SCE	3700	C	4260	5000	0008 CORRECTED A DATA INPUT ERROR
415903	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 783 TO 2000 PDT	500	AMPS	Fri May 26 09 35 44	SCE	SCE	3700	C	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
2434774	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 853 TO 2000 PST	500	AMPS	Mon Dec 18 09 03 09	SCE	SCE	3700	C	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
415923	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 863 TO 2000 PDT	500	AMPS	Fri May 26 09 35 47	SCE	SCE	3700	C	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415925	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 873 TO 2000 PDT	500	AMPS	Fri May 26 09 35 50	SCE	SCE	3700	C	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
425497	ELDORADO	DISCONNECT TO BUS LEADS, BUS 1 1033 MCM 2000 PDT	115	AMPS	Tue Oct 07 04 11	SCE	SCE	1240	C	1425	1675	0008 CORRECTED A DATA INPUT ERROR
397240	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 2000 PST	230	AMPS	Tue Jan 11 12 01 23	SCE	SCE	3950	C	4540	5330	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
397486	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 2000 PST	230	AMPS	Tue Jan 11 12 01 28	SCE	SCE	3950	C	4540	5330	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)
2042490	ELDORADO	DISCONNECT TO BUS LEADS, BUS 2 2156 MCM 2001 PST	230	AMPS	Fri Jan 26 13 45 18	SCE	SCE	3950	C	4540	5330	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)

400244	ELDORADO	COND	230	AMP	Wd	54	06	07	55	30	3950	4540	5330	0008 CORRECTED A DATA INPUT ERROR
415507	ELDORADO	COND	500	AMP	Fr	12	26	09	42	04	3950	4540	5330	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
400666	ELDORADO	COND	230	AMP	Wd	54	06	07	55	33	3950	4540	5330	0008 CORRECTED A DATA INPUT ERROR
415827	ELDORADO	COND	500	AMP	Fr	12	26	09	42	04	3950	4540	5330	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
2434778	ELDORADO	COND	500	AMP	Mon	Dec	18	09	03	09	3950	4540	5330	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)
400640	ELDORADO	COND	230	AMP	Fr	12	26	09	35	39	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
2042498	ELDORADO	COND	230	AMP	Fr	12	26	09	42	22	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)
307294	ELDORADO	COND	230	AMP	Fr	12	26	09	35	28	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
307534	ELDORADO	COND	230	AMP	Fr	12	26	09	35	31	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
2434786	ELDORADO	COND	500	AMP	Mon	Dec	18	09	03	11	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)
1878523	ELDORADO	COND	500	AMP	Tue	Aug	15	11	34	25	3700	4260	5000	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)
415848	ELDORADO	COND	500	AMP	Fr	12	26	09	35	47	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
415941	ELDORADO	COND	500	AMP	Fr	12	26	09	35	51	3700	4260	5000	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
423501	ELDORADO	COND	115	AMP	Tue	Oct	07	54	12	12	415	475	510	0008 CORRECTED A DATA INPUT ERROR
307250	ELDORADO	COND	230	AMP	Tue	Jan	11	12	01	24	725	725	725	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)
307480	ELDORADO	COND	230	AMP	Thu	Jan	11	12	01	29	725	725	725	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)
400522	ELDORADO	COND	230	AMP	Fr	12	26	09	17	37	2480	2850	3350	0003 FACILITY DESCRIPTION CHANGED
400676	ELDORADO	COND	230	AMP	Fr	12	26	09	17	37	2480	2850	3350	0003 FACILITY DESCRIPTION CHANGED
415825	ELDORADO	COND	500	AMP	Fr	12	26	09	41	59	3070	4320	4320	0006 REVISED RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
2434782	ELDORADO	COND	500	AMP	Mon	Dec	18	09	03	10	3950	4540	5330	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)
415845	ELDORADO	COND	500	AMP	Fr	12	26	09	17	37	3950	4540	5330	0003 FACILITY DESCRIPTION CHANGED
415837	ELDORADO	COND	500	AMP	Fr	12	26	09	16	07	3100	4320	4320	DELETED
2042494	ELDORADO	COND	230	AMP	Fr	12	26	13	45	20	1800	2280	2670	0001 PST
415821	ELDORADO	DISC	500	AMP	Fr	12	26	09	18	10	3000	3000	3000	0000

3227001	MOHAVE	CIRCUIT BREAKER 852	CB	500	AMPS	2000	PT	Mon Mar 26 09 03 34	SCE	SCE	3000	C	5400	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	415272	MOHAVE	CIRCUIT BREAKER 862	CB	500	AMPS	2000	PT	Thu Mar 27 08 09 29	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3227010	MOHAVE	INSUR TO RES MAIN BUS	2001	PT	Mon Mar 26 09 03 36	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	415295	MOHAVE	BREAKER TO DISCONNECT LEADS, 2 2156 MCM 752 TO 732	COND	500	AMPS	2001	PT	Fri Mar 26 09 38 49	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3227068	MOHAVE	BREAKER TO DISCONNECT LEADS, 2 2156 MCM 762 TO 763	COND	500	AMPS	2000	PT	Mon Mar 26 09 03 04	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	415231	MOHAVE	BREAKER TO DISCONNECT LEADS, 2 2156 MCM 802 TO 803	COND	500	AMPS	2001	PT	Thu Aug 15 11 34 26	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3227117	MOHAVE	BREAKER TO DISCONNECT LEADS, 2 2156 MCM 882 TO 883	COND	500	AMPS	2000	PT	Thu Mar 27 08 09 36	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3231970	MOHAVE	MCM EAST BUS	COND	500	AMPS	2001	PT	Mon Mar 26 09 03 15	SCE	SCE	5590	C	6390	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	415278	MOHAVE	BUS TO DISCONNECT LEADS, 2 2156 MCM EAST BUS TO 731	COND	500	AMPS	2001	PT	Fri Mar 26 09 38 48	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	415239	MOHAVE	BUS TO DISCONNECT LEADS, 2 2156 MCM EAST BUS TO 711	COND	500	AMPS	2000	PT	Thu Aug 15 11 34 25	SCE	SCE	5590	C	6390	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3231981	MOHAVE	DISCONNECT TO BREAKER LEADS, 2 2156 MCM 751 TO 752	COND	500	AMPS	2001	PT	Mon Mar 26 09 03 20	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3237881	MOHAVE	DISCONNECT TO BREAKER LEADS, 2 2156 MCM 721 TO 722	COND	500	AMPS	2001	PT	Thu Mar 27 08 09 19	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3237036	MOHAVE	DISCONNECT TO BREAKER LEADS, 2 2156 MCM 731 TO 732	COND	500	AMPS	2001	PT	Mon Mar 26 09 03 48	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	415287	MOHAVE	DISCONNECT TO BREAKER LEADS, 2 2156 MCM 761 TO 762	COND	500	AMPS	2000	PT	Fri Mar 26 09 38 48	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3232071	MOHAVE	DISCONNECT TO BREAKER LEADS, 2 2156 MCM 821 TO 822	COND	500	AMPS	2001	PT	Wed Mar 28 09 48 16	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3232081	MOHAVE	DISCONNECT TO BREAKER LEADS, 2 2156 MCM 831 TO 832	COND	500	AMPS	2001	PT	Mon Mar 26 09 04 00	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	3232091	MOHAVE	DISCONNECT TO BREAKER LEADS, 2 2156 MCM 831 TO 832	COND	500	AMPS	2001	PT	Mon Mar 26 09 03 32	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)	415273	MOHAVE	DISCONNECT TO BREAKER LEADS, 2 2156 MCM 851 TO 852	COND	500	AMPS	2000	PT	Fri May 29 09 38 51	SCE	SCE	3700	C	4260	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTER)	PHYSICALLY UNCHANGED)	REVISD RATINGS (EQUIPMENT PHYSICALLY UNCHANGED)
---------	--------	---------------------	----	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	--------	--------	---------------------	----	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	-----------------------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	--------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	--------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	--------------	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	--------	--------	---	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	--------	--------	---	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	--------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	---------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---	--------	--------	--	------	-----	------	------	----	---------------------	-----	-----	------	---	------	--	-----------------------	---

416543	MOHAVE	DISCONNECT 711	DISC	500	AMPS	2000	PT	Fri May 26 09 18 14	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0003 FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
327678	MOHAVE	DISCONNECT 721	DISC	500	AMPS	2001	PST	Tue Mar 27 08 09 17	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
327692	MOHAVE	DISCONNECT 723	DISC	500	AMPS	2001	PST	Tue Mar 27 08 09 24	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
322033	MOHAVE	DISCONNECT 731	DISC	500	AMPS	2001	PST	Mon Mar 28 09 03 46	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
327178	MOHAVE	DISCONNECT 751	DISC	500	AMPS	2001	PST	Mon Mar 28 09 03 18	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
327667	MOHAVE	DISCONNECT 753	DISC	500	AMPS	2001	PST	Tue Mar 27 08 09 12	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
415283	MOHAVE	DISCONNECT 761	DISC	500	AMPS	2000	PT	Fri May 26 10 09 09	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
415296	MOHAVE	DISCONNECT 763	DISC	500	AMPS	2000	PT	Fri May 26 10 09 09	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
327711	MOHAVE	DISCONNECT 821	DISC	500	AMPS	2001	PST	Tue Mar 27 08 09 33	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
323058	MOHAVE	DISCONNECT 831	DISC	500	AMPS	2001	PST	Mon Mar 28 09 03 58	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
323000	MOHAVE	DISCONNECT 851	DISC	500	AMPS	2001	PST	Mon Mar 28 09 03 30	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
415318	MOHAVE	DISCONNECT 861	DISC	500	AMPS	2000	PT	Fri May 26 10 09 10	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0010 RATING REPEITION (REMOVED EMERGENCY RATINGS IDENTICAL TO NORMAL RATINGS)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
323721	MOHAVE	DISCONNECT 923	DISC	500	AMPS	2001	PST	Tue Mar 27 08 09 38	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
323072	MOHAVE	DISCONNECT 933	DISC	500	AMPS	2001	PST	Mon Mar 28 09 04 05	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
416545	MOHAVE	DISCONNECT 943 BUS DISC	DISC	500	AMPS	2000	PT	Fri May 26 09 18 15	1600	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	2880	1	0003 FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
3232014	MOHAVE	DISCONNECT 953	DISC	500	AMPS	2001	PST	Mon Mar 28 09 03 37	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
416335	MOHAVE	DISCONNECT 863	DISC	500	AMPS	2000	PT	Tue Aug 15 11 34 27	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0008 CORRECTED A DATA INPUT ERROR (REGISTRY)	DESCRIPTION ERROR
4165310	MOHAVE	DISCONNECT, CAP DISC	DISC	500	AMPS	2000	PT	Fri Dec 19 00 00 00	1600	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5330	1	0009 DELETED DUPLICATE FACILITY ENTRY	DESCRIPTION ERROR
4165310	MOHAVE	DISCONNECT, CAP LINE DISC	DISC	500	AMPS	1997	PST	Fri Dec 19 00 00 00	1600	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	2880	1	0009 DELETED DUPLICATE FACILITY ENTRY	DESCRIPTION ERROR
3232047	MOHAVE	DISCONNECT 733	DISC	500	AMPS	2001	PST	Mon Mar 28 09 03 53	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5400	1	0002 FACILITY ADDED (FACILITY PREVIOUSLY EXISTING BUT NOT IN REGISTRY)	DESCRIPTION ERROR
415993	MOHAVE	711 - EAST PATH	LEG	500	AMPS	2000	PT	Fri Aug 18 16 17 28	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	3210	1	0008 CORRECTED A DATA INPUT ERROR (REGISTRY)	RATING REPETITION
41207	MOHAVE	702 - EAST PATH	LEG	500	AMPS	2000	PT	Fri Aug 18 16 11 37	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	3000	1	0008 CORRECTED A DATA INPUT ERROR	RATING REPETITION
419271	MOHAVE	802 - WEST PATH	LEG	500	AMPS	2000	PT	Fri Aug 18 16 17 25	3000	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	5000	1	0008 CORRECTED A DATA INPUT ERROR	RATING REPETITION & B RATING
416445	MOHAVE	913 - WEST PATH	LEG	500	AMPS	2000	PT	Tue Aug 17 08 12 36	1600	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	2140	0.5	0008 CORRECTED A DATA INPUT ERROR	CORRECTED DURATION
416335	MOHAVE	SHUNT REACTOR, MVAR	RCT	500	MVAR	2000	PT	Fri May 26 09 18 30	100	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	2140	0.5	0003 FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)	FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
416527	MOHAVE	SERIES CAPACITOR (282	SCAP	500	AMPS	2000	PT	Tue Aug 17 08 12 39	1600	C	SCE	SCE	SCE	SCE	SCE	SCE	SCE	SCE	2140	0.5	0008 CORRECTED A DATA INPUT ERROR	CORRECTED DURATION

415255	MOHAVE	WAVE TRAP (ELDORADO)	WTRP	500 AMPS Fm May 26 09 18 59 2000 PWT	SCE	SCE	3000 C	3210	1	0003 FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED)
415511	MOHAVE	WAVE TRAP (UGO)	WTRP	500 AMPS Fm May 26 10 21 31 2000 PWT	SCE	SCE	3000 C	3210		0010 RATING REPTITION (REMOVED EMERGENCY RATINGS IDENTICAL TO NORMAL RATINGS) 0003 FACILITY DESCRIPTION CHANGED (PHYSICALLY UNCHANGED) REPTITION (REMOVED EMERGENCY RATINGS IDENTICAL TO NORMAL RATINGS)

Record ID	Update Station Name	Description	Type	KV	Units	From	To	Owner	Operator	N Rating	N Duration	A Rating	A Duration	B Rating	B Duration	C Rating	C Duration	D Rating	D Duration	E Rating	E Duration	F Rating	F Duration	Non-ISO Equipment Change Category	Reason		
37878		50001 Miguel Imperial Valley	TL	500	amps	1998 PST	00 00 00	SDGE	SDGE	1232 C																	
		50002 Imperial Valley	TL	500	amps	1997 PST	00 00 00	SDGE	SDGE	1400 C																	
37882		50002 Imperial Valley	TL	500	amps	1997 PST	00 00 00	SDGE	SDGE	1400 C																	
37874		50001 Palo Verde N Gilva	TL	500	amps	1997 PST	00 00 00	SDGE	SDGE	1400 C																	

