



Exceptional Dispatch Report

Table 2: May 2019

Market Quality and Renewable Integration

August 30, 2019

TABLE OF CONTENTS

Introduction	3
The Nature of Exceptional Dispatch.....	3
Appendix A: Explanation by Example	26
Example 1: Exceptional Dispatch Instructions Prior to DAM	26
Example 2: Incremental Exceptional Dispatch Instructions in RTM.....	26
Example 3: Decremental Exceptional Dispatch Instructions in RTM	28
Appendix B: Price Impact Analysis	30
Appendix C: Exceptional Dispatch Bid Mitigation Analysis	38

LIST OF TABLES AND FIGURES

Table 1: Exceptional Dispatches in May 2019	7
Table 2: Instructions Prior to Day-Ahead Market	26
Table 3: FERC Summary of Instructions Prior to DAM	26
Table 4: Incremental Exceptional Dispatch Instructions in RTM	27
Table 5: FERC Summary of ED Instructions in RTM	28
Table 6: Decremental Exceptional Dispatch Instructions in RTM	28
Table 7: FERC Summary of Decremental ED Instructions in RTM.....	29
Table 8: Price Impact Analysis Information for Pricing Node A in PG&E LAP	31
Table 9: Price Impact Analysis Information for Pricing Node B in SCE LAP	33
Table 10: Bid Mitigation Analysis for May 2019	38

Introduction

This report is filed pursuant to FERC's September 2, 2009, and May 4, 2010, orders in ER08-1178. These orders require two monthly Exceptional Dispatch reports—one issued on the 15th of each month and one issued on the 30th of each month. This report provides data on the frequency, reasons and costs for Exceptional Dispatches issued in May 2019.

This report contains a price impact analysis as prescribed by FERC in its September 2 order. The price impact analysis for the month of May is presented in Appendix B. This report also includes mitigation analysis for May 2019 required by section 34.11.4 of the CAISO tariff. This analysis compares those Exceptional Dispatches subject to bid mitigation (i.e. Exceptional Dispatches to address noncompetitive constraints and Delta Dispatch), and determines the cost difference between the Exceptional Dispatch bid mitigation settlement rules and what the settlement amount would have been had the Exceptional Dispatches not been subject to bid mitigation. The Exceptional Dispatch bid mitigation analysis for May is presented in Appendix C.

The Nature of Exceptional Dispatch

The CAISO can issue exceptional dispatch instructions for a resource as a pre-day-ahead unit commitment, a post day-ahead unit commitment or a real-time exceptional dispatch. A pre-day-ahead unit commitment is an exceptional dispatch instruction committing a resource at or above its physical minimum (Pmin) operating level in the day-ahead market. A post-day-ahead unit commitment is an exceptional dispatch instruction committing a resource at or above its (Pmin) operating level in the real-time market. A real-time exceptional dispatch instructs a resource to operate at or above its physical minimum operating point. A real-time exceptional dispatch above the resource's day-ahead award is an incremental exceptional dispatch instruction and a real-time exceptional dispatch below the day-ahead award is considered a decremental dispatch instruction. The CAISO issues exceptional dispatch instructions to maintain the reliability of the grid when the market software cannot do so. Whenever the CAISO issues an exceptional dispatch instruction, the operator logs the dispatch and the associated reason. Reliability requirements are calculated for both local area and the system wide needs, and are classified into various requirements including local generation, transmission management, non-modeled transmission outages, ramping and inertia emergency assistance. Whenever the CAISO issues an exceptional dispatch instruction, the operators log these instructions and the associated reason for each instruction.

Most of the generation procedures are internal to the CAISO and not available publicly on the CAISO website; however, all of the transmission procedures are available on the CAISO website.¹

Additional reasons for exceptional dispatch instructions in 2019 include Software Limitation. Software Limitation is used when an exceptional dispatch instruction was issued to bridge schedules across days for resources with a minimum down time of 24 hours, as the CAISO software does not handle multi-day commitment. For instance, a resource has a day-ahead schedule from 0600 till 2300, and then is shut down in 2400. If this resource had a minimum down time of 24 hours and it is required the following day, then the CAISO issues an exceptional dispatch to commit this resource in 2400 so it can be dispatched economically in the following day. Software Limitation was also used for exceptional dispatches to manually issue shut down instructions to a resource because of a temporary Automatic Dispatch System (“ADS”) failure, or similar issues. Interconnection Reliability Operating Limits (IROL) are system operating limits that are established to prevent instability, uncontrolled separation or cascading as described in operating procedure 3100. System Operating Limit (SOL) are the facility ratings, system voltage limits, transient stability limits, and voltage stability limits that are used in the operating horizon – any of which can be the most restrictive limit at any point in time, pre – or post – contingency. Control Point (CP) are imposed to protect the area transmission network against N – 1 contingencies. There were a few other reasons used to explain exceptional dispatch instructions in May, which are self-explanatory.

The data in Table 1 is based on a template specified in the September 2009 order.² This table contains all the information published in Table 1 of the first report for May 2019. In addition, it contains volume (MWh) and cost information. Each entry in Table 1 is a summary of exceptional dispatches classified by (1) the reason for the exceptional dispatch; (2) the location of the resource by Participating Transmission Owner (PTO) service area; (3) the Local Reliability Area (LRA) where applicable; (4) the market in which the exceptional dispatch occurred (day-ahead vs. real-time); and (5) the date of the exceptional dispatch. For each classification the following information is provided: (1) Megawatts (MW); (2) Commitment; (3) Inc or Dec; (4) Hours; (5) Begin Time; (6) End Time; (7) Total Volume (MWh); (8) Min Load Cost; (9) Start Up Cost; (10) CC6470; (11) ED Volume (MWh INC/DEC); (12) CC6470 INC; (13) CC6470 DEC; (14) CC6482; (15) CC6488; and (16) CC6620. Each column is defined:

¹ A list of all of the CAISO’s Operating Procedures and all the publicly available Operating Procedures are available at the following link:
<http://www.caiso.com/thegrid/operations/opsdoc/index.html>

² The data in Table 1 is principally SLIC information supplemented with data from the Market Quality System (MQS) and Settlements database. The volume and cost information is based on t+51B Recalculation Statements.

- The MW column shows the range of exceptional dispatch instruction in MW for the classification.
- The Commitment column specifies if there was a unit commitment for the classification.
- The INC/DEC/NA column specifies if there was an incremental dispatch (INC), a decremental dispatch (DEC), or only a unit commitment (NA). The Begin Time and End Time columns show the start and end time of exceptional dispatch for the classification respectively.
- The Hours column is the time difference between begin time and end time rounded up to the next hour.
- The total volume column shows the total MWh dispatch quantity dispatched for that classification. This quantity includes the minimum load quantity, the imbalance energy quantity, and the exceptional dispatch quantity.
- The Min-Load Cost column shows eligible minimum load cost for the classification.
- The Start-Up Cost column shows the eligible start up cost for the classification. The CAISO does not explicitly pay resources for its start up and minimum load costs; however, it ensures that resources are compensated adequately through its bid cost recovery.³
- The CC6470 column shows the total imbalance energy costs for the classification. This cost contains the portion of exceptional dispatch instruction settled as optimal energy due to its bid price being less than the LMP in the relevant settlement interval.
- The ED Volume MWh (MWh INC/DEC) column shows the incremental or the decremental portion of the real-time exceptional dispatch MWh for the classification. The CC6470-INC shows that portion of incremental exceptional dispatch instruction settled at the resource LMP.
- The CC6470-DEC column shows that portion of decremental exceptional dispatch instruction settled at the resource specific LMP. Both these charge codes are portions of the real-time instructed imbalance energy charge code (6470).⁴
- The CC6482 column shows the real-time excess cost for the classification.⁵
- The CC6488 column shows the real-time exceptional dispatch uplift settlement for the classification.⁶ The CC6620 shows the bid cost recovery payment for the classification. This cost is shown for all pre-day-ahead unit commitments only.

³ For further details regarding the Bid Cost Recovery process please refer to section 11.8 of the CAISO tariff.

⁴ For further details please refer to the BPM configuration Guide: Real-Time Instructed Imbalance Energy Settlement published on the CAISO's website.

⁵ For further details please refer to the BPM configuration Guide: Real Time Excess Cost for Instructed Energy Settlement published on the CAISO's website.

⁶ For further details please refer to the BPM configuration Guide: Real Time Exceptional Dispatch Uplift Settlement published on the CAISO's website.

Charge codes 6470, 6470 INC, 6470 DEC, 6482 and 6488 are shown in Table 1 because all these charge codes pertain to real-time exceptional dispatch MWH quantities. The classification of data is further explained for example in Attachment A.

Table 1: Exceptional Dispatches in May 2019

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
1	RT	Fast Start Unit Management	SCE	LA Basin	5/31/2019	0	No	INC	1	23:15	23:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	RT	Fast Start Unit Management	SDGE	San Diego-IV	5/15/2019	23	No	INC	5	16:10	21:00	-35.63	8688.66	749.53	-1635.64	0.30	-18.42	0.00	0.00	0.00	0.00
3	RT	Fire Threats	SDGE	San Diego-IV	5/15/2019	50 - 300	No	INC	7	14:45	21:00	88.91	83578.15	614.56	-53198.57	91.31	-3475.77	0.00	-15232.42	0.00	0.00
4	RT	Load Pull	PGAE	Fresno	5/31/2019	83	No	INC	1	5:30	5:45	-7.04	0.00	0.00	224.10	0.00	0.00	0.00	0.00	0.00	0.00
5	RT	Market Disruption	PGAE	Fresno	5/2/2019	0	No	INC	1	21:00	22:00	-38.04	2405.66	0.00	0.00	-38.04	0.00	0.00	0.00	0.00	0.00
6	RT	Market Disruption	PGAE	Fresno	5/21/2019	83 - 407	No	INC	2	18:20	20:00	121.72	9355.34	0.00	-82423.67	3.32	-30.71	0.00	-114.41	0.00	0.00
7	RT	Market Disruption	SCE	LA Basin	5/2/2019	200	No	INC	2	20:50	22:00	-225.71	15639.05	0.00	4044.44	0.00	0.00	0.00	0.00	0.00	0.00
8	RT	Market Disruption	SCE	NA	5/2/2019	470	No	DEC	1	20:55	21:05	-19.22	-10.92	0.00	218.10	-19.00	0.00	213.64	0.00	0.00	0.00
9	RT	Market Disruption	SCE	NA	5/2/2019	0	No	INC	4	20:45	0:00	-60.79	3334.49	0.00	-114.69	-65.65	0.00	0.00	0.00	0.00	0.00
10	RT	Market Disruption	SCE	NA	5/3/2019	0	No	INC	3	0:00	2:10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	RT	Operating Procedure Number and Constraint (7110)	PGAE	Humboldt	5/8/2019	32	No	INC	14	6:30	20:00	83.38	-8302.66	0.00	-3845.31	34.40	-1469.88	0.00	0.00	0.00	0.00
12	RT	Operating Procedure Number and Constraint (7110)	PGAE	Humboldt	5/9/2019	14 - 32	No	INC	18	6:15	0:00	27.83	-3183.44	0.00	-921.28	12.11	-459.65	0.00	0.00	0.00	0.00
13	RT	Operating Procedure Number and Constraint (7110)	PGAE	Humboldt	5/20/2019	14 - 32	No	INC	18	6:50	0:00	64.31	0.00	0.00	-1518.61	14.92	-343.08	0.00	0.00	0.00	0.00
14	RT	Operating Procedure Number and Constraint (7110)	PGAE	Humboldt	5/21/2019	16 - 32	No	INC	24	0:00	0:00	49.88	0.00	0.00	-539.69	10.58	-232.11	0.00	0.00	0.00	0.00
15	RT	Operating Procedure Number and Constraint (7110)	PGAE	Humboldt	5/22/2019	32	No	INC	24	0:00	0:00	2.67	0.00	0.00	-60.89	2.00	-48.68	0.00	0.00	0.00	0.00
16	RT	Operating Procedure Number and Constraint (7110)	PGAE	Humboldt	5/23/2019	32	No	INC	3	0:00	3:00	0.01	0.00	0.00	-0.03	0.00	0.00	0.00	0.00	0.00	0.00
17	RT	Operating Procedure Number and Constraint (7110)	PGAE	Humboldt	5/27/2019	14	No	INC	4	20:30	0:00	16.24	0.00	0.00	-375.94	0.00	0.00	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
18	RT	Operating Procedure Number and Constraint (7110)	PGAE	Humboldt	5/28/2019	16 - 32	No	INC	6	7:30	13:00	11.05	0.00	0.00	-88.43	3.28	-66.90	0.00	0.00	0.00	0.00
19	RT	Operating Procedure Number and Constraint (7110)	PGAE	Humboldt	5/31/2019	16	No	INC	3	21:40	0:00	16.16	0.00	0.00	-380.31	1.33	-23.68	0.00	0.00	0.00	0.00
20	RT	Operating Procedure Number and Constraint (7430)	PGAE	Fresno	5/18/2019	4	No	DEC	1	11:00	12:00	-0.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
21	RT	Operating Procedure Number and Constraint (7430)	PGAE	Fresno	5/18/2019	4 - 77	No	INC	18	6:05	0:00	12.78	0.00	0.00	82.17	0.00	0.00	0.00	0.00	0.00	0.00
22	RT	Operating Procedure Number and Constraint (7430)	PGAE	Fresno	5/19/2019	72 - 77	No	INC	8	0:00	8:00	22.64	0.00	0.00	-412.06	0.00	0.00	0.00	0.00	0.00	0.00
23	RT	Operating Procedure Number and Constraint (7430)	PGAE	Fresno	5/26/2019	5	No	DEC	4	11:00	15:00	-6.54	0.00	0.00	-9.01	0.00	0.00	0.00	0.00	0.00	0.00
24	RT	Operating Procedure Number and Constraint (7430)	PGAE	Fresno	5/26/2019	5 - 75	No	INC	14	6:00	20:00	6.89	0.00	0.00	462.96	0.00	0.00	0.00	0.00	0.00	0.00
25	RT	Operating Procedure Number and Constraint (7720)	SCE	NA	5/6/2019	425	No	DEC	1	19:45	20:00	-1.88	0.00	0.00	38.90	-3.59	0.00	93.81	0.00	0.00	0.00
26	RT	Operating Procedure Number and Constraint (7720)	SCE	NA	5/6/2019	425	No	INC	3	20:00	23:00	6.87	0.00	0.00	-125.53	0.00	0.00	0.00	0.00	0.00	0.00
27	RT	Operating Procedure Number and Constraint (7720)	SCE	NA	5/29/2019	430 - 440	No	INC	4	19:00	23:00	-9.36	0.00	0.00	301.62	0.00	0.00	0.00	0.00	0.00	0.00
28	RT	Other Reliability Requirement	PGAE	Bay Area	5/23/2019	90 - 120	No	INC	3	13:00	15:45	285.08	0.00	0.00	-13358.65	257.16	-12149.84	0.00	0.00	0.00	0.00
29	RT	Other Reliability Requirement	PGAE	Fresno	5/4/2019	20	No	DEC	2	18:40	19:45	-7.80	0.00	0.00	601.79	-14.72	0.00	-3352.78	0.00	0.00	0.00
30	RT	Other Reliability Requirement	PGAE	Fresno	5/10/2019	10	No	DEC	1	8:35	9:00	1.07	0.00	0.00	-62.69	0.00	0.00	0.00	0.00	0.00	0.00
31	RT	Other Reliability Requirement	PGAE	Fresno	5/10/2019	10	No	INC	2	9:00	10:25	0.64	0.00	0.00	-97.54	0.00	0.00	0.00	0.00	0.00	0.00
32	RT	Other Reliability Requirement	PGAE	Fresno	5/15/2019	5 - 11	No	DEC	7	10:00	17:00	-10.78	0.00	0.00	364.88	0.00	0.00	0.00	0.00	0.00	0.00
33	RT	Other Reliability Requirement	PGAE	Fresno	5/15/2019	4 - 12	No	INC	14	6:05	20:00	-88.34	0.00	0.00	11399.39	0.00	0.00	0.00	0.00	0.00	0.00
34	RT	Other Reliability Requirement	PGAE	Fresno	5/16/2019	4 - 12	No	DEC	9	8:00	17:00	-30.79	0.00	0.00	-77.07	0.00	0.00	0.00	0.00	0.00	0.00
35	RT	Other Reliability Requirement	PGAE	Fresno	5/16/2019	4 - 12	No	INC	14	6:05	20:00	-21.86	0.00	0.00	1375.38	0.00	0.00	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
36	RT	Other Reliability Requirement	PGAE	Fresno	5/17/2019	4 - 12	No	DEC	10	8:00	18:00	8.94	0.00	0.00	159.61	0.00	0.00	0.00	0.00	0.00	0.00
37	RT	Other Reliability Requirement	PGAE	Fresno	5/17/2019	4 - 12	No	INC	14	6:05	20:00	12.59	0.00	0.00	302.12	0.00	0.00	0.00	0.00	0.00	0.00
38	RT	Other Reliability Requirement	PGAE	Fresno	5/18/2019	5 - 11	No	DEC	5	8:00	13:00	-5.29	0.00	0.00	77.72	0.00	0.00	0.00	0.00	0.00	0.00
39	RT	Other Reliability Requirement	PGAE	Fresno	5/18/2019	5 - 12	No	INC	14	6:05	20:00	-54.47	0.00	0.00	2021.60	0.00	0.00	0.00	0.00	0.00	0.00
40	RT	Other Reliability Requirement	PGAE	Fresno	5/19/2019	4 - 11	No	DEC	10	8:00	18:00	-33.28	0.00	0.00	1482.61	0.00	0.00	0.00	0.00	0.00	0.00
41	RT	Other Reliability Requirement	PGAE	Fresno	5/19/2019	4 - 12	No	INC	14	6:00	20:00	-21.42	0.00	0.00	4805.22	0.00	0.00	0.00	0.00	0.00	0.00
42	RT	Other Reliability Requirement	PGAE	Fresno	5/20/2019	4 - 11	No	DEC	11	7:00	18:00	-22.65	0.00	0.00	-172.79	0.00	0.00	0.00	0.00	0.00	0.00
43	RT	Other Reliability Requirement	PGAE	Fresno	5/20/2019	4 - 11	No	INC	14	6:00	20:00	-8.10	0.00	0.00	-18.18	0.00	0.00	0.00	0.00	0.00	0.00
44	RT	Other Reliability Requirement	PGAE	Fresno	5/21/2019	5 - 11	No	DEC	10	8:00	18:00	-11.79	0.00	0.00	28.15	0.00	0.00	0.00	0.00	0.00	0.00
45	RT	Other Reliability Requirement	PGAE	Fresno	5/21/2019	4 - 11	No	INC	14	6:00	20:00	-12.39	0.00	0.00	-2355.91	0.00	0.00	0.00	0.00	0.00	0.00
46	RT	Other Reliability Requirement	PGAE	Fresno	5/22/2019	4 - 11	No	DEC	10	8:00	18:00	-9.58	0.00	0.00	212.78	0.00	0.00	0.00	0.00	0.00	0.00
47	RT	Other Reliability Requirement	PGAE	Fresno	5/22/2019	4 - 11	No	INC	14	6:00	20:00	-34.76	0.00	0.00	526.27	0.00	0.00	0.00	0.00	0.00	0.00
48	RT	Other Reliability Requirement	PGAE	Fresno	5/23/2019	4 - 11	No	DEC	10	8:00	18:00	-27.85	0.00	0.00	207.77	0.00	0.00	0.00	0.00	0.00	0.00
49	RT	Other Reliability Requirement	PGAE	Fresno	5/23/2019	4 - 11	No	INC	14	6:00	20:00	-14.15	0.00	0.00	-205.11	0.00	0.00	0.00	0.00	0.00	0.00
50	RT	Other Reliability Requirement	PGAE	Fresno	5/24/2019	4 - 11	No	DEC	11	7:00	18:00	-13.26	0.00	0.00	-5.15	0.00	0.00	0.00	0.00	0.00	0.00
51	RT	Other Reliability Requirement	PGAE	Fresno	5/24/2019	4 - 14	No	INC	14	6:00	20:00	0.21	0.00	0.00	1.42	0.00	0.00	0.00	0.00	0.00	0.00
52	RT	Other Reliability Requirement	PGAE	Fresno	5/25/2019	4 - 11	No	DEC	11	7:00	18:00	-11.62	0.00	0.00	-11.21	0.00	0.00	0.00	0.00	0.00	0.00
53	RT	Other Reliability Requirement	PGAE	Fresno	5/25/2019	4 - 11	No	INC	14	6:00	20:00	9.08	0.00	0.00	-31.71	0.00	0.00	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
54	RT	Other Reliability Requirement	PGAE	Fresno	5/26/2019	5 - 11	No	DEC	6	11:00	17:00	-6.41	0.00	0.00	-20.84	0.00	0.00	0.00	0.00	0.00	0.00
55	RT	Other Reliability Requirement	PGAE	Fresno	5/26/2019	4 - 11	No	INC	14	6:00	20:00	-21.93	0.00	0.00	530.18	0.00	0.00	0.00	0.00	0.00	0.00
56	RT	Other Reliability Requirement	PGAE	Fresno	5/27/2019	4 - 11	No	DEC	6	9:00	15:00	-6.24	0.00	0.00	-63.61	0.00	0.00	0.00	0.00	0.00	0.00
57	RT	Other Reliability Requirement	PGAE	Fresno	5/27/2019	4 - 12	No	INC	14	6:00	20:00	-36.49	0.00	0.00	-117.12	0.00	0.00	0.00	0.00	0.00	0.00
58	RT	Other Reliability Requirement	PGAE	Fresno	5/28/2019	4 - 12	No	DEC	11	7:00	18:00	-43.75	0.00	0.00	157.42	0.00	0.00	0.00	0.00	0.00	0.00
59	RT	Other Reliability Requirement	PGAE	Fresno	5/28/2019	4 - 12	No	INC	14	6:00	20:00	-16.01	0.00	0.00	190.71	0.00	0.00	0.00	0.00	0.00	0.00
60	RT	Other Reliability Requirement	PGAE	Fresno	5/29/2019	4 - 12	No	DEC	10	8:00	18:00	-12.77	0.00	0.00	-354.36	0.00	0.00	0.00	0.00	0.00	0.00
61	RT	Other Reliability Requirement	PGAE	Fresno	5/29/2019	4 - 12	No	INC	14	6:00	20:00	-27.35	0.00	0.00	486.07	0.00	0.00	0.00	0.00	0.00	0.00
62	RT	Other Reliability Requirement	PGAE	Fresno	5/30/2019	4 - 12	No	DEC	11	7:00	18:00	-33.29	0.00	0.00	384.76	0.00	0.00	0.00	0.00	0.00	0.00
63	RT	Other Reliability Requirement	PGAE	Fresno	5/30/2019	4 - 12	No	INC	14	6:00	20:00	-0.26	0.00	0.00	890.26	0.00	0.00	0.00	0.00	0.00	0.00
64	RT	Other Reliability Requirement	PGAE	Fresno	5/31/2019	4 - 12	No	DEC	10	8:00	18:00	-6.10	0.00	0.00	212.98	0.00	0.00	0.00	0.00	0.00	0.00
65	RT	Other Reliability Requirement	PGAE	Fresno	5/31/2019	4 - 12	No	INC	14	6:00	20:00	-24.30	0.00	0.00	482.95	0.00	0.00	0.00	0.00	0.00	0.00
66	RT	Other Reliability Requirement	PGAE	Humboldt	5/8/2019	32	No	INC	4	20:45	0:00	5.85	-2165.91	0.00	-168.68	2.92	-84.34	0.00	0.00	0.00	0.00
67	RT	Other Reliability Requirement	PGAE	Humboldt	5/10/2019	15	No	INC	15	7:35	22:00	10.56	0.00	0.00	-395.79	1.58	-85.04	0.00	0.00	0.00	0.00
68	RT	Other Reliability Requirement	PGAE	NA	5/5/2019	325	No	DEC	1	8:25	9:00	-5.12	0.00	0.00	-853.03	0.00	0.00	0.00	0.00	0.00	0.00
69	RT	Other Reliability Requirement	PGAE	NA	5/15/2019	8	No	DEC	1	11:55	12:05	-0.47	0.00	0.00	-17.68	-0.92	0.00	-11.86	0.00	0.00	0.00
70	RT	Other Reliability Requirement	PGAE	NA	5/15/2019	38	No	INC	8	12:05	20:00	-10.43	0.00	0.00	2368.28	0.00	0.00	0.00	0.00	0.00	0.00
71	RT	Other Reliability Requirement	PGAE	NA	5/16/2019	38	No	INC	14	6:05	20:00	14.29	0.00	0.00	228.52	0.00	0.00	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
72	RT	Other Reliability Requirement	PGAE	NA	5/17/2019	38	No	INC	14	6:05	20:00	4.79	0.00	0.00	742.99	0.00	0.00	0.00	0.00	0.00	0.00
73	RT	Other Reliability Requirement	PGAE	NA	5/18/2019	38	No	INC	14	6:05	20:00	-27.19	0.00	0.00	2227.24	0.00	0.00	0.00	0.00	0.00	0.00
74	RT	Other Reliability Requirement	PGAE	NA	5/20/2019	36	No	INC	2	7:50	9:00	0.43	0.00	0.00	-3.72	0.00	0.00	0.00	0.00	0.00	0.00
75	RT	Other Reliability Requirement	PGAE	NA	5/24/2019	35	No	INC	9	10:55	19:00	-1.73	0.00	0.00	525.60	0.00	0.00	0.00	0.00	0.00	0.00
76	RT	Other Reliability Requirement	PGAE	NA	5/25/2019	35	No	INC	4	6:00	9:30	12.21	0.00	0.00	33.62	0.00	0.00	0.00	0.00	0.00	0.00
77	RT	Other Reliability Requirement	PGAE	NA	5/26/2019	35	No	INC	14	6:00	20:00	-14.76	0.00	0.00	-296.15	0.00	0.00	0.00	0.00	0.00	0.00
78	RT	Other Reliability Requirement	PGAE	NA	5/27/2019	38	No	INC	14	6:00	20:00	30.14	0.00	0.00	361.11	0.00	0.00	0.00	0.00	0.00	0.00
79	RT	Other Reliability Requirement	PGAE	NA	5/28/2019	38	No	INC	14	6:00	20:00	-2.85	0.00	0.00	277.08	0.00	0.00	0.00	0.00	0.00	0.00
80	RT	Other Reliability Requirement	PGAE	NA	5/29/2019	38	No	INC	14	6:00	20:00	-26.74	0.00	0.00	13.52	0.00	0.00	0.00	0.00	0.00	0.00
81	RT	Other Reliability Requirement	PGAE	NA	5/30/2019	38	No	INC	14	6:00	20:00	-26.86	0.00	0.00	-126.30	0.00	0.00	0.00	0.00	0.00	0.00
82	RT	Other Reliability Requirement	PGAE	NA	5/31/2019	38	No	DEC	1	9:00	10:00	-0.37	0.00	0.00	-4.73	0.00	0.00	0.00	0.00	0.00	0.00
83	RT	Other Reliability Requirement	PGAE	NA	5/31/2019	38	No	INC	14	6:00	20:00	-7.31	0.00	0.00	157.46	0.00	0.00	0.00	0.00	0.00	0.00
84	RT	Other Reliability Requirement	PGAE	NCNB	5/30/2019	22 - 30	No	DEC	2	15:45	17:00	-9.59	0.00	0.00	-607.46	-9.57	0.00	-248.87	0.00	0.00	0.00
85	RT	Other Reliability Requirement	PGAE	Sierra	5/25/2019	107	No	DEC	1	21:00	22:00	-0.62	0.00	0.00	-93.37	-3.75	0.00	-563.34	0.00	0.00	0.00
86	RT	Other Reliability Requirement	PGAE	Stockton	5/1/2019	30 - 50	No	DEC	16	6:00	22:00	-58.76	0.00	0.00	69.74	-58.14	0.00	-58.14	0.00	0.00	0.00
87	RT	Other Reliability Requirement	PGAE	Stockton	5/1/2019	40 - 65	No	INC	24	0:00	0:00	14.44	0.00	0.00	-97.57	-0.90	0.00	-0.90	0.00	0.00	0.00
88	RT	Other Reliability Requirement	PGAE	Stockton	5/2/2019	37 - 65	No	DEC	24	0:00	0:00	-178.21	0.00	0.00	1286.11	-7.52	0.00	23.75	0.00	0.00	0.00
89	RT	Other Reliability Requirement	PGAE	Stockton	5/2/2019	60 - 65	No	INC	24	0:00	0:00	69.09	0.00	0.00	-677.76	0.00	0.00	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
90	RT	Other Reliability Requirement	PGAE	Stockton	5/3/2019	30 - 65	No	DEC	24	0:30	0:00	-61.17	0.00	0.00	625.78	-14.42	0.00	36.45	0.00	0.00	0.00
91	RT	Other Reliability Requirement	PGAE	Stockton	5/3/2019	60 - 65	No	INC	24	0:25	0:00	32.98	0.00	0.00	-644.66	0.00	0.00	0.00	0.00	0.00	0.00
92	RT	Other Reliability Requirement	PGAE	Stockton	5/4/2019	45 - 70	No	DEC	23	0:00	23:00	-104.24	0.00	0.00	-1133.51	-125.37	0.00	-632.98	0.00	0.00	0.00
93	RT	Other Reliability Requirement	PGAE	Stockton	5/4/2019	30 - 70	No	INC	23	1:55	0:00	29.07	0.00	0.00	-11652.07	21.68	-10841.94	0.00	0.00	0.00	0.00
94	RT	Other Reliability Requirement	PGAE	Stockton	5/5/2019	45	No	DEC	21	2:00	23:00	-143.93	0.00	0.00	-129.74	-91.10	0.00	-6.91	0.00	0.00	0.00
95	RT	Other Reliability Requirement	PGAE	Stockton	5/5/2019	45 - 70	No	INC	24	0:00	0:00	68.41	0.00	0.00	-1006.13	-5.83	0.00	-87.50	0.00	0.00	0.00
96	RT	Other Reliability Requirement	PGAE	Stockton	5/6/2019	60 - 65	No	DEC	7	1:00	8:00	0.54	0.00	0.00	-13.49	0.00	0.00	0.00	0.00	0.00	0.00
97	RT	Other Reliability Requirement	PGAE	Stockton	5/6/2019	45 - 70	No	INC	18	0:00	17:30	41.53	0.00	0.00	-471.68	0.00	0.00	0.00	0.00	0.00	0.00
98	RT	Other Reliability Requirement	PGAE	Stockton	5/7/2019	55	No	DEC	4	20:55	0:00	-8.98	0.00	0.00	-61.94	-8.22	0.00	0.00	0.00	0.00	0.00
99	RT	Other Reliability Requirement	PGAE	Stockton	5/7/2019	89	No	INC	11	9:00	20:00	-15.92	47265.52	0.00	504.81	0.00	0.00	0.00	0.00	0.00	0.00
100	RT	Other Reliability Requirement	PGAE	Stockton	5/8/2019	50	No	DEC	3	16:00	19:00	-0.69	0.00	0.00	5.85	0.00	0.00	0.00	0.00	0.00	0.00
101	RT	Other Reliability Requirement	PGAE	Stockton	5/8/2019	50 - 89	No	INC	24	0:00	0:00	44.81	8090.52	0.00	-1659.18	-3.95	0.00	-3.95	0.00	0.00	0.00
102	RT	Other Reliability Requirement	PGAE	Stockton	5/9/2019	70	No	DEC	3	20:35	23:00	-17.79	0.00	0.00	-266.35	-7.96	0.00	-119.40	0.00	0.00	0.00
103	RT	Other Reliability Requirement	PGAE	Stockton	5/9/2019	70	No	INC	1	23:00	0:00	-2.54	0.00	0.00	5.82	0.00	0.00	0.00	0.00	0.00	0.00
104	RT	Other Reliability Requirement	PGAE	Stockton	5/10/2019	40 - 50	No	DEC	24	0:40	0:00	-42.33	0.00	0.00	-483.42	-26.94	0.00	-322.74	0.00	0.00	0.00
105	RT	Other Reliability Requirement	PGAE	Stockton	5/11/2019	45	No	DEC	1	20:00	21:00	-4.61	0.00	0.00	-37.47	-5.98	0.00	-5.98	0.00	0.00	0.00
106	RT	Other Reliability Requirement	PGAE	Stockton	5/11/2019	40 - 50	No	INC	24	0:00	0:00	-3.48	0.00	0.00	-248.68	-5.15	0.00	-5.15	0.00	0.00	0.00
107	RT	Other Reliability Requirement	PGAE	Stockton	5/12/2019	45	No	DEC	5	1:00	6:00	-104.09	0.00	0.00	-10.35	-46.85	0.00	-21.85	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
108	RT	Other Reliability Requirement	PGAE	Stockton	5/12/2019	45	No	INC	8	0:00	8:00	-0.21	0.00	0.00	32.61	0.00	0.00	0.00	0.00	0.00	0.00
109	RT	Other Reliability Requirement	PGAE	Stockton	5/14/2019	40	No	DEC	6	14:00	20:00	-128.46	0.00	0.00	-211.72	-4.13	0.00	-4.13	0.00	0.00	0.00
110	RT	Other Reliability Requirement	PGAE	Stockton	5/14/2019	40	No	INC	7	12:40	19:00	-5.38	0.00	0.00	188.48	-1.65	0.00	-1.65	0.00	0.00	0.00
111	RT	Other Reliability Requirement	PGAE	Stockton	5/15/2019	40 - 75	No	DEC	19	5:00	0:00	-266.10	0.00	0.00	-3485.23	-237.05	0.00	-424.12	0.00	0.00	0.00
112	RT	Other Reliability Requirement	PGAE	Stockton	5/15/2019	40 - 75	No	INC	14	10:00	0:00	-7.09	0.00	0.00	-3548.51	0.00	0.00	0.00	0.00	0.00	0.00
113	RT	Other Reliability Requirement	PGAE	Stockton	5/16/2019	70 - 80	No	INC	3	0:00	3:00	0.51	0.00	0.00	-8.00	0.00	0.00	0.00	0.00	0.00	0.00
114	RT	Other Reliability Requirement	PGAE	Stockton	5/17/2019	25 - 40	No	DEC	21	1:30	22:00	-48.88	0.00	0.00	-51.73	-31.80	0.00	-21.80	0.00	0.00	0.00
115	RT	Other Reliability Requirement	PGAE	Stockton	5/17/2019	25 - 70	No	INC	5	19:55	0:00	-34.39	0.00	0.00	331.06	-30.97	0.00	239.54	0.00	0.00	0.00
116	RT	Other Reliability Requirement	PGAE	Stockton	5/18/2019	25 - 35	No	DEC	22	1:00	23:00	-260.72	0.00	0.00	-628.32	-261.62	0.00	-195.91	0.00	0.00	0.00
117	RT	Other Reliability Requirement	PGAE	Stockton	5/18/2019	25 - 70	No	INC	24	0:00	0:00	17.63	0.00	0.00	-328.61	-2.85	0.00	-2.85	0.00	0.00	0.00
118	RT	Other Reliability Requirement	PGAE	Stockton	5/19/2019	30 - 70	No	DEC	21	2:00	23:00	-124.49	0.00	0.00	-684.02	-7.16	0.00	-13.99	0.00	0.00	0.00
119	RT	Other Reliability Requirement	PGAE	Stockton	5/19/2019	30 - 70	No	INC	24	0:00	0:00	56.03	0.00	0.00	-147.43	0.00	0.00	0.00	0.00	0.00	0.00
120	RT	Other Reliability Requirement	PGAE	Stockton	5/20/2019	70	No	DEC	3	5:00	8:00	-1.53	0.00	0.00	1.57	0.00	0.00	0.00	0.00	0.00	0.00
121	RT	Other Reliability Requirement	PGAE	Stockton	5/20/2019	35 - 70	No	INC	8	0:00	8:00	7.83	0.00	0.00	87.87	0.00	0.00	0.00	0.00	0.00	0.00
122	RT	Other Reliability Requirement	PGAE	Stockton	5/21/2019	50	No	DEC	2	5:20	7:00	1.20	0.00	0.00	249.60	0.00	0.00	0.00	0.00	0.00	0.00
123	RT	Other Reliability Requirement	PGAE	Stockton	5/21/2019	50	No	INC	5	7:00	12:00	-1.58	0.00	0.00	11.93	0.00	0.00	0.00	0.00	0.00	0.00
124	RT	Other Reliability Requirement	PGAE	Stockton	5/22/2019	30	No	DEC	18	2:25	20:00	-400.56	0.00	0.00	-509.22	-380.64	0.00	-380.64	0.00	0.00	0.00
125	RT	Other Reliability Requirement	PGAE	Stockton	5/22/2019	30	No	INC	2	3:00	5:00	-6.71	0.00	0.00	-3.86	-6.62	0.00	-6.62	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620	
126	RT	Other Reliability Requirement	PGAE	Stockton	5/23/2019	1 - 70	No	DEC	22	2:50	0:00	-98.24	0.00	0.00	437.18	-77.32	0.00	714.62	0.00	0.00	0.00	
127	RT	Other Reliability Requirement	PGAE	Stockton	5/23/2019	1 - 80	No	INC	23	0:30	23:00	-95.45	0.00	0.00	-4030.67	-33.91	-5176.03	280.69	0.00	-	32977.43	0.00
128	RT	Other Reliability Requirement	PGAE	Stockton	5/24/2019	30 - 50	No	INC	8	0:00	8:00	-21.05	0.00	0.00	-120.97	-7.53	0.00	-15.05	0.00	0.00	0.00	
129	RT	Other Reliability Requirement	PGAE	Stockton	5/25/2019	60	No	DEC	3	19:00	22:00	-7.93	0.00	0.00	-109.20	-7.75	0.00	-116.25	0.00	0.00	0.00	
130	RT	Other Reliability Requirement	PGAE	Stockton	5/25/2019	40 - 60	No	INC	17	7:00	0:00	2.46	0.00	0.00	-143.31	-6.71	0.00	-13.42	0.00	0.00	0.00	
131	RT	Other Reliability Requirement	PGAE	Stockton	5/26/2019	40 - 50	No	INC	11	1:15	12:00	-31.99	0.00	0.00	-40.15	-0.83	0.00	-1.67	0.00	0.00	0.00	
132	RT	Other Reliability Requirement	PGAE	Stockton	5/27/2019	50 - 60	No	INC	18	1:15	19:00	-27.40	0.00	0.00	-70.14	-6.91	0.00	-13.82	0.00	0.00	0.00	
133	RT	Other Reliability Requirement	PGAE	Stockton	5/29/2019	55	No	DEC	1	19:00	20:00	-22.39	0.00	0.00	-44.79	0.00	0.00	0.00	0.00	0.00	0.00	
134	RT	Other Reliability Requirement	PGAE	Stockton	5/29/2019	50 - 55	No	INC	14	10:45	0:00	-58.74	0.00	0.00	-251.96	-13.94	0.00	-27.88	0.00	0.00	0.00	
135	RT	Other Reliability Requirement	PGAE	Stockton	5/30/2019	28	No	DEC	1	20:35	21:10	-14.16	0.00	0.00	-40.70	-6.62	0.00	-13.23	0.00	0.00	0.00	
136	RT	Other Reliability Requirement	PGAE	Stockton	5/30/2019	35 - 50	No	INC	8	0:00	8:00	-33.41	0.00	0.00	-76.27	-3.96	0.00	-7.91	0.00	0.00	0.00	
137	RT	Other Reliability Requirement	PGAE	Stockton	5/31/2019	50 - 60	No	DEC	23	1:35	0:00	-93.95	0.00	0.00	-254.77	-24.13	0.00	-48.26	0.00	0.00	0.00	
138	RT	Other Reliability Requirement	PGAE	Stockton	5/31/2019	55	No	INC	1	6:00	7:00	-0.56	0.00	0.00	-7.95	0.00	0.00	0.00	0.00	0.00	0.00	
139	RT	Other Reliability Requirement	SCE	Big Creek-Ventura	5/31/2019	64	No	DEC	2	12:00	14:00	-1.00	0.00	0.00	9.57	0.00	0.00	0.00	0.00	0.00	0.00	
140	RT	Other Reliability Requirement	SCE	Big Creek-Ventura	5/31/2019	64	No	INC	9	11:10	20:00	0.30	0.00	0.00	3.69	0.00	0.00	0.00	0.00	0.00	0.00	
141	RT	Other Reliability Requirement	SDGE	San Diego-IV	5/31/2019	106 - 160	No	INC	9	7:55	16:00	106.76	59057.61	712.68	-10960.54	4.76	-240.69	0.00	0.00	0.00	0.00	
142	RT	Planned Transmission Outage	PGAE	Bay Area	5/20/2019	175	No	INC	2	6:30	7:45	6.49	11213.01	0.00	-239.48	0.00	0.00	0.00	0.00	0.00	0.00	
143	RT	Planned Transmission Outage	PGAE	Bay Area	5/23/2019	20 - 175	No	INC	12	9:20	21:00	927.76	295631.71	44620.53	-65343.80	459.81	-23884.60	0.00	0.00	-	84003.11	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
144	RT	Planned Transmission Outage	PGAE	Fresno	5/1/2019	60	No	INC	9	0:00	9:00	-158.29	0.00	0.00	1964.13	0.00	0.00	0.00	0.00	0.00	0.00
145	RT	Planned Transmission Outage	PGAE	Fresno	5/2/2019	65	No	DEC	2	6:00	8:00	-14.18	0.00	0.00	-783.23	-0.50	0.00	-48.51	0.00	0.00	0.00
146	RT	Planned Transmission Outage	PGAE	Fresno	5/2/2019	65 - 67	No	INC	9	3:40	12:30	-37.96	0.00	0.00	164.60	0.00	0.00	0.00	0.00	0.00	0.00
147	RT	Planned Transmission Outage	PGAE	Fresno	5/31/2019	0 - 7	No	DEC	13	7:40	20:00	-12.50	-3694.16	0.00	260.72	-7.42	0.00	130.99	0.00	-6704.04	0.00
148	RT	Planned Transmission Outage	PGAE	Fresno	5/31/2019	4 - 6	No	INC	1	19:00	20:00	-0.31	0.00	0.00	8.15	0.00	0.00	0.00	0.00	0.00	0.00
149	RT	Planned Transmission Outage	PGAE	Humboldt	5/1/2019	16	No	DEC	2	17:45	19:00	-1.57	-179.72	0.00	13.36	0.00	0.00	0.00	0.00	0.00	0.00
150	RT	Planned Transmission Outage	PGAE	Humboldt	5/1/2019	28 - 32	No	INC	24	0:00	0:00	44.87	-8986.13	0.00	-240.69	21.64	-49.45	0.00	0.00	-526.62	0.00
151	RT	Planned Transmission Outage	PGAE	Humboldt	5/2/2019	14	No	DEC	5	12:30	17:30	-8.43	-181.64	0.00	62.81	-3.65	0.00	22.97	0.00	-38.58	0.00
152	RT	Planned Transmission Outage	PGAE	Humboldt	5/2/2019	28	No	INC	24	0:00	0:00	52.62	-6720.86	0.00	-866.98	4.89	-92.24	0.00	0.00	0.00	0.00
153	RT	Planned Transmission Outage	PGAE	Humboldt	5/3/2019	14	No	DEC	3	16:00	19:00	4.89	-2143.56	0.00	-73.21	0.00	0.00	0.00	0.00	0.00	0.00
154	RT	Planned Transmission Outage	PGAE	Humboldt	5/3/2019	28	No	INC	24	0:00	0:00	67.30	-8395.61	0.00	-1466.99	0.00	0.00	0.00	0.00	0.00	0.00
155	RT	Planned Transmission Outage	PGAE	Humboldt	5/4/2019	14 - 28	No	INC	24	0:00	0:00	74.91	-688.67	0.00	-2105.48	0.00	0.00	0.00	0.00	0.00	0.00
156	RT	Planned Transmission Outage	PGAE	Humboldt	5/5/2019	14 - 32	No	INC	23	0:00	22:45	30.97	516.81	0.00	-728.15	3.91	-153.03	0.00	0.00	0.00	0.00
157	RT	Planned Transmission Outage	PGAE	Humboldt	5/6/2019	28	No	INC	10	7:35	17:00	12.09	-6373.99	0.00	-193.95	0.00	0.00	0.00	0.00	0.00	0.00
158	RT	Planned Transmission Outage	PGAE	Humboldt	5/7/2019	32	No	INC	14	7:00	21:00	37.71	-10122.75	546.15	-1355.34	35.32	-1155.12	0.00	0.00	-63.05	0.00
159	RT	Planned Transmission Outage	PGAE	Humboldt	5/11/2019	15	No	INC	13	6:50	19:45	6.49	0.00	0.00	-121.59	0.74	-12.27	0.00	0.00	-109.94	0.00
160	RT	Planned Transmission Outage	PGAE	Humboldt	5/12/2019	14 - 32	No	INC	16	6:15	21:45	51.11	-694.71	0.00	-721.26	17.09	-397.39	0.00	0.00	-545.23	0.00
161	RT	Planned Transmission Outage	PGAE	Humboldt	5/13/2019	32	No	INC	19	5:05	0:00	48.47	-11983.75	0.00	-1034.14	34.67	-734.68	0.00	0.00	-739.76	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
162	RT	Planned Transmission Outage	PGAE	Humboldt	5/14/2019	16	No	DEC	5	2:15	6:40	1.08	0.00	0.00	-9.38	1.00	-8.95	0.00	0.00	-8.66	0.00
163	RT	Planned Transmission Outage	PGAE	Humboldt	5/14/2019	16 - 44	No	INC	24	0:00	0:00	19.09	-13766.83	0.00	-310.45	10.39	-236.56	0.00	0.00	-448.47	0.00
164	RT	Planned Transmission Outage	PGAE	Humboldt	5/15/2019	16	No	DEC	1	23:00	0:00	12.94	-732.57	0.00	-327.26	0.00	0.00	0.00	0.00	0.00	0.00
165	RT	Planned Transmission Outage	PGAE	Humboldt	5/15/2019	16 - 48	No	INC	24	0:00	0:00	56.03	-16665.97	0.00	-2880.99	16.98	-847.60	0.00	0.00	-119.08	0.00
166	RT	Planned Transmission Outage	PGAE	Humboldt	5/16/2019	16	No	DEC	3	0:00	3:00	6.22	-2201.58	0.00	-112.85	0.00	0.00	0.00	0.00	0.00	0.00
167	RT	Planned Transmission Outage	PGAE	Humboldt	5/16/2019	28	No	INC	20	0:00	20:00	17.95	0.00	0.00	-376.22	0.00	0.00	0.00	0.00	0.00	0.00
168	RT	Planned Transmission Outage	PGAE	Humboldt	5/17/2019	14	No	INC	17	7:00	0:00	14.64	0.00	0.00	-112.48	0.00	0.00	0.00	0.00	0.00	0.00
169	RT	Planned Transmission Outage	PGAE	Humboldt	5/18/2019	14 - 32	No	INC	21	0:00	21:00	46.07	0.00	0.00	-552.32	1.48	-27.76	0.00	0.00	-18.17	0.00
170	RT	Planned Transmission Outage	PGAE	Humboldt	5/19/2019	28 - 32	No	INC	17	5:45	22:00	65.97	-8616.65	0.00	-2581.42	10.52	-922.08	0.00	0.00	-384.27	0.00
171	RT	Planned Transmission Outage	PGAE	Humboldt	5/23/2019	14 - 28	No	INC	15	5:55	20:00	11.37	0.00	0.00	-350.76	0.54	-14.69	0.00	0.00	0.00	0.00
172	RT	Planned Transmission Outage	PGAE	Humboldt	5/24/2019	14	No	INC	17	7:15	0:00	32.03	0.00	0.00	-431.25	0.00	0.00	0.00	0.00	0.00	0.00
173	RT	Planned Transmission Outage	PGAE	Humboldt	5/25/2019	14	No	INC	12	0:00	12:00	5.86	0.00	0.00	-9.67	0.00	0.00	0.00	0.00	0.00	0.00
174	RT	Planned Transmission Outage	PGAE	Humboldt	5/28/2019	14 - 32	No	INC	11	13:10	23:30	15.69	0.00	0.00	117.79	3.08	-10.89	0.00	0.00	-37.77	0.00
175	RT	Planned Transmission Outage	PGAE	NA	5/1/2019	400	No	DEC	2	11:50	13:15	-40.36	0.00	0.00	0.78	-74.69	0.00	0.56	0.00	-1996.34	0.00
176	RT	Planned Transmission Outage	PGAE	NA	5/5/2019	29 - 39	No	DEC	1	9:35	10:30	-38.21	0.00	0.00	-80.75	-13.15	0.00	-50.19	0.00	0.00	0.00
177	RT	Planned Transmission Outage	PGAE	NCNB	5/3/2019	50	No	DEC	6	18:00	23:30	-22.80	0.00	0.00	765.09	-20.21	0.00	705.32	0.00	-	11752.99
178	RT	Planned Transmission Outage	PGAE	NCNB	5/3/2019	50	No	INC	9	9:05	18:00	-18.48	0.00	0.00	419.82	-18.16	0.00	410.69	0.00	-874.81	0.00
179	RT	Planned Transmission Outage	PGAE	Sierra	5/8/2019	29.1 - 46	No	DEC	4	2:15	6:00	-25.16	0.00	0.00	187.56	-24.46	0.00	120.47	0.00	-34.42	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
180	RT	Planned Transmission Outage	PGAE	Sierra	5/15/2019	35 - 40	No	DEC	13	7:10	20:00	-8.02	0.00	0.00	137.37	-9.42	0.00	1343.25	0.00	-1843.83	0.00
181	RT	Planned Transmission Outage	PGAE	Sierra	5/15/2019	35 - 40	No	INC	8	9:00	17:00	-0.26	0.00	0.00	94.21	0.00	0.00	0.00	0.00	0.00	0.00
182	RT	Planned Transmission Outage	PGAE	Sierra	5/28/2019	0 - 25	No	DEC	15	6:15	21:15	-93.51	0.00	0.00	411.13	-128.25	0.00	877.48	0.00	-5310.41	0.00
183	RT	Planned Transmission Outage	PGAE	Sierra	5/30/2019	1 - 5	No	DEC	3	20:55	23:20	-503.16	0.00	0.00	67652.12	-503.16	0.00	67652.12	0.00	-	91337.25
184	RT	Planned Transmission Outage	PGAE	Sierra	5/31/2019	1 - 5	No	DEC	2	5:25	6:30	-205.03	0.00	0.00	6429.02	-164.82	0.00	5057.88	0.00	-	12913.73
185	RT	Planned Transmission Outage	PGAE	Stockton	5/9/2019	50	No	DEC	3	19:00	22:00	0.54	0.00	0.00	-19.96	0.00	0.00	0.00	0.00	-371.50	0.00
186	RT	Planned Transmission Outage	PGAE	Stockton	5/9/2019	50	No	INC	12	11:25	23:00	-17.47	0.00	0.00	-418.77	-7.74	0.00	64.67	0.00	-72.38	0.00
187	RT	Planned Transmission Outage	PGAE	Stockton	5/20/2019	40	No	DEC	4	19:00	23:00	-77.96	0.00	0.00	958.97	-37.36	0.00	986.05	0.00	-1388.76	0.00
188	RT	Planned Transmission Outage	PGAE	Stockton	5/20/2019	40	No	INC	7	17:00	0:00	-6.75	0.00	0.00	46.22	-3.50	0.00	50.45	0.00	-39.47	0.00
189	RT	Planned Transmission Outage	PGAE	Stockton	5/21/2019	30 - 40	No	DEC	7	5:00	12:00	-88.42	0.00	0.00	355.53	-89.19	0.00	389.52	0.00	-477.50	0.00
190	RT	Planned Transmission Outage	PGAE	Stockton	5/21/2019	30 - 40	No	INC	9	0:00	9:00	-29.94	0.00	0.00	108.00	-32.92	0.00	139.34	0.00	-167.02	0.00
191	RT	Planned Transmission Outage	PGAE	Stockton	5/23/2019	25 - 60	No	INC	7	5:50	12:30	-28.85	0.00	0.00	988.85	-9.00	-148.60	456.51	0.00	-	33297.77
192	RT	Planned Transmission Outage	PGAE	Stockton	5/24/2019	40 - 50	No	DEC	13	9:00	22:00	-56.80	0.00	0.00	3246.92	-24.39	0.00	3377.71	0.00	-8607.77	0.00
193	RT	Planned Transmission Outage	PGAE	Stockton	5/24/2019	40 - 60	No	INC	16	8:20	0:00	14.17	0.00	0.00	-493.38	-9.79	0.00	175.46	0.00	-195.04	0.00
194	RT	Planned Transmission Outage	PGAE	Stockton	5/25/2019	25 - 60	No	DEC	6	0:00	6:00	-16.23	0.00	0.00	150.37	-32.11	0.00	310.30	0.00	-954.97	0.00
195	RT	Planned Transmission Outage	PGAE	Stockton	5/25/2019	25 - 60	No	INC	8	0:00	7:15	-9.52	0.00	0.00	42.08	-1.05	-42.34	66.83	0.00	-	33023.80
196	RT	Planned Transmission Outage	SCE	NA	5/12/2019	200	No	INC	8	16:00	0:00	0.00	58604.32	15460.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00
197	RT	Planned Transmission Outage	SCE	NA	5/16/2019	395	No	INC	6	18:50	0:00	59.34	0.00	0.00	-1737.75	0.00	0.00	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
198	RT	Planned Transmission Outage	SCE	NA	5/17/2019	200 - 395	No	INC	24	0:00	0:00	30.36	54186.17	16307.26	-238.94	0.00	0.00	0.00	0.00	0.00	0.00
199	RT	Planned Transmission Outage	SCE	NA	5/18/2019	200	No	INC	24	0:00	0:00	17.84	59444.33	15306.29	-8505.37	0.00	0.00	0.00	0.00	0.00	0.00
200	RT	Planned Transmission Outage	SCE	NA	5/19/2019	200	No	INC	24	0:00	0:00	8.53	58080.80	15306.29	-631.50	0.00	0.00	0.00	0.00	0.00	0.00
201	RT	Planned Transmission Outage	SCE	NA	5/20/2019	200	No	INC	24	0:00	0:00	-2.32	46586.80	12280.80	-1342.80	0.00	0.00	0.00	0.00	0.00	0.00
202	RT	Planned Transmission Outage	SCE	NA	5/21/2019	200	No	INC	24	0:00	0:00	100.00	31148.04	15471.49	-2002.62	0.00	0.00	0.00	0.00	0.00	0.00
203	RT	Planned Transmission Outage	SCE	NA	5/22/2019	200	No	INC	24	0:00	0:00	-4.74	77965.45	0.00	-342.53	0.00	0.00	0.00	0.00	0.00	0.00
204	RT	Planned Transmission Outage	SCE	NA	5/23/2019	200	No	INC	24	0:00	0:00	14.24	51315.54	15487.66	37.12	0.00	0.00	0.00	0.00	0.00	0.00
205	RT	Planned Transmission Outage	SCE	NA	5/24/2019	200	No	INC	1	0:00	1:00	8.33	0.00	0.00	-104.31	0.00	0.00	0.00	0.00	0.00	0.00
206	RT	Planned Transmission Outage	SCE	NA	5/25/2019	200	No	INC	7	17:00	0:00	-4.17	47793.76	14261.90	-0.01	0.00	0.00	0.00	0.00	0.00	0.00
207	RT	Planned Transmission Outage	SCE	NA	5/26/2019	200	No	INC	24	0:00	0:00	16.15	40879.23	12318.59	-2724.66	0.00	0.00	0.00	0.00	0.00	0.00
208	RT	Planned Transmission Outage	SCE	NA	5/27/2019	200	No	INC	24	0:00	0:00	0.00	46719.12	12318.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00
209	RT	Planned Transmission Outage	SCE	NA	5/28/2019	200	No	INC	24	0:00	0:00	16.80	42854.81	12318.59	-298.76	0.00	0.00	0.00	0.00	0.00	0.00
210	RT	Planned Transmission Outage	SCE	NA	5/29/2019	200	No	INC	24	0:00	0:00	14.06	49362.04	14800.89	-3377.92	0.00	0.00	0.00	0.00	0.00	0.00
211	RT	Planned Transmission Outage	SCE	NA	5/30/2019	200	No	INC	24	0:00	0:00	26.46	49530.67	14858.00	-7780.74	0.00	0.00	0.00	0.00	0.00	0.00
212	RT	Planned Transmission Outage	SCE	NA	5/31/2019	200	No	INC	24	0:00	0:00	-11.68	57808.08	15220.64	358.14	0.00	0.00	0.00	0.00	0.00	0.00
213	RT	Planned Transmission Outage	SDGE	San Diego-IV	5/1/2019	290	No	INC	18	5:00	23:00	28.97	259425.72	0.00	-884.80	0.00	0.00	0.00	0.00	0.00	0.00
214	RT	Planned Transmission Outage	SDGE	San Diego-IV	5/6/2019	190 - 210	No	DEC	2	9:55	11:30	13.97	0.00	0.00	-43.18	28.75	110.88	0.00	0.00	-528.15	0.00
215	RT	Planned Transmission Outage	SDGE	San Diego-IV	5/7/2019	37 - 160	No	INC	4	8:45	12:00	133.38	10107.21	114.83	-3029.97	63.03	-1429.67	0.00	0.00	-3962.13	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620	
216	RT	Planned Transmission Outage	SDGE	San Diego-IV	5/8/2019	160	No	INC	8	9:10	17:00	689.89	12662.79	0.00	-5135.42	0.00	0.00	0.00	0.00	0.00	0.00	
217	RT	Planned Transmission Outage	SDGE	San Diego-IV	5/15/2019	47 - 300	No	INC	5	9:00	13:45	101.39	30067.92	606.26	-8858.47	123.14	-7217.17	0.00	0.00	-	32704.37	0.00
218	RT	Planned Transmission Outage	SDGE	San Diego-IV	5/31/2019	10 - 77	No	DEC	7	7:00	13:15	39.72	0.00	0.00	8645.53	-54.66	0.00	6795.19	0.00	-	134456.34	0.00
219	RT	Planned Transmission Outage	SDGE	San Diego-IV	5/31/2019	14 - 77	No	INC	2	6:30	8:00	-23.17	0.00	0.00	5575.96	0.00	0.00	0.00	0.00	0.00	0.00	
220	RT	Pump Management	PGAE	Fresno	5/17/2019	-301	No	DEC	1	18:15	18:30	3.14	0.00	0.00	17.26	0.00	0.00	0.00	0.00	0.00	0.00	
221	RT	Ramping Capacity	PGAE	Fresno	5/10/2019	83	No	INC	2	6:10	8:00	32.10	0.00	0.00	-1604.01	0.00	0.00	0.00	0.00	0.00	0.00	
222	RT	Software Limitation	Intertie	NA	5/22/2019	0	No	INC	4	4:25	8:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
223	RT	Software Limitation	PGAE	Bay Area	5/5/2019	0	No	INC	4	0:20	4:20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
224	RT	Software Limitation	PGAE	Fresno	5/10/2019	7 - 15	No	INC	2	13:00	15:00	1.85	0.00	0.00	73.54	3.70	13.29	0.00	0.00	0.00	0.00	
225	RT	Software Limitation	PGAE	Fresno	5/26/2019	0	No	INC	3	11:10	14:10	-8.75	0.00	0.00	-0.09	-8.75	0.00	-0.09	0.00	0.00	0.00	
226	RT	Software Limitation	PGAE	NA	5/10/2019	25	No	DEC	1	12:55	13:00	-0.27	0.00	0.00	3.55	0.10	-1.26	0.00	0.00	0.00	0.00	
227	RT	Software Limitation	PGAE	NA	5/10/2019	25	No	INC	1	13:00	13:30	-2.75	0.00	0.00	49.25	0.22	-3.52	0.00	0.00	0.00	0.00	
228	RT	Software Limitation	SCE	LA Basin	5/18/2019	0	No	INC	1	22:30	23:30	-12.01	0.00	0.00	0.00	-12.01	0.00	0.00	0.00	0.00	0.00	
229	RT	Software Limitation	SDGE	San Diego-IV	5/20/2019	155	No	INC	1	3:00	4:00	0.00	7511.88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
230	RT	SOL	PGAE	Fresno	5/19/2019	8	No	DEC	1	12:40	13:30	2.51	0.00	0.00	-11.63	-0.45	0.00	-5.84	0.00	0.00	0.00	
231	RT	SOL	PGAE	NA	5/16/2019	40	No	INC	1	14:10	15:00	15.65	0.00	0.00	181.43	0.00	0.00	0.00	0.00	0.00	0.00	
232	RT	SOL	PGAE	Stockton	5/6/2019	45 - 55	No	DEC	3	19:45	22:00	-58.06	0.00	0.00	0.00	-4.98	0.00	0.00	0.00	0.00	0.00	
233	RT	SOL	PGAE	Stockton	5/6/2019	40 - 55	No	INC	2	22:00	0:00	1.21	0.00	0.00	-1835.45	2.07	-1869.85	-1.67	0.00	0.00	0.00	

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
234	RT	SOL	PGAE	Stockton	5/7/2019	45	No	DEC	1	0:00	1:00	-5.15	0.00	0.00	-19.55	-7.50	0.00	23.78	0.00	0.00	0.00
235	RT	Unit Testing	Intertie	NA	5/2/2019	11	No	INC	15	9:00	0:00	164.82	0.00	0.00	-1675.36	164.77	-1674.53	0.00	0.00	0.00	0.00
236	RT	Unit Testing	Intertie	NA	5/3/2019	16	No	INC	24	0:00	0:00	383.90	0.00	0.00	-7345.23	383.90	-7345.23	0.00	0.00	0.00	0.00
237	RT	Unit Testing	Intertie	NA	5/4/2019	11	No	INC	24	0:00	0:00	264.05	0.00	0.00	-7964.54	264.00	-7963.61	0.00	0.00	0.00	0.00
238	RT	Unit Testing	Intertie	NA	5/5/2019	11	Yes	INC	24	0:00	0:00	264.00	0.00	0.00	-3824.83	264.00	-3824.83	0.00	0.00	0.00	0.00
239	RT	Unit Testing	Intertie	NA	5/6/2019	11	Yes	INC	24	0:00	0:00	264.00	0.00	0.00	-4668.41	264.00	-4668.41	0.00	0.00	0.00	0.00
240	RT	Unit Testing	Intertie	NA	5/7/2019	11	Yes	INC	24	0:00	0:00	264.00	0.00	0.00	-8240.26	264.00	-8240.26	0.00	0.00	0.00	0.00
241	RT	Unit Testing	Intertie	NA	5/8/2019	11	No	INC	24	0:00	0:00	264.00	0.00	0.00	-5715.51	264.00	-5715.51	0.00	0.00	0.00	0.00
242	RT	Unit Testing	Intertie	NA	5/9/2019	16	Yes	INC	24	0:00	0:00	318.58	0.00	0.00	-6923.44	318.58	-6923.44	0.00	0.00	0.00	0.00
243	RT	Unit Testing	Intertie	NA	5/10/2019	16	No	INC	24	0:00	0:00	384.02	0.00	0.00	-13442.20	384.00	-13441.78	0.00	0.00	0.00	0.00
244	RT	Unit Testing	Intertie	NA	5/11/2019	18	Yes	INC	24	0:00	0:00	432.01	0.00	0.00	-6054.14	431.98	-6053.66	0.00	0.00	0.00	0.00
245	RT	Unit Testing	Intertie	NA	5/12/2019	21	No	INC	24	0:00	0:00	503.97	0.00	0.00	-5409.99	503.97	-5409.99	0.00	0.00	0.00	0.00
246	RT	Unit Testing	Intertie	NA	5/13/2019	21	No	INC	24	0:00	0:00	504.11	0.00	0.00	-9824.99	504.00	-9823.66	0.00	0.00	0.00	0.00
247	RT	Unit Testing	Intertie	NA	5/14/2019	32	No	INC	24	0:00	0:00	767.94	0.00	0.00	-16437.37	767.89	-16436.61	0.00	0.00	0.00	0.00
248	RT	Unit Testing	Intertie	NA	5/15/2019	37	No	INC	24	0:00	0:00	887.95	0.00	0.00	-20714.44	887.95	-20714.44	0.00	0.00	0.00	0.00
249	RT	Unit Testing	Intertie	NA	5/16/2019	37	No	INC	24	0:00	0:00	888.00	0.00	0.00	-11314.78	888.00	-11314.78	0.00	0.00	0.00	0.00
250	RT	Unit Testing	Intertie	NA	5/17/2019	37	No	INC	24	0:00	0:00	802.49	0.00	0.00	-4335.61	802.44	-4335.61	0.00	0.00	0.00	0.00
251	RT	Unit Testing	Intertie	NA	5/18/2019	42	Yes	INC	24	0:00	0:00	1007.95	0.00	0.00	-34735.59	1007.95	-34735.59	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
252	RT	Unit Testing	Intertie	NA	5/19/2019	42	Yes	INC	24	0:00	0:00	1008.00	0.00	0.00	-29534.99	1008.00	-29534.99	0.00	0.00	0.00	0.00
253	RT	Unit Testing	Intertie	NA	5/20/2019	42	No	INC	24	0:00	0:00	492.63	0.00	0.00	-4279.72	492.63	-4279.72	0.00	0.00	0.00	0.00
254	RT	Unit Testing	Intertie	NA	5/21/2019	45	No	INC	24	0:00	0:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
255	RT	Unit Testing	Intertie	NA	5/22/2019	45	No	INC	5	0:00	4:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
256	RT	Unit Testing	Intertie	NA	5/23/2019	45	No	INC	24	0:00	0:00	1060.31	0.00	0.00	-29443.12	1060.31	-29443.12	0.00	0.00	0.00	0.00
257	RT	Unit Testing	Intertie	NA	5/24/2019	45	Yes	INC	24	0:00	0:00	1080.02	0.00	0.00	-12601.46	1080.00	-12601.24	0.00	0.00	0.00	0.00
258	RT	Unit Testing	Intertie	NA	5/25/2019	47	Yes	INC	24	0:00	0:00	1127.98	0.00	0.00	-7486.42	1127.98	-7486.42	0.00	0.00	0.00	0.00
259	RT	Unit Testing	Intertie	NA	5/26/2019	47	No	INC	24	0:00	0:00	1128.03	0.00	0.00	-15770.86	1128.00	-15770.46	0.00	0.00	0.00	0.00
260	RT	Unit Testing	Intertie	NA	5/27/2019	50	No	INC	24	0:00	0:00	1200.02	0.00	0.00	-8763.65	1199.97	-8763.41	0.00	0.00	0.00	0.00
261	RT	Unit Testing	Intertie	NA	5/28/2019	55	Yes	INC	24	0:00	0:00	1320.15	0.00	0.00	-12800.32	1319.95	-12797.73	0.00	0.00	0.00	0.00
262	RT	Unit Testing	Intertie	NA	5/29/2019	75	No	INC	24	0:00	0:00	1775.80	0.00	0.00	-44223.36	1775.80	-44223.36	0.00	0.00	0.00	0.00
263	RT	Unit Testing	Intertie	NA	5/30/2019	74	Yes	INC	24	0:00	0:00	1776.14	0.00	0.00	-62751.11	1776.00	-62749.36	0.00	0.00	0.00	0.00
264	RT	Unit Testing	Intertie	NA	5/31/2019	87	No	INC	24	0:00	0:00	2087.92	0.00	0.00	-38932.51	2087.86	-38931.61	0.00	0.00	0.00	0.00
265	RT	Unit Testing	PGAE	Bay Area	5/13/2019	175 - 400	No	INC	6	10:00	15:15	-40.74	13379.92	0.00	1493.54	15.57	-526.68	0.00	0.00	0.00	0.00
266	RT	Unit Testing	PGAE	Bay Area	5/14/2019	160 - 585	No	INC	12	4:00	15:30	366.38	-85.06	0.00	-13967.22	431.51	-13025.99	0.00	0.00	0.00	0.00
267	RT	Unit Testing	PGAE	Bay Area	5/22/2019	20 - 47	No	INC	9	6:00	14:45	17.37	0.00	0.00	-949.39	19.12	-871.91	0.00	0.00	0.00	0.00
268	RT	Unit Testing	PGAE	Bay Area	5/23/2019	47	Yes	INC	8	6:30	14:30	4.39	358.71	0.00	-265.24	4.08	-191.71	0.00	0.00	0.00	0.00
269	RT	Unit Testing	PGAE	Bay Area	5/24/2019	47	No	INC	1	10:00	11:00	9.05	0.00	0.00	-36.90	7.54	-36.95	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
270	RT	Unit Testing	PGAE	Bay Area	5/25/2019	20	No	INC	1	12:30	13:30	-1.67	0.00	0.00	-0.02	0.00	0.00	0.00	0.00	0.00	0.00
271	RT	Unit Testing	PGAE	Bay Area	5/28/2019	24	No	INC	7	8:35	15:30	18.08	0.00	0.00	-88.57	0.87	-38.31	0.00	0.00	0.00	0.00
272	RT	Unit Testing	PGAE	Bay Area	5/29/2019	25	No	INC	8	8:00	15:30	4.95	0.00	0.00	-119.24	2.59	-117.10	0.00	0.00	0.00	0.00
273	RT	Unit Testing	PGAE	Fresno	5/10/2019	100	No	INC	2	15:50	16:55	19.94	1439.28	0.00	-376.38	4.25	-229.24	0.00	0.00	0.00	0.00
274	RT	Unit Testing	PGAE	Fresno	5/12/2019	20 - 42	No	INC	2	14:35	15:40	0.62	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00
275	RT	Unit Testing	PGAE	Fresno	5/25/2019	44	No	INC	1	15:50	16:50	4.14	0.00	0.00	-310.50	4.14	-310.50	0.00	0.00	0.00	0.00
276	RT	Unit Testing	PGAE	Fresno	5/26/2019	40	No	INC	3	11:20	13:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
277	RT	Unit Testing	PGAE	Kern	5/10/2019	0 - 51	No	INC	10	7:30	16:35	-1.48	0.00	0.00	-410.96	-24.81	-58.51	52.70	0.00	0.00	0.00
278	RT	Unit Testing	PGAE	Kern	5/23/2019	0 - 51	No	INC	5	12:35	17:00	4.92	0.00	0.00	-36.09	-10.75	-37.73	-6.77	0.00	0.00	0.00
279	RT	Unit Testing	PGAE	Kern	5/28/2019	48	No	INC	4	12:30	16:30	9.82	3543.72	0.00	-46.12	1.86	-34.42	0.00	0.00	0.00	0.00
280	RT	Unit Testing	PGAE	NA	5/7/2019	100	No	INC	4	7:00	10:45	140.79	0.00	0.00	-1600.18	112.29	-1082.98	0.00	0.00	0.00	0.00
281	RT	Unit Testing	PGAE	NA	5/8/2019	100	No	INC	13	7:00	20:00	137.46	0.00	0.00	-675.43	69.15	-1112.29	0.00	0.00	0.00	0.00
282	RT	Unit Testing	PGAE	NA	5/9/2019	100	No	INC	12	7:00	19:00	87.30	0.00	0.00	-2441.29	76.10	-2032.60	0.00	0.00	0.00	0.00
283	RT	Unit Testing	PGAE	NA	5/11/2019	20 - 30	No	INC	8	10:00	18:00	173.90	0.00	0.00	-443.88	176.87	-469.56	0.00	0.00	0.00	0.00
284	RT	Unit Testing	PGAE	NA	5/14/2019	0 - 100	No	INC	13	6:15	18:40	-9.77	352.84	0.00	-161.21	-15.11	-18.82	-14.30	0.00	0.00	0.00
285	RT	Unit Testing	PGAE	NA	5/15/2019	100	No	INC	12	7:15	19:00	74.88	0.00	0.00	-3484.74	50.40	-2213.06	0.00	0.00	0.00	0.00
286	RT	Unit Testing	PGAE	NA	5/16/2019	100	No	INC	14	7:00	21:00	121.50	0.00	0.00	-12427.28	101.45	-9484.46	0.00	0.00	0.00	0.00
287	RT	Unit Testing	PGAE	NA	5/17/2019	0 - 100	No	INC	16	7:00	23:00	81.79	0.00	0.00	-849.76	95.10	0.00	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
288	RT	Unit Testing	PGAE	Stockton	5/18/2019	112	No	INC	1	22:00	23:00	88.03	0.00	0.00	-1570.04	6.13	-189.23	0.00	0.00	0.00	0.00
289	RT	Unit Testing	SCE	Big Creek-Ventura	5/8/2019	50 - 750	No	INC	8	15:00	23:00	3110.65	0.00	0.00	-109636.06	352.03	-23896.13	0.00	0.00	0.00	0.00
290	RT	Unit Testing	SCE	Big Creek-Ventura	5/29/2019	100 - 741.27	No	INC	5	15:30	20:30	223.96	0.00	0.00	-28782.38	0.00	0.00	0.00	0.00	0.00	0.00
291	RT	Unit Testing	SCE	LA Basin	5/1/2019	20 - 335	No	INC	21	3:00	0:00	386.62	169493.65	32332.59	-7325.31	36.15	-3358.16	0.00	0.00	0.00	0.00
292	RT	Unit Testing	SCE	LA Basin	5/2/2019	20 - 497.97	No	INC	24	0:00	0:00	1079.00	281013.49	0.00	-23734.21	100.08	-10531.98	0.00	0.00	0.00	0.00
293	RT	Unit Testing	SCE	LA Basin	5/3/2019	20 - 70	No	INC	7	0:00	7:00	63.19	69548.43	0.00	-1321.86	0.00	0.00	0.00	0.00	0.00	0.00
294	RT	Unit Testing	SCE	LA Basin	5/6/2019	20 - 40	No	INC	7	17:00	0:00	-4.65	20756.20	19304.09	-2700.41	14.87	-3250.86	0.00	0.00	0.00	0.00
295	RT	Unit Testing	SCE	LA Basin	5/7/2019	20 - 130	No	INC	24	0:00	0:00	43.40	119153.18	32536.38	-14317.47	20.87	-2605.92	0.00	0.00	0.00	0.00
296	RT	Unit Testing	SCE	LA Basin	5/8/2019	10 - 505.96	No	INC	24	0:00	0:00	380.08	570798.70	0.00	-14728.92	141.08	-8066.08	0.00	0.00	0.00	0.00
297	RT	Unit Testing	SCE	LA Basin	5/9/2019	10 - 130	No	INC	14	0:00	13:30	53.07	56594.27	0.00	-4267.31	14.87	-3479.57	0.00	0.00	0.00	0.00
298	RT	Unit Testing	SCE	LA Basin	5/11/2019	10 - 16	No	INC	12	10:40	22:15	-0.92	946.52	0.00	70.16	0.00	-0.39	0.00	0.00	0.00	0.00
299	RT	Unit Testing	SCE	LA Basin	5/12/2019	10	No	INC	21	3:20	0:00	30.44	67873.18	0.00	85.86	0.00	0.00	0.00	0.00	0.00	0.00
300	RT	Unit Testing	SCE	LA Basin	5/13/2019	10 - 475	No	INC	24	0:00	0:00	1082.98	310343.08	49032.45	-56544.09	329.94	-28755.85	0.00	0.00	0.00	0.00
301	RT	Unit Testing	SCE	LA Basin	5/14/2019	20 - 497	No	INC	24	0:00	0:00	3660.70	188847.97	0.00	-222958.91	574.33	-44699.44	0.00	0.00	0.00	0.00
302	RT	Unit Testing	SCE	LA Basin	5/15/2019	70 - 130	No	INC	21	0:00	21:00	2782.71	113817.00	0.00	-235350.37	0.00	0.00	0.00	0.00	0.00	0.00
303	RT	Unit Testing	SCE	LA Basin	5/23/2019	98 - 535	No	INC	5	8:00	12:15	544.75	11206.23	0.00	-11165.61	276.06	-8257.38	0.00	0.00	0.00	0.00
304	RT	Unit Testing	SCE	LA Basin	5/31/2019	5	No	DEC	1	20:30	21:00	-0.29	0.00	0.00	10.02	0.00	0.00	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
305	RT	Unit Testing	SCE	LA Basin	5/31/2019	5	No	INC	2	20:30	22:30	1.84	0.00	0.00	-60.71	0.00	0.00	0.00	0.00	0.00	0.00
306	RT	Unit Testing	SCE	NA	5/1/2019	214	No	INC	7	13:45	20:00	301.09	-6222.14	0.00	-1888.72	304.48	-2099.97	0.00	0.00	0.00	0.00
307	RT	Unit Testing	SCE	NA	5/2/2019	125 - 410.01	No	INC	9	12:35	21:00	-42.36	8275.33	0.00	-1110.20	23.88	-973.52	0.00	0.00	0.00	0.00
308	RT	Unit Testing	SCE	NA	5/3/2019	0	No	INC	2	19:10	20:45	-34.82	750.44	10491.68	-3157.61	-161.17	0.00	32.25	0.00	0.00	0.00
309	RT	Unit Testing	SDGE	San Diego-IV	5/9/2019	101	No	INC	1	8:30	8:50	13.51	0.00	0.00	-538.36	13.51	-538.36	0.00	0.00	0.00	0.00
310	RT	Unit Testing	SDGE	San Diego-IV	5/11/2019	60 - 100	No	INC	5	17:15	21:25	-16.24	3218.75	1337.15	-768.07	32.25	-1617.98	0.00	0.00	0.00	0.00
311	RT	Unit Testing	SDGE	San Diego-IV	5/16/2019	24	No	INC	3	6:40	9:30	1.17	-27.99	0.00	-102.93	0.00	0.00	0.00	0.00	0.00	0.00
312	RT	Unit Testing	SDGE	San Diego-IV	5/21/2019	105 - 422	No	INC	2	13:00	14:30	614.35	0.00	0.00	105.74	575.04	-25.54	0.00	0.00	0.00	0.00
313	RT	Unit Testing	SDGE	San Diego-IV	5/22/2019	50	No	INC	1	18:00	18:30	9.68	0.00	0.00	-164.04	2.34	-164.03	0.00	0.00	0.00	0.00
314	RT	Unit Testing	SDGE	San Diego-IV	5/30/2019	107.8	No	INC	1	20:30	20:40	9.03	0.00	0.00	-461.32	9.03	-461.32	0.00	0.00	0.00	0.00
315	RT	Voltage Support	PGAE	Fresno	5/16/2019	83	No	INC	1	18:00	19:00	30.57	4153.35	0.00	-397.10	0.00	0.00	0.00	0.00	0.00	0.00
316	RT	Voltage Support	PGAE	Fresno	5/19/2019	-297	No	DEC	23	1:30	0:00	-74.25	0.00	0.00	954.17	0.00	0.00	0.00	0.00	0.00	0.00
317	RT	Voltage Support	PGAE	Fresno	5/19/2019	83	No	INC	2	17:30	19:00	78.21	9560.95	0.00	-4750.70	0.00	0.00	0.00	0.00	0.00	0.00
318	RT	Voltage Support	PGAE	Fresno	5/20/2019	-297	No	DEC	5	0:00	4:45	-33.25	0.00	0.00	469.76	0.00	0.00	0.00	0.00	0.00	0.00
319	RT	Voltage Support	PGAE	Fresno	5/21/2019	20	No	INC	2	16:30	18:30	2.48	3144.82	0.00	-1304.48	0.00	0.00	0.00	0.00	0.00	0.00
320	RT	Voltage Support	PGAE	Fresno	5/22/2019	-301 - -288	No	DEC	16	0:30	16:10	-186.42	0.00	0.00	6064.53	0.00	0.00	0.00	0.00	0.00	0.00
321	RT	Voltage Support	PGAE	Fresno	5/22/2019	83 - 292	No	INC	11	8:30	19:00	18.66	10979.67	0.00	-85.71	3.00	-62.71	0.00	0.00	0.00	0.00
322	RT	Voltage Support	PGAE	Fresno	5/26/2019	-286	No	DEC	2	8:55	10:30	-71.50	0.00	0.00	-0.75	0.00	0.00	0.00	0.00	0.00	0.00

**California Independent System Operator Corporation
Exceptional Dispatch Report
August 30, 2019**

Chart 2: Table of Exceptional Dispatches for Period 01/May/2019 - 31/May/2019

Number	Market Type	Reason	Location	Local Reliability Area	Trade Date	MW	Commitment	INC_DEC	Hours	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488	CC6620
323	RT	Voltage Support	PGAE	Fresno	5/26/2019	0 - 83	No	INC	19	0:40	19:00	270.23	98729.80	0.00	-43431.37	-41.50	0.00	-285.51	0.00	0.00	0.00
324	RT	Voltage Support	PGAE	Fresno	5/27/2019	-308 - -286	No	DEC	18	0:00	18:00	-74.96	0.00	0.00	1153.81	0.00	0.00	0.00	0.00	0.00	0.00
325	RT	Voltage Support	PGAE	Fresno	5/28/2019	-292	No	DEC	4	1:15	4:30	-138.33	0.00	0.00	659.45	0.00	0.00	0.00	0.00	0.00	0.00

Appendix A: Explanation by Example

All examples listed below are based on fictitious data. Many simplified assumptions are made to explain settlement charge codes, and not all assumptions are explicitly stated in these examples. For instance, settlement charge codes are calculated based on metered quantities, whereas in these examples, the dispatch quantities are assumed to be equal to metered quantities. These assumptions have been made to simplify the understanding of settlements calculations.

Example 1: Exceptional Dispatch Instructions Prior to DAM

In this fictitious example, the CAISO issued an exceptional dispatch instruction for resource A to be committed at its Pmin of 50 MW from hours ending 5 through 10 for a generation procedure 7630. Similarly, the CAISO issued additional instructions to resources B and C for the same reason in Table 2. Exceptional dispatches prior to the day-ahead market are commitments to minimum load. Here the dispatch levels are all at minimum load. Table 2 below also shows the commitment costs and the total volume (MWh) of exceptional dispatch instruction for each resource. The minimum load costs and start up costs, shown in Table 2 are the eligible minimum load and start up costs different from the bid-in minimum load and start up costs⁷. Only those quantities which relate to pre-day-ahead unit commitments are shown in this table.

Table 2: Instructions Prior to Day-Ahead Market

Date	Market	Resource	Location	Local Reliability Area (LRA)	Begin Time	End Time	Dispatch level (MW)	Reason	Total Volume (MWh)	Min-Load Cost	Start- Up Cost	CC6620 (BCR)
01-Jul-09	DA	A	SCE	LA BASIN	05:00	10:00	50	7630	300	\$5000	\$0	0
01-Jul-09	DA	B	SCE	LA BASIN	08:00	20:00	30	7630	390	\$6000	\$500	\$4000
01-Jul-09	DA	C	SCE	LA BASIN	09:00	23:00	20	7630	300	\$400	\$1000	\$1000

This data is summarized as shown in Table 3, which is the prescribed format specified in the FERC order on September 02, 2009. This summary classifies the data by reason, resource location, local reliability area, and trade date. The MW column in Table 3 is the range of MW; in this case the minimum instruction MW is 20 MW for resource C which occurs from hours ending 21 through 23. The maximum instruction occurs in hour ending 10. In this hour resource A is committed at 50 MW, resource B is committed at 30 MW and resource C is committed at 20 MW. This adds up to 100 MW. The MW column shows the minimum and maximum of the overlaps of all the exceptional dispatch instructions. The Commitment column shows whether a resource was committed between the begin time and end time. Commitments are broken out separately from energy dispatches. In the day-ahead however, the exceptional dispatches are nearly always just commitments, as in this example. The Begin Time column shows hour ending 5 as this was the hour ending for first dispatch of the day, and the End Time column shows hour ending 23, as this was the hour with last dispatch. It is also possible there might be hours between the begin time and the end time where there might not be exceptional dispatch instructions for the reason, meaning that the range between the begin time and end time can include null hours with no dispatch. The total volume (MWh) is the MWh quantity for each resource, which adds up to 990 MWh. Similarly, all cost information is sum of individual resource costs. Some resources bid-in zero start-up cost; as seen in this example, resource A bid in zero for its start up cost. Since the CAISO does not explicitly pay a resource for bid-in minimum load costs and start-up costs; these costs are recovered through the charge code CC6620 (Bid Cost Recovery), this table shows the summary of CC6620 for the classification. Here, it is the CC6620 for all three resources which adds up to \$5000. This column shows the impact of exceptional dispatch on bid cost recovery for all pre-day-ahead exceptional dispatch commitments.

Table 3: FERC Summary of Instructions Prior to DAM

Number	Market Type	Reason	Location	Local Reliability Area (LRA)	Trade Date	MW	Commitment	INC/DEC	Hour	Begin Time	End Time	Total Volume (MWh)	Min-Load Cost	Start-Up Cost	CC6620
1	DA	7630	SCE	LA Basin	1-Jul-09	20-100	Yes	N/A	19	05:00	23:00	990	\$11,400	\$1,500	\$5000

Example 2: Incremental Exceptional Dispatch Instructions in RTM

In this fictitious example the CAISO issued an exceptional dispatch instruction to resource A to be committed at its Pmin of 30 MW from hours 6:00 through 11:00 after completion of the day-ahead market for the transmission procedure 7110. This resource had no day-ahead award in those hours. The CAISO issued another exceptional dispatch instruction to resource B, to be dispatched at 40 MW from hours 7:00

⁷ Please refer to the BPM configuration Guide: Bid Cost Recovery Settlements published on the CAISO's website for details about eligible minimum load and start up costs.

through 9:00 in real-time for the transmission procedure 7110. This resource had a day-ahead schedule of 20 MW from the day-ahead market, which implies this exceptional dispatch instruction was an incremental instruction and the exceptional dispatch MW was 20 MW. Similarly, the details of exceptional dispatch (ED) instruction for resource C are shown in Table 4. This table also shows volume (MWh) and various real-time charge codes associated with the exceptional dispatch instructions. The total MWh column for each resource shows all types of imbalance energy quantities for this resource between the begin time and end time which includes both the exceptional dispatch energy quantities and optimal energy quantities.

Resource A was committed at its Pmin so its total volume (MWh) is equal to its Pmin times the number of hours, which is calculated as 30 MW times 6 hours and is equal to 180 MWh. The resource Minimum load costs and the start up costs are its eligible commitment costs for that period. LMP at this resource is \$10/MWh, so the charge code CC6470 is calculated at (180 MWh * \$10/MWh) and is equal to \$1,800. Since this resource is not dispatched above its Pmin, it has a zero volume (MWh) of exceptional dispatch. All charge codes associated with the exceptional dispatch increment or decrement quantities are zero.

Resource B is dispatched 20 MW above its day-ahead schedule, so its total volume (MWh) is calculated as 20 MW times 3 hours which is equal to 60 MWh. Since the resource was committed in the Day-Ahead Market there are no minimum load quantity and start up costs associated with this resource. The resource had a bid price of \$100/MWh and the LMP at that resource was \$10/MWh. All of 60 MWh is considered as exceptional dispatch incremental quantity shown in ED Volume (MWH INC/DEC) column. The charge code CC6470 INC is calculated as 60 MWh * resource LMP (\$10/MWh) which is equal to \$600. Since the only imbalance energy in this timeframe was the exceptional dispatch volume, the charge code CC6470 is equal to CC6470 INC. The charge code CC6488 is calculated as MWH quantity *(bid price – LMP), which is equal to \$5400 (60 MWh *(\$10/MWh-\$100/MWh)). Similarly, volumes and real-time charge codes are calculated for resource C.

Table 4: Incremental Exceptional Dispatch Instructions in RTM

Date	Market	Resource	Location	Local Reliability Area (LRA)	Begin Time	End Time	Dispatch level (MW)	Day-Ahead Award (MW)	Commitment	INC/DEC	ED (MW)	Reason	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488
1-Jul-09	RT	A	PG&E	Humboldt	6:00	11:00	30	0	Yes	INC	30	7110	180	1000	50	1800	0	0	0	0	0
1-Jul-09	RT	B	PG&E	Humboldt	7:00	9:00	40	20	No	INC	20	7110	60	0	0	600	60	600	0	0	5400
1-Jul-09	RT	C	PG&E	Humboldt	12:00	15:00	50	50	No	INC	0	7110	0	0	0	0	0	0	0	0	0
1-Jul-09	RT	C	PG&E	Humboldt	16:00	20:00	50	40	No	INC	10	7110	50	0	0	300	20	300	0	0	200

This data is summarized as shown in Table 5 and is classified by reason, resource location, local reliability area, and trade date. The MW column in Table 5 is the range of MW; in this case the minimum instruction MW is 0 MW for resource C which occurs from hours ending 13 through 15. The maximum instruction occurs in hours ending 8 & 9, as during these two hours both resources A and B have an ED MW of 30MW and 20MW, respectively. This adds up to 50 MW. The MW column shows the minimum and maximum of the overlaps of all the exceptional dispatch instructions. The Commitment column shows whether a resource was committed between the begin time and end time. This column shows a commitment if there was a single commitment in the entire interval of exceptional dispatch. The Begin Time column shows the time of the first dispatch of the day. This is a time not a range. Similarly, the End Time column shows a time and not a range. Exceptional dispatches occurred between these two times. Since there was a commitment between the begin time and end time, the Commitment column displays yes for the summary. Similarly, the INC/DEC column shows an INC, as there was an incremental dispatch between the begin time and end time. As mentioned in the previous example, it is possible there might be hours between the begin time and end time where there were no exceptional dispatch instructions for the reason. Both volume and cost information columns are the summation for all the respective columns for resources A, B and C. For instance, the Total volume (MWh) column is calculated as summation of 180,60,0 and 50, which are the individual volumes (MWh) for resources A, B and C for time periods shown in Table 4.

Table 5: FERC Summary of ED Instructions in RTM

Number	Market Type	Reason	Location	Local Reliability Area (LRA)	Trade Date	MW	Commitment	INC/DEC	Hour	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488
1	RT	7110	PG&E	Humboldt	1-Jul-09	0-50	Yes	INC	15	6:00	20:00	290	1000	50	1700	140	1500	0	0	11000

It is possible that the CAISO would dispatch a particular resource, for instance at 10 MW from hours ending 1 through 4, and all or part of its energy might settle as optimal energy. This situation occurs when the LMP at the resource pricing node is above the resource bid price. This cost will only be captured in charge code 6470. It is also possible that CAISO issues an exceptional dispatch for the resource to operate at a minimum of 10 MW which is its Pmin; however the market application might dispatch this resource above Pmin because the resource is economical. When this occurs, the charge code CC6470 and the total MWh quantity might overstate the actual exceptional dispatch MWh quantities. So, to best estimate the cost and volume (MWh) of exceptional dispatch, it is appropriate to consider only the following columns: ED MWh (INC/DEC), CC6470 INC, CC6470 DEC, CC6482, CC6488.

Example 3: Decremental Exceptional Dispatch Instructions in RTM

This example highlights decremental exceptional dispatch instructions in the real-time market. In this fictitious example, the CAISO issued an exceptional dispatch instruction to resource A to be committed at its Pmin of 20 MW from hours ending 15 through 20 after completion of the day-ahead market for the transmission procedure 7430. The CAISO issued additional exceptional dispatch instructions for resources B and C; details of those instructions are shown in Table 6. This table also includes volume (MWh) and cost information.

Resource A is committed in real-time at its Pmin, its total volume (MWh) is 20MW *6 hours which is equal to 120 MWh. This resource has a zero MW of incremental dispatch in all hours, so all other relevant cost and volume columns result in zeros. Resource B has a decremental MW of 20 MW in 3 hours, which results in 60 MWh of decremental volume. Since this resource is not committed in real-time, both the minimum load cost and start up costs are zero. This resource had a bid price of \$50/MWh and LMP at the resource pricing node is \$10/ MWh. Based on this information CC6470-Dec is calculated as 60 MWh *\$10/MWh which is equal to \$600. Since this resource has its ED volume (MWh) equal to its Total volume, CC6470 is equal to CC6470- DEC. The CC6488 is calculated as (60 MWh * (\$50/MWh - \$10/MWh)), which is equal to \$2400. Resource C had a bid price of \$10/MWh and the LMP at its pricing node is \$50/MWh. Based on this information, volume and cost information is calculated for resource C.

Table 6: Decremental Exceptional Dispatch Instructions in RTM

Date	Market Type	Resource	Location	Local Reliability Area (LRA)	Begin Time	End Time	Dispatch level (MW)	Day-Ahead Award (MW)	Commitment	INC/DEC	ED (MW)	Reason	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488
1-Jul-09	RT	A	PG&E	Fresno	15:00	20:00	20	0	Yes	INC	20	7430	120	\$ 120	\$ 100	\$ -	0	\$ -	\$ -	\$ -	\$ -
1-Jul-09	RT	B	PG&E	Fresno	7:00	9:00	40	60	No	DEC	20	7430	(60)	\$ -	\$ -	\$ 600	-60	\$ -	\$ 600	\$ -	\$2,400
1-Jul-09	RT	C	PG&E	Fresno	10:00	14:00	40	50	No	DEC	10	7430	(50)	\$ -	\$ -	\$ 500	-50	\$ -	\$ 500	\$ -	\$2,000

This data is summarized according to FERC convention in Table 7. This summary classifies the data by reason, resource location, local reliability area, and trade date. Incs and decs are broken out separately. The inc entry is self-explanatory and similar to the previous example. Regarding the dec entry the MW column is the range of MW; in this case the minimum dec instruction is 10 MW (actually -10MW as it is a dec) for resource C which occurs from hours ending 10 through 14. The maximum instruction occurs from hours ending 7 through 9, when resource B was issued a dec instruction of 20 MW. The MW column shows the minimum and maximum of the overlaps of all the exceptional dispatch instructions. The Commitment column shows whether a resource was committed between the begin time and end time. The volume and cost information are summarized by INC and DEC classification.

Table 7: FERC Summary of Decremental ED Instructions in RTM

Number	Market Type	Reason	Location	Local Reliability Area (LRA)	Trade Date	MW	Commitment	INC/DEC	Hour	Begin Time	End Time	Total MWH	Min Load Cost	Start Up Cost	CC6470	ED MWH (INC/DEC)	CC6470 INC	CC6470 DEC	CC6482	CC6488
1	RT	7430	PG&E	Fresno	1-Jul-09	20	Yes	INC	6	15:00	20:00	120	\$ 120	\$ 100	\$ -	0	\$ -	\$ -	\$ -	\$ -
2	RT	7430	PG&E	Fresno	1-Jul-09	10-20	Yes	DEC	8	7:00	14:00	(110)	\$ -	\$ -	\$ (1,100)	\$ (110)	\$ -	\$ (1,100)	\$ -	\$ (4,400)

Appendix B: Price Impact Analysis

In the September 2 FERC order, FERC requested the CAISO to perform price impact analysis on two distinct pricing nodes for the entire reporting period. The order also mentioned that the CAISO must pick two pricing nodes for the entire reporting period that are most affected by the exceptional dispatch instructions, and the two pricing nodes must belong to two load aggregation points (LAPs).

Based on this requirement the CAISO implemented a methodology to perform price impact analysis. First, the CAISO identified a heavily affected pricing node from each of the Pacific Gas & Electric (PG&E) LAP and Southern California Edison (SCE) LAP. These two pricing nodes had the maximum amount of exceptional dispatch volume (MWh) in their respective LAP. Point A is in PG&E LAP and point B is in SCE LAP. Please note these two points correspond to an actual pricing node in the CAISO system. Only one resource was connected to each of these pricing nodes. For each resource the following input parameters were obtained to perform the analysis:

Exceptional dispatch information: constrained level, constraint type, start of exceptional dispatch instruction and end of exceptional dispatch instruction.
 Real-Time LMPs for each of the five minute intervals for the month.
 Real-Time hourly bid set for each trade hour.
 Day-Ahead award for the resources.

The exceptional dispatch intervals have a begin time and an end time which can span as small as one minute to as large as 24 hours. Since the market application dispatches resources on five-minute basis, the exceptional dispatch instructions for each of these resources were broken down into five-minute intervals. If the begin time or end time for an instruction was in the middle of the five-minute interval, that instruction was rounded up to the next five-minute interval. These five-minute intervals were then coupled with resource five-minute LMPs calculated by the real-time market application. Also, the hourly bid information and the hourly day-ahead schedule were put together to create a dataset that had all the information to perform price impact analysis.

An exceptional dispatch instruction can be classified as a start up instruction, an instruction to be dispatched at or above the constrained level, an instruction to be dispatched at or below a constrained level, an instruction to be dispatched at a fixed constrained level, or a shut down instruction. The Locational Marginal Price (LMP) is set by a resource which can provide the next incremental MW of energy. Based on this definition of LMP and the classification of exceptional dispatches based on constraint type, a resource may set the LMP in only those intervals in which the resource is eligible to move either up or down from its constrained level. Hence, in those intervals in which the resource was constrained up at its Pmax or the resource was exceptionally dispatched to its Pmax and forced to generate at that level, the resource was ineligible to set the price as it had no room to move up. Similarly, if the resource was constrained down at its Pmin, then the resource was not eligible to set the price. All those intervals in which the resource was ineligible to set the price were dropped from the dataset under consideration. From this dataset of only eligible intervals, for both pricing nodes A and B, LMPs were calculated for all intervals based on the resource dispatch level and the its bid set. The calculated LMP is equal to that bid price corresponding to the constrained MW segment.

Table 8 shows the price impact analysis information for node A, which is in the PG&E area. This table shows all the five minute intervals in which the resource at PNode A was issued an exceptional dispatch instruction and was eligible to set the price. Out of the 8,928 five-minute intervals in May, this resource was issued exceptional dispatch instructions in 132 five-minute intervals. This resource was eligible to set the LMP in 48 intervals. Out of the 48 intervals, resource calculated LMP was larger than the market LMP in 48 intervals. In the 48 intervals, the average increase in five minute LMP was \$412.51/MWh. Out of the 48 intervals, resource calculated LMP was less than the market LMP in 0 intervals. This implies that if the CAISO could model the constraint for this exceptional dispatch, then this resource and all other pricing nodes associated with that constraint would observe an average increase of \$412.51/MWh

Table 9 shows the price impact analysis information for node B, which is in the SCE area. This table shows all the five minute intervals in which the resource at PNode B was issued an exceptional dispatch instruction and was eligible to set the price. Out of the 8,928 five-minute intervals in May, this resource was issued exceptional dispatch instructions in 442 five-minute intervals. This resource was eligible to set the LMP in 185 intervals. Out of the 185 intervals, resource calculated LMP was larger than the market LMP in 140 intervals. In the 140 intervals, the average increase in five minute LMP was \$19.34/MWh. Out of the 185 intervals, resource calculated LMP was less than the market LMP in 45 intervals. In the 45 intervals, the average decrease in five minute LMP was \$10.96/MWh. This implies that if the CAISO could model the constraint for this exceptional dispatch, then this resource and all other pricing nodes associated with that constraint would observe an average increase of \$11.97/MWh

Table 8: Price Impact Analysis Information for Pricing Node A in PG&E LAP

Number	Trade Date	Trade Hour	Interval	Market LMP	Eligible Flag	Calculated LMP	Change in LMP
1	5/23/2019	18	1	21.62	Yes	74.09	52.47
2	5/23/2019	18	2	21.59	Yes	74.09	52.50
3	5/23/2019	18	3	21.59	Yes	74.09	52.50
4	5/23/2019	18	4	19.98	Yes	74.09	54.11
5	5/23/2019	18	5	19.98	Yes	74.09	54.11
6	5/23/2019	18	6	19.98	Yes	74.09	54.11
7	5/23/2019	18	7	28.00	Yes	74.09	46.09
8	5/23/2019	18	8	34.50	Yes	74.09	39.59
9	5/23/2019	18	9	29.88	Yes	74.09	44.21
10	5/23/2019	18	10	36.22	Yes	74.09	37.87
11	5/23/2019	18	11	30.58	Yes	74.09	43.51
12	5/23/2019	18	12	29.50	Yes	74.09	44.59
13	5/23/2019	19	1	17.51	Yes	900	882.49
14	5/23/2019	19	2	16.51	Yes	900	883.49
15	5/23/2019	19	3	14.00	Yes	900	886.00
16	5/23/2019	19	4	18.37	Yes	900	881.63
17	5/23/2019	19	5	16.98	Yes	900	883.02
18	5/23/2019	19	6	17.36	Yes	900	882.64
19	5/23/2019	19	7	29.04	Yes	74.09	45.05
20	5/23/2019	19	8	31.45	Yes	74.09	42.64
21	5/23/2019	19	9	19.99	Yes	74.09	54.10
22	5/23/2019	19	10	28.91	Yes	900	871.09
23	5/23/2019	19	11	29.23	Yes	900	870.77
24	5/23/2019	19	12	28.91	Yes	900	871.09
25	5/23/2019	20	1	15.74	Yes	74.09	58.35
26	5/23/2019	20	2	15.00	Yes	74.09	59.09
27	5/23/2019	20	3	14.82	Yes	74.09	59.27
28	5/23/2019	20	4	16.33	Yes	74.09	57.76
29	5/23/2019	20	5	18.28	Yes	74.09	55.81
30	5/23/2019	20	6	18.28	Yes	74.09	55.81
31	5/23/2019	20	7	18.28	Yes	74.09	55.81
32	5/23/2019	20	8	19.98	Yes	74.09	54.11
33	5/23/2019	20	9	20.38	Yes	74.09	53.71
34	5/23/2019	20	10	28.05	Yes	74.09	46.04

Department of Market Quality and Renewable Integration – California ISO

Number	Trade Date	Trade Hour	Interval	Market LMP	Eligible Flag	Calculated LMP	Change in LMP
35	5/23/2019	20	11	22.88	Yes	74.09	51.21
36	5/23/2019	20	12	19.97	Yes	74.09	54.12
37	5/23/2019	21	1	20.58	Yes	900	879.42
38	5/23/2019	21	2	19.97	Yes	900	880.03
39	5/23/2019	21	3	19.97	Yes	900	880.03
40	5/23/2019	21	4	20.68	Yes	900	879.32
41	5/23/2019	21	5	20.09	Yes	900	879.91
42	5/23/2019	21	6	22.82	Yes	900	877.18
43	5/23/2019	21	7	28.60	Yes	900	871.40
44	5/23/2019	21	8	29.08	Yes	900	870.92
45	5/23/2019	21	9	29.23	Yes	900	870.77
46	5/23/2019	21	10	29.08	Yes	900	870.92
47	5/23/2019	21	11	28.91	Yes	900	871.09
48	5/23/2019	21	12	21.40	Yes	900	878.60

Table 9: Price Impact Analysis Information for Pricing Node B in SCE LAP

Number	Trade Date	Trade Hour	Interval	Market LMP	Eligible Flag	Calculated LMP	Change in LMP
1	5/6/2019	20	10	28.55	Yes	30.32	1.77
2	5/6/2019	20	11	33.43	Yes	30.32	-3.11
3	5/6/2019	20	12	32.79	Yes	30.32	-2.47
4	5/6/2019	21	1	25.01	Yes	30.32	5.31
5	5/6/2019	21	2	28.29	Yes	30.32	2.03
6	5/6/2019	21	3	26.80	Yes	30.32	3.52
7	5/6/2019	21	4	28.48	Yes	30.32	1.84
8	5/6/2019	21	5	28.70	Yes	30.32	1.62
9	5/6/2019	21	6	28.70	Yes	30.32	1.62
10	5/6/2019	21	7	28.70	Yes	30.32	1.62
11	5/6/2019	21	8	29.00	Yes	30.32	1.32
12	5/6/2019	21	9	26.33	Yes	30.32	3.99
13	5/6/2019	21	10	26.01	Yes	30.32	4.31
14	5/6/2019	21	11	26.30	Yes	30.32	4.02
15	5/6/2019	21	12	29.00	Yes	30.32	1.32
16	5/6/2019	22	1	26.81	Yes	30.32	3.51
17	5/6/2019	22	2	28.21	Yes	30.32	2.11
18	5/6/2019	22	3	28.29	Yes	30.32	2.03
19	5/6/2019	22	4	26.30	Yes	30.32	4.02
20	5/6/2019	22	5	26.00	Yes	30.32	4.32
21	5/6/2019	22	6	28.67	Yes	30.32	1.65
22	5/6/2019	22	7	26.00	Yes	30.32	4.32
23	5/6/2019	22	8	25.05	Yes	30.32	5.27
24	5/6/2019	22	9	20.25	Yes	30.32	10.07
25	5/6/2019	22	10	20.25	Yes	30.32	10.07
26	5/6/2019	22	11	20.25	Yes	30.32	10.07
27	5/6/2019	22	12	20.00	Yes	30.32	10.32
28	5/6/2019	23	1	20.64	Yes	30.32	9.68
29	5/6/2019	23	2	22.79	Yes	30.32	7.53
30	5/6/2019	23	3	39.28	Yes	30.32	-8.96
31	5/6/2019	23	4	35.00	Yes	30.32	-4.68
32	5/6/2019	23	5	30.44	Yes	30.32	-0.12
33	5/6/2019	23	6	27.47	Yes	30.32	2.85
34	5/6/2019	23	7	25.24	Yes	30.32	5.08

Department of Market Quality and Renewable Integration – California ISO

Number	Trade Date	Trade Hour	Interval	Market LMP	Eligible Flag	Calculated LMP	Change in LMP
35	5/6/2019	23	8	20.87	Yes	30.32	9.45
36	5/6/2019	23	9	20.17	Yes	30.32	10.15
37	5/6/2019	23	10	17.18	Yes	30.32	13.14
38	5/6/2019	23	11	19.96	Yes	30.32	10.36
39	5/6/2019	23	12	16.89	Yes	30.32	13.43
40	5/16/2019	19	11	24.57	Yes	28.66	4.09
41	5/16/2019	19	12	31.91	Yes	28.66	-3.25
42	5/16/2019	20	1	17.39	Yes	28.66	11.27
43	5/16/2019	20	2	22.29	Yes	28.66	6.37
44	5/16/2019	20	3	26.23	Yes	28.66	2.43
45	5/16/2019	20	4	31.33	Yes	28.66	-2.67
46	5/16/2019	20	5	34.81	Yes	28.66	-6.15
47	5/16/2019	20	6	34.67	Yes	28.66	-6.01
48	5/16/2019	20	7	29.51	Yes	28.66	-0.85
49	5/16/2019	20	8	34.73	Yes	28.66	-6.07
50	5/16/2019	20	9	36.58	Yes	28.66	-7.92
51	5/16/2019	20	10	37.86	Yes	28.66	-9.20
52	5/16/2019	20	11	85.26	Yes	28.66	-56.60
53	5/16/2019	20	12	38.30	Yes	28.66	-9.64
54	5/16/2019	21	1	54.47	Yes	28.66	-25.81
55	5/16/2019	21	2	54.18	Yes	28.66	-25.52
56	5/16/2019	21	3	48.86	Yes	28.66	-20.20
57	5/16/2019	21	4	44.88	Yes	28.66	-16.22
58	5/16/2019	21	5	47.84	Yes	28.66	-19.18
59	5/16/2019	21	6	71.47	Yes	28.66	-42.81
60	5/16/2019	21	7	71.47	Yes	28.66	-42.81
61	5/16/2019	21	8	71.47	Yes	28.66	-42.81
62	5/16/2019	21	9	71.47	Yes	28.66	-42.81
63	5/16/2019	21	10	29.45	Yes	28.66	-0.79
64	5/16/2019	21	11	29.06	Yes	28.66	-0.40
65	5/16/2019	21	12	25.58	Yes	28.66	3.08
66	5/16/2019	22	1	26.33	Yes	28.22	1.89
67	5/16/2019	22	2	26.22	Yes	28.22	2.00
68	5/16/2019	22	3	26.45	Yes	28.22	1.77
69	5/16/2019	22	4	28.88	Yes	28.22	-0.66
70	5/16/2019	22	5	28.81	Yes	28.22	-0.59
71	5/16/2019	22	6	28.81	Yes	28.22	-0.59
72	5/16/2019	22	7	25.70	Yes	28.22	2.52

Department of Market Quality and Renewable Integration – California ISO

Number	Trade Date	Trade Hour	Interval	Market LMP	Eligible Flag	Calculated LMP	Change in LMP
73	5/16/2019	22	8	25.40	Yes	28.22	2.82
74	5/16/2019	22	9	23.64	Yes	28.22	4.58
75	5/16/2019	22	10	23.90	Yes	28.22	4.32
76	5/16/2019	22	11	14.26	Yes	28.22	13.96
77	5/16/2019	22	12	13.44	Yes	28.22	14.78
78	5/16/2019	23	1	26.21	Yes	28.66	2.45
79	5/16/2019	23	2	29.55	Yes	28.66	-0.89
80	5/16/2019	23	3	30.43	Yes	28.66	-1.77
81	5/16/2019	23	4	30.08	Yes	28.66	-1.42
82	5/16/2019	23	5	30.14	Yes	28.66	-1.48
83	5/16/2019	23	6	29.30	Yes	28.66	-0.64
84	5/16/2019	23	7	39.05	Yes	28.66	-10.39
85	5/16/2019	23	8	24.53	Yes	28.22	3.69
86	5/16/2019	23	9	21.11	Yes	28.22	7.11
87	5/16/2019	23	10	12.81	Yes	28.66	15.85
88	5/16/2019	23	11	17.24	Yes	28.66	11.42
89	5/16/2019	23	12	16.22	Yes	28.66	12.44
90	5/16/2019	24	1	28.89	Yes	28.66	-0.23
91	5/16/2019	24	2	25.42	Yes	28.22	2.80
92	5/16/2019	24	3	26.77	Yes	28.22	1.45
93	5/16/2019	24	4	15.45	Yes	28.22	12.77
94	5/16/2019	24	5	24.48	Yes	28.22	3.74
95	5/16/2019	24	6	25.51	Yes	28.22	2.71
96	5/16/2019	24	7	20.98	Yes	28.22	7.24
97	5/16/2019	24	8	18.74	Yes	28.22	9.48
98	5/16/2019	24	9	14.78	Yes	28.22	13.44
99	5/16/2019	24	10	19.80	Yes	28.22	8.42
100	5/16/2019	24	11	21.99	Yes	28.22	6.23
101	5/16/2019	24	12	25.01	Yes	28.22	3.21
102	5/17/2019	1	1	20.80	Yes	28.66	7.86
103	5/17/2019	1	2	54.05	Yes	25.38	-28.67
104	5/17/2019	1	3	57.10	Yes	25.38	-31.72
105	5/17/2019	1	4	18.29	Yes	28.66	10.37
106	5/17/2019	1	5	26.08	Yes	28.66	2.58
107	5/17/2019	1	6	18.64	Yes	28.66	10.02
108	5/17/2019	1	7	19.25	Yes	28.66	9.41
109	5/17/2019	1	8	17.15	Yes	28.66	11.51
110	5/17/2019	1	9	17.15	Yes	28.66	11.51

Department of Market Quality and Renewable Integration – California ISO

Number	Trade Date	Trade Hour	Interval	Market LMP	Eligible Flag	Calculated LMP	Change in LMP
111	5/17/2019	1	10	14.18	Yes	28.66	14.48
112	5/17/2019	1	11	12.90	Yes	28.66	15.76
113	5/17/2019	1	12	0.03	Yes	28.66	28.63
114	5/17/2019	2	1	0.01	Yes	28.66	28.65
115	5/17/2019	2	2	2.11	Yes	28.66	26.55
116	5/17/2019	2	3	0.01	Yes	28.66	28.65
117	5/17/2019	2	4	0.01	Yes	28.66	28.65
118	5/17/2019	2	5	0.02	Yes	28.66	28.64
119	5/17/2019	2	6	0.96	Yes	28.66	27.70
120	5/17/2019	2	7	0.01	Yes	28.66	28.65
121	5/17/2019	2	8	0.01	Yes	28.66	28.65
122	5/17/2019	2	9	0.01	Yes	28.66	28.65
123	5/17/2019	2	10	0.07	Yes	28.66	28.59
124	5/17/2019	2	11	12.77	Yes	28.66	15.89
125	5/17/2019	2	12	2.05	Yes	28.66	26.61
126	5/17/2019	3	1	0.07	Yes	28.66	28.59
127	5/17/2019	3	2	2.03	Yes	28.66	26.63
128	5/17/2019	3	3	0.01	Yes	28.66	28.65
129	5/17/2019	3	4	0.94	Yes	28.66	27.72
130	5/17/2019	3	5	0.94	Yes	28.66	27.72
131	5/17/2019	3	6	1.00	Yes	28.66	27.66
132	5/17/2019	3	7	0.99	Yes	28.66	27.67
133	5/17/2019	3	8	0.03	Yes	28.66	28.63
134	5/17/2019	3	9	2.03	Yes	28.66	26.63
135	5/17/2019	3	10	0.97	Yes	28.66	27.69
136	5/17/2019	3	11	10.85	Yes	28.66	17.81
137	5/17/2019	3	12	11.01	Yes	28.66	17.65
138	5/29/2019	20	1	23.80	Yes	22.97	-0.83
139	5/29/2019	20	2	21.38	Yes	22.97	1.59
140	5/29/2019	20	3	19.99	Yes	22.97	2.98
141	5/29/2019	20	4	-104.04	Yes	22.97	127.01
142	5/29/2019	20	5	-102.70	Yes	22.97	125.67
143	5/29/2019	20	6	-102.70	Yes	22.97	125.67
144	5/29/2019	20	7	-101.96	Yes	22.97	124.93
145	5/29/2019	20	8	-90.90	Yes	22.97	113.87
146	5/29/2019	20	9	23.76	Yes	22.97	-0.79
147	5/29/2019	20	10	23.68	Yes	22.97	-0.71
148	5/29/2019	20	11	22.25	Yes	22.97	0.72

Department of Market Quality and Renewable Integration – California ISO

Number	Trade Date	Trade Hour	Interval	Market LMP	Eligible Flag	Calculated LMP	Change in LMP
149	5/29/2019	20	12	20.21	Yes	22.97	2.76
150	5/29/2019	21	1	-125.72	Yes	22.97	148.69
151	5/29/2019	21	2	-71.40	Yes	22.97	94.37
152	5/29/2019	21	3	-108.03	Yes	22.97	131.00
153	5/29/2019	21	4	-125.28	Yes	22.97	148.25
154	5/29/2019	21	5	-91.20	Yes	22.97	114.17
155	5/29/2019	21	6	-81.38	Yes	22.97	104.35
156	5/29/2019	21	7	-78.14	Yes	22.97	101.11
157	5/29/2019	21	8	20.46	Yes	22.97	2.51
158	5/29/2019	21	9	20.45	Yes	22.97	2.52
159	5/29/2019	21	10	20.06	Yes	22.97	2.91
160	5/29/2019	21	11	20.06	Yes	22.97	2.91
161	5/29/2019	21	12	19.63	Yes	22.97	3.34
162	5/29/2019	22	1	20.37	Yes	22.97	2.60
163	5/29/2019	22	2	20.05	Yes	22.97	2.92
164	5/29/2019	22	3	19.28	Yes	22.97	3.69
165	5/29/2019	22	4	20.12	Yes	22.97	2.85
166	5/29/2019	22	5	19.67	Yes	22.97	3.30
167	5/29/2019	22	6	19.67	Yes	22.97	3.30
168	5/29/2019	22	7	20.09	Yes	22.97	2.88
169	5/29/2019	22	8	19.30	Yes	22.97	3.67
170	5/29/2019	22	9	18.17	Yes	22.97	4.80
171	5/29/2019	22	10	16.94	Yes	22.97	6.03
172	5/29/2019	22	11	17.42	Yes	22.97	5.55
173	5/29/2019	22	12	18.72	Yes	22.97	4.25
174	5/29/2019	23	1	20.23	Yes	22.97	2.74
175	5/29/2019	23	2	23.81	Yes	22.97	-0.84
176	5/29/2019	23	3	25.14	Yes	22.97	-2.17
177	5/29/2019	23	4	22.05	Yes	22.97	0.92
178	5/29/2019	23	5	24.40	Yes	22.97	-1.43
179	5/29/2019	23	6	23.35	Yes	22.97	-0.38
180	5/29/2019	23	7	20.33	Yes	22.97	2.64
181	5/29/2019	23	8	19.87	Yes	22.97	3.10
182	5/29/2019	23	9	17.34	Yes	22.97	5.63
183	5/29/2019	23	10	17.08	Yes	22.97	5.89
184	5/29/2019	23	11	17.08	Yes	22.97	5.89
185	5/29/2019	23	12	14.19	Yes	22.97	8.78

Appendix C: Exceptional Dispatch Bid Mitigation Analysis

In May 2019, the ISO applied the exceptional dispatch bid mitigation to the exceptional dispatches. Table 10 shows the costs by instruction type in May. With exceptional dispatch bid mitigation, the costs for these types of exceptional dispatches were \$ 18. Without the exceptional dispatch bid mitigation, the costs for these types of exceptional dispatches would be \$ 49. The cost saving from the exceptional dispatch bid mitigation was \$ 31.

Table 10: Bid Mitigation Analysis for May 2019

Type	Number of Resources	Costs without Bid Mitigation	Costs with Bid Mitigation	Cost Saving
NONTMOD	2	\$ 49	\$ 18	\$ 31
Total	2	\$ 49	\$ 18	\$ 31