

Application No.: \_\_\_\_\_

Exhibit No.: \_\_\_\_\_

Witness: Robert Sparks

Application of San Diego Gas & Electric Company  
(U902 E) for Authority to Enter into Purchase Power  
Tolling Agreements with Escondido Energy Center,  
Pio Pico Energy Center and Quail Brush Power

Application 11-05-023

**REBUTTAL TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 1 of 19

**BEFORE THE PUBLIC UTILITIES COMMISSION OF THE  
STATE OF CALIFORNIA**

Application of San Diego Gas & Electric Company  
(U902 E) for Authority to Enter into Purchase Power  
Tolling Agreements with Escondido Energy Center,  
Pio Pico Energy Center and Quail Brush Power

Application 11-05-023

**REBUTTAL TESTIMONY OF ROBERT SPARKS  
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR  
CORPORATION**

**Q. What is your name and by whom are you employed?**

**A.** My name is Robert Sparks. I am employed by the California Independent System Operator Corporation (ISO), 250 Outcropping Way, Folsom, California as Manager, Regional Transmission.

**Q. Have you previously provided testimony in this proceeding?**

**A.** Yes, I have. On March 9, 2012, the ISO served my testimony to parties in the proceeding, along with Mr. Rothleder's testimony, and supplemental testimony was served on April 6, 2012. We also sponsored a workshop on April 17, 2012.

**Q. What is the purpose of your rebuttal testimony?**

**A.** In this rebuttal testimony I will respond to certain statements and conclusions sponsored in testimony submitted by the California Environmental Justice Alliance (CEJA), the Division of Ratepayer Advocates (DRA) and the National Resources Defense Council (NRDC) on May 18, 2012.

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 2 of 19

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

**Modeling Incremental Demand Response (DR), Uncommitted Energy Efficiency (EE),  
Uncommitted Combined Heat and Power (CHP) and Energy Storage**

**Q. What levels of DR, uncommitted EE, CHP and storage did the ISO use in its local capacity area studies?**

**A.** The ISO used the 2009 CEC 1-in-10 load forecast, which includes certain levels of EE and CHP. Uncommitted EE was not included, and CHP generation was counted on for meeting local reliability needs only to the extent it was included in the CEC's officially adopted demand forecast.

The ISO shares the CEC's concerns about uncommitted energy savings from uncommitted resources. To the extent such uncommitted resources ultimately develop, they can be helpful in reducing overall net-demand, but the ISO does not believe it is prudent to rely on uncommitted resources for assessing future local system needs and ensuring the reliability of the bulk power system.

The load was not reduced for incremental demand response in the OTC and LCR studies and incremental demand response was not treated as an existing resource in these studies.

A small amount of energy storage (40 MW representing the Lake Hodges project) was also modeled.

**Q. Can you provide a brief summary of the intervener testimony regarding the levels of DR, uncommitted EE, CHP and storage modeled in the ISO's local capacity area studies?**

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 3 of 19

1    **A.**    Yes. NRDC witness Martinez, DRA witnesses Ghazzagh and Spencer, and CEJA  
2           witness Powers all suggest that the ISO should have used 544MW of uncommitted EE,  
3           although DRA also recommended 284MW as part of the “high need” proposal. The  
4           DRA and CEJA witnesses also suggest that 302MW of DR identified in the planning  
5           assumptions in the R.10-05-006 LTPP proceeding be modeled in the ISO’s local capacity  
6           studies. All of these witnesses claim that CHP should have been included as a supply  
7           resource. CEJA witness Powers also takes issue with the level of energy storage that the  
8           ISO included in its studies.

9  
10   **Q.**    **What is the ISO response to the recommendations that additional amounts of**  
11           **uncommitted energy efficiency should have been included in the load forecast?**

12  
13   **A.**    In considering all of these recommendations, we must first consider the different  
14           applications in which the load forecast information is used, and the consequences of the  
15           different assumptions. Deliberately conservative forecasts must be employed in the  
16           assessment of reliability requirements for capacity in constrained areas since the  
17           consequences of being marginally short versus marginally long are asymmetric. A  
18           marginal shortage means the loss of firm load, which puts public safety and the economy  
19           in jeopardy, whereas a marginal surplus has only a marginal cost implication. Thus, the  
20           ISO has a responsibility to carefully consider demand forecast assumptions and how they  
21           are developed, especially if such forecasts include assumptions about uncommitted  
22           resources that can only provide uncommitted energy savings, for planning purposes.

23  
24           As CEC observed in a report issued in May 2010 entitled Incremental Impacts of Energy  
25           Efficiency Policy Initiatives relative to the 2009 Integrated Energy Policy Report  
26           Adopted Demand Forecast (“CEC EE Report”), there is substantial uncertainty regarding  
27           whether the amount of additional energy savings that will be achieved through

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

1 uncommitted energy efficiency.<sup>1</sup> This conclusion is further supported by the CEC’s more  
2 recent comment provided in the 2011 Integrated Energy Policy Report dated January  
3 2012 (“CEC 2011 IEP Report”), which stated in its discussion of EE that “[u]ncommitted  
4 savings” for EE “while plausible, have a great deal of uncertainty surrounding the  
5 method, timing, and relative impact of their implementation.”<sup>2</sup>  
6

7 In this regard, the NRDC, DRA and CEJA witnesses appear to ignore the caution  
8 expressed by the originators of California’s demand forecast. Heightening the ISO’s  
9 concern for the lack of certainty regarding uncommitted energy efficiency, the ISO notes  
10 that even programs that are more successful than anticipated may fail to produce the  
11 required energy savings in the particular area specifically where they are needed and  
12 when they are needed— effectiveness on a broad system-wide basis can be invaluable  
13 from a total resource adequacy perspective, but can easily fail to provide the expected  
14 load relief if the programs are not successfully deployed when and where needed in the  
15 constrained local capacity area.  
16

17 **Q. Do you agree with CEJA that higher levels of energy storage should have been**  
18 **modeled along with other system resources?**  
19

20 **A.** No, although the ISO is interested in the ability of viable energy storage devices to  
21 address system reliability needs. However, such devices must not only provide sufficient  
22 capacity, but also that capacity must be in the correct location to be effective. At this  
23 juncture, there is not sufficient certainty that effective storage will be developed in the  
24 necessary locations to warrant including such uncommitted resources in the ISO’s  
25 models. Moreover, the examples cited by CEJA’s witness (Powers) suggesting these  
26 resources are already viable require further scrutiny. For example, Mr. Powers noted the

---

<sup>1</sup> See CEC EE Report at 5, 53-54.

<sup>2</sup> CEC 2011 IEP Report at 110.

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 5 of 19

1 incentive rates approved by FERC in 2010 for the Western Grid Development proposed  
2 storage projects to alleviate transmission issues identified by the ISO. He failed to note  
3 that the projects submitted to the ISO for consideration were found to be uneconomic  
4 alternatives to transmission projects and were not approved in the ISO's transmission  
5 planning process. Further, he cites examples of a Beacon Power flywheel being installed  
6 at a California wind farm and a 4 MW battery storage project being installed by PG&E as  
7 "a viable way to meet load requirements." However, reviewing the referenced sources  
8 indicates that both projects are being installed as demonstration projects.

9  
10 **Q. Do you agree that a certain level of uncommitted CHP should have been included as**  
11 **a system resource in the ISO's local area capacity studies?**

12  
13 **A.** The ISO does not consider it reasonable or prudent to rely on incremental combined heat  
14 and power programs beyond what has been considered in CEC forecasts due to the level  
15 of uncertainty that exists with regard to future increases in CHP development that was  
16 noted in both the CEC's 2009 IEP Report<sup>3</sup> and the 2011 IEP Report. The 2011 IEP  
17 Report further supports the conclusion that it is not prudent to count on any incremental  
18 CHP at this time; the forecast CHP additions to the system may simply offset retirements  
19 to existing CHP resources.<sup>4</sup>

20  
21 **Q. Why didn't the ISO model DR in its local area capacity studies?**

22  
23 **A.** The ISO does not agree that Demand Response can be relied upon to address local  
24 capacity needs, unless the DR can provide equivalent characteristics and response to that

---

<sup>3</sup> See CEC 2009 IEP Report at 97 ("The continued existence and viability of this power is a major issue ..."), 236 ("The barriers to increased penetration of CHP technologies have been identified repeatedly in past *IEPRs*, but little progress has been made.").

<sup>4</sup> See CEC 2011 IEP Report at 108-110 ("For traditional combined heat and power (CHP) technologies, self-generation is assumed constant, so that retired CHP plants are replaced with new ones with no net change in generation in the current forecast.").

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 6 of 19

1 of a dispatchable generator. DR should be dispatchable when and where needed and for a  
2 specific megawatt quantity, to address local capacity needs. However, Demand Response  
3 does not have these characteristics as this time.  
4

5 Demand Response programs have generally been considered an alternative to generation  
6 resources in meeting system-wide load and supply balances. Spread over a larger system,  
7 the exact amount of DR that materializes, and the location, is not relevant within certain  
8 bounds. However, to ensure that DR does not materialize in an area that compounds a  
9 system problem, and does materialize in the area needed to mitigate the system problem  
10 that drove the need for reliance on DR, the ISO strongly supports DR being location-  
11 based and dispatchable – in the past, the ISO has referred to this as “generation  
12 substitutable.” Further, if it is being relied upon instead of construction of new  
13 generating plants, the DR programs must be dependable over a significant period of time  
14 equivalent to the construction of new generation resources – which the ISO has referred  
15 to in the past as “durable.”<sup>5</sup> Demand Response is generally a very use-limited and use-  
16 restricted resource that has limited energy-delivery duration, callable hours and/or timely  
17 dispatch. These use-restrictions are generally inadequate to enable their inclusion in local  
18 capacity area studies, particularly related to satisfying reliability requirements triggered  
19 by transmission-related contingencies. Typically, following a contingency event, the ISO  
20 is faced with restoring the system to a state positioned for the next, worst contingency  
21 within 30 minutes. These types of requirements are location-specific and time-specific.  
22 Unlike the system needs, addressing local capacity requirements that are contingency  
23 driven require prompt and very dependable response – operators simply cannot wait to  
24 see what load reduction materializes, and still have time remaining to respond to address  
25 a shortfall.  
26

---

<sup>5</sup> The ISO recently discussed the importance of durability in comments submitted in CPUC Proceeding A.11-03-001. *See* Comments of the California Independent System Operator Corporation on Alternate Proposed Decision Adopting Demand Response Activities and Budgets for 2012 through 2014, at 7-8 (April 9, 2012).

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 7 of 19

1 **Q. Has the ISO provided information about the characteristics of demand response**  
2 **programs that can be used to meet grid reliability needs in other CPUC**  
3 **proceedings?**

4  
5 **A.** Yes. Specifically, demand resources can clearly aid reliability when these demand  
6 resources are available to the ISO when and where needed and for how much energy is  
7 needed.

8  
9 **Distributed Generation (DG)**

10  
11 **Q. Both CEJA witness Powers and DRA witness Ghazzagh state that higher levels of**  
12 **DG should have been modeled in the ISO's local capacity area studies. Do you**  
13 **agree with this recommendation?**

14  
15 **A.** No. The ISO studied the need for replacement OTC generation under four 33% RPS  
16 scenarios during the 2011-2012 transmission planning cycle. The amount of DG in the  
17 San Diego area ranged from 52 MW to 104 MW for three of the scenarios. The high DG  
18 scenario had 402 MW. The ISO believes that the 52 MW to 104 MW range is a  
19 reasonable assumption for planning to ensure that the system will be reliable. Although  
20 the 402 MW high DG scenario may be plausible and an admirable goal; however, it is not  
21 a capacity amount that can be depended on for ensuring the reliability of the bulk power  
22 system.

23  
24 **Q. Is the ISO's position on the appropriate level of DG for the purposes of its local**  
25 **capacity area studies inconsistent with the ISO's DG initiative, as suggested by DRA**  
26 **witness Spencer's testimony at pages 10-11?**

27  
28 **A.** No. The ISO's DG initiative is designed to help facilitate the development of DG by  
29 providing useful information regarding locations to site DG that would not create



**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 8 of 19

1 deliverability problems on the transmission system. The initiative also expedites the DG  
2 interconnection study process so that DG will not have to wait for a deliverability study  
3 to be completed if they site their DG at a location predetermined to be deliverable and if  
4 it is contracted with a load serving entity that has a DG deliverability allocation at that  
5 location. However, the ISO's DG initiative does not ensure that the DG will be  
6 developed. For planning purposes, the ISO must make reasonable assumptions about  
7 future DG development as previously discussed in this testimony.  
8

9 **Load Shedding and Special Protection Schemes (SPS)**

10  
11 **Q. Please summarize the ISO's position on using SPS involving load shedding to meet**  
12 **reliability needs in the San Diego local area, as well as the interveners' testimony on**  
13 **this issue.**

14  
15 **A.** In my supplemental testimony, I stated that with the change in the WECC criterion,  
16 causing the Sunrise/IV-Miguel double outage to be reclassified as a Category D  
17 contingency, the most limiting contingency for the San Diego sub-area is the loss of the  
18 Imperial Valley-Suncrest 500 kV line followed by the loss of ECO- Miguel 500 kV line  
19 (N-1-1). While the change in categorization of the double outage did not change the  
20 ISO's local capacity area study methodology, the more severe G-1/N-2 contingency that  
21 previously had been studied conceptually assumed that an automatic load shedding SPS  
22 would be installed and available to prevent voltage collapse. I explained that with the  
23 more likely N-1-1 as the most limiting contingency, the ISO did not believe that it would  
24 be prudent planning to rely on an automatic load shedding SPS.

25  
26 This is because the history of transmission line outages due to fires and equipment  
27 failures in the area and the configuration of the system indicate that outage risks and  
28 consequences are high. The Imperial Valley substation is a major source of imported  
29 power for three different utilities: SDG&E, IID, and CFE. This is not only evidence of

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 9 of 19

1 the criticality of this substation, but also the level of exposure to operational coordination  
2 issues and failures. Relying on load shedding as a primary mitigation measure is an  
3 indication that the system is being planned and operated at a very high stress level, and  
4 with very little margin for error. Based on this information, it is not prudent to plan and  
5 operate the Imperial Valley system with currently expected high outage risks and  
6 consequences at a very high stress level and with very little margin for error. On the  
7 other hand, the ISO would rely on the load shedding SPS during extreme operating  
8 conditions beyond the N-1-1 contingency scenario considered in the OTC studies, that  
9 would otherwise require pre-contingency load shedding.

10  
11 Both DRA (witness Fagan) and CEJA (witness Firooz) have argued that the ISO's  
12 approach to load shedding under an N-1-1 contingency is too conservative, and that the  
13 local capacity needs in San Diego would be lower if the ISO planned for automatic load  
14 shedding in the event of extreme circumstances or severe contingency events. As  
15 described below, these arguments are misplaced.

16  
17 **Q. Has Ms. Firooz accurately described the ISO's position with respect to load**  
18 **shedding as an N-1-1 contingency mitigation for the most limiting contingency for**  
19 **the San Diego area?**

20  
21 **A.** No. First, at page 7 of her testimony, Ms. Firooz broadly states that the ISO will not rely  
22 on load shedding in the San Diego area as mitigation for N-1-1 contingencies. That is not  
23 correct. My testimony focused specifically on load shedding as mitigation for the ECO-  
24 Miguel 500 kV line and Sunrise contingency and it is for this contingency that I believe it  
25 would not be prudent to rely on load shedding.

26  
27 Ms. Firooz goes on to mischaracterize an ISO data request response on this topic by  
28 suggesting incorrectly that the ISO stated that it is not permitted to shed load for N-1-1  
29 events and, based on that mischaracterization, she concludes that the ISO's "reason for

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 10 of 19

1 not allowing load drop in the San Diego area is not reasonable,” (Firooz testimony, pages  
2 8- 9). Specifically, CEJA posed the following question:

3  
4 Does NERC, WECC, and/or CAISO reliability criteria prevent the use of  
5 controlled load drop for an N-1-1 transmission contingency? If so, where is this  
6 criteria documented? If not, what threshold does the CAISO use to determine  
7 when controlled load drop is acceptable mitigation and when it is not? Are there  
8 any limits on the amount of controlled load drop which is acceptable?  
9

10 The CAISO responded:

11 The ISO is required by NERC TPL 003 to plan its network so that it can be  
12 operated to supply projected customer demands for N-1-1 events regardless of  
13 their probability. *NERC Transmission Planning Standards allow the use of*  
14 *controlled load drop depending on system design and expected system impacts...*  
15

16 The rest of the ISO’s response provided more explanation as to why, under the specific  
17 system configuration and consistent with NERC TPL 003, the ISO would operate all  
18 available generation to avoid the need to shed load to mitigate the category C  
19 Sunrise/ECO-Miguel overlapping outage, for the reasons I discussed above. In other  
20 words, although NERC TPL 003 *permits* load shedding as a mitigation for an N-1-1  
21 contingency, the standard does not *require* the ISO, as the Planning Coordinator, to  
22 approve an automatic load shedding SPS under all such circumstances and instead allows  
23 for the Planning Coordinator to consider system design and expected system impacts in  
24 deciding whether an automatic load shedding SPS is appropriate. Ms. Firooz seems to  
25 misunderstand both the planning standard and the ISO response to the CEJA data request,  
26 and has provided no basis for her conclusion that the ISO’s planning decision to avoid a  
27 load shedding SPS for the Sunrise/ECO-Miguel N-1-1 is “unreasonable.”  
28

29 **Q. Do you agree with Ms. Firooz’s suggestion at pages 7- 8 of her testimony that**  
30 **considering the probability that a contingency will occur- which allegedly would**  
31 **result in lower costs for consumers- would not lower grid reliability?**  
32

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 11 of 19

1    **A.**    Absolutely not. In the first place, the ISO is required to comply with NERC planning  
2           requirements, which are deterministic and not probabilistic. More importantly, Ms.  
3           Firooz has not conducted a complete probabilistic analysis so she has no basis for her  
4           conclusion that local area needs would be lower and that costs to consumers would  
5           therefore be lower. It is possible that a probabilistic analysis could result in higher local  
6           needs.

7  
8           To briefly summarize the issue, deterministic criteria apply specific tests to the system –  
9           with specific assumptions regarding load level and the “worst” contingency as set out in  
10          the various disturbance classifications in the NERC standards. A probabilistic approach  
11          examines the probability of a wide range of outages under a wide range of conditions,  
12          and compares the results to a predetermined criteria related to the acceptable level of risk  
13          one is willing to take on a probabilistic basis.

14  
15          Simply applying probabilities to the “worst case” scenario ignores all of the other  
16          potential events that could result in loss of reliable service, under a wide range of  
17          scenarios, providing no effective means to assess the robustness of the transmission  
18          system on a probabilistic basis or deterministic basis.

19  
20    **Q.**    **DRA witness Fagan also takes issue with the ISO’s position on load shedding, at**  
21           **pages 19-25 of his testimony. He notes that SDG&E has agreed to the use of**  
22           **controlled load drop under N-1-1 contingencies and intends to install a “safety net”**  
23           **that will shed load in the event of the sequential loss of two 500 kV lines. Do you**  
24           **agree that this “safety net” should be considered as a mitigation for the Category C**  
25           **contingency you described previously?**

26  
27    **A.**    No. A safety net is only acceptable for a Category D outage. The safety net would need  
28           to be upgraded to a WECC approved SPS before it could be used for the N-1-1.  
29           However, as I explained above, the current transmission system design in the Imperial

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 12 of 19

1 Valley area and the expected system impacts of overstressing this system make the  
2 reliance on load dropping SPS for the Category C overlapping outage of ECO-Miguel  
3 and Sunrise 500 kV an imprudent choice.  
4

5 **Q. Mr. Fagan also states that the ISO has not analyzed the difference in costs between**  
6 **procuring additional local generation and installing an SPS that would trigger load**  
7 **shedding under an N-1-1 contingency. Please respond to this contention.**  
8

9 **A.** The ISO does not compare the costs of these two approaches because they are not  
10 substitutes for each other. Unlike load shedding, there are significant benefits for  
11 additional generation beyond addressing an immediate reliability issue. The ISO believes  
12 that the cost of procuring additional local generation to meet the local area needs without  
13 shedding load, is offset by the benefits provided, both locally and system-wide.  
14 Generation is required to be procured for system needs and for renewable integration.  
15 Procuring generation in the local area to meet local needs, system needs, and for  
16 renewable integration has only a marginal cost and provides reliability under the studied  
17 system conditions as well as many other system conditions during planned and forced  
18 outages of generation and transmission resources.  
19

20 **Load Forecasts and Planning Horizons**  
21

22 **Q. At page 17 of his testimony, Mr. Fagan states that the planning horizon for**  
23 **generation (supply) resources is from one to five years. Do you agree that this is the**  
24 **appropriate time horizon for consideration of the San Diego local needs?**  
25

26 **A.** No, Mr. Fagan is incorrect. The conventional lead time for constructing new generation  
27 or repowering existing facilities, such as the OTC units, is five to seven years. Encina  
28 OTC compliance is before 2018; thus there is considerable urgency in making  
29 procurement decisions as soon as possible and certainly no later than 2012. The

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 13 of 19

1 transmission system will be designed around the resources that are procured and Mr.  
2 Fagan agrees that infrastructure development can take as long as ten years.

3  
4 **Q. DRA witness Gharrzagh takes issue with the ISO's use of the 1-in-10 load forecast**  
5 **for the purposes of this proceeding and suggests that the use of this forecast be**  
6 **deferred to the LTPP proceeding (pages 3-5). What is your response?**

7  
8 **A.** The ISO's OTC studies are based on the 1-in-10 2009 CEC load forecast [CEC-200-  
9 2009-012-CMF] which is actually lower than the latest CEC load forecast which was  
10 published on May 31, 2012 [CEC-200-2012-001-SF-VI]. In this regard, the forecast  
11 used by the ISO is low.

12  
13 Furthermore, the ISO Planning Standards require the use of 1-in-10 load forecast for all  
14 local system reliability analyses. Because the load forecast appears to be increasing, the  
15 use of a more recent forecast would only increase the justification for the power contracts  
16 that SDG&E is requesting for approval. Therefore, the ISO does not believe that the load  
17 forecast assumption needs to be deferred to the current LTPP proceeding (R.12-03-014).

18  
19 **Other Transmission Planning Issues**

20  
21 **Q. Both DRA witnesses Fagan and Ghazzagh state that the import limit into the San**  
22 **Diego area used by the ISO is too low and inconsistent with the ISO's testimony in**  
23 **the Sunrise Powerlink proceeding (A.06-08-010). Is this correct?**

24  
25 **A.** No. First of all, local area generation requirements are based on following the LCR study  
26 methodology. DRA focuses on import capability for the purpose of performing a  
27 spreadsheet calculation of local area generation requirements. DRA insists on  
28 establishing a number for import capability that can be subtracted from the area load to  
29 determine the local generation requirement. This approach is fundamentally inconsistent

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 14 of 19

1 with the LCR study methodology, which does not rely on an import capability value to  
2 determine local area resource requirements. Therefore, there is no import capability  
3 number in the ISO study results that can be compared to the DRA study results.  
4 However, both the ISO studies and the DRA studies produce a local area resource  
5 requirement which can be compared. Table FG-1 of Mr. Ghazzagh's testimony shows  
6 that the DRA calculated resource requirement on line 7 is 2713 MW. It also shows the  
7 ISO resource requirement of 2663 MW. In addition the ISO resource requirement is  
8 based on a higher San Diego area load level than what is assumed by DRA. In summary,  
9 the ISO calculated resource requirement based on the LCR study methodology is lower  
10 than the DRA calculated resource requirement. The local area resource requirement is a  
11 measure of the local area transmission system capability. Given that the ISO studies  
12 produced a lower local area resource requirement than DRA, the ISOs assessment  
13 indicates that the transmission system capability is greater than what has been determined  
14 by DRA.

15  
16 **Q. At page 11 of Ms. Firooz's testimony she suggests that reactive support devices**  
17 **(synchronous condensers) should have been studied as more cost effective**  
18 **alternatives to local generation. Does the ISO believe that these devices should be**  
19 **used to meet some of the local needs described in your testimony?**

20  
21 **A.** No. While the ISO, in its 2011/2012 Transmission Plan, found that the reactive support  
22 device proposed by SDG&E during that cycle would mitigate possible voltage issues in  
23 the Encina area, these devices do not provide the benefits that local generation provides,  
24 and therefore would not be more cost effective. Specifically, Ms. Firooz does not appear  
25 to have accounted for the system resource adequacy and renewable integration benefits of  
26 the generation that are not provided by the synchronous condensers.

27  
28 **Q. Ms. Firooz also suggests installing phase shifting transformers, at a cost of \$50**  
29 **million, to control loop flows on the CFE system, thus providing a cost effective and**

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 15 of 19

1 **environmentally superior means by which to reduce LCR needs in San Diego. Do**  
2 **you agree?**

3  
4 **A.** No, for several reasons. The cost of a 1000 MVA of phase shifters is expected to be  
5 much more than \$50 million. The ISO estimates the cost of a similar phase shifter to be  
6 approximately \$100 million based on the cost of a similar sized 500/230 kV transformer.  
7 In addition, Ms. Firooz again does not appear to have accounted for the system resource  
8 adequacy and renewable integration benefits of the generation that are not provided by  
9 the phase shifter.

10  
11 **Q.** **In addition, Ms. Firooz proposes a transmission alternative to local generation- the**  
12 **Talega-Escondido/Valley Serrano (TE/VS) interconnection facility associated with**  
13 **the Lake Elsinore Advanced Pumped Storage (LEAPS) project. She points to your**  
14 **March 9, 2012, testimony in which you note that the transmission alternative to the**  
15 **local capacity needs in San Diego would basically be a 500 kV connection between**  
16 **the SDG&E and SCE systems. What is your opinion of TE/VS as a viable**  
17 **alternative to local generation?**

18  
19 **A.** As with her other alternatives, the 500 kV line proposal also overlooks the system  
20 resource adequacy and renewable integration benefits of the generation that is not  
21 provided by the TE/VS line. Furthermore, while a 500 kV connection was identified as a  
22 possible transmission alternative, if local generation needs are not met, this transmission  
23 need- and the TE/VS line as a standalone project- has never been studied and approved  
24 through the ISO's transmission planning process. It is my understanding that the TE/VS  
25 application for a CPCN has recently been dismissed, so it is unlikely that a 500 kV  
26 connection between the SDG&E and SCE systems could be online by the 2018 Encina  
27 OTC compliance date.

28



**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 16 of 19

1 **Q. Starting at page 14 of her testimony, Ms. Firooz claims that the ISO has, in its**  
2 **testimony, “provided the end results of three series of complex analyses**  
3 **without discussing or providing much of the underlying data.” She states that the**  
4 **ISO’s studies therefore provide an inadequate basis upon which to make a decision**  
5 **in this proceeding. What is your response to these criticisms?**  
6

7 **A.** The study results addressed in my testimony are based on a 433 page Transmission Plan  
8 with hundreds of pages of appendices that is posted on the ISO’s website. The ISO  
9 conducted an all day workshop at the CPUC offices in San Francisco on April 17, 2012  
10 to present the analysis of local capacity needs in San Diego and provided data and  
11 information in the form of Powerpoint slides. In addition, dozens of powerflow models  
12 were posted that provide full detail of every assumption and were readily available to all  
13 participants in this proceeding. The ISO has consistently urged all interested parties to  
14 take advantage of the ISO’s non-disclosure agreement arrangements so that the data and  
15 backup materials for our studies could be accessed as quickly as possible. All of this  
16 information and documentation has been available for scrutiny since the ISO submitted  
17 its testimony in early March. Although the OTC study was conducted for the first time in  
18 the 2011/2012 cycle, it is basically a longer term version of the LCR studies the ISO  
19 performs every year and with which Ms. Firooz should be very familiar.  
20

21 **Q. Ms. Firooz has identified several purported “inconsistencies” between the 2013 LCR**  
22 **study and the 2021 OTC study. On page 16 she focuses on a voltage collapse**  
23 **scenario, identified in both the 2013 study and the 2021 study, and claims that the**  
24 **ISO failed to explain the reasons why a voltage collapse for the same contingencies**  
25 **would be present in both 2021 and 2013. Can you address this issue?**  
26

27 **A.** Yes. Ms. Firooz suggests that it is somehow inconsistent for the ISO to show a voltage  
28 collapse for the same contingencies in its 2013 study as in its 2021 study given that, in  
29 2013, the Encina plant will not yet have been shut down and load projections are lower

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

1 for 2013. This analysis is faulty because it improperly assumes that differences in total  
2 load and the total amount of local resources are the only factors to consider in  
3 determining whether a voltage collapse may occur. In response to a CEJA data request  
4 on this issue, I explained that it was not proper to compare these two studies in this overly  
5 simplistic manner because there are major differences between the 2013 and 2021 base  
6 case models. The largest difference is the addition of approximately 20,000 MW of  
7 installed renewable generation capacity by 2021, which causes substantial differences in  
8 system usage. There are, moreover, various other differences between the two scenarios  
9 that would be apparent from a review of the base cases.

10  
11 For example, in addition to the approximately 20,000 MW difference in renewable  
12 resources between 2013 and 2021, there are several transmission projects that will not yet  
13 be on line by 2013 that affect the voltage stability performance of the southern California  
14 transmission system. These projects include Vincent-Mira Loma 500 kV, Sycamore-  
15 Bernardo 69 kV line, and various reconductoring projects. There is also substantially  
16 more generation dispatched in the Western LA Basin in the 2021 model than in the 2013  
17 model. In addition, with the large amount of renewable generation, the Path 26 flow  
18 from northern California to southern California is over 1000 MW lower in the 2021 case  
19 than in the 2013 case. Furthermore, the DG in the 2021 case is located in a heavily  
20 loaded sub-transmission area and improves voltage stability of the San Diego area. All of  
21 these differences result in significantly increasing the capability of the transmission  
22 system to serve San Diego load in 2021 relative to 2013. Because these enhancements  
23 will not be available in 2013, they are not included in the 2013 base case, and in the  
24 absence of such improvements a voltage collapse scenario occurs in 2013  
25 notwithstanding the availability of Encina and the comparatively lower demand forecast.

26  
27 **Q. Ms. Firooz identifies another purported “inconsistency” on pages 16-17 involving a**  
28 **comparison between the G-1/N-2 and N-1-1 contingencies identified in your April 6,**  
29 **2012, supplemental testimony in the table on page 3. She states that these**

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

Page 18 of 19

1           contingencies are identical except for the outage of Otay Mesa for the G-1/N-2, but  
2           that the study results for each contingency are quite different, which should not be  
3           the case. Has she correctly identified a problem with the ISO's power flow models?  
4

5    **A.**    No. In fact, Ms. Firooz has misstated my testimony and has incorrectly described the G-  
6           1/N-2 contingency. The entire basis for her to claim that there is a discrepancy  
7           apparently is a misunderstanding on her part. The G-1/N-2 and the N-1-1 contingencies  
8           do not involve the same two lines. The G-1/N-2 involves the simultaneous outage of the  
9           500 kV Sunrise Powerlink and the Imperial Valley-ECO 500 kV line. The N-1-1  
10          involves the loss of Imperial Valley-Suncrest 500 kV line (Sunrise Powerlink) followed  
11          by the loss of ECO-Miguel 500 kV line. This was described on page 2 of my April 6,  
12          2012, testimony. The difference in the transmission components associated with the two  
13          contingencies is the reason that the study results were different under these two  
14          contingencies.  
15

16    **Need for Flexible Resources**  
17

18    **Q.**    Both DRA witnesses Fagan and Spencer state that there is no basis upon which the  
19           Commission could find a need for flexible local resources. What is your response to  
20           these statements?  
21

22    **A.**    New generation developed at sites that are electrically equivalent to the former OTC  
23           generation sites would meet the local area generation needs as well as repowering the  
24           former OTC generation. Chapter 3 of the ISO's 2011-2012 Transmission Plan provides  
25           effectiveness factors for various electrical locations inside the local area boundaries that  
26           can be used to facilitate the identification of electrically equivalent sites. The OTC  
27           generation characteristics include ramp rates and minimum output levels that allow the  
28           generation to be ramped-up quickly following the first transmission contingency in order  
29           to ensure reliable system operation following the next transmission contingency. The

**REBUTTAL TESTIMONY OF THE CALIFORNIA  
INDEPENDENT SYSTEM OPERATOR CORPORATION  
A.11-05-023**

1 flexibility of the OTC generation allows efficient system dispatch when all transmission  
2 equipment is in-service, but still provides for reliable system operation following a  
3 transmission contingency. Replacement generation should have similar flexible  
4 characteristics. Quick starting generation would also provide for efficient system  
5 dispatch, but still provide for reliable system operation following a transmission  
6 contingency.

7  
8 **Conclusion**

9  
10 **Q. Based on your review of the testimony submitted by DRA, CEJA and NRDC, is**  
11 **there any reason for the ISO to modify its recommendations in this proceeding?**

12  
13 **A.** No. The ISO studies show a need for flexible thermal generation in the San Diego area  
14 starting in 2018, and, consistent with my testimony, the generating projects at issue in  
15 this proceeding are deliverable and would satisfy a portion of these local needs.

16  
17 **Q. Does this conclude your rebuttal testimony?**

18  
19 **A.** Yes, it does.  
20  
21