

November 14 2018 Exceptional Dispatch CPM Designation Report**Designation Summary:**

The California ISO issued an Exceptional Dispatch Capacity Procurement Mechanism (CPM) designation to HUMBPP_6_UNITS for a non-system reliability need. The designation is effective November 14, 2018 for a duration of 60 days.

Duration and Cost:

RESOURCE_ID	MW	ED Code	Estimated CPM Cost
HUMBPP_6_UNITS	12.46	Local Reliability Issue	\$157,245.2

The estimated capacity cost is based on the accepted offer price of \$6.31/kw-month.

Reason for CPM:

The ISO issued an Exceptional Dispatch CPM designation to HUMBPP_6_UNITS to address an Exceptional Dispatch Non-System Reliability Need. The Exceptional Dispatch was issued to address a potential thermal overload on a 60 kV line in the PG&E Area for the next contingency event. The designation amount reflects the minimum amount of capacity the ISO could designate to mitigate the reliability need posed by the potential thermal overload.

Prior CPM report information is available to download at:
<http://www.caiso.com/market/Pages/ReportsBulletins/Default.aspx>