



California ISO

# 2019 & 23 Draft LCR Study Results Humboldt and North Coast/North Bay Areas


Bryan Fong

Senior Regional Transmission Engineer

Stakeholder Meeting

April 9, 2018


# Humboldt and North Coast/North Bay



# Humboldt Load and Resources (MW)

		<b>2019</b>	<b>2023</b>
Load	=	180	196
AAEE	=	-5	-19
Transmission Losses	=	12	12
Total Load	=	<b>187</b>	<b>188</b>
Market Generation	=	202	202
QF/Self-Gen Generation	=	0	0
Total Qualifying Capacity	=	<b>202</b>	<b>202</b>

# Critical Contingencies Humboldt Area



# Critical Contingencies Humboldt Area

## **Humboldt Overall – Single Contingency Winter Peak**

Contingency: Cottonwood-Bridgeville 115 kV line + one Humboldt  
PP units out of service

Limiting component: Thermal overload on Humboldt -Trinity 115 kV line

2019 LCR Need: 116 MW

2023 LCR Need: 111 MW

## **Humboldt Overall – Double Contingencies Winter Peak**

Contingency: Cottonwood – Bridgeville 115 kV line + Humboldt – Humboldt  
Bay 115kV line

Limiting component: Thermal overload on Humboldt -Trinity 115 kV line

2019 LCR need: 165 MW

2023 LCR need: 169 MW

# Changes


## Since last year:

- 1) Updated NQC.
- 2) Load did not change in 2019 compared with 2018
- 3) LCR decreased by 4 MW in 2019 compared to 2018.
- 4) Load went down by 2 MW in 2023 compared with 2022
- 5) LCR remained the same in 2023 compared to 2022.

# North Coast/North Bay Load and Resources (MW)

		<b>2019</b>	<b>2023</b>
Load	=	1500	1557
AAEE	=	-18	-60
Behind the meter DG	=	-56	-15
Transmission Losses	=	40	42
Total Load	=	<b>1465</b>	<b>1524</b>
Market Generation	=	736	736
Wind Generation	=	0	0
Muni Generation	=	114	114
QF Generation	=	5	5
Total Qualifying Capacity	=	<b>855</b>	<b>855</b>

# North Coast and North Bay





# New major transmission projects

2019:

None

2023:

Vaca Dixon-Lakeville 230 kV Corridor Series Compensation

# Eagle Rock Sub-Area

## **Eagle Rock Sub-area – Single Contingency**

Contingency: Cortina-Mendocino 115 kV line, with Geyser #11 unit out

2019 LCR need: 212 MW

2023 LCR need: 238 MW

Limiting component: Thermal overload on Eagle Rock-Cortina 115 kV line

## **Eagle Rock Sub-area – Double Contingency**


Contingency: Cortina-Mendocino and Geysers #3-Geysers #5 115 kV lines

2019 LCR need: 228 MW

2023 LCR need: 257 MW

Limiting component: Thermal overload on Eagle Rock-Cortina 115 kV line

# Eagle Rock Sub-Area



Largest single unit in the pocket

Radial line connecting two units

# Fulton Sub-area

## **Fulton Sub-area – Single Contingency**

No requirement

## **Fulton Sub-area – Double Contingency**


Contingency: Fulton-Lakeville and Fulton-Ignacio 230 kV lines

Limiting component: Thermal overload on Lakeville# 2 60 kV line  
(Lakeville-Petaluma-Cotati 60 kV)

2019 LCR need: 525 MW

2023 LCR need: 553 MW

# Fulton Sub-area



# Lakeville Sub-area

## Lakeville Sub-area (NCNB Overall) – Category B

Contingency: Vaca Dixon-Tulucay 230 kV line with Delta Energy Center power plant out of service

Limiting component: Thermal overload on the Vaca Dixon-Lakeville 230 kV line

## Ames/Pittsburg/Oakland Sub-area – Category C

Contingency1: DCTL Newark-Ravenswood & Tesla-Ravenswood 230 kV

Limiting component: Thermal overload on the Ames-Ravenswood #1 115 kV line

Contingency2: Moraga-Sobrante & Moraga-Claremont #1 115 kV

Limiting component: Thermal overload on the Moraga-Claremont #2 115 kV line

2019 LCR need:

2023 LCR need:


NCNB: 689 MW

553 MW

Ames/Pittsburg/Oakland : 1741 MW


1630 MW

# Lakeville sub-area one line and generator



LCR need depends on the generation in the Pittsburg/Ames/Oakland sub-areas.

# Lakeville Sub-area double line outage



LCR need depends on the generation in the Pittsburg/Ames/Oakland sub-areas.



# Changes

## Since last year:

- 1) Updated NQC.
- 2) 2019 load forecast has increased by 167 MW vs. 2018
- 3) LCR need has increased in 2019 vs. 2018 by 55 MW mainly due to load increase.
- 4) 2023 load forecast has increased by 275 MW vs. 2022
- 5) LCR need has increased in 2023 vs. 2022 by 113 MW. In 2022 the Vaca Dixon – Lakeville 230 kV Reconductoring project was assumed in-service, which resulted in lower need identified. In the 2023 study the Vaca Dixon-Lakeville 230kV Line Reactor Project was assumed in-service.

# THANK YOU

Your comments and questions are welcome.

For written comments, please send to: [RegionalTransmission@caiso.com](mailto:RegionalTransmission@caiso.com)

---

## Stay connected



@California\_ISO



Download ISO Today  
mobile app



Sign up for the Daily Briefing  
at [www.caiso.com](http://www.caiso.com)