




# 2018 & 22 Final LCR Study Results Humboldt Area

Irina Green


Senior Advisor, Regional Transmission North

Stakeholder Call

April 13, 2017




# Humboldt and North Coast/North Bay



# Humboldt Load and Resources (MW)

		<b>2018</b>	<b>2022</b>
Load	=	184	196
AAEE	=	-8	-17
Transmission Losses	=	11	11
Total Load	=	<b>187</b>	<b>190</b>
Market Generation	=	196	196
QF/Self-Gen Generation	=	14	14
Total Qualifying Capacity	=	<b>210</b>	<b>210</b>

# Critical Contingencies Humboldt Area



# Critical Contingencies Humboldt Area

## **Humboldt Overall – Single Contingency Winter Peak**

Contingency: Cottonwood-Bridgeville 115 kV line + one Humboldt  
PP units out of service

Limiting component: Thermal overload on Humboldt -Trinity 115 kV line

2018 LCR Need: 121 MW

2022 LCR Need: 121 MW

## **Humboldt Overall – Double Contingencies Winter Peak**

Contingency: Cottonwood – Bridgeville 115 kV line + Humboldt – Humboldt  
Bay 115kV line

Limiting component: Thermal overload on Humboldt -Trinity 115 kV line

2018 LCR need: 169 MW

2022 LCR need: 169 MW

# Changes

## Since last year:

- 1) Load went down by 1 MW in 2018 compared with 2017
- 2) LCR need increased by 12 MW in 2018 compared to 2017 due to different limiting contingency.
- 3) Load went down by 5 MW in 2022 compared with 2021
- 4) LCR need remained the same in 2022 compared to 2021.

## Since last stakeholder meeting:

- 1) Updated NQC.

**Your comments and questions are welcomed**

**Please send written comments to:**

**[RegionalTransmission@caiso.com](mailto:RegionalTransmission@caiso.com)**