

Summary

- This status update covers upgrades required for Projects that have an LGIA and are moving forward with construction activities.
- TPP-approved projects in the SDG&E area have not been identified as Precursor Network Upgrades (PNU).
- There are currently 2 new generator interconnection remedial action schemes (RAS) being designed/built in the SDG&E area.



Status – Network Upgrades

No.	ID	Network Upgrades	Status	Estimated In- service Date Jan- TDF	Current Estimated In- service Date	Comments
1	SDGE-C11-PHII-RNU-02	Friars - Doublet Tap - Pasquitos RAS	In construction	Jun-22	Jun-22	
3	I .	CEC RAS: 230kV overloads on San Luis Rey-Encina- Palomar Energy; and San Luis Rey- San Onofre lines	In design	Jun-23	Jun-23	CEC RAS will address previously identified RNUs.
5	SDGE-C08-PHII-RNU-05	Silvergate - Old Town RAS : 230kV overload on TL23028/29	Not needed	Jun-23	Not needed ¹	

^{1:} Operational Deliverability study results do not show need for this RAS until 2024 or beyond.

