

Study Area: SCE Metro

Thermal Overloads



ID	Overloaded Facility	Worst Contingency	Category	Category Description	Loading (%)								Potential Mitigation Solutions
					2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Spring Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
METRO-T-1	VINCENT 500/230 KV #1	VINCENT 500/230 kV #4	P1	T-1	<100	<100	<100	108.05	<100				1) Dispatch generation in LA Basin 2) Replace Vincent #1 transformer to match the rating of the #4 transformer.
METRO-T-2	LUGO – VICTORVL 500 KV #1	LUGO – ELDORDO 500 KV #1	P1	L-1	<100	<100	99.80	<100	<100				Increase the rating of the line.
METRO-T-3		LUGO – ELDORDO 500 KV #1 & MOUNTAIN VIEW CC MODULE	P3	G-1/L-1	<100	<100	100.53	<100	<100				
METRO-T-4	LAGUBELL – MESA CAL 230 #1	MESA CAL – LITEHIPE 230.0 #1 & MESA CAL – REDONDO 230.0 #1	P6	L-1/L-1	<100	<100	107.66	<100	<100				Utilize Preferred Resources and Energy Storage.
METRO-T-5		MESA CAL – LITEHIPE 230.0 #1 & MESACALS – LAGUBELL 230.0 #2	P7	L-2	<100	<100	101.99	<100	<100				
METRO-T-6		MESA 500./230 KV #3 & #4	P6	T-1/T-1	<100	<100	104.66	<100	<100				
METRO-SP-T-7	LUGO – VICTORVL 500 KV #1	LUGO – ELDORDO 500 KV #1 & MOHAVE – ELDORDO 500 KV #1 OR MOHAVE – LUGO 500 KV #1	P6	L-1/L-1	113.98	111.50	127.47	<100	<100				Increase the rating of the line.
METRO-T-8	VINCENT 500/230 KV #1	VINCENT 500/230 KV #4 & VINCENT – MESA CAL 500 KV #1	P6	T-1/L-1	N/A	N/A	112.12	N/A	N/A				1) Replace Vincent #1 transformer to match the rating of the #4 transformer . 2) System adjustment after intial or second contingency including utilizing Preferred Resources & Energy Storage.
METRO-T-9		VINCENT 500/230 kV #4 & SYLMAR1 – SYLMAR S 230 KV #1	P6	T-1/L-1	104.53	111.70	<100	113.53	116.38				
METRO-T-10	LCIENEGA – LA FRESA 230KV #1	EL NIDO – LA FRESA 230 KV #3 & #4	P7	L-2	<100	<100	<100	103.00	<100				Increase pre-contingency generation in the El Nido local area.
METRO-T-11	SERRANO 500/230 KV #1, #2, OR #3	TWO SERRANO 500/230 KV TRAN.	P6	T-1/T-1	100.97	108.46	117.37	125.03	<100				1) Install a hot spare transformer 2) System adjustments after intial or second contingency including dispatching generation and Preferred Resources & Storage.

Study Area: **SCE Metro**

Thermal Overloads



ID	Overloaded Facility	Worst Contingency	Category	Category Description	Loading (%)								Potential Mitigation Solutions
					2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Spring Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
METRO-T-12	MIRALOMA 500/230 KV #4	MIRALOMA – SERRANO 500 KV #2 & LUGO – RANCHVST 500 KV #1	P6	L-1/L-1	127.82	122.02	<100	<100	<100				System adjustments after initial or second contingency including looping-in the Rancho Vista-Serrano line into Mira Loma.
METRO-T-13	MIRALOMA 500/230 KV #1 OR #2	MIRALOMA 500/230 KV #2 OR #1 & MIRALOMA – SERRANO 500 KV #2	P6	T-1/L-1	107.67	108.08	<100	<100	<100				System adjustments after first or second contingency including looping-in the Rancho Vista-Serrano line into Mira Loma and energizing the spare Mira Loma 500/230 kV transformer.
METRO-T-14	BARRE – LEWIS 230 KV #1	S.ONOFRE – SERRANO 230 KV # & BARRE – VILLA PK 230 KV #1	P6	L-1/L-1	<100	<100	<100	110.90	<100				Dispatch generation in Orange County after initial contingency .
METRO-T-15	MIRALOMA – SERRANO 500 KV #2	LUGO – RANCHVST 500 KV #1 & PALOVRDE – COLRIVER 500 KV #1	P6	L-1/L-1	105.65	<100	<100	<100	<100				Dispatch generation in LA Basin or loop-in Rancho Vista-Serrano line into Mira Loma after initial or second contingency.
METRO-T-16	MIDWAY – WIRLWIND 500 KV #3	MIDWAY – VINCENT 500 KV #1 & #2	P7	L-2	111.72	108.60	104.57	<100	<100				Reduce transfers on Path 26 within 30 minutes after the contingency.

Study Area: **SCE Metro**

Voltage Deviations



ID	Substation	Worst Contingency	Category	Category Description	Post Cont. Voltage Deviation %								Potential Mitigation Solutions
					2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Spring Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
Metro-VD-1	GOLETA 66 KV	S.CLARA – GOLETA #1 OR #2	P1	L-1	<5%	<5%	<5%	<5%	5%	<5%	<5%	<5%	Voltage deviation at limit. Available generators at Goletta can be used to reduce voltage deviation.

Study Area: **SCE Metro**

High/Low Voltage



ID	Substation	Worst Contingency	Category	Category Description	Voltage (PU)								Potential Mitigation Solutions
					2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Spring Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	

No high/low voltage deviations identified.

Study Area: **SCE Metro**

Transient Stability



ID	Contingency	Category	Category Description	Transient Stability Performance								Potential Mitigation Solutions
				2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Spring Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
X-TS-1												



Single Contingency Load Drop

ID	Worst Contingency	Category	Category Description	Amount of Load Drop (MW)								Potential Mitigation Solutions
				2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Spring Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
X-SP-SLD-1												

No single contingency resulted in total load drop of more than 250 MW.

Study Area: **SCE Metro**



Single Source Substation with more than 100 MW Load

ID	Substation	Load Served (MW)								Potential Mitigation Solutions
		2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Spring Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
X-SP-SS-1										

No single source substation with more than 100 MW Load