

Study Area: **SCE Bulk**

Thermal Overloads



ID	Overloaded Facility	Worst Contingency	Category	Category Description	Loading (%)								Potential Mitigation Solutions
					2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Spring Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
Bulk-SP-T-1	Lugo-Victorville 500 kV	Lugo-Eldorado 500 kV and Eldorado-Mohave/Lugo-Mohave 500 kV lines	P6	L-1/L-1	111.47	113.25	120.03	<100	<100				Increase line rating
Bulk-SP-T-2	Midway-Whirlwind 500 kV	N-2 Midway-Vincent 500kV lines with RAS	P7	L-2	109.34	107.49	107.59	<100	<100				Reduce transfers on Path 26 within 30 minutes after the contingency.
Bulk-SP-T-3	Otay Mesa-Tijuana 230 kV	Eco-Miguel 500 kV and Ocotillo-Suncrest 500 kV lines	P6	L-1/L-1	<100	124.70	131.70	Diverge	<100				Systems adjustments after initial contingency including IV phase shifter adjustment and dispatching preferred resources.
Bulk-SP-T-4	La Rosita-Imperial Valley 230 kV	Eco-Miguel 500 kV and Ocotillo-Suncrest 500 kV lines	P6	L-1/L-1	116.76	116.34	115.37	Diverge	<100				Systems adjustments after initial contingency including IV phase shifter adjustment and dispatching preferred resources.
Bulk-SP-T-5	Barre-Ellis 230 kV lines #1-4	Eco-Miguel 500 kV and Ocotillo-Suncrest 500 kV lines	P6	L-1/L-1	<100	102.32	<100	<100	<100				Systems adjustments after initial contingency including IV phase shifter adjustment and dispatching preferred resources.
Bulk-SP-T-6	N/A	Eco-Miguel 500 kV and Ocotillo-Suncrest 500 kV lines with Otay-Mesa-Tijuana 230 kV line tripped	P6	L-1/L-1	Diverge	Diverge	Diverge	Diverge	Converge				Systems adjustments after initial contingency including IV phase shifter adjustment and dispatching preferred resources.
Bulk-SP-T-7	N/A	Eco-Miguel 500 kV and Ocotillo-Suncrest 500 kV lines with La Rosita-Imperial Valley 230 kV line tripped	P6	L-1/L-1	Diverge	Diverge	Diverge	Diverge	Converge				Systems adjustments after initial contingency including IV phase shifter adjustment and dispatching preferred resources.

Study Area: **SCE Bulk**

Voltage Deviations



ID	Substation	Worst Contingency	Category	Category Description	Post Cont. Voltage Deviation %								Potential Mitigation Solutions
					2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Summer Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
X-VD-1													

No voltage deviations identified.

Study Area: **SCE Bulk**

High/Low Voltage



ID	Substation	Worst Contingency	Category	Category Description	Voltage (PU)								Potential Mitigation Solutions
					2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Summer Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
X-V-1													

No high/low voltage violations identified.

Study Area: **SCE Bulk**

Transient Stability



ID	Contingency	Category	Category Description	Transient Stability Performance								Potential Mitigation Solutions
				2017 Summer Peak	2020 Summer Peak	2025 Summer Peak	2017 Summer Off-Peak	2020 Spring Light Load	N/A	N/A	N/A	
X-TS-1												

Study Area: **SCE Bulk**



Single Contingency Load Drop

ID	Worst Contingency	Category	Category Description	Amount of Load Drop (MW)								Potential Mitigation Solutions
				Select..	Select..	Select..	Select..	Select..	Select..	Select..	Select..	
X-SLD-1												

No single contingency resulted in total load drop of more than 250 MW.

Study Area: **SCE Bulk**



Single Source Substation with more than 100 MW Load

ID	Substation	Load Served (MW)								Potential Mitigation Solutions
		Select..	Select..	Select..	Select..	Select..	Select..	Select..	Select..	
X-SS-1										

No single source substation with more than 100 MW Load