

| A               | B                     | C                    | D                       | E    | F                   | G     | H                    | I                           | J                    | K            | L                                 |
|-----------------|-----------------------|----------------------|-------------------------|------|---------------------|-------|----------------------|-----------------------------|----------------------|--------------|-----------------------------------|
| DG Node         |                       | DG in Base Portfolio | WDAT/Rule 21 non-NEM DG |      | Existing non-NEM DG |       | 2017 Unassigned PDGD | Total Additional DG Modeled | Total DG Deliverable | 2017-18 PDGD | Notes                             |
| Substation Name | Transmission Level kV |                      | EO                      | FC   | EO                  | FC    |                      |                             |                      |              |                                   |
| ASH             | 69                    | 1.00                 |                         |      |                     |       |                      | 1.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| ARTESN          | 69                    | 1.00                 |                         |      |                     |       |                      | 1.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| BORDER          | 69                    | 9.68                 | 9.68                    |      |                     |       |                      | 9.68                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| BORREGO         | 69                    | 6.50                 |                         |      |                     | 6.50  |                      | 0.00                        | 0.00                 | 0.00         | PDGD = Deliverable MW             |
| BOULEVRD        | 69                    | 2.00                 | 2.00                    |      |                     |       |                      | 2.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| CAPSTRNO        | 138                   | 8.00                 | 4.00                    | 4.00 |                     |       |                      | 4.00                        | 4.00                 | 4.00         | PDGD = Deliverable MW             |
| CHCARITA        | 138                   | 4.73                 | 4.73                    |      |                     |       |                      | 23.11                       | 0.00                 | 0.00         | Constrained by multiple overloads |
| CORONADO        | 69                    | 4.00                 |                         | 4.00 |                     |       |                      | 0.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| CREELMAN        | 69                    | 14.82                |                         | 3.50 |                     | 10.46 |                      | 8.69                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| CRSTNTS         | 69                    | 0.00                 |                         |      |                     |       |                      | 5.16                        | 5.16                 | 0.00         | PDGD = MW in base portfolio       |
| DEL MAR         | 69                    | 0.00                 |                         |      |                     |       |                      | 17.79                       | 0.00                 | 0.00         | Constrained by multiple overloads |
| EASTGATE        | 69                    | 1.60                 |                         |      |                     |       |                      | 12.43                       | 0.00                 | 0.00         | Constrained by multiple overloads |
| EL CAJON        | 69                    | 7.50                 |                         |      |                     | 7.50  |                      | 0.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| ENCNITAS        | 69                    | 0.00                 |                         |      |                     |       |                      | 7.38                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| ESCNDIDO        | 69                    | 31.50                | 1.50                    |      |                     | 30.00 |                      | 1.50                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| FENTON          | 69                    | 0.00                 |                         |      |                     |       |                      | 0.62                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| IMPRLBCH        | 69                    | 0.00                 |                         |      |                     |       |                      | 7.24                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| LAGNA NL        | 138                   | 0.00                 |                         |      |                     |       | 1.10                 | 1.10                        | 1.10                 | 1.10         | PDGD = 2017 Unassigned            |
| LILAC           | 69                    | 5.00                 |                         | 2.00 |                     | 3.00  |                      | 0.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| LOSCOCHS        | 69                    | 3.00                 |                         |      |                     |       |                      | 3.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| MARGARTA        | 138                   | 0.89                 |                         |      |                     |       | 20.89                | 20.89                       | 20.89                | 20.89        | PDGD = 2017 Unassigned            |
| MELROSE         | 69                    | 3.50                 |                         | 3.50 |                     |       |                      | 0.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| MIRAMAR         | 69                    | 0.00                 |                         |      |                     |       |                      | 12.43                       | 0.00                 | 0.00         | Constrained by multiple overloads |
| MONSRATE        | 69                    | 2.72                 | 0.72                    | 2.00 |                     |       |                      | 0.72                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| MOROHILL        | 69                    | 0.00                 |                         |      |                     |       |                      | 4.20                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| MURRAY          | 69                    | 4.50                 |                         |      |                     |       |                      | 4.50                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| NORTHCTY        | 69                    | 0.00                 |                         |      |                     |       |                      | 16.24                       | 0.00                 | 0.00         | Constrained by multiple overloads |
| OMWD            | 69                    | 0.00                 |                         |      |                     |       |                      | 0.70                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| OTAY            | 69                    | 3.20                 |                         |      |                     |       |                      | 3.20                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| OTAYLAKE        | 69                    | 0.00                 |                         |      |                     |       |                      | 0.36                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| PICO            | 138                   | 0.42                 |                         |      |                     |       | 4.42                 | 4.42                        | 4.42                 | 4.42         | PDGD = 2017 Unassigned            |
| POMERADO        | 69                    | 6.00                 | 6.00                    |      |                     |       |                      | 6.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| PRCTRVLY        | 138                   | 3.00                 | 3.00                    |      |                     |       |                      | 3.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| R.SNTAFE        | 69                    | 0.00                 |                         |      |                     |       |                      | 4.51                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| SANTYSBL        | 69                    | 0.82                 |                         |      |                     |       |                      | 0.82                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| SANYSRO         | 69                    | 0.00                 |                         |      |                     |       |                      | 9.95                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| SCRIPPS         | 69                    | 0.00                 |                         |      |                     |       |                      | 0.12                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| STREAMVW        | 69                    | 6.25                 |                         |      |                     |       |                      | 6.25                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| SUNYSIDE        | 69                    | 0.00                 |                         |      |                     |       |                      | 2.92                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| TOREYPNS        | 69                    | 0.00                 |                         |      |                     |       |                      | 1.52                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| TRABUCO         | 138                   | 0.00                 |                         |      |                     |       | 1.38                 | 6.09                        | 6.09                 | 1.38         | PDGD = 2017 Unassigned            |
| VALCNTR         | 69                    | 10.83                |                         |      |                     | 9.83  |                      | 1.00                        | 0.00                 | 0.00         | Constrained by multiple overloads |
| WARNERS         | 69                    | 1.50                 |                         |      |                     |       |                      | 1.50                        | 0.00                 | 0.00         | Constrained by multiple overloads |