

California Independent System Operator Corporation
Fifth Replacement Tariff

transmission elements feed radial Load.

- RAS or SPS - existing Remedial Action Schemes (RAS) or special protection systems (SPS) may impact the derivation of simple flow limits. When developing the limit, the CAISO determines if the RAS or SPS will be in-service during the Outage and factors the interrelationship between the RAS or SPS and the derived flow limit. CAISO will update the transfer limits in recognition of the changing status and/or availability of the RAS or SPS.