

ATTACHMENT B

2.5.21 Scheduling of Units to Provide Ancillary Services.

The ISO shall prepare supplier schedules for Ancillary Services (both self provided and purchased by the ISO) for the Day-Ahead and the Hour-Ahead Markets. The ISO shall notify each Scheduling Coordinator no later than 1:00 p.m. of the day prior to the Trading Day of their Ancillary Services schedules for the Day-Ahead and no later than one hour prior to the operating hour of their Ancillary Services schedules for the Hour-Ahead. The ISO Protocols set forth the information, which will be included in these schedules. Where long-term contracts are involved, the information may be treated as standing information for the duration of the contract.

If, at any time after the issuance of Final Day-Ahead Schedules for the Trading Day and before the close of the Hour-Ahead Market for the first Settlement Period of the Trading Day, the ISO determines that it requires Ancillary Services in addition to those included in the Final Day-Ahead Schedule (in the appropriate zone if procuring zonally), the ISO may procure such additional Ancillary Services by providing Scheduling Coordinators with amended supplier schedules for the Day-Ahead Markets that include Ancillary Services for which previously submitted (but not selected) bids remain available and have not previously been withdrawn. The ISO shall select such Ancillary Services in price merit order (and in the relevant zone if the ISO is procuring Ancillary Services on a zonal basis). Such amended supplier schedules shall be provided to the Scheduling Coordinators no later than the close of the Hour-Ahead Market for the first Settlement Period of the Trading Day.

Once the ISO has given Scheduling Coordinators notice of the Day-Ahead and Hour-Ahead schedules, these schedules represent binding commitments made in the markets between the ISO and the Scheduling Coordinators concerned, subject to any amendments issued as described above. Any minimum energy input and output

associated with Regulation and Spinning Reserve services shall be the responsibility of the Scheduling Coordinator, as the ISO's auction does not compensate the Scheduling Coordinator for the minimum energy output of Generating Units bidding to provide these services. Accordingly the Scheduling Coordinators shall adjust their schedules to accommodate the minimum outputs required by the Generating Units included on the Schedules.

Notwithstanding the foregoing, a Scheduling Coordinator who has sold or self-provided Regulation, Spinning Reserve, Non-Spinning Reserve or Replacement Reserve capacity to the ISO in the Day-Ahead Market shall be required to replace that capacity in whole or in part from the ISO if the scheduled self-provision is decreased between the Day-Ahead and Hour-Ahead Markets, or if the Ancillary Service associated with a Generating Unit, Curtailable Demand, or System Resource successfully bid in a Day-Ahead Ancillary Service Market is reduced in the Hour-Ahead Market, for any reason (other than the negligence or willful misconduct of the ISO, or a Scheduling Coordinator's involuntary decrease in [such sold capacity or](#) scheduled self-provision on the instruction of the ISO). The price for such replaced Ancillary Service shall be the Market Clearing Price in the Hour-Ahead Market for the Ancillary Service for the Settlement Period concerned for the Zone in which the Generating Units or other resources are located. The ISO will purchase the Ancillary Service concerned from another Scheduling Coordinator in the Hour-Ahead Market in accordance with the provisions of the ISO Tariff.

Schedules and Bids Protocol

SBP 5.3 Buy Back of Ancillary Services

A Scheduling Coordinator who has sold or self-provided Regulation, Spinning Reserve, Non-Spinning Reserve or Replacement Reserve capacity to the ISO in the Day-Ahead Market shall be required to replace such capacity to the extent scheduled self-provision is decreased between the Day-Ahead and Hour-Ahead Markets, or to the extent the Ancillary Service associated with a Generating Unit, Curtailable Demand, or System Resource successfully bid in a Day-Ahead Ancillary Service Market is reduced in the Hour-Ahead Market, for any reason (other than the negligence or willful misconduct of the ISO, or a Scheduling Coordinator's involuntary decrease in [such sold capacity or](#) scheduled self-provision on the instruction of the ISO). The price for such replaced Ancillary Service shall be at the Market Clearing Price in the Hour-Ahead Market for the same Settlement Period for the Ancillary Service capacity concerned.

Scheduling Protocol

SP 9.1 Bid Evaluation and Scheduling Principles

The ISO will evaluate Ancillary Services bids based on the following principles:

- (a) the ISO will not differentiate between bidders other than through reserve (Regulation and Operating Reserves) price and capability to provide the reserve service, and the required locational mix of services;
- (b) to minimize the costs to users of the ISO Controlled Grid, the ISO will select the bidders with lowest bids for reserve which meet its technical requirements, including location and operating capability;
- (c) the ISO will (to the extent available) procure sufficient Ancillary Services to meet its technical requirements as defined in the ASRP;
- (d) the ISO will evaluate and price only those Ancillary Services bids received in accordance with the SBP;
- (e) the ISO will require SCs to honor their Day-Ahead Ancillary Services schedules and/or bids when submitting their Hour-Ahead Ancillary Services schedules and/or bids. A Scheduling Coordinator who has sold or self-provided Regulation, Spinning Reserve, Non-Spinning Reserve or Replacement Reserve capacity to the ISO in the Day-Ahead Market shall be required to replace such capacity to the extent scheduled self-provision is decreased between the Day-Ahead and Hour-Ahead Markets, or to the extent the Ancillary Service associated with a Generating Unit, Curtailable Demand, or System Resource successfully bid in a Day-Ahead Ancillary Service Market is reduced in the Hour-Ahead Market, for any reason (other than the negligence or willful misconduct of the ISO, or a Scheduling Coordinator's involuntary decrease in [such sold capacity or](#) scheduled self-provision on the instruction of the ISO). The price for such replaced Ancillary Service shall be at the Market Clearing Price in the Hour-Ahead Market for the same Settlement Period for the Ancillary Service capacity concerned. Increases in each Scheduling Coordinator's self-provided Ancillary Services between the Day-Ahead and Hour-Ahead Markets shall be limited to the estimated incremental Ancillary Service requirement associated with the increase between the Day-Ahead and Hour-Ahead Markets in that Scheduling Coordinator's scheduled Zonal Load. Notwithstanding this limit on increases in Hour-Ahead self-provision, a Scheduling Coordinator may buy or sell Ancillary

Services through Inter-Scheduling Coordinator Ancillary Service Trades in the Hour-Ahead Market;

- (f) due to the design of the ISO's scheduling software, the ISO will not take into account Usage Charges in the evaluation of Ancillary Services bids or in price determination and, in the event of Congestion in the Day-Ahead Market or Hour-Ahead Market, Ancillary Services will be procured and priced on a Zonal basis; and
- (g) due to the design of the ISO's scheduling system, any specific resource can bid to supply a specific Ancillary Service or can self-provide such Ancillary Service but cannot do both in the same Settlement Period.

Scheduling Protocol

SP 9.3

Scheduling Ancillary Services Resources

- (a) SCs are allowed to self-provide all or a portion of the following Ancillary Services to satisfy their obligations to the ISO:
 - (i) Regulation;
 - (ii) Spinning Reserve;
 - (iii) Non-Spinning Reserve; and
 - (iv) Replacement Reserve.
- (b) The ISO will reduce the quantity of Ancillary Services it competitively procures by the corresponding amount of the Ancillary Services that SCs self-provide.
- (c) The ISO shall prepare supplier schedules for Ancillary Services (both self-provided and purchased by the ISO) for the Day-Ahead Market and the Hour-Ahead Market.
- (d) The Ancillary Services schedules shall contain the information set out in the SBP for each Settlement Period of the following Trading Day in the case of the Day-Ahead schedules or for a specific Settlement Period in the case of Hour-Ahead schedules.
- (e) Once the ISO has given SCs notice of the Day-Ahead and Hour-Ahead schedules, these schedules represent binding commitments made in the reserve markets between the ISO and the SCs concerned. A Scheduling Coordinator who has sold or self-provided Regulation, Spinning Reserve, Non-Spinning Reserve or Replacement Reserve capacity to the ISO in the Day-Ahead Market shall be required to replace such capacity to the extent scheduled self-provision is decreased between the Day-Ahead and Hour-Ahead Markets, or to the extent the Ancillary Service associated with a Generating Unit, Curtailable Demand, or System Resource successfully bid in a Day-Ahead Ancillary Service Market is reduced in the Hour-Ahead Market, for any reason (other than the negligence or willful misconduct of the ISO, or a Scheduling Coordinator's involuntary decrease in [such sold capacity or](#) scheduled self-provision on the instruction of the ISO). The price for such replacement shall be at the Market Clearing Price in the Hour-Ahead Market for the Ancillary Service for the Settlement Period concerned for the Zone in which the Generating Unit or other resources on behalf of which the Scheduling Coordinator buys back the capacity, are located. The ISO will purchase the Ancillary Service concerned from another

Scheduling Coordinator in the Hour-Ahead Market in accordance with the provisions of the ISO Tariff.

- (f) Any minimum Energy output associated with Regulation and Spinning Reserve services shall be the responsibility of the SC, as the ISO's auction does not compensate the SC for the minimum Energy output of its Generating Units or System Unit, if any, bidding to provide these services. Accordingly, the SCs shall adjust their Balanced Schedules to accommodate the minimum Energy outputs required by the Generating Units or System Units, if any, included in the Ancillary Services schedules.
- (g) SCs providing one or more of the Ancillary Services cannot change the identification of the Generating Units System Units or external imports of System Resources, if any, or Curtailable Demands offered in the Day-Ahead Market, in the Hour-Ahead Market, or in the Real Time Market (except with respect to System Units, if any, in which case SCs are required to identify and disclose the resource specific information for all Generating Units and Curtailable Demands constituting the System Unit scheduled or bid into the ISO's Day-Ahead Market and Hour-Ahead Market as required in SP 3.3.2(e)).