

2.3.3.5 Maintenance Outage Planning. Each Operator shall, by not later than October 1 each year, provide the ISO with a program of all Maintenance Outages which it wishes to undertake during the next following year. In the case of a Participating TO, that program shall be developed in consultation with the UDCs interconnected with that Participating TO's system and shall take account of each UDC's planned maintenance requirements. The nature of the information to be provided and the detailed Maintenance Outage planning procedure shall be established by the ISO in consultation with the ISO Grid Operations Committee and set out in an ISO Protocol. Either the ISO, pursuant to Section 2.3.3.6, or an Operator, subject to Section 2.3.3.5.4, may at any time request a change to an Approved Maintenance Outage. An Operator may, upon seventy-two (72) hours advance notice, schedule with the ISO Outage Coordination Office a Maintenance Outage on its system, subject to the conditions of Sections 2.3.3.5.1, 2.3.3.5.2, and 2.3.3.5.3.

* * * * *

2.3.3.5.4 In the event an Operator of facilities forming part of the ISO Controlled Grid cancels an Approved Maintenance Outage after 5:00 a.m. of the day prior to the day upon which the outage is scheduled to commence and the ISO determines that the change was not required to preserve System Reliability, the ISO may disregard the availability of the affected facilities in determining the availability of transmission capacity in the Day-Ahead Market, provided, however, that the ISO will, as promptly as practicable, notify Market Participants and reflect the availability of the affected facilities in determining the availability of transmission capacity in the Hour-Ahead Market.

* * * * *

2.3.3.6 Maintenance Outage Requests by the ISO. The ISO Outage Coordination Office may at any time request a Maintenance Outage or a change to an Approved Maintenance Outage from an Operator if, in the opinion of the ISO Outage Coordination Office, the requested Maintenance Outage or change is required to secure the efficient use and reliable operation of the ISO Controlled Grid. In addition, the ISO Outage Coordination Office may, by providing notice no later than 5:00 a.m. of the day prior to the day upon which the outage is scheduled to commence, direct the Operator of facilities forming part of the ISO Controlled Grid to cancel an Approved Maintenance Outage, when necessary to preserve or maintain System Reliability or to avoid unduly significant market impacts that would arise if the outage were to proceed as scheduled. The Operator, acting in accordance with Good Utility Practice, shall comply with the

ISO's direction and the provisions of Sections 2.3.3.6.1 and 2.3.3.6.2 shall not apply. The ISO shall give notice of any such direction to Market Participants prior to the deadline for submission of initial Preferred Day-Ahead Schedules for the day on which the outage was to have commenced.

* * * * *

OCP 3.1.3 Changes to Planned Maintenance Outages

A Participating TO may submit changes to its planned Maintenance Outage information at any time, provided, however, that if the Participating TO cancels an Approved Maintenance Outage after 5:00 a.m. of the day prior to the day upon which the outage is scheduled to commence and the ISO determines that the change was not required to preserve System Reliability, the ISO may disregard the availability of the affected facilities in determining the availability of transmission capacity in the Day-Ahead Market. The ISO will, however, notify Market Participants and reflect the availability of transmission capacity in the Hour-Ahead Market as promptly as practicable.

* * * * *

OCP 3.2.3 Direction by the ISO

The ISO Outage Coordination Office may, by providing notice no later than 5:00 a.m. of the day prior to the day upon which the outage is scheduled to commence, direct the Operator of facilities forming part of the ISO Controlled Grid to cancel an Approved Maintenance Outage, when necessary to preserve or maintain System Reliability or to avoid unduly significant market impacts that would arise if the outage were to proceed as scheduled. The Operator, acting in accordance with Good Utility Practice, shall comply with the ISO's direction. The ISO shall give notice of any such direction to Market Participants prior to the deadline for submission of initial Preferred Day-Ahead Schedules for the day on which the outage was to have commenced.