

Application No.: R.12-03-014

Exhibit No.: _____

Witness: Robert Sparks

Order Instituting Rulemaking to Integrate
and Refine Procurement Policies and
Consider Long-Term Procurement Plans.

Rulemaking 12-03-014

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE
CALIFORNIA INDEPENDENT SYSTEM OPERATOR CORPORATION**

1
2
3

4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE
STATE OF CALIFORNIA**

Order Instituting Rulemaking to Integrate
and Refine Procurement Policies and
Consider Long-Term Procurement Plans.

Rulemaking 12-03-014

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE
CALIFORNIA INDEPENDENT SYSTEM OPERATOR CORPORATION**

Q. What is your name and by whom are you employed?

A. My name is Robert Sparks. I am employed by the California Independent System Operator Corporation (ISO), 250 Outcropping Way, Folsom, California as Manager, Regional Transmission.

Q. Have you previously submitted testimony in Track 4?

A. Yes. On August 5, 2013, I submitted opening testimony on behalf of the ISO containing the results of the ISO's Track 4 studies and an explanation of the modeling and study methodology.

Q. What is the purpose of your rebuttal testimony?

A. Numerous parties to this proceeding have taken issue with the ISO's study methodology and identification of residual resource needs in the absence of SONGS. In this rebuttal testimony, I will respond to issues involving the technical aspects of the ISO's studies and application of the NERC/WECC reliability standards. Mr. Millar will address topics raised by parties regarding the ISO's transmission planning studies and the joint agency reliability report on the SONGS retirement, as well as some recommendations for the Commission's consideration.

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
R.12-03-014**

Page 2 of 19

The ISO's Study Methodology: Transmission Planning Standards, the N-1-1 Contingency and Load-Shedding

1
2
3
4 **Q. Many of the parties to this Track 4 proceeding, including SCE and SDG&E,**
5 **have raised issues about the ISO's application of NERC/ WECC/ISO**
6 **transmission planning standards embodied in the study methodology approved**
7 **by the Commission in D.13-02-015 (Track 1 decision) and also in D.13-03-029**
8 **(SDG&E procurement decision). Do you believe that this topic and the ISO's**
9 **study methodology in general are issues to be addressed in Track 4?**

10
11 **A.** No. As I discussed in my opening testimony, according to the May 21, 2013,
12 Revised Scoping Ruling, the ISO was to determine the residual local capacity needs
13 in the LA Basin and San Diego local areas (combined into a SONGS study area),
14 using the assumptions approved in D.13-02-015 and D.13-03-029, assuming a
15 SONGS outage for years 2018 and 2022 and SONGS online in 2022. The ISO's
16 local capacity requirement (LCR) study methodology was thoroughly litigated in
17 both proceedings and it was approved in both decisions. This study methodology
18 includes the ISO's position that load shedding in the highly urbanized San Diego
19 local capacity area is not appropriate to mitigate the N-1-1 contingency of
20 overlapping outages of the SWPL and Sunrise Powerlink transmission lines.
21 Indeed, as I explained in rebuttal testimony recently submitted in the Commission
22 proceeding evaluating the need for the Pio Pico generation facility, Docket A.13-06-
23 015, the ISO takes the same position with respect to load shedding as a transmission
24 planning mechanism in highly urbanized areas of the ISO grid in all areas of the
25 grid, including the SCE and PG&E service territories (see attachment 1).

26
27 **Q. Based on the testimony presented in Track 4, should the Commission re-**
28 **evaluate its prior decisions regarding the ISO's study methodology and the**
29 **ISO's position on load shedding for N-1-1 contingencies?**

30

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 3 of 19

1 **A.** No. None of the parties submitting testimony have presented any compelling basis
2 for the Commission to change its determinations in D.13-02-015 and D.13-03-029
3 that the ISO’s LCR methodology should be used to determine local capacity needs
4 for the LA Basin and the San Diego local areas. In fact, as described below, much
5 of the intervener’s testimony is factually incorrect.

6
7 **Q.** **Both SDG&E and SCE ran studies that included load shedding in the San**
8 **Diego local area for the overlapping outage of SWPL and Sunrise. Does the**
9 **ISO believe that these parties recommend load shedding as a long term**
10 **mitigation solution for this N-1-1 contingency?**

11
12 **A.** No, I don’t believe that either party recommends load shedding in highly urbanized
13 areas for Category C contingencies, consistent with the ISO’s position on this issue.
14 Although both SDG&E and SCE presented a scenario with load shedding, both
15 parties also based their procurement recommendations and requests for additional
16 procurement on the results of the ISO’s studies that did not include load drop (See
17 SCE-1, page 44 and page 2 of Mr. Jontry’s testimony). At page 37 SCE also makes
18 the point that the Mesa loop-in does not effectively address the N-1-1 contingency,
19 and that load shedding or additional generation in San Diego is more effective at
20 addressing the N-1-1 contingency.

21
22 **Q.** **Based on your understanding that SCE is not recommending load shedding for**
23 **the N-1-1 contingency in SDG&E, does the ISO have any concerns with SCE’s**
24 **other study assumptions?**

25
26 **A.** Yes. At SCE-1, page 27, SCE notes that their studies meet NERC reliability
27 standards but not the “more stringent” requirements used by the ISO. One of the
28 standards referred to is the WECC requirement that, in order to account for
29 modeling uncertainties (e.g. power factor, equipment mis-operation during
30 contingencies, variations in neighboring system models, etc) without resulting in

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 4 of 19

1 voltage collapse and wide area blackouts, the modeled amount of load should be
2 increased by 5% for Category A or B and 2.5% for Category C contingencies. SCE
3 refers to this adjustment as an ISO requirement but notes, at footnote 21, that this is
4 a WECC Regional Business Practice.

5
6 This WECC Regional Business Practice was approved in 2011 by the WECC
7 Planning Coordination Committee, which includes SCE as a member, and the
8 WECC Board of Directors. While SCE states that their studies, which do not
9 account for this WECC reactive margin, reduce the risk of monetary sanctions to the
10 ISO, SDG&E and SCE, the ISO does not share this view. Indeed, in the event of a
11 blackout related to inadequate reactive margin, the ISO believes that NERC may
12 view this as a violation, and it is possible that it could seek to impose monetary
13 penalties for non-compliance with this widespread and well-accepted business
14 practice. At a minimum, this regional business practice is an industry best practice
15 which the ISO believes should be followed. It is also worth noting that the WECC
16 planning standard for reactive power was utilized in the 2012 SCE Annual
17 Transmission Reliability Assessment report published by SCE.

18
19 **Q. Have other witnesses in Track 4 also recommended that additional local**
20 **capacity needs for the LA Basin/San Diego study area be based on an**
21 **assumption that SDG&E will drop load as a permanent mitigation solution for**
22 **the N-1-1 contingency?**

23
24 **A.** Yes. This topic was addressed in detail by witnesses Powers (Sierra Club), May
25 (CEJA), Fagan (DRA), Woodruff (TURN), Caldwell (CEERT), Peffer (POC) and
26 Firooz (City of Redondo Beach); they raise mostly the same issues that I address
27 above. I will respond to some of their arguments in this rebuttal testimony and Mr.
28 Millar will respond to other topics.

29

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 5 of 19

1 **Q. Isn't load shedding permitted by NERC reliability standard TPL 003 in**
2 **response to a Category C N-1-1 event?**

3

4 **A.** Yes, and the ISO has load shedding in small amounts through special protection
5 schemes (SPS) on the sub-transmission system or for extreme category D
6 contingencies. However, although NERC TPL 003 *permits* load shedding as a
7 mitigation for an N-1-1 contingency, the standard does not *require* the ISO, as the
8 Planning Coordinator, to approve an automatic load shedding SPS under all such
9 circumstances and instead requires the Planning Coordinator to consider system
10 design and expected system impacts in deciding whether an automatic load
11 shedding SPS is appropriate. The historical practice has been, as a last resort, to
12 rely on large amounts of urban load shedding as an interim measure only. In fact,
13 there are two such load shedding arrangements currently in place, both of which
14 have transmission projects underway to eliminate the need for the load shedding.
15 The ISO notes as well, that load shedding was also relied upon in SCE's south
16 Orange County area to mitigate one N-2 outage until the Del Amo-Ellis loop in
17 project could be completed in the summer of 2012, and a different load shedding
18 arrangement was relied upon until the Barre-Ellis reconfiguration and the Johanna,
19 Santiago and Viejo shunt capacitor bank projects could be completed in the summer
20 of 2013.

21

22 **Q. Why not consider load shedding for the N-1-1 contingency of Sunrise and**
23 **SWPL?**

24

25 **A.** The load area targeted for shedding is an urban high population density load area.
26 In addition the lines have a high exposure to outages. Based on information
27 documented in a study performed by SDG&E, over a period of 13 years of fire data,
28 there were 11 fires in the area where the two lines are only four to eight miles apart.
29 One of those fires could have taken out both lines. Although the sample size is
30 statistically small, one could argue that an N-1-1 outage of these lines could occur

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 6 of 19

1 on the order of once in 13 years¹. In addition, the WECC Reliability Subcommittee
2 noted the probability of a simultaneous outage trending to one in 21 years, versus
3 928 years for the originally proposed Sunrise route.

4
5 SDG&E, CFE, and IID all have major tie-lines emanating from Imperial Valley
6 Substation. Not only is the reliability of this substation critical for the reliability of
7 the electric supply to each of these utilities, Imperial Valley substation is a seam
8 between these three utilities, and is vulnerable to human coordination errors due to
9 miscommunication and inconsistent practices for taking clearances and designing
10 protection systems. This exposure is a potential contribution towards an increased
11 risk of line outages and the N-1-1 outage in particular. With SONGS retiring, the
12 dependence on Imperial Valley substation increased.

13
14 Given the selection of the Sunrise environmentally preferred route, which has a
15 higher outage risk, and the retirement of SONGS, the risk profile impacts of outages
16 interrupting supply from Imperial Valley have significantly increased in recent
17 years. For all of these reasons, load shedding in the San Diego local area is not a
18 reasonable or prudent long-term mitigation solution for the N-1-1 contingency.

19
20 **Q. How much load shedding would be required under a 1 in 10 peak load**
21 **condition if the ISO were to plan to a G-1/N-1 only?**

22
23 **A.** The load shedding would be accomplished via an existing safety net special
24 protection scheme. The safety net has two blocks of approximately 500 MW of
25 load each. Therefore, if the ISO were to plan for only the G-1/N-1, we would need
26 to shed 500 MW of load for the N-1-1 contingency. However, the incremental

¹ Data from Performance Category Upgrade Request for Imperial Valley - Miguel 500 kV and Imperial Valley - Central 500 kV Double Line Outage Probability Analysis Seven Step Process Document Final Report Prepared By San Diego Gas & Electric Transmission Planning dated December 19, 2007

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 7 of 19

1 procurement difference between the G-1, N-1 and the N-1-1 criteria would only be
2 approximately 150 to 300 MW, not 500 MW.

3

4 **Q. If the Commission adopted load shedding as a long-term, transmission**
5 **planning mitigation solution for this particular N-1-1 Category C contingency,**
6 **what would be the impact across the ISO grid?**

7

8 **A.** As described above, the exposure to outages of the SWPL and Sunrise lines is
9 higher than average, so if it were deemed that the risk and consequences of this N-1-
10 1 was acceptable, then the risk and consequences of all other category C
11 contingencies and their associated mitigation plans would conceivably be measured
12 against this particular N-1-1. It would also be conceivable that numerous load
13 dropping SPSs across the ISO, which involve large amounts of load drop, would be
14 identified as equally acceptable mitigation plans to be installed in lieu of
15 transmission upgrades and generation procurement.

16

17 **Q. Doesn't SDG&E have a WECC-certified load-dropping "safety net" in place**
18 **that is automatically triggered under certain circumstances?**

19

20 **A.** Yes. This safety net is currently utilized for the category D simultaneous
21 contingency of both lines. Under normal conditions (e.g. no nearby wildfires,
22 normal wind speeds, no lightning storms, etc), the risk of a simultaneous outage of
23 both lines is significantly lower than an overlapping outage. One additional point is
24 that planning for the N-1-1 increases the available resources that can be called upon
25 to protect against the simultaneous outage when outage exposure is known to be
26 higher (e.g. nearby wildfires, high wind speeds, nearby lightning storms, etc). The
27 safety net may also need to be utilized for the N-1-1 when installed resources are
28 unavailable, depending on the load level.

29

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 8 of 19

1 **Q. Is the ISO's approach to planning for the N-1-1 contingency in the San Diego**
2 **local capacity area inconsistent with the ISO's analysis of the benefits of**
3 **Sunrise that were recognized in D.08-12-058, as Mr. Powers claims in his**
4 **testimony on pages 5-7?**

5
6 **A.** Mr. Powers correctly points out that it was demonstrated in the Sunrise CPCN
7 proceeding that the Sunrise Powerlink transmission line would add 1,000 MW of
8 reliability to meet the SDG&E LCR under a G-1, N-1 reliability standard, and that upon
9 energization of the Sunrise Powerlink, the SDG&E LCR area would be expanded to
10 include SDG&E's Imperial Valley substation. Both of these points have proven to be
11 true as explained as follows.

12
13 The 1000 MW benefit was based on increasing the existing import capability into
14 San Diego from 2500 MW to 3500 MW after an outage of either Sunrise or SWPL.
15 At that time, the ISO assumed that the 3500 MW amount would be based on
16 establishing a 3500 MW WECC path rating to replace the existing 2500 MW
17 WECC Path 44 rating. Also at that time, SDG&E was well into the WECC Path
18 Rating Process for establishing a 1000 MW rating on the Sunrise line itself. Since
19 that time, the 1000 MW Sunrise WECC path rating was found to impair the
20 capability of the internal ISO system line and therefore has been eliminated, as well
21 as any notion of pursuing a 3500 MW WECC N-1 Path Rating, for the same reason.
22 Although these path ratings would have helped ensure that changes within
23 neighboring systems could not impact the capability of the ISO system, and
24 provided reasonable margin for this urban load area which has only two reliable
25 connections (SONGS and Imperial Valley) to the rest of the ISO and WECC, they
26 also would have impaired the capability of the internal ISO system. With Sunrise
27 in-service, the Imperial Valley connection became more reliable, and the path
28 ratings are not being pursued any further. Without the path rating impairing the
29 capability of the internal ISO system, the N-1-1 is the most limiting contingency,

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
R.12-03-014**

1 and with only the N-1-1 considered, Sunrise provides more than 1000 MW of
2 incremental benefit.

3
4 To make this point, I have attached page 3 from my supplemental testimony in
5 A.11-05-023. The table on that page shows that the LCR in the San Diego local
6 area need based on the N-1-1 is approximately 2700 MW. The table below
7 compares LCR need based on the G-1/N-1 study methodology utilized by both the
8 ISO and SDG&E in the Sunrise CPCN proceeding, with the LCR need based on the
9 N-1-1 contingency. As can be seen, the San Diego load driving that LCR need was
10 approximately 5700 MW. In the Sunrise proceeding, a 3500 MW import capability
11 after the N-1 was established to determine the LCR need for the G-1/N-1. Using
12 that import capability, with the 600 MW Otay Mesa out of service as the G-1, the
13 LCR need is 2800 MW. Therefore, the LCR need based on the G-1/N-1 utilizing
14 the 3500 MW import capability established in the Sunrise proceeding, with Sunrise
15 completed, is 2800 MW. Utilizing the 2500 MW import capability without Sunrise,
16 the LCR need is 3800 MW. Therefore, the LCR need was actually reduced by 1100
17 MW with the N-1-1 as the worst contingency. With the G-1/N-1 and the 3500 MW
18 import capability the LCR need was only reduced by 1000 MW due to Sunrise.

		Base Case: Without Sunrise based on G-1/N-1 and 2500 MW N- 1 WECC Path 44 Import Limit	With Sunrise based on G-1/N-1 and 3500 MW N-1 Import Limit	With Sunrise based on N-1-1
1	San Diego Area Load	5700 MW	5700 MW	5700 MW
2	Import Limit	2500 MW	3500 MW	not applicable
3	G-1	600 MW	600 MW	not applicable
4	LCR Need (Line 1 - Line 2 + Line 3)	3800 MW	2800 MW	2700 MW
5	Reduction In LCR (relative to the Base Case)		1000 MW	1100 MW

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 10 of 19

1

2 I would note that this topic was thoroughly addressed at a workshop held on April
3 17, 2012 in A.11-05-023.

4

5 With respect to Mr. Power's second point about expanding the SDG&E LCR area to
6 include SDG&E's Imperial Valley substation, this has been done. As shown in the
7 2014 Local Capacity Technical Study report, pages 2 and 94 (attached), the SDG&E
8 LCR area includes the Imperial Valley substation and the name of the area has been
9 changed to "San Diego/Imperial Valley". However, there are also several LCR Sub-
10 areas within the San Diego/Imperial Valley LCR area including the San Diego LCR
11 subarea.

12

13 **Q. Both Mr. Powers and Ms. May describe the critical N-1-1 contingency for the**
14 **San Diego local area as the loss of three major transmission lines- Sunrise,**
15 **SWPL and the automatic cross-trip of the Otay-Mesa-Tijuana 230 kV line.**
16 **They then characterize this contingency as an "extreme" event (N-2) and argue**
17 **that it is incorrect to plan for sufficient generation and transmission to be in**
18 **place in response to these outages (see, e.g. Powers, page 4-5). Mr. Peffer also**
19 **claims that the N-1-1 contingency is really a Category D event (Peffer, page 7,**
20 **11). Is this correct?**

21

22 **A.** No. These witnesses appear to be confusing the Category C.3 overlapping outage of
23 SWPL and Sunrise with the extreme contingency N-2 event, which is a
24 simultaneous loss of two transmission circuits. The N-1-1 reference is shorthand
25 for the loss of one element, time for the system to be adjusted (within 30 minutes),
26 followed by the loss of a second element. I note that Ms. May also advanced the
27 argument that because the outage of Sunrise and SWPL results in the planned
28 opening of a third 230 kV circuit and is therefore a Category D contingency, the
29 2.5% voltage reactive margin should not be applied per language of the WECC
30 requirement (see May testimony at page 34). Because Ms. May has incorrectly

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 11 of 19

1 classified the contingency, her argument about the 2.5% margin required by WECC
2 similarly has no credibility. Furthermore, as I discussed above, although this
3 WECC requirement is not a mandatory reliability standard, it is a WECC Regional
4 Business Practice that applies to WECC member systems.

5

6 **Q. How do you respond to Ms. May’s testimony that the automatic tripping of the**
7 **Otay-Mesa-Tijuana line constitutes a third major transmission outage and**
8 **therefore the N-1-1 is a Category D contingency (testimony, pages 3, 29-31)?**

9

10 **A.** The opening of the Otay-Mesa-Tijuana line following the N-1-1 is a planned and
11 controlled opening of the line to protect it and CFE’s further downstream 230 kV
12 facilities from overloading following the contingency. The opening of this line is
13 not part of the contingency. A contingency is the unexpected failure of the line, but
14 because the opening of this line is an intentional mitigation measure, it is not a
15 contingency. Alternatively, the ISO could recommend the need for additional
16 generation procurement to avoid the overloading of this line following the
17 contingency, but it is more cost effective to simply plan on the opening of this line.
18 This is also a mitigation that was approved by CFE to protect its 230 kV facilities as
19 a result of a contingency on the SWPL and Sunrise line.

20

21 **Q. Would transmission improvements prevent the overloading on this line and**
22 **reduce local capacity needs in the San Diego local area?**

23

24 **A.** As explained in my Track 4 Testimony, the ISO is investigating potential
25 transmission mitigation that might address a portion of the local capacity needs.

26

27 **Q. Ms. Firooz also raises the load shedding issue as well as the probability that the**
28 **N-1-1 contingency will occur under 1-in-10 peak load conditions. Weren’t**
29 **these issues thoroughly addressed in Track 1?**

30

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 12 of 19

1 **A.** Yes. Mr. Millar, in his Track 1 rebuttal testimony (Ex. ISO-6) presented a complete
2 description of the deterministic planning standards embedded in the NERC
3 reliability standards and how this methodology compares with a probabilistic
4 evaluation of the transmission system. This portion of Mr. Millar’s testimony, as
5 well as a discussion of load shedding and the N-1-1 contingency was submitted in
6 response to the opening testimony of CEJA witness Julia May, who in turn relied on
7 testimony that Ms. Firooz presented in Docket A.11-05-023. In her Track 4
8 testimony, Ms. Firooz (at pages 5-6) simply has advanced the same arguments that
9 have been considered and rejected by the Commission in two prior proceedings,
10 without providing any new facts or evidence.

11

12 **Q.** **In a similar vein, Mr. Powers makes that statement that “The purpose of grid**
13 **reliability standards is to assure that a utility can continue to provide reliable**
14 **power during peak demand periods . . . (page 1).” Is this a correct statement?**

15

16 **A.** This is incorrect. The purpose is to provide a transmission system that is sufficiently
17 reliable, based on deterministic analysis that considers the periods of most heavily
18 stressed conditions – which at times can be peak loads, off peak, or “shoulder hour”
19 periods where other stressed conditions can emerge. The times of highest system
20 stress for the local areas are in fact currently forecast at peak conditions, but the
21 system needs to be reliable year round, during lower load level periods where the
22 idealized assumption that all other transmission and generation are in-service and
23 operating perfectly is not the case.

24

25 **Q.** **Mr. Powers also states that “An example of a Category D event that is directly**
26 **relevant to Track 4 modeling is the double contingency of SDG&E's Sunrise**
27 **Powerlink and Southwest Powerlink, an N-1-1 event. . . . (page 2).” Is this a**
28 **correct statement?**

29

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 13 of 19

1 **A.** No, this is incorrect. The simultaneous (N-2) outage of Sunrise Powerlink and
2 Southwest Powerlink is a Category D event. However, the overlapping (N-1-1)
3 outage of Sunrise Powerlink and Southwest Powerlink is a Category C event.
4

5 **Q.** **At page 10 Ms. Firooz points to a FERC notice of proposed rulemaking**
6 **(NOPR) proposing revisions to TPL-001-4 that would allow load-shedding**
7 **under certain circumstances for an N-1 contingency. Should the Commission**
8 **take this into consideration in Track 4?**
9

10 **A.** No. The proposed revisions to TPL-001-4 would still prohibit load shedding for an
11 N-1 contingency, but only if certain conditions are met such as providing extensive
12 documentation through a public consultation process, and in no circumstances can
13 the amount of load shedding exceed 75 MW. The purpose of these particular
14 changes in TPL-001-4 is to specify clear limitations on a similar provision that
15 currently exists in existing TPL 001. This NOPR is meant to provide clarity for
16 mandatory enforcement purposes—not to relax the standards and has nothing to do
17 with suggesting, as does Ms. Firooz and other parties, that hundreds of megawatts
18 and thousands of network-connected customers should be dropped for the N-1-1
19 contingency.
20

21 **Q.** **Ms. Firooz also argues, at page 10, that controlled load drop is a more reliable**
22 **means by which to respond to stressed system conditions than bringing up**
23 **additional generation, given the complexities of communications and**
24 **coordination with these resources. What is your response to this testimony?**
25

26 **A.** The ISO agrees with Ms. Firooz’s statement regarding the complexities of the
27 design and operation of the power system. However, Ms. Firooz ignores the
28 complexity of dropping load. The transmission grid is complex and many things
29 can go wrong that impact reliability. Ms. Firooz does not appear to have taken these

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 14 of 19

1 complexities into account in her probabilistic analysis which was limited to
2 considering only one contingency condition. In addition to not considering any of
3 the myriad of other contingency and system conditions, (additional generation
4 outages, fires north or south of SONGS, generation and line maintenance outages,
5 etc) Ms. Firooz's analysis did not consider the potential risk associated with an
6 armed load-shedding SPS inadvertently and unnecessarily shedding load when the
7 system is not under stressed conditions. Given the complexities of communications
8 and sensing equipment associated with the load shedding scheme, this is a potential
9 risk, and the magnitude of the risk is proportional to the amount of time that the
10 scheme needs to be armed.

11
12 **Other Transmission Planning and Study Methodology Issues**

13
14 **Q. In addition to the N-1-1 contingency, load shedding and the WECC-required**
15 **voltage support margin, parties have taken issue with other aspects of the**
16 **ISO's LCR study methodology and transmission planning requirements. Are**
17 **these topics that should be considered in Track 4?**

18
19 **A.** No. As I stated previously, the ISO believes that the study methodology- which is
20 the same LCR methodology used for many years in the Commission's resource
21 adequacy proceeding- was adopted in Track 1 and was not an issue to be re-litigated
22 in Track 4. Constantly re-evaluating this decision is not an efficient use of time and
23 resources for the Commission and the parties. However, because there have been
24 other planning and study issues raised in intervener testimony, I will respond to
25 some of these points.

26
27 **Q. At page 7 of his testimony, Mr. Powers states that the ISO's assumptions**
28 **regarding the operational capabilities of combined cycle plants, for the**
29 **purposes of applying the G-1/N-1 contingency standard, is "fatally flawed."**
30 **What is your response?**

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
R.12-03-014**

Page 15 of 19

1

2 **A.** I disagree. The ISO applies a performance-based standard in this case. As stated in
3 the ISO Planning Standards (attached), a single module of a combined cycle power
4 plant is considered a single contingency (G-1) and shall meet the performance
5 requirements of the NERC TPL standards for single contingencies (TPL002).
6 Furthermore a single transmission circuit outage with one combined cycle module
7 already out of service and the system adjusted shall meet the performance
8 requirements of the NERC TPL standards for single contingencies (TPL002). A re-
9 categorization of any combined cycle facility that falls under this standard to a less
10 stringent requirement is allowed if the operating performance of the combined cycle
11 facility demonstrates a re-categorization is warranted. The ISO will assess re-
12 categorization on a case by case based on the following:

- 13 a) Due to high historical outage rates in the first few years of operation no
14 exceptions will be given for the first two years of operation of a new
15 combined cycle module.
- 16 b) After two years, an exception can be given upon request if historical data
17 proves that no outage of the combined cycle module was encountered since
18 start-up.
- 19 c) After three years, an exception can be given upon request if historical data
20 proves that outage frequency is less than once in three years.

21

22 Consistent with this planning standard, the ISO assessed the historical outage rates
23 of Otay Mesa (the limiting contingency in the G-1, N-1 scenario) over the period
24 between 2009 to 2012 and determined that the plant had full plant outage
25 frequencies well beyond once in three years. Otay Mesa has had 14 full plant
26 outages over the three year period. (The ISO will be reviewing the most recent
27 outage history of Palomar, as its performance has been improving in this regard.)

28

29 In his testimony, Mr. Powers takes issue with the ISO's use of the entire output of
30 the Otay Mesa combined cycle generation facilities for the purpose of establishing

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 16 of 19

1 the largest generation unit offline (the G-1). Mr. Powers asserts that the gas turbines
2 have the ability to ride through the loss of the steam turbine, and that the ISO should
3 therefore consider that the plant should be modeled differently. However, based on
4 historical performance over the last three years that I described above, there is no
5 indication that the plant is capable of this performance or, if the plant does have this
6 capability, what new conditions would lead to the gas turbines riding through the
7 loss of the steam turbines now when they have not in the past. Mr. Powers claims
8 there were no economic reasons for the plant to ride through the loss of its steam
9 turbines, but also provides no basis for this claim. Of course, the ISO will
10 reconsider the treatment of this plant if the performance-based standard for
11 demonstrating reliable capability is met in the future.

12

13 **Q. Ms. Firooz, at page 6 of her testimony, states that the amounts of existing**
14 **generation used in the ISO’s 2012/2013 transmission plan are “conservative”**
15 **and based on NQCs established by the ISO, rather than nameplate capacity. Is**
16 **this correct?**

17

18 **A.** Ms. Firooz is correct in that the ISO does use the NQCs of generating units in its
19 transmission planning studies. However, NQC calculations based on the production
20 from non-dispatchable generation is not set by the ISO, but rather the Commission,
21 according to well-established resource adequacy procedures. Furthermore, contrary
22 to Ms. Firooz’s statement, the NQC for gas fired generation, other than non-
23 dispatchable small QFs, is not affected by forced outages.

24

25 **Q. At page 11, Ms. Firooz testifies that she conducted a power flow analysis by**
26 **modifying the ISO’s base case and then testing it by taking the worst case**
27 **scenario for the LA Basin (the outage of the 230 kV Serrano-Lewis #1 line**
28 **followed by the outage of the Serrano-Village Park #2 line- an N-1-1**
29 **contingency). According to Ms. Firooz, this analysis did not result in any**

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 17 of 19

1 **reliability violations. Should the Commission use this analysis in making**
2 **procurement decisions in Track 4?**

3

4 **A.** No. This is not the worst contingency driving resource needs in the LA Basin with
5 SONGS retired. Furthermore, even ignoring the N-1-1 contingency, it does not
6 appear that Ms. Firooz conducted a contingency analysis to determine the next
7 worst contingency. Therefore her study is incomplete and should not be relied upon
8 to make procurement decisions.

9

10 **Track 4 Modeling**

11

12 **Q.** **At page 14 of her testimony, Ms. May states that while the ISO claims to have**
13 **followed the May 21, 2013 Revised Scoping Ruling required modeling**
14 **assumptions, “these assumptions are frequently not actually used to meet**
15 **needs.” She then goes on to address several different modeling assumptions. Is**
16 **Ms. May correct on these points?**

17

18 **A.** No. I have reviewed the ISO’s studies and will address each of her points below.

19

20 **Q.** **Did the ISO accurately account for the 997 MW of demand response resources**
21 **that the ISO was instructed to use to reduce the need in the case of an N-1-1**
22 **contingency?**

23

24 **A.** Yes. Ms. May misunderstands the instructions in the Revised Scoping Ruling. As I
25 explained in my opening testimony at pages 6-7, the Scoping Ruling identified 173
26 MW of demand response for the LA Basin and 16 MW of demand response for San
27 Diego that was to be used following the first contingency (i.e. post first
28 contingency) to address the first contingency as the system is readjusted in
29 preparation for the next overlapping contingency. The demand response utilized for
30 the post first contingency is a fast response type program located in more effective

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION
R.12-03-014**

Page 18 of 19

1 areas in southern Orange County and San Diego load areas. The additional 997
2 MW were then to be relied upon following the second contingency (i.e. post second
3 contingency) to address the post second contingency conditions. The post-second
4 contingency demand response is not fast enough to be effective at preparing for the
5 second contingency, but it could be effective at mitigating subsequent contingencies
6 which could happen after a period of time following the second contingency. Once
7 the second contingency has occurred, the next contingency would be considered an
8 extreme event, and although the ISO would need to be prepared for this event, from
9 a planning perspective, it is classified as a Category D event. This language in my
10 opening testimony apparently caused Ms. May some confusion.

11

12 **Q. At page 15, Ms. May criticizes the ISO’s modeling assumptions for customer-**
13 **side distributed generation, stating that the 796 MW reflected after the second**
14 **contingency is incorrect and that these resources were only used “to a certain**
15 **extent,” referring to your opening testimony. What is your response to this**
16 **testimony?**

17

18 **A.** Again, Ms. May misunderstands the instructions in the Revised Scoping Ruling. As
19 I explained in my opening testimony (pages 7-8),the customer connected small PV
20 was relied upon following the second contingency (post second contingency). One
21 clarification is that the 796 MW of customer connected PV was the amount
22 determined by the ISO that would potentially avoid activating the safety net after
23 some extreme contingency events, based on technical power system modeling
24 analysis.

25

26 **Q. Citing to an ISO data request response, Ms. May has concluded that the ISO**
27 **did not account for the 50 MW of energy storage the Commission directed SCE**
28 **to procure. Is she correct?**

29

**TRACK 4 REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

R.12-03-014

Page 19 of 19

1 **A.** No, the ISO did account for the 50 MW energy storage procurement required in
2 Track 1. Apparently Ms. May did not understand the data request response. The
3 data request sought specific information about the energy storage facilities modeled
4 in the study, including nameplate capacity. Because the 50 MW has not yet been
5 procured, the ISO did not have such information for this assumption. Thus, in
6 response to the question, the ISO described only the 40 MW of pumped storage at
7 Lake Hodges and explained that there was no specific information provided about
8 the 50 MW. However, the ISO’s understanding is that the 50 MW of storage is
9 included in the 1800 MW of Maximum Track 1 authorization amount, so therefore
10 it is accounted for in the residual resource need calculation in Table 13 of my Track
11 4 testimony.

12

13 **Q.** **Ms. May argues that the ISO should have included the 188 MW of capacity**
14 **provided by the Cabrillo peakers as existing generation in the San Diego area,**
15 **citing testimony provided by Mr. Powers in A.11-05-023 (May testimony, pages**
16 **19-21). Is this recommendation consistent with the Revised Scoping Ruling?**

17

18 **A.** No, the ISO modeled the generation described in the Revised Scoping Ruling,
19 which assumed the retirement of 238 MW of non OTC generation, based on facility
20 age, in the San Diego area which the ISO understands to include the Cabrillo
21 peakers.

22

23 **Q.** **Does this conclude your testimony?**

24

25 **A.** Yes, it does.

ATTACHMENT 1

A.13-06-015

*Application of San Diego Gas & Electric Company (U 902 E) to Fill Local Capacity
Requirement Need Identified in D.13-03-029*

Rebuttal Testimony of Robert Sparks on Behalf of the
California Independent System Operator Corporation
October 4, 2013

Application No.: A.13-06-015

Exhibit No.: _____

Witness: Robert Sparks

Application of San Diego Gas & Electric
Company (U 902 E) to Fill Local Capacity
Requirement Need Identified in D.13-03-029

Application 13-06-015
(Filed June 21, 2013)

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 2 of 14

1 systems needs in light of the environmental requirements placed on once-through-
2 cooling generating facilities by the State Water Resources Board and the absence of
3 the San Onofre Nuclear Generating Station (SONGS).

4

5 **Q. Have you provided testimony about local capacity needs in the San Diego area**
6 **previously in other proceedings?**

7

8 **A.** Yes. I submitted opening, supplemental and rebuttal testimony addressing the
9 ISO's assessment of local area needs in San Diego in Docket A.11-05-023 which
10 was based on the ISO's once through cooling studies developed during the
11 2011/2012 transmission planning process.

12

13 **Q. What is the purpose of your rebuttal testimony?**

14

15 **A.** The purpose of my testimony is to respond to some of the topics raised by the
16 testimony of William Powers on behalf of Sierra Club, CA; California
17 Environmental Justice Alliance (CEJA); Protect Our Communities (POC) and the
18 testimony of David Peffer on behalf of POC.

19

20 **Q. What are the issues that you intend to address in this testimony?**

21

22 **A.** Both Mr. Powers and Mr. Peffer have made factually inaccurate statements about
23 the ISO's LCR study methodology that underlies the 298 MW local capacity
24 resource need established by the Commission in D.13-03-029. While I do not
25 believe that the ISO's study methodology is an issue to be considered in this
26 proceeding because it was extensively litigated and approved in D.13-03-029, the
27 ISO is concerned that without a response, such incorrect information may be taken
28 out of context and relied upon in other venues or proceedings. I will also address
29 Mr. Power's testimony about intervening circumstances that he recommends should

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 3 of 14

1 be taken into consideration by the Commission in deciding whether to approve the
2 Pio Pico PPTA.

3

4 **Probabilistic versus Deterministic Transmission Planning Requirements**

5

6 **Q. Mr. Powers and Mr. Peffer have characterized the ISO’s contingency planning**
7 **methodology as relying on a “highly improbable” and overly conservative**
8 **reliability contingency in developing the local area needs in A.11-05-023. Was**
9 **this topic addressed in A.11-05-023?**

10

11 **A.** Yes. I provided rebuttal testimony explaining transmission planning requirements,
12 responding to the witness sponsored by CEJA. I was extensively cross-examined on
13 my testimony, and the ISO devoted a portion of its opening brief and reply brief to
14 these topics. Contrary to Mr. Peffer’s assertions at pages 12-14 of his testimony, I
15 believe that the Commission had a very complete record upon which to rule on these
16 issues in D.13-02-015. I am attaching these materials as exhibits to my testimony,
17 and will include them in the record in this proceeding.

18

19 **Q. Does the ISO’s local capacity requirements (LCR) study methodology consider**
20 **the probability that a reliability contingency will occur?**

21

22 **A.** Not in the sense used by Mr. Powers at page 4 of his testimony. The contingencies
23 and required system performance levels that are applied are based on the NERC
24 transmission planning reliability criteria, as augmented by WECC regional
25 standards and California-specific standards. These mandatory standards are
26 deterministic, not probabilistic. Assumptions are made regarding load levels and
27 system conditions prior to a disturbance and then specific disturbances are simulated
28 to test modeled performance against performance requirement scales. In general, a
29 broader range of system impacts are permissible for more extreme, and less likely,
30 types of contingencies.

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 4 of 14

1

2 The deterministic test is exactly that – a test. It is a test that is developed through
3 broad industry and stakeholder participation to arrive at an appropriate balance
4 between reliability and cost. It is not an assessment of every possible operating
5 condition and the anticipated system response to each possible operating condition.

6

7 This is an important distinction, because the probabilistic methodologies that are
8 more common in system-wide resource adequacy analysis focus primarily on all
9 possible combinations of generation outages, but for the most part assume an
10 unconstrained and highly reliable transmission system. The two types of analyses
11 have fundamental differences and applying probabilistic arguments to one possible
12 transmission outage system condition without considering all other possible outage
13 conditions is a fundamentally flawed application of the probabilistic study
14 technique.

15

16 **Q. What is the difference between a deterministic study and a probabilistic**
17 **analysis?**

18

19 **A.** A deterministic transmission planning study, used by the ISO for the OTC/LCR
20 studies and its transmission planning studies, makes a number of idealized
21 assumptions, and then tests the system performance following simulated
22 contingencies, whether in the steady-state power flow analysis or dynamic stability
23 analysis. The required performance for each level of contingency is established
24 through years of industry-wide experience and stakeholder input, resulting in a
25 testing methodology that has been adopted by NERC and FERC and provides
26 consistent and acceptable system performance across the United States, Canada, and
27 the interconnected portions of Mexico. Those performance levels differ for different
28 broad categories of contingencies, recognizing the significantly different likelihood
29 of occurrence for each of those categories of contingencies.

30

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 5 of 14

1 Probabilistic analysis, in contrast, sums the probabilities of a number of events, each
2 with its own probability of occurring, occurring at a particular time or in
3 combination and assesses the anticipated impacts of all of the potential events.
4 System-wide resource adequacy analysis lends itself to this type of approach.
5 Individual generators each have their unique performance characteristics, including
6 the probability of forced outages, and the combined effect of the individual
7 performance characteristics can be considered on a probabilistic basis.

8

9 Studying a transmission system on a probabilistic basis has not replaced
10 deterministic assessments for a number of reasons. These include the complexity of
11 needing to consider the individual performance of a significantly larger number of
12 transmission and generation components, considering the interaction on the
13 transmission system between those components, and also the wide range of
14 operating conditions that could exist at any point in time. Also, and to some extent
15 because of these complexities, there is no meaningful industry standard to compare
16 forecast performance against, unlike the deterministic criteria adopted by NERC and
17 WECC. Probabilistic techniques are emerging that can be applied to transmission
18 system planning working in conjunction with deterministic analysis. To this point,
19 however, these techniques have been utilized more frequently to assist in the
20 selection of the optional alternative to address a reliability issue, or to consider the
21 merits of transmission reinforcements to address economic or policy-related issues.
22 Haphazardly or selectively applying probabilities of a particular event occurring in
23 the midst of a deterministic analysis is not a probabilistic analysis –indeed it is
24 neither. Arbitrary adjustments to exclude certain contingencies from analysis, as
25 suggested in the referenced testimony, simply weaken and undermine the test being
26 applied in the deterministic analysis.

27

28 Applying probabilities selectively, which would weaken the deterministic test,
29 would be analogous to a medical student seeking to have his or her grades
30 improved, by pointing out that the likelihood of being confronted with a particular

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 6 of 14

1 disease or condition that was the subject of a test question is quite low, and therefore
2 should be removed from the grading. It defeats the entire purpose of testing the
3 integrity of the transmission system through a deterministic analysis, and fails to
4 provide the comprehensive view of risk under a wide range of operating conditions
5 that probabilistic analysis would provide.

6

7 **Q. Was this information provided to the Commission in A.11-05-023?**

8

9 **A.** Yes, I discussed deterministic versus probabilistic methodologies in my rebuttal
10 testimony at pages 10-11, as well as the ISO's opening brief at pages 13-16, both of
11 which are attached as exhibits to my testimony here.

12

13 **Q. Has the Commission approved the ISO's LCR study methodology in other
14 proceedings in addition to A.11-05-023?**

15

16 **A.** Yes. The Commission made determinations in D.06-06-064 regarding the criteria
17 and test contingencies, as the ISO discussed in its reply brief in A.11-05-023, pages
18 9-12 (attached). Furthermore, the Commission approves the ISO's annual LCR
19 study each year for purposes of resource adequacy. The Commission also
20 considered these issues in Track 1 of the current LTPP proceeding, R.12-03-014,
21 and once again supported the ISO's study methodology in D.13-02-015.

22

23 **N-1-1 Planning Criteria and Load Shedding**

24

25 **Q. Mr. Powers and Mr. Peffer have questioned the reasonableness of the ISO's
26 transmission planning practices with regard to load shedding as a mitigation
27 solution for the N-1-1 contingency in the San Diego local area. Was this issue
28 also addressed in A.11-05-023?**

29

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 7 of 14

1 **A.** Yes, the witnesses presented by CEJA and DRA made the same arguments that have
2 been raised by Mr. Powers and Mr. Peffer. I addressed the topic of the N-1-1
3 reliability planning criteria in my rebuttal testimony in A.11-05-023 (pages 8-10,
4 attached), and the ISO briefed the issue in its opening brief (pages 16-18, attached).
5 The ISO provided the Commission with ample information about how engineers at
6 the ISO develop mitigation solutions for the N-1-1 contingency and the
7 circumstances under which load shedding is not a prudent planning option. The
8 ISO's position is that load shedding in the densely populated San Diego area should
9 not be used as a transmission planning tool for the N-1-1 NERC Category C
10 contingency of the 500 kV lines between the Imperial Valley, Miguel and Suncrest
11 substations. This is due to the significant amount of load that would be subject to
12 load shedding, the sensitivity of urban loads to large blocks of shedding, the
13 complexity of operating arrangements in the area, and the proximity of the
14 particular transmission lines.

15
16 **Q.** **Has either witness provided new factual information about the ISO's planning**
17 **criteria that would cause the Commission to reconsider D.13-03-029?**

18
19 **A.** No. In fact, Mr. Peffer in particular appears to be quite confused about NERC,
20 WECC, and ISO planning standards and how LCR studies are conducted. His
21 testimony should not cause the Commission to re-evaluate its previous decision
22 establishing a need for 298 MW of local resources. Similarly, Mr. Powers'
23 testimony simply repeats the argument raised by the witnesses in A.11-05-023 that
24 the ISO should have used load shedding- in the highly urbanized San Diego area- as
25 a mitigation solution in lieu of generation or other local resources (see Powers
26 testimony, page 4).

27
28 **Q.** **Mr. Peffer states that the ISO "switched" from a G-1/N-1 planning criteria to**
29 **the more severe N-1-1 and that this "fundamental switch" was "revealed" for**
30 **the first time in your Supplemental Testimony in A.11-05-023. Did the ISO**

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 8 of 14

1 **change from a G-1/N-1 standard to an N-1-1 standard for the San Diego area,**
2 **as described by Mr. Peffer at pages 8 and 9 of his testimony?**

3

4 **A.** No. Both the G-1/N-1 and the N-1-1 are part of the LCR criteria, and the most
5 limiting test sets the requirements – in this case, the N-1-1 contingency. Mr. Peffer
6 seems to conclude that when the ISO ceased to consider the even more demanding
7 G-1/N-2 as the worst outage which then shifted the N-1-1 to being the worst outage,
8 as described above, that the ISO had changed its standards and began applying a
9 higher more demanding requirement . However, eliminating the test of the more
10 onerous contingency was in response to a change in WECC criteria and not a
11 change to ISO planning standards. Furthermore, the ISO’s consideration of the N-1-
12 1 as the most limiting contingency resulted in a less demanding test being the
13 limiting condition.

14

15 **Q. Can you briefly summarize the information provided in your Supplemental**
16 **Testimony?**

17

18 **A.** After performing a comprehensive contingency analysis of all contingencies
19 required to be assessed in an LCR study, the ISO found that the G-1/N-2
20 contingency was demonstrated through the study results to be the worst
21 contingency. As described in my supplemental testimony, prior to the change in the
22 WECC criterion, the most limiting contingency for the determination of LCR needs
23 in the San Diego area was the simultaneous outage of the 500 kV Sunrise Powerlink
24 and the Imperial Valley-ECO 500 kV line overlapping with an outage of the Otay
25 Mesa combined-cycle power plant (G-1/N-2). The limiting constraint for this
26 contingency is the South of SONGS Separation Scheme. With the change to the
27 WECC criterion, the most limiting contingency for San Diego sub-area becomes
28 instead the loss of Imperial Valley-Suncrest 500 kV line followed by the loss of
29 ECO-Miguel 500 kV line (N-1-1).

30

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 9 of 14

1 **Q. Why do you believe that load shedding is not appropriate under the**
2 **circumstances of the loss of Sunrise followed by the loss of SWPL?**

3
4 **A.** As I discussed in my rebuttal testimony, the history of transmission line outages due
5 to fires and equipment failures in the area and the configuration of the system
6 indicate that outage risks and consequences are high. The Imperial Valley
7 substation is a major source of imported power for three different utilities: SDG&E,
8 IID, and CFE. This is not only evidence of the criticality of this substation, but also
9 the level of exposure to operational coordination issues and failures. Relying on
10 load shedding as a primary mitigation measure is an indication that the system is
11 being planned and operated at a very high stress level, and with very little margin
12 for error. Based on this information, it is not prudent to plan and operate the
13 Imperial Valley system with currently expected high outage risks and consequences
14 at a very high stress level and with very little margin for error. In other words,
15 relying on load shedding as part of the long-term plan leaves no allowance for
16 unexpected circumstances such as generation retirements or higher load growth,
17 other than additional load shedding which could lead to overly excessive amounts of
18 load shedding. The ISO does not believe that load shedding should be used as a
19 transmission planning tool for this particular contingency and for this densely
20 populated area where - contrary to Mr. Peffer's testimony - widespread and possibly
21 sustained outages could jeopardize public safety and have widespread economic
22 consequences.

23
24 **Q. Isn't load shedding permitted by NERC reliability standard TPL 003 in**
25 **response to a Category C N-1-1 event?**

26
27 **A.** Yes, and the ISO has special protection schemes (SPS) in place that employ some
28 form of load shedding in small amounts on the sub-transmission system or for
29 extreme category D contingencies. However, although NERC TPL 003 *permits*
30 load shedding as a mitigation for an N-1-1 contingency, the standard does not

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 10 of 14

1 *require* the ISO, as the Planning Coordinator, to approve an automatic load
2 shedding SPS under all such circumstances and instead requires the Planning
3 Coordinator to consider system design and expected system impacts in deciding
4 whether an automatic load shedding SPS is appropriate.

5

6 **Q. Is the ISO's position with respect to load shedding in highly urbanized areas**
7 **under the N-1-1 contingency unique to SDG&E?**

8

9 **A.** No. Similar to the San Diego area, the ISO does not use load shedding as a long
10 term mitigation solution for the N-1-1 contingency in areas of dense population
11 throughout the SCE and PG&E service territories as well. Changing this position
12 for SDG&E would lead the ISO to make sweeping changes from current and
13 historical practices for the entire ISO controlled grid. Furthermore, the ISO's
14 position with respect to load shedding in highly urbanized areas is consistent with
15 current practices in the rest of the ISOs and, in general, in much of the United States
16 and Canada.

17

18 **Q. Does the N-1-1 limiting contingency reduce the reliability benefits of the**
19 **Sunrise Powerlink line below the 1000 MW reduction in LCR claimed as a**
20 **benefit when the line was approved, as argued by Mr. Peffer at pages 9-11 of**
21 **his testimony?**

22

23 **A.** No. The 1000 MW benefit was based on increasing the existing import capability
24 from 2500 MW to 3500 MW after an outage of either Sunrise or SWPL. At that
25 time, the ISO assumed that the 3500 MW amount would be based on establishing a
26 3500 MW WECC path rating to replace the 2500 MW WECC Path 44 rating. Since
27 that time the 1000 MW Sunrise WECC path rating has been eliminated as well as
28 any notion of pursuing a 3500 MW WECC N-1 Path Rating. Although these path
29 ratings would have helped ensure that changes within neighboring systems could
30 not impact the capability of the ISO system, and provided reasonable margin for this

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 11 of 14

1 urban load area which has only two reliable connections (SONGS and Imperial
2 Valley) to the rest of the ISO and WECC, they also would limit the capability of the
3 system. With Sunrise in-service the Imperial connection became more reliable, and
4 the path ratings are not being pursued any further. Without the path rating
5 limitations the N-1-1 is the most limiting contingency, and with only the N-1-1
6 considered, Sunrise provides more than 1000 MW of benefit. This information was
7 shared by the ISO during the workshop for the San Diego procurement proceeding.
8

9 **Q. Mr. Peffer accuses the ISO of a “lack of transparency” about its planning
10 standards (testimony, page 12), noting specifically that the ISO objected to
11 POC data requests on this subject. Do you agree that there is a lack of
12 transparency regarding the ISO’s reliability criteria?**

13
14 **A.** No. As I have discussed above, and throughout the record in A.11-05-023, the N-1-
15 1 limiting contingency for the San Diego area is firmly grounded in the LCR
16 planning methodology and the NERC/WECC planning standards. It has been used
17 for many years in the Commission’s resource adequacy proceedings and is clearly
18 described in numerous documents on the ISO’s website. The N-1-1 issue was
19 litigated in A.11-05-023 and resolved in D.13-03-029. For all of these reasons, the
20 ISO objected to POC’s data requests.
21

22 **San Diego Local Capacity Area and Local Generation**

23
24 **Q. Mr. Peffer states that the ISO “wrongfully excluded” generation assets from
25 the San Diego local area, thus overstating the LCR need (testimony, pages 5-7).
26 Can you respond to this testimony?**

27
28 **A.** Once again, Mr. Peffer misunderstands the ISO’s LCR study methodology, and also
29 has confused planning criteria with operational requirements. As I discussed in
30 my supplemental testimony in A.11-05-023, the ISO studies identified two local

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 12 of 14

1 capacity subareas in the SDG&E service territory: the San Diego LCR subarea and
2 the IV-San Diego LCR area. From a transmission planning standpoint, the N-1-1
3 criteria discussed above is the most limiting contingency for the San Diego LCR
4 subarea. The most limiting contingency in the Greater Imperial Valley-San Diego
5 (IV-San Diego) area is described by the outage of 500 kV SWPL between Imperial
6 Valley and N. Gila substations overlapping with an outage of the Otay Mesa
7 combined-cycle power plant (603 MW). Generation at the Imperial Valley
8 substation, such as La Rosita II and Sempra TDM is not effective at meeting the
9 needs of the San Diego LCR subarea since that generation cannot flow into the area
10 during the worst contingency. However, the generation at the Imperial Valley
11 substation is effective at meeting the IV-San Diego LCR needs. Pio Pico is needed
12 to meet the San Diego LCR subarea needs, and since the generation at Imperial
13 Valley substation such as La Rosita II and Sempra TDM combined cycle projects
14 (with generator ties to the Imperial Valley Substation) cannot meet the needs of this
15 subarea, they are not substitutes for Pio Pico. Although from an operating
16 standpoint, in order to protect against certain under frequency islanding situations,
17 these generating units would be dispatched to meet the 25% internal generation
18 requirement, as discussed in the FERC order Mr. Peffer describes in his testimony,
19 this has nothing to do with the ISO's LCR study methodology, which does not
20 consider islanding situations, and resource needs in the San Diego subarea identified
21 in A.11-05-023.

22
23 **Intervening Events Following D.13-03-029**

24
25 **Q. At pages 4-10 of his testimony, Mr. Powers suggests that the Commission**
26 **should reconsider the local capacity need established in D.13-03-029 to take**
27 **into account various changed circumstances since the decision was issued. Do**
28 **you agree that the Commission should follow this course?**

29

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 13 of 14

1 **A.** No, I do not. Mr. Powers has requested that Commission reconsider many of the
2 study assumptions that were approved in D.13-03-029, thus necessitating that the
3 studies be performed again so that new local resource needs can be identified.
4 Using this approach will lead to never-ending studies with no conclusions because
5 there will always be changed circumstances after a study is completed and decisions
6 are rendered.

7

8 **Q.** **Isn't the ISO evaluating local capacity needs in the San Diego and LA Basin**
9 **areas in light of the SONGS retirement in Track 4 of the current LTPP, R.12-**
10 **03-014?**

11

12 **A.** Yes. The ISO's LCR studies underlying the resource needs identified in D. 13-03-
13 029 did not take the SONGS retirement into account. The ISO's Track 4 studies
14 have identified substantial needs in the LA Basin and San Diego that are in addition
15 to the 298 MW approved for San Diego and the 1400-1800 MW approved for the
16 LA Basin in Track 1. The ISO suggests that if preferred resources, energy storage
17 and DG are developing at a rapid pace, as Mr. Powers suggests, the Commission
18 can consider whether these resources can fill the residual needs identified by the
19 ISO in Track 4.

20

21 **ISO Recommendation**

22

23 **Q.** **What is the ISO's recommendation regarding the SDG&E request for**
24 **approval of the Pio Pico PPTA?**

25

26 **A.** Based on the ISO's local capacity studies, the Commission in D.13-03-029
27 determined there to be a 298 MW local need in the San Diego area, starting in early
28 2018. It is my understanding that the decision gave SDG&E the option of either re-
29 submitting the Pio Pico and/or Quail Brush PPTA(s) with modifications to the
30 commercial in-service dates to coincide with the retirement of the once-through-

**REBUTTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.13-06-015

Page 14 of 14

1 cooling generation, or issuing a new request for offers. Given the lead time needed
2 for new generation permitting and construction, it would seem that conducting a
3 new request for offers could adversely impact the commercial operation date of new
4 resources responding to the request, ultimately impacting local reliability if the
5 resource is not available after January 1, 2018.

6

7 **Q. Would other resources, particularly preferred resources, also be able to fill the**
8 **298 MW need determined in D. 13-03-029?**

9

10 **A.** Yes, if such resources provide the characteristics needed by the ISO to respond to
11 local contingencies. However, as SDG&E witness Eekhout noted, the Commission
12 took into account certain assumed levels of demand response and uncommitted
13 energy efficiency that would be available to meet local resource needs, and reduced
14 the ISO's study results to reflect these additional assumptions. The ISO agrees with
15 SDG&E that it would not be prudent to assume that even greater levels of these
16 preferred resources could supplant the need for a conventional gas-fired resource
17 such as Pio Pico.

18

19 **Q. Does this conclude your testimony?**

20

21 **A.** Yes, it does.

ATTACHMENT 1

R. Sparks Rebuttal Testimony
Pages 10-11

ISO Opening Brief
Pages 13-16

**REBUTTAL TESTIMONY OF THE CALIFORNIA
INDEPENDENT SYSTEM OPERATOR CORPORATION
A.11-05-023**

Page 10 of 19

1 not allowing load drop in the San Diego area is not reasonable,” (Firooz testimony, pages
2 8- 9). Specifically, CEJA posed the following question:

3
4 Does NERC, WECC, and/or CAISO reliability criteria prevent the use of
5 controlled load drop for an N-1-1 transmission contingency? If so, where is this
6 criteria documented? If not, what threshold does the CAISO use to determine
7 when controlled load drop is acceptable mitigation and when it is not? Are there
8 any limits on the amount of controlled load drop which is acceptable?
9

10 The CAISO responded:

11 The ISO is required by NERC TPL 003 to plan its network so that it can be
12 operated to supply projected customer demands for N-1-1 events regardless of
13 their probability. *NERC Transmission Planning Standards allow the use of*
14 *controlled load drop depending on system design and expected system impacts...*
15

16 The rest of the ISO’s response provided more explanation as to why, under the specific
17 system configuration and consistent with NERC TPL 003, the ISO would operate all
18 available generation to avoid the need to shed load to mitigate the category C
19 Sunrise/ECO-Miguel overlapping outage, for the reasons I discussed above. In other
20 words, although NERC TPL 003 *permits* load shedding as a mitigation for an N-1-1
21 contingency, the standard does not *require* the ISO, as the Planning Coordinator, to
22 approve an automatic load shedding SPS under all such circumstances and instead allows
23 for the Planning Coordinator to consider system design and expected system impacts in
24 deciding whether an automatic load shedding SPS is appropriate. Ms. Firooz seems to
25 misunderstand both the planning standard and the ISO response to the CEJA data request,
26 and has provided no basis for her conclusion that the ISO’s planning decision to avoid a
27 load shedding SPS for the Sunrise/ECO-Miguel N-1-1 is “unreasonable.”
28

29 **Q. Do you agree with Ms. Firooz’s suggestion at pages 7- 8 of her testimony that**
30 **considering the probability that a contingency will occur- which allegedly would**
31 **result in lower costs for consumers- would not lower grid reliability?**
32

**REBUTTAL TESTIMONY OF THE CALIFORNIA
INDEPENDENT SYSTEM OPERATOR CORPORATION
A.11-05-023**

Page 11 of 19

1 **A.** Absolutely not. In the first place, the ISO is required to comply with NERC planning
2 requirements, which are deterministic and not probabilistic. More importantly, Ms.
3 Firooz has not conducted a complete probabilistic analysis so she has no basis for her
4 conclusion that local area needs would be lower and that costs to consumers would
5 therefore be lower. It is possible that a probabilistic analysis could result in higher local
6 needs.

7
8 To briefly summarize the issue, deterministic criteria apply specific tests to the system –
9 with specific assumptions regarding load level and the “worst” contingency as set out in
10 the various disturbance classifications in the NERC standards. A probabilistic approach
11 examines the probability of a wide range of outages under a wide range of conditions,
12 and compares the results to a predetermined criteria related to the acceptable level of risk
13 one is willing to take on a probabilistic basis.

14
15 Simply applying probabilities to the “worst case” scenario ignores all of the other
16 potential events that could result in loss of reliable service, under a wide range of
17 scenarios, providing no effective means to assess the robustness of the transmission
18 system on a probabilistic basis or deterministic basis.

19
20 **Q.** **DRA witness Fagan also takes issue with the ISO’s position on load shedding, at**
21 **pages 19-25 of his testimony. He notes that SDG&E has agreed to the use of**
22 **controlled load drop under N-1-1 contingencies and intends to install a “safety net”**
23 **that will shed load in the event of the sequential loss of two 500 kV lines. Do you**
24 **agree that this “safety net” should be considered as a mitigation for the Category C**
25 **contingency you described previously?**

26
27 **A.** No. A safety net is only acceptable for a Category D outage. The safety net would need
28 to be upgraded to a WECC approved SPS before it could be used for the N-1-1.
29 However, as I explained above, the current transmission system design in the Imperial

ISO Opening Brief

ISO used for an import capability and the 3500 MW San Diego area import level used by SDG&E is 414MW and should be added back into the LCR deficiency calculation, DRA witness Ghazzagh's determination of the local area resource requirement for 2020 under the high load scenario- 2713MW- is actually higher than the ISO's calculation for 2021 in the ISO base case. Thus, while the ISO cautions the Commission against using the "apples to oranges" approach to establish the import capability for purposes of LCR needs, the final conclusions as to the LCR needs reached by DRA and the ISO are not so far apart.³⁰

CEJA witness Ms. Firooz also mixed apples and oranges by suggesting that the 3500MW import limit recommended by SDG&E should be increased by 730MW, based on the ISO's analysis. While it is rather difficult to follow and understand her analysis, Ms. Firooz seems to suggest that ISO's post-contingency import flow of 3230MW in 2021 should be increased by 1000MW to reflect the additional import capability provided by Sunrise (which would produce an import capability of 4230MW, or 730 MW higher than the 3500 MW used by SDG&E and DRA).³¹ Her apparent assumption is incorrect. Ms. Firooz seems to have overlooked the fact that the ISO's post-contingency import flow is based on the N-1-1 contingency with Sunrise out of service, so that there were no Sunrise flows in the ISO's analysis that produced the 3230 MW flow limit. As noted above, the 3500 MW import capability was based on the G-1/N-1 contingency with only SWPL out of service, and with 604 MW of local generation out of service. Thus, Ms. Firooz's recommendation of a higher import limit lacks justification and is not consistent with any study methodology.

³⁰ Mr. Fagan's overall spreadsheet conclusions as to the LCR deficiencies for San Diego are dramatically different than the ISO's because of other assumptions that he adds to the spreadsheet analysis such as assumptions about uncommitted EE, incremental DR and others.

³¹ Ex. 20, page 19.

IV. Intervener Concerns with the ISO's Study Methodologies and Assumptions are Misplaced.

In addition to the power flow and import capability issues addressed above, interveners DRA, NRDC and CEJA raised other issues with the ISO's LCR/OTC studies. For the most part, these parties argued that the ISO's assumptions in the base case renewable portfolio- the case upon which the ISO is basing its recommendations- are too conservative and do not reflect reasonable levels of demand response (DR), energy efficiency (EE), distributed generation (DG), combined heat and power (CHP) resources and energy storage. They have also questioned the ISO's use of a 1-in-10 load forecast and urge the Commission to adopt other mitigation solutions in lieu of local generation. CEJA witness Firooz also discussed other aspects of the ISO planning studies.

In essence, each intervener recommended the adoption of revised planning assumptions and non-generation mitigation solutions that, on paper, would substantially reduce the local capacity deficiencies identified by the ISO. As discussed below, these recommendations should be approached with great caution. The risks to grid reliability are too significant -- and the time frame for procuring needed flexible thermal generation is too short -- to allow for any errors in judgment. Furthermore, some of the intervener's proposals, if adopted for the Commission's procurement decisions, would require fundamental and unjustifiable changes in the ISO's LCR study methodology and could introduce substantial, inappropriate variations between transmission planning and resource procurement assumptions.

A. Load Forecasts and Planning Assumptions

1. Probabilistic versus Deterministic Planning Studies

CEJA witness Firooz begins her testimony by questioning the entire LCR methodology- and indeed, all of the ISO's transmission planning studies-with arguments that the deterministic approach to planning is "overly conservative" and produces results that are too expensive for the ratepayers.³² According to Ms. Firooz, starting with the use of the 1-in-10 load forecast, which uses peak loads that are "not expected," and then layering on the NERC/WECC mandated planning requirements (which "probably" won't happen at peak load conditions) and the planning reserve margin requirements adopted by the Commission, dictates unnecessary mitigation solutions that are not needed. Ms. Firooz suggests that the Commission adopt a "probabilistic" approach to resource procurement decisions, concluding that this will not lead to reliability issues but will save the ratepayers money.

Not only are such suggestions beyond the scope of this docket, but Ms. Firooz did not conduct a probabilistic analysis of the transmission grid that would support her conclusions. Her discussion of this topic is based on mere observations regarding the likelihood that the most sever N-1-1 contingency might occur at the 1-in-10 system peak and ignores the cumulative probability of the other potential contingencies and system conditions that could also result in loss of reliable service. Furthermore, as Mr. Sparks noted, it is entirely possible that a full-blown probabilistic analysis could result in higher local needs.³³

In contrast, the NERC/WECC mandatory planning standards are deterministic; meaning that the system is tested with specific assumptions regarding load level and appropriate contingency levels to design the system to a target reliability level. A

³² Ex. 20, pages 5-8.

³³ Ex. 27, page 11.

probabilistic analysis examines the individual probability of each contingency under a particular system condition over a wide range of scenarios. A deterministic criteria is similar to using one standard driving test for all drivers in California and a probabilistic criteria is similar to giving every driver an individualized test based on his or her expected driving plans. In this analogy it is difficult to predict whether the test failure rate would go up or down, or if the driving accident rate would go up or down, if the State switched from a standard driving test to individualized tests. Continuing with the analogy, while there may be some questions on the standard test that do not apply to many driving situations, this would not be a valid argument for lowering the passing score level. This is because the standard test is only a sample of potential questions that could have been asked, and the score is indicative of the knowledge level of the entire driver's handbook. Ms. Firooz's approach- which is to apply probabilities to the "worst case" under a deterministic evaluation- again mixes apples and oranges and is not an effective means by which to test the robustness of the system. Going back to the analogy, her argument is a little like finding one person and saying that since the test does not match his or her expected driving plans, the passing score for the test should be lowered for everyone.

2. Load Shedding as a Mitigation Solution

Both CEJA and DRA suggest that controlled load shedding in the event of an N-1-1 contingency should be viewed as an acceptable mitigation solution that would reduce the local capacity needs in San Diego; CEJA witness Firooz proposed dropping 378 MW and DRA witness Fagan proposed a 370 MW load drop.³⁴ Just to put these recommendations in perspective, this amount of load drop could equate to well over 300,000 homes.³⁵ To adopt the

³⁴ Ex. 17 (Fagan), page 12, table RF-3; Ex. 20 (Firooz), page 3, table 1.

³⁵ See Ex. 20, footnote 3 discussing an April 6, 2010 outage of 310 MW, which was 291,000 homes.

ATTACHMENT 2

ISO Reply Brief
Pages 9-12

in the area because with the large amount of renewable that we're expecting based on the renewable portfolio that we've studied...¹⁵

CEJA's statement that the "CAISO failed to evaluate the impact of four synchronous condensers that SDG&E proposed" appears to display a lack of understanding of the ISO's comprehensive transmission planning process and the testimony provided by the ISO.

D. The ISO's OTC Study is Consistent with the LCR Methodology and the Contingency Analysis Required by NERC/WECC Planning Standards.

CEJA has completely mischaracterized the ISO's local capacity area study methodology in an attempt to show that the ISO has engaged in a "backhanded attempt to increase procurement requirements" beyond those established by the Commission in D.06-06-064, the 2006 decision in which the Commission first addressed the LCR methodology.¹⁶ This line of argument appears to be based on two general misperceptions: (1) that the ISO has "increased" the reserve margin by 2.5%, and (2) that the ISO has "failed to consider" operational solutions that would lower the LCR for San Diego.¹⁷

To begin with, while it is true that the ISO has never conducted a ten year local capacity technical study such as the OTC study, the OTC study is a "long-term LCR" study and it uses the same study methodology employed in the shorter term LCR studies described in Mr. Spark's initial testimony.¹⁸ As discussed in the ISO's opening brief at pages 9-11, the ISO followed the study methodology for an LCR study, as described in

¹⁵ Tr. III, 539:15-540:7

¹⁶ CEJA Opening Brief, page 11.

¹⁷ *Id.* at pages 11-13.

¹⁸ See Ex. 18, Attachment AA, page 213; Ex. 9, pages 2-6.

the 2013 Local Area Technical Study¹⁹ and in the ISO's tariff.²⁰ It goes without saying that the LCR/OTC studies are conducted in accordance with NERC/WECC transmission planning standards.

Contrary to CEJA's assertions, the "2.5% reserve margin" is not related to the operational reserve requirements established by the Commission and was not unilaterally "added in" to the OTC study outside of the criteria used for an LCR/OTC study. Rather, the "2.5%" margin is a WECC transmission planning criteria that is followed as part of the LCR/OTC study methodology. Mr. Sparks explained this concept in response to questions from DRA about the OTC results table on page 3 of his supplemental testimony (Ex. 10).²¹ Specifically, Mr. Sparks stated:

...I also want to mention that [the] 2.5 percent margin...is required by the WECC or reliability criteria on top of the forecasted load. It is meant to be a margin for error because the studies are obviously not perfect.

Q. And that criteria...is what you were just discussing with Ms. Behles a little earlier ...the reserve margin?

A. No, the reserve margin requirements are resource planning needs. The reactive power margin is more of a transmission planning need.

And so there are two different problems. One is solved with reactive power or local resources in this case and is localized, very localized problem on the system. Resource adequacy is a much bigger picture. It is not necessarily a transmission issue. That is why they break them up into two disciplines, if you will.²²

As I mentioned earlier, the ISO is also a planning authority. So we are subject to the transmission planning standards. There are many standards. And so the transmission planning standards do need to be performed out to a 10 year horizon. And the WECC reactive power planning requirements specify this

¹⁹ Ex. 18, Attachment O

²⁰ See ISO tariff § 40.3

²¹ Tr.III, 579:17-585:2.

²² *Id.* at 580:24-581:20.

2.5 percent margin for Category C outages, and a 5 percent margin for Category B outages. And in a load pocket that means increasing the load...²³

CEJA also cites the language of D.06-06-064 wherein the Commission selected the ISO's reliability planning Option 2, and argues that the ISO has not presented the Commission with "options" as part of the OTC study.²⁴ True, the description of the OTC study at Chapter 3 of the 2011/2012 Transmission Plan does not set forth the reliability planning options customarily set forth in the annual LCR study. However, since the issuance of D.06-06-064, the ISO has in fact consistently conducted its LCR studies in accordance with Option 2, as described at page 16 of the 2013 Local Capacity Technical Study²⁵:

Option 2 is a service reliability level that reflects generation capacity that is needed to readjust the system to prepare for the loss of a second transmission element (N-1-1) using generation capacity *after* considering all reasonable and feasible operating solutions (including those involving customer load interruption) developed and approved by the CAISO, in consultation with the PTOs...

Because the OTC study was conducted using the same criteria, the local capacity deficiencies were based on the Option 2 local capacity level. Further, as the ISO discussed extensively throughout the testimony and briefs in this proceeding, the ISO did in fact evaluate all "reasonable and feasible operating solutions," including load interruption, and concluded that additional local generation presented the most feasible mitigation solution. The OTC study is consistent with D.06-06-064 and the LCR studies that have been approved annually by the Commission since the issuance of that decision.

Besides misunderstanding the ISO's LCR study methodology, CEJA also appears to be confused about the NERC/WECC- required contingency analysis, which is the basis

²³ *Id.* at 582:15-583:4.

²⁴ CEJA opening brief, page 12.

²⁵ Ex. 18, Attachment O

of the OTC study. The CEJA opening brief contains an entire section entitled “*CAISO Assumes that Sunrise Powerlink, SWPL, and the CFE Line Provide No Import Capability.*”²⁶ Apparently in support of this statement, CEJA entered into the record as Ex. 41 the pre- and post- import flows for two scenarios provided by the ISO in discovery. These are reproduced on page 15 of CEJA’s opening brief. This table shows that after the most limiting N-1-1 contingency, which is the loss of an element of the Sunrise line followed by the loss of an element of SWPL, the parallel CFE transmission line will be disconnected. CEJA misses the obvious fact that the when these transmission line are lost to due electrical short circuit conditions, they must be removed from service. When this occurs, the parallel CFE transmission line must be protected from overload, which requires that it be removed from service as well. When these lines are removed from service, no power can flow through them. However, prior to this contingency these lines were carrying over 2600 MW of imported power. Until these lines are repaired by SDG&E, there can be no import flows on these major connections into San Diego. That is how a contingency study is conducted-- the ISO must mitigate a situation where substantial import flows into the local area have been cut off by a transmission outage.²⁷ This has nothing to do with the substantial benefits that Sunrise brings to the local area that CEJA describes. Contrary to CEJA’s section heading, the benefits of Sunrise are assumed in the ISO’s study methodology.

III. Credibility of the CEJA Testimony

CEJA witness Firooz made certain statements in the introduction and *curriculum vitae* sections of her written testimony which the ISO believed were unsustainable or

²⁶ CEJA Opening Brief pages 14-16.

²⁷ The ISO provided an explanation about import flows and CEJA’s misunderstanding about the role of Sunrise in an N-1-1 contingency at page 13 of its opening brief.

ATTACHMENT 3

R. Sparks Rebuttal Testimony
Pages 8-10

ISO Opening Brief
Pages 16-18

**REBUTTAL TESTIMONY OF THE CALIFORNIA
INDEPENDENT SYSTEM OPERATOR CORPORATION
A.11-05-023**

Page 8 of 19

1 deliverability problems on the transmission system. The initiative also expedites the DG
2 interconnection study process so that DG will not have to wait for a deliverability study
3 to be completed if they site their DG at a location predetermined to be deliverable and if
4 it is contracted with a load serving entity that has a DG deliverability allocation at that
5 location. However, the ISO's DG initiative does not ensure that the DG will be
6 developed. For planning purposes, the ISO must make reasonable assumptions about
7 future DG development as previously discussed in this testimony.

8
9 **Load Shedding and Special Protection Schemes (SPS)**

10
11 **Q. Please summarize the ISO's position on using SPS involving load shedding to meet**
12 **reliability needs in the San Diego local area, as well as the interveners' testimony on**
13 **this issue.**

14
15 **A.** In my supplemental testimony, I stated that with the change in the WECC criterion,
16 causing the Sunrise/IV-Miguel double outage to be reclassified as a Category D
17 contingency, the most limiting contingency for the San Diego sub-area is the loss of the
18 Imperial Valley-Suncrest 500 kV line followed by the loss of ECO- Miguel 500 kV line
19 (N-1-1). While the change in categorization of the double outage did not change the
20 ISO's local capacity area study methodology, the more severe G-1/N-2 contingency that
21 previously had been studied conceptually assumed that an automatic load shedding SPS
22 would be installed and available to prevent voltage collapse. I explained that with the
23 more likely N-1-1 as the most limiting contingency, the ISO did not believe that it would
24 be prudent planning to rely on an automatic load shedding SPS.

25
26 This is because the history of transmission line outages due to fires and equipment
27 failures in the area and the configuration of the system indicate that outage risks and
28 consequences are high. The Imperial Valley substation is a major source of imported
29 power for three different utilities: SDG&E, IID, and CFE. This is not only evidence of

**REBUTTAL TESTIMONY OF THE CALIFORNIA
INDEPENDENT SYSTEM OPERATOR CORPORATION
A.11-05-023**

Page 9 of 19

1 the criticality of this substation, but also the level of exposure to operational coordination
2 issues and failures. Relying on load shedding as a primary mitigation measure is an
3 indication that the system is being planned and operated at a very high stress level, and
4 with very little margin for error. Based on this information, it is not prudent to plan and
5 operate the Imperial Valley system with currently expected high outage risks and
6 consequences at a very high stress level and with very little margin for error. On the
7 other hand, the ISO would rely on the load shedding SPS during extreme operating
8 conditions beyond the N-1-1 contingency scenario considered in the OTC studies, that
9 would otherwise require pre-contingency load shedding.

10
11 Both DRA (witness Fagan) and CEJA (witness Firooz) have argued that the ISO's
12 approach to load shedding under an N-1-1 contingency is too conservative, and that the
13 local capacity needs in San Diego would be lower if the ISO planned for automatic load
14 shedding in the event of extreme circumstances or severe contingency events. As
15 described below, these arguments are misplaced.

16
17 **Q. Has Ms. Firooz accurately described the ISO's position with respect to load**
18 **shedding as an N-1-1 contingency mitigation for the most limiting contingency for**
19 **the San Diego area?**

20
21 **A.** No. First, at page 7 of her testimony, Ms. Firooz broadly states that the ISO will not rely
22 on load shedding in the San Diego area as mitigation for N-1-1 contingencies. That is not
23 correct. My testimony focused specifically on load shedding as mitigation for the ECO-
24 Miguel 500 kV line and Sunrise contingency and it is for this contingency that I believe it
25 would not be prudent to rely on load shedding.

26
27 Ms. Firooz goes on to mischaracterize an ISO data request response on this topic by
28 suggesting incorrectly that the ISO stated that it is not permitted to shed load for N-1-1
29 events and, based on that mischaracterization, she concludes that the ISO's "reason for

**REBUTTAL TESTIMONY OF THE CALIFORNIA
INDEPENDENT SYSTEM OPERATOR CORPORATION
A.11-05-023**

Page 10 of 19

1 not allowing load drop in the San Diego area is not reasonable,” (Firooz testimony, pages
2 8- 9). Specifically, CEJA posed the following question:

3
4 Does NERC, WECC, and/or CAISO reliability criteria prevent the use of
5 controlled load drop for an N-1-1 transmission contingency? If so, where is this
6 criteria documented? If not, what threshold does the CAISO use to determine
7 when controlled load drop is acceptable mitigation and when it is not? Are there
8 any limits on the amount of controlled load drop which is acceptable?
9

10 The CAISO responded:

11 The ISO is required by NERC TPL 003 to plan its network so that it can be
12 operated to supply projected customer demands for N-1-1 events regardless of
13 their probability. *NERC Transmission Planning Standards allow the use of*
14 *controlled load drop depending on system design and expected system impacts...*
15

16 The rest of the ISO’s response provided more explanation as to why, under the specific
17 system configuration and consistent with NERC TPL 003, the ISO would operate all
18 available generation to avoid the need to shed load to mitigate the category C
19 Sunrise/ECO-Miguel overlapping outage, for the reasons I discussed above. In other
20 words, although NERC TPL 003 *permits* load shedding as a mitigation for an N-1-1
21 contingency, the standard does not *require* the ISO, as the Planning Coordinator, to
22 approve an automatic load shedding SPS under all such circumstances and instead allows
23 for the Planning Coordinator to consider system design and expected system impacts in
24 deciding whether an automatic load shedding SPS is appropriate. Ms. Firooz seems to
25 misunderstand both the planning standard and the ISO response to the CEJA data request,
26 and has provided no basis for her conclusion that the ISO’s planning decision to avoid a
27 load shedding SPS for the Sunrise/ECO-Miguel N-1-1 is “unreasonable.”
28

29 **Q. Do you agree with Ms. Firooz’s suggestion at pages 7- 8 of her testimony that**
30 **considering the probability that a contingency will occur- which allegedly would**
31 **result in lower costs for consumers- would not lower grid reliability?**
32

ISO Opening Brief

probabilistic analysis examines the individual probability of each contingency under a particular system condition over a wide range of scenarios. A deterministic criteria is similar to using one standard driving test for all drivers in California and a probabilistic criteria is similar to giving every driver an individualized test based on his or her expected driving plans. In this analogy it is difficult to predict whether the test failure rate would go up or down, or if the driving accident rate would go up or down, if the State switched from a standard driving test to individualized tests. Continuing with the analogy, while there may be some questions on the standard test that do not apply to many driving situations, this would not be a valid argument for lowering the passing score level. This is because the standard test is only a sample of potential questions that could have been asked, and the score is indicative of the knowledge level of the entire driver's handbook. Ms. Firooz's approach- which is to apply probabilities to the "worst case" under a deterministic evaluation- again mixes apples and oranges and is not an effective means by which to test the robustness of the system. Going back to the analogy, her argument is a little like finding one person and saying that since the test does not match his or her expected driving plans, the passing score for the test should be lowered for everyone.

2. Load Shedding as a Mitigation Solution

Both CEJA and DRA suggest that controlled load shedding in the event of an N-1-1 contingency should be viewed as an acceptable mitigation solution that would reduce the local capacity needs in San Diego; CEJA witness Firooz proposed dropping 378 MW and DRA witness Fagan proposed a 370 MW load drop.³⁴ Just to put these recommendations in perspective, this amount of load drop could equate to well over 300,000 homes.³⁵ To adopt the

³⁴ Ex. 17 (Fagan), page 12, table RF-3; Ex. 20 (Firooz), page 3, table 1.

³⁵ See Ex. 20, footnote 3 discussing an April 6, 2010 outage of 310 MW, which was 291,000 homes.

recommendations of DRA and CEJA, the Commission would have to find that cutting off power to 300,000 homes is an acceptable outcome. This goes far beyond targeted load shedding in a limited area.

NERC planning standard TPL 003 permits load shedding for an N-1-1 contingency, but does not require the ISO, as the Planning Coordinator, to approve automatic load shedding under all circumstances. Rather, the planning standards allow for prudent engineering judgment taking into consideration system design and expected system impacts.³⁶ As Mr. Sparks explained, the history of the IV substation area includes outages due to fires and equipment failures, and the configuration of the system shows that outage risks are very high. This substation is a major source of imported power for three utilities: SDG&E, IID and CFE, which is evidence of the level of exposure to operational and coordination issues. In response to questions by CEJA, he stated:

...All three of those systems rely on that point in the grid as one of their two major sources of imports in their systems. So it's a very critical piece of the system. And our concern is that if we rely on load shed, we're certainly overstressing that part of the system.³⁷

At a later point Mr. Sparks added that it is not the ISO's position that automatic load shed would not be allowed for any of the "hundreds of overlapping contingencies (N-1-1) on the system." It is just that "there are some where it's okay and there are some where it is not,"³⁸ and this analysis must be done on a case by case basis. Ms. Firooz admitted that there is a host of engineering criteria that should be taken into account in determining whether controlled load shedding should be adopted as a mitigation solution, such as the design of the system,

³⁶ Ex. 27, page 10.

³⁷ Tr.III, page 546.

³⁸ *Id.*, page 550.

probability and severity of outages, and the existence of other special protection systems.³⁹

Thus, although Ms. Firooz clearly does not agree with the ISO's ultimate decision about load shedding, she provided no reasonable basis for disagreement with the engineering judgment that went into the analysis.

Similarly, Mr. Fagan offered no engineering basis for a load shedding scheme but pointed to SDG&E's consideration of a "safety net" as a mitigation solution for a Category C contingency. He further argued that the ISO should have performed a cost benefit analysis of the costs of a load shedding SPS versus procuring additional local generation. However, these two solutions are not substitutes for each other. Mr. Sparks explained that unlike load shedding, generation provides both local and system benefits, as well as renewable integration and reliability benefits for a marginal cost.⁴⁰ The wide-scale load shedding that would result from adoption of their proposals provides none of those benefits and only creates other problems.

3. Modeling Assumptions: Uncommitted EE, Incremental DR, Uncommitted CHP and Energy Storage

In addition to the other proposed reductions to the ISO's local deficiency findings, NRDC, CEJA and DRA all criticized the ISO's modeling assumptions regarding uncommitted EE and CHP, incremental DR and energy storage. They suggest that the ISO should have used assumptions from the planning standards used in the prior LTPP case (R.10-05-006). Specifically, these parties propose reductions in the ISO's local area requirements for 544 MW of uncommitted EE (DRA proposed an alternative 284 MW for "high need") and 302 MW of incremental demand response. CEJA and DRA also propose 64 MW of incremental

³⁹ Tr. III, pages 491-492.

⁴⁰ Ex. 27, page 12.

ATTACHMENT 2

A.11-05-023

*Application of San Diego Gas & Electric Company (U 902 E) for Authority to Enter into
Purchase Power Tolling Agreements with Escondido Energy Center, Pio Pico Energy Center
and Quail Brush Power*

Supplemental Testimony of Robert Sparks on Behalf of the
California Independent System Operator Corporation
April 6, 2012

Page 3

Application No.: A.11-05-023

Exhibit No.: _____

Witness: Robert Sparks

Application of San Diego Gas & Electric Company
(U902 E) for Authority to Enter into Purchase Power
Tolling Agreements with Escondido Energy Center,
Pio Pico Energy Center and Quail Brush Power

Application 11-05-023

**SUPPLEMENTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

**SUPPLEMENTAL TESTIMONY OF ROBERT SPARKS
ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR
CORPORATION**

A.11-05-023

1 overlapping with an outage of the Otay Mesa combined-cycle power plant (G-1/N-
2 2). The limiting constraint for this contingency is the South of SONGS Separation
3 Scheme. With this change to the WECC criterion, the most limiting contingency for
4 San Diego sub-area is the loss of Imperial Valley-Suncrest 500 kV line followed by
5 the loss of ECO-Miguel 500 kV line (N-1-1).

6
7 The table below shows the difference in study results between the two different
8 limiting contingency scenarios.

LCR Area	Contingency	Limiting Constraint	Traject (MW)	Env (MW)	ISO Base (MW)	Time (MW)
San Diego	G-1/N-2 (Assuming load shed)	8000 Amp limit on P44	LCR = 2,883** OTC = 531* - 950	LCR = 2,854** OTC = 231* - 650	LCR = 2,864** OTC = 231* - 650	LCR = 2,856** OTC = 421* - 840
		7800 Amp limit on P44 (2.5% margin)	LCR = 2,939** OTC = 520* - 939	LCR = 2,922** OTC = 299* - 718	LCR = 2,930** OTC = 299* - 718	LCR = 2,911** OTC = 470* - 889
San Diego	N-1-1 (No load shed)	8000 Amp limit on P44	LCR = 2,680 OTC = 318* - 737	LCR = 2,625 OTC = 0* - 402	LCR = 2,669 OTC = 218* - 637	LCR = 2,633 OTC = 201* - 620
		7800 Amp limit on P44 (2.5% margin)	LCR = 2,735 OTC = 373* - 792	LCR = 2,702 OTC = 60* - 479	LCR = 2,694 OTC = 243* - 662	LCR = 2,691 OTC = 260* - 679
		Voltage Collapse (accounting for 2.5% margin)	LCR = 2,646 OTC = 311* - 730	LCR = 2,524 OTC = 0* - 300	LCR = 2,663 OTC = 211* - 630	LCR = 2,553 OTC = 121* - 540

9
10
11
12 * Lower OTC range value corresponds to the use of SDG&E-proposed generation
13 included in the Long-Term Procurement Plan. The numbers in the table identified
14 as OTC refer to an incremental local capacity need in the San Diego area driven by
15 the loss of OTC generation in the San Diego area. This need could be met by
16 repowering the existing OTC generation or by other new generation that is
17 connected to an electrically equivalent location.

18 ** Load curtailment of approximately 370 MW was simulated to achieve stability
19 under G-1/N-2 contingency.
20

ATTACHMENT 3

2014 Local Capacity Technical Analysis
Final Report & Study Results

Pages 2 & 94



2014 LOCAL CAPACITY TECHNICAL ANALYSIS

FINAL REPORT AND STUDY RESULTS

April 30, 2013

Below is a comparison of the 2014 vs. 2013 total LCR:

2014 Local Capacity Requirements

Local Area Name	Qualifying Capacity			2014 LCR Need Based on Category B			2014 LCR Need Based on Category C with operating procedure		
	QF/ Muni (MW)	Market (MW)	Total (MW)	Existing Capacity Needed	Deficiency	Total (MW)	Existing Capacity Needed**	Deficiency	Total (MW)
Humboldt	70	173	243	145	0	145	195	0	195
North Coast / North Bay	150	771	921	623	0	623	623	0	623
Sierra	1288	762	2050	1414	0	1414	1803	285*	2088
Stockton	212	392	604	354	25*	379	446	255*	701
Greater Bay	1336	6280	7616	3747	0	3747	4423	215*	4638
Greater Fresno	318	2510	2828	1857	0	1857	1857	0	1857
Kern	613	64	677	421	14*	435	421	41*	462
LA Basin***	2242	9547	11789	10063	0	10063	10430	0	10430
Big Creek/ Ventura	1112	4206	5318	2156	0	2156	2250	0	2250
San Diego/ Imperial Valley***	200	4506	4706	3605	167*	3772	3605	458*	4063
Total	7541	29211	36752	24385	206	24591	26053	1254	27307

2013 Local Capacity Requirements

Local Area Name	Qualifying Capacity			2013 LCR Need Based on Category B			2013 LCR Need Based on Category C with operating procedure		
	QF/ Muni (MW)	Market (MW)	Total (MW)	Existing Capacity Needed	Deficiency	Total (MW)	Existing Capacity Needed**	Deficiency	Total (MW)
Humboldt	55	162	217	143	0	143	190	22*	212
North Coast / North Bay	130	739	869	629	0	629	629	0	629
Sierra	1274	765	2039	1408	0	1408	1712	218*	1930
Stockton	216	404	620	242	0	242	413	154*	567
Greater Bay	1368	6296	7664	3479	0	3479	4502	0	4502
Greater Fresno	314	2503	2817	1786	0	1786	1786	0	1786
Kern	684	0	684	295	0	295	483	42*	525
LA Basin	4452	8675	13127	10295	0	10295	10295	0	10295
Big Creek/ Ventura	1179	4097	5276	2161	0	2161	2241	0	2241
San Diego	158	3991	4149	2938	0	2938	2938	144*	3082
Total	9830	27632	37462	23376	0	23376	25189	580	25769

10. San Diego-Imperial Valley Area

Area Definition

The transmission tie lines forming a boundary around the Greater San Diego-Imperial Valley area include:

- 1) Imperial Valley – North Gila 500 kV Line
- 2) Otay Mesa – Tijuana 230 kV Line
- 3) San Onofre - San Luis Rey #1 230 kV Line
- 4) San Onofre - San Luis Rey #2 230 kV Line
- 5) San Onofre - San Luis Rey #3 230 kV Line
- 6) San Onofre – Talega #1 230 kV Line
- 7) San Onofre – Talega #2 230 kV Line
- 8) Imperial Valley – El Centro 230 kV Line
- 9) Imperial Valley – Dixieland 230 kV Line
- 10) Imperial Valley – La Rosita 230 kV Line

The substations that delineate the Greater San Diego-Imperial Valley area are:

- 1) Imperial Valley is in North Gila is out
- 2) Otay Mesa is in Tijuana is out
- 3) San Onofre is out San Luis Rey is in
- 4) San Onofre is out San Luis Rey is in
- 5) San Onofre is out San Luis Rey is in
- 6) San Onofre is out Talega is in
- 7) San Onofre is out Talega is in
- 8) Imperial Valley is in El Centro is out
- 9) Imperial Valley is in Dixieland is out
- 10) Imperial Valley is in La Rosita is out

Total 2014 busload within the defined area: 5073 MW with 127 MW of losses resulting in total load + losses of 5200 MW.

Total units and qualifying capacity available in this area:

MKT/SCHED RESOURCE ID	BUS #	BUS NAME	kV	NQC	UNIT ID	LCR SUB-AREA NAME	NQC Comments	CAISO Tag
BORDER_6_UNITA1	22149	CALPK_BD	13.8	45.00	1	San Diego, Border		Market

the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by NERC transmission operations standards.

ATTACHMENT 4

California ISO Planning Standards
June 23, 2011



California ISO Planning Standards

June 23, 2011

Table of Contents

- I. Introduction**
- II. ISO Planning Standards**
 - 1. Applicability of NERC Reliability Standards to Low Voltage Facilities under ISO Operational Control
 - 2. Combined Line and Generator Outage Standard
 - 3. Voltage Standard
 - 4. Specific Nuclear Unit Standards
 - 5. Loss of Combined Cycle Power Plant Module as a Single Generator Outage
 - 6. Planning for New Transmission versus Involuntary Load Interruption Standard
- III. ISO Planning Guidelines**
 - 1. New Special Protection Systems
- IV. Combined Line and Generator Unit Outage Standards Supporting Information**
- V. Loss of Combined Cycle Power Plant Module as a Single Generator Outage Standard Supporting Information**
- VI. Background behind Planning for New Transmission versus Involuntary Load Interruption Standard**
- VII. Interpretations of Terms from the NERC Reliability Standards and WECC Regional Criteria**

I. Introduction

The California ISO (ISO) tariff provides for the establishment of planning guidelines and standards above those established by NERC and WECC to ensure the secure and reliable operation of the ISO controlled grid. The primary guiding principle of these Planning Standards is to develop consistent reliability standards for the ISO grid that will maintain or improve transmission system reliability to a level appropriate for the California system.

These ISO Planning Standards are not intended to duplicate the NERC and WECC reliability standards, but to complement them where it is in the best interests of the security and reliability of the ISO controlled grid. The ISO planning standards will be revised from time to time to ensure they are consistent with the current state of the electrical industry and in conformance with NERC Reliability Standards and WECC Regional Criteria. In particular, the ISO planning standards:

- Address specifics not covered in the NERC Reliability Standards and WECC Regional Criteria;
- Provide interpretations of the NERC Reliability Standards and WECC Regional Criteria specific to the ISO Grid;
- Identify whether specific criteria should be adopted that are more stringent than the NERC Reliability Standards and WECC Regional Criteria where it is in the best interest of ensuring the ISO controlled grid remains secure and reliable.

NERC Reliability Standards and WECC Regional Criteria:

The following links provide the minimum standards that ISO needs to follow in its planning process unless NERC or WECC formally grants an exemption or deference to the ISO. They are the NERC Transmission Planning (TPL) standards, other applicable NERC standards (i.e., NUC-001 Nuclear Plant Interface Requirements (NPIRs) for Diablo Canyon Power Plant and San Onofre Nuclear Generating Station), and the WECC Regional Criteria:

<http://www.nerc.com/page.php?cid=2|20>

<http://www.wecc.biz/Standards/WECC%20Criteria/Forms/AllItems.aspx>

Section II of this document provides additional details about the ISO Planning Standards. Guidelines are provided in subsequent sections to address certain ISO planning standards, such as the use of new Special Protection Systems, which are not specifically addressed at the regional level of NERC and WECC. Where appropriate, background information behind the development of these standards and references (web links) to subjects associated with reliable transmission planning and operation are provided.

II. ISO Planning Standards

The ISO Planning Standards are:

1. **Applicability of NERC Reliability Standards to Low Voltage Facilities under ISO Operational Control**

The ISO will apply NERC Transmission Planning (TPL) standards, the NUC-001 Nuclear Plant Interface Requirements (NPIRs) for Diablo Canyon Power Plant and San Onofre Nuclear Generating Station, and the approved WECC Regional Criteria to facilities with voltages levels less than 100 kV or otherwise not covered under the NERC Bulk Electric System definition that have been turned over to the ISO operational control.

2. **Combined Line and Generator Outage Standard**

A single transmission circuit outage with one generator already out of service and the system adjusted shall meet the performance requirements of the NERC TPL standards for single contingencies (TPL002). Supporting information is located within Section IV of this document.

3. **Voltage Standard**

Standardization of low and high voltage levels as well as voltage deviations across the TPL-001, TPL-002, and TPL-003 standards is required across all transmission elements in the ISO controlled grid. The low voltage and voltage deviation guideline applies only to load and generating buses within the ISO controlled grid (including generator auxiliary load) since they are impacted by the magnitude of low voltage and voltage deviations. The high voltage standard applies to all buses since unacceptable high voltages can damage station and transmission equipment. These voltage standards are shown in Table 1.

All buses within the ISO controlled grid that cannot meet the requirements specified in Table 1 will require further investigation. Exceptions to this voltage standard may be granted by the ISO based on documented evidence vetted through an open stakeholder process. The ISO will make public all exceptions through its website.

Table 1
(Voltages are relative to the nominal voltage of the system studied)

Voltage level	Normal Conditions (TPL-001)		Contingency Conditions (TPL-002 & TPL-003)		Voltage Deviation	
	Vmin (pu)	Vmax (pu)	Vmin (pu)	Vmax (pu)	TPL-002	TPL-003
≤ 200 kV	0.95	1.05	0.90	1.1	≤5%	≤10%
≥ 200 kV	0.95	1.05	0.90	1.1	≤5%	≤10%
≥ 500 kV	1.0	1.05	0.90	1.1	≤5%	≤10%

4. Specific Nuclear Unit Standards

The criteria pertaining to the Diablo Canyon Power Plant (DCPP) and San Onofre Nuclear Generating Station (SONGS), as specified in the NUC-001 Nuclear Plant Interface Requirements (NPIRs) for DCPP and SONGS, and Appendix E of the Transmission Control Agreement located on the ISO web site at:

<http://www.caiso.com/docs/09003a6080/25/a3/09003a608025a3bd.pdf>

5. Loss of Combined Cycle Power Plant Module as a Single Generator Outage Standard

A single module of a combined cycle power plant is considered a single contingency (G-1) and shall meet the performance requirements of the NERC TPL standards for single contingencies (TPL002). Supporting information is located in Section V of this document. Furthermore a single transmission circuit outage with one combined cycle module already out of service and the system adjusted shall meet the performance requirements of the NERC TPL standards for single contingencies (TPL002) as established in item 1 above.

A re-categorization of any combined cycle facility that falls under this standard to a less stringent requirement is allowed if the operating performance of the combined cycle facility demonstrates a re-categorization is warranted. The ISO will assess re-categorization on a case by case based on the following:

- a) Due to high historical outage rates in the first few years of operation no exceptions will be given for the first two years of operation of a new combined cycle module.
- b) After two years, an exception can be given upon request if historical data proves that no outage of the combined cycle module was encountered since start-up.
- c) After three years, an exception can be given upon request if historical data proves that outage frequency is less than once in three years.

The ISO may withdraw the re-categorization if the operating performance of the combined cycle facility demonstrates that the combined cycle module exceeds a failure rate of once in three year. The ISO will make public all exceptions through its website.

6. Planning for New Transmission versus Involuntary Load Interruption Standard

This standard sets out when it is necessary to upgrade the transmission system from a radial to a looped configuration or to eliminate load dropping otherwise permitted by WECC and NERC planning standards through transmission

infrastructure improvements. It does not address all circumstances under which load dropping is permitted under NERC and WECC planning standards.

1. No single contingency (TPL002 and ISO standard [G-1] [L-1]) should result in loss of more than 250 MW of load. This includes consequential loss of load as well as load that may need to be dropped after the first contingency (during the system adjustment period) in order to position the electric system for reliable operation in anticipation of the next worst contingency.
2. All single substations of 100 MW or more should be served through a looped system with at least two transmission lines “closed in” during normal operation.
3. Existing radial loads with available back-tie(s) (drop and automatic or manual pick-up schemes) should have their back-up tie(s) sized at a minimum of 50% of the yearly peak load or to accommodate the load 80% of the hours in a year (based on actual load shape for the area), whichever is more constraining.
4. Upgrades to the system that are not required by the standards in 1, 2 and 3 above may be justified by eliminating or reducing load outage exposure, through a benefit to cost ratio (BCR) above 1.0 and/or where there are other extenuating circumstances.

To better understand the potential impact of the updated “planning for new transmission versus involuntary load interruption” standard, this standard will be considered a guideline for the first year that it is in effect in order to get an inventory of stations and transmission elements not in compliance and a cost impact of bringing them into compliance.

III. ISO Planning Guidelines

The ISO Planning Guidelines include the following:

1. New Special Protection Systems

As stated in the NERC glossary, a Special Protection System (SPS) is “an automatic protection system designed to detect abnormal or predetermined system conditions, and take corrective actions other than and/or in addition of faulted components to maintain system reliability.” In the context of new projects, the possible action of an SPS would be to detect a transmission outage (either a single contingency or credible multiple contingencies) or an overloaded transmission facility and then curtail generation output and/or load in order to avoid potentially overloading facilities or prevent the situation of not meeting other system performance criteria. A SPS can also have different functions such as executing plant generation reduction requested by other SPS; detecting unit outages and transmitting commands to other locations for specific action to be taken; forced excitation pulsing; capacitor and reactor switching; out-of-step tripping; and load dropping among other things.

The primary reasons why SPS might be selected over building new transmission facilities are that SPS can normally be implemented much more quickly and at a much lower cost than constructing new infrastructure. In addition, SPS can increase the utilization of the existing transmission facilities, make better use of scarce transmission resources and maintain system reliability. Due to these advantages, SPS is a commonly considered alternative to building new infrastructure in an effort to keep costs down when integrating new generation into the grid and/or addressing reliability concerns under multiple contingency conditions. While SPSs have substantial advantages, they have disadvantages as well. With the increased transmission system utilization that comes with application of SPS, there can be increased exposure to not meeting system performance criteria if the SPS fails or inadvertently operates. Transmission outages can become more difficult to schedule due to increased flows across a larger portion of the year; and/or the system can become more difficult to operate because of the independent nature of the SPS. If there are a large number of SPSs, it may become difficult to assess the interdependency of these various schemes on system reliability. These reliability concerns necessarily dictate that guidelines be established to ensure that performance of all SPSs are consistent across the ISO controlled grid. It is the intent of these guidelines to allow the use of SPSs to maximize the capability of existing transmission facilities while maintaining system reliability and optimizing operability of the ISO controlled grid. Needless to say, with the large number of generator interconnections that are occurring on the ISO controlled grid, the need for these guidelines has become more critical.

It needs to be emphasized that these are guidelines rather than standards. In general, these guidelines are intended to be applied with more flexibility for low exposure outages (e.g., double line outages, bus outages, etc.) than for high exposure outages (e.g., single contingencies). This is to emphasize that best engineering practice and judgement will need to be exercised by system planners and operators in determining when the application of SPS will be acceptable. It is recognized that it is not possible or desirable to have strict standards for the acceptability of the use of SPS in all potential applications.

ISO SPS1

The overall reliability of the system should not be degraded after the combined addition of the SPS.

ISO SPS2

The SPS needs to be highly reliable. Normally, SPS failure will need to be determined to be non-credible. In situations where the design of the SPS requires WECC approval, the WECC Remedial Action Scheme Design Guide will be followed.

ISO SPS3

The total net amount of generation tripped by a SPS for a single contingency cannot exceed the ISO's largest single generation contingency (currently one Diablo Canyon unit at 1150 MW). The total net amount of generation tripped by a SPS for a double contingency cannot exceed 1400 MW. This amount is related to the minimum amount of

spinning reserves that the ISO has historically been required to carry. The quantities of generation specified in this standard represent the current upper limits for generation tripping. These quantities will be reviewed periodically and revised as needed. In addition, the actual amount of generation that can be tripped is project specific and may depend on specific system performance issues to be addressed. Therefore, the amount of generation that can be tripped for a specific project may be lower than the amounts provided in this guide. The net amount of generation is the gross plant output less the plant's and other auxiliary load tripped by the same SPS.

ISO SPS4

For SPSs, the following consequences are unacceptable should the SPS fail to operate correctly:

- A) Cascading outages beyond the outage of the facility that the SPS is intended to protect: For example, if a SPS were to fail to operate as designed for a single contingency and the transmission line that the SPS was intended to protect were to trip on overload protection, then the subsequent loss of additional facilities due to overloads or system stability would not be an acceptable consequence.
- B) Voltage instability, transient instability, or small signal instability: While these are rare concerns associated with the addition of new generation, the consequences can be so severe that they are deemed to be unacceptable results following SPS failure.

ISO SPS5

Close coordination of SPS is required to eliminate cascading events. All SPS in a local area (such as SDG&E, Fresno, etc.) and grid-wide need to be evaluated as a whole and studied as such.

ISO SPS6

The SPS must be simple and manageable. As a general guideline:

- A) There should be no more than 6 local contingencies (single or credible double contingencies) that would trigger the operation of a SPS.
- B) The SPS should not be monitoring more than 4 system elements or variables. A variable can be a combination of related elements, such as a path flow, if it is used as a single variable in the logic equation. Exceptions include:
 - i. The number of elements or variables being monitored may be increased if it results in the elimination of unnecessary actions, for example: generation tripping, line sectionalizing or load shedding.
 - ii. If the new SPS is part of an existing SPS that is triggered by more than 4 local contingencies or that monitors more than 4 system elements or variables, then the new generation cannot materially increase the complexity of the existing SPS scheme. However, additions to an existing SPS using a modular design should be considered as preferable to the

addition of a new SPS that deals with the same contingencies covered by an existing SPS.

- C) Generally, the SPS should only monitor facilities that are connected to the plant or to the first point of interconnection with the grid. Monitoring remote facilities may add substantial complexity to system operation and should be avoided.
- D) An SPS should not require real-time operator actions to arm or disarm the SPS or change its set points.

ISO SPS7

If the SPS is designed for new generation interconnection, the SPS may not include the involuntary interruption of load. Voluntary interruption of load paid for by the generator is acceptable. The exception is that the new generator can be added to an existing SPS that includes involuntary load tripping. However, the amount of involuntary load tripped by the combined SPS may not be increased as a result of the addition of the generator.

ISO SPS8

Action of the SPS shall limit the post-disturbance loadings and voltages on the system to be within all applicable ratings and shall ultimately bring the system to within the long-term (4 hour or longer) emergency ratings of the transmission equipment. For example, the operation of SPS may result in a transmission line initially being loaded at its one-hour rating. The SPS could then automatically trip or run-back additional generation (or trip load if not already addressed under ISO SPS7 above) to bring the line loading within the line's four-hour or longer rating. This is intended to minimize real-time operator intervention.

ISO SPS9

The SPS needs to be agreed upon by the ISO and may need to be approved by the WECC Remedial Action Scheme Reliability Task Force.

ISO SPS10

The ISO, in coordination with affected parties, may relax SPS requirements as a temporary "bridge" to system reinforcements. Normally this "bridging" period would be limited to the time it takes to implement a specified alternative solution. An example of a relaxation of SPS requirement would be to allow 8 initiating events rather than limiting the SPS to 6 initiating events until the identified system reinforcements are placed into service.

ISO SPS11

The ISO will consider the expected frequency of operation in its review of SPS proposals.

ISO SPS12

The actual performance of existing and new SPS schemes will be documented by the transmission owners and periodically reviewed by the ISO and other interested parties so that poorly performing schemes may be identified and revised.

ISO SPS13

All SPS schemes will be documented by the owner of the transmission system where the SPS exists. The generation owner, the transmission owner, and the ISO shall retain copies of this documentation.

ISO SPS14

To ensure that the ISO's transmission planning process consistently reflects the utilization of SPS in its annual plan, the ISO will maintain documentation of all SPS utilized to meet its reliability obligations under the NERC reliability standards, WECC regional criteria, and ISO planning standards.

ISO SPS15

The transmission owner in whose territory the SPS is installed will, in coordination with affected parties, be responsible for designing, installing, testing, documenting, and maintaining the SPS.

ISO SPS16 Generally, the SPS should trip load and/or resources that have the highest effectiveness factors to the constraints that need mitigation such that the magnitude of load and/or resources to be tripped is minimized. As a matter of principle, voluntary load tripping and other pre-determined mitigations should be implemented before involuntary load tripping is utilized.

ISO SPS17

Telemetry from the SPS (e.g., SPS status, overload status, etc.) to both the Transmission Owner and the ISO is required unless otherwise deemed unnecessary by the ISO. Specific telemetry requirements will be determined by the Transmission Owner and the ISO on a project specific basis.

IV. Combined Line and Generator Unit Outage Standards Supporting Information

Combined Line and Generator Outage Standard - A single transmission circuit outage with one generator already out of service and the system adjusted shall meet the performance requirements of the NERC TPL standards for single contingencies (TPL002).

The ISO Planning Standards require that system performance for an over-lapping outage of a generator unit (G-1) and transmission line (L-1) must meet the same system performance level defined for the NERC standard TPL-002. The ISO recognizes that this planning standard is more stringent than allowed by NERC, but it is considered appropriate for assessing the reliability of the ISO's controlled grid as it remains consistent with the standard utilized by the PTOs prior to creation of the ISO.

V. Loss of Combined Cycle Power Plant Module as a Single Generator Outage Standard Supporting Information

Loss of Combined Cycle Power Plant Module as a Single Generator Outage

Standard - A single module of a combined cycle power plant is considered a single (G-1) contingency and shall meet the performance requirements of the NERC TPL standards for single contingencies (TPL002).

The purpose of this standard is to require that an outage of any turbine element of a combustion turbine be considered as a single outage of the entire plant and therefore must meet the same performance level as the NERC TPL standard TPL-002.

The ISO has determined that, a combined cycle module should be treated as a single contingency. In making this determination, the ISO reviewed the actual operating experience to date with similar (but not identical) combined cycle units currently in operation in California. The ISO's determination is based in large part on the performance history of new combined cycle units and experience to date with these units. The number of combined cycle facility forced outages that have taken place does not support a double contingency categorization for combined cycle module units in general. It should be noted that all of the combined cycle units that are online today are treated as single contingencies.

Immediately after the first few combined cycle modules became operational, the ISO undertook a review of their performance. In defining the appropriate categorization for combined cycle modules, the ISO reviewed the forced outage history for the following three combined cycle facilities in California: Los Medanos Energy Center (Los Medanos), Delta Energy Center (Delta), and Sutter Energy Center (Sutter)¹. Los Medanos and Sutter have been in service since the summer of 2001, Delta has only been operational since early summer 2002.

Table 2 below sets forth the facility forced outages for each of these facilities after they went into operation (i.e. forced outages² that resulted in an output of zero MWs.) The table demonstrates that facility forced outages have significantly exceeded once every 3 to 30 years. Moreover, the ISO considers that the level of facility forced outages is significantly above the once every 3 to 30 years even accounting for the fact that new combined cycle facilities tend to be less reliable during start-up periods and during the initial weeks of operation. For example, four of the forced outages that caused all the

¹ Los Medanos and Sutter have two combustion turbines (CT's) and one steam turbine (ST) each in a 2x1 configuration. Delta has three combustion turbines (CT's) and one steam turbine (ST) in a 3x1 configuration. All three are owned by the Calpine Corporation.

² Only forced outages due to failure at the power plant itself are reported, forced outages due to failure on the transmission system/switchyard are excluded. The fact that a facility experienced a forced outage on a particular day is public information. In fact, information on unavailable generating units has been posted daily on the ISO website since January 1, 2001. However, the ISO treats information regarding the cause of an outage as confidential information.

three units at Los Medanos to go off-line took place more than nine months after the facility went into operation.

Facility	Date	# units lost
Sutter ³	08/17/01	No visibility
Sutter	10/08/01	1 CT
Sutter	12/29/01	All 3
Sutter	04/15/02	1 CT + ST
Sutter	05/28/02	1 CT
Sutter	09/06/02	All 3
Los Medanos ⁴	10/04/01	All 3
Los Medanos	06/05/02	All 3
Los Medanos	06/17/02	All 3
Los Medanos	06/23/02	1CT+ST
Los Medanos	07/19/02	All 3
Los Medanos	07/23/02	1CT+ST
Los Medanos	09/12/02	All 3
Delta ⁵	06/23/02	All 4
Delta	06/29/02	2 CT's + ST
Delta	08/07/02	2 CT's + ST

Table 2: Forced outages that have resulted in 0 MW output from Sutter, Los Medanos and Delta after they became operational

The ISO realizes that this data is very limited. Nevertheless, the data adequately justifies the current classification of each module of these three power plants as a single contingency.

VI. Background behind Planning for New Transmission versus Involuntary Load Interruption Standard

For practical and economic reasons, all electric transmission systems are planned to allow for some involuntary loss of firm load under certain contingency conditions. For some systems, such a loss of load may require several contingencies to occur while for other systems, loss of load may occur in the event of a specific single contingency. Historically, a wide variation among the PTOs has existed predominantly due to slightly differing planning and design philosophies. This standard is intended to provide a consistent framework upon which involuntary load interruption decisions can be made by the ISO when planning infrastructure needs for the ISO controlled grid.

³ Data for Sutter is recorded from 07/03/01 to 08/10/02

⁴ Data for Los Medanos is recorded from 08/23/01 to 08/10/02

⁵ Data for Delta is recorded from 06/17/02 to 08/10/02

The overarching requirement is that implementation of these standards should not result in lower levels of reliability to end-use customers than existed prior to restructuring. As such, the following is required:

1. No single contingency (TPL002 and ISO standard [G-1] [L-1]) may result in loss of more than 250 MW of load. This includes consequential loss of load as well as load that may need to be dropped after the first contingency (during the system adjustment period) in order to protect for the next worst single contingency.

This standard is intended to coordinate ISO planning standards with the WECC requirement that all transmission outages with at least 300 MW or more be directly reported to WECC. It is the ISO's intent that no single contingency (TPL002 and ISO standard [G-1] [L-1]) should trigger loss of 300 MW or more of load. The 250 MW level is chosen in order to allow for differences between the load forecast and actual real time load that can be higher in some instances than the forecast and to also allow time for transmission projects to become operational since some require 5-6 years of planning and permitting with inherent delays. It is also ISO's intent to put a cap on the footnote to the NERC TPL-002 that may allow radial and/or non-consequential loss of load for single contingencies.

2. All single substations of 100 MW or more should be served through a looped system with at least two transmission lines "closed in" during normal operation.

This standard is intended to bring consistency between the PTOs' substation designs. It is not the ISO's intention to disallow substations with load below 100 MW from having looped connections; however it is ISO's intention that all substations with peak load above 100 MW must be connected through a looped configuration to the grid.

3. Existing radial loads with available back-tie(s) (drop and automatic or manual pick-up schemes) should have their back-up tie(s) sized at a minimum of 50% of the yearly peak load or to accommodate the load 80% of the hours in a year (based on actual load shape for the area), whichever is more stringent.

This standard is intended to insure that the system is maintained at the level that existed prior to restructuring. It is obvious that as load grows, existing back-ties for radial loads (or remaining feed after a single contingency for looped substations) may not be able to pick up the entire load; therefore the reliability to customers connected to this system may deteriorate over time. It is the ISO's intention to establish a minimum level of back-up tie capability that needs to be maintained.

4. Upgrades to the system that are not required by the standards in 1, 2 and 3 above may be justified by eliminating or reducing load outage exposure through a benefit to cost ratio (BCR) above 1.0 and/or where there are other extenuating circumstances.

It is ISO's intention to allow the build-up of transmission projects that are proven to have a positive benefit to ratepayers by reducing load drop exposure.

Information Required for BCR calculation: For each of the outages that required involuntary interruption of load, the following should be estimated:

- The maximum amount of load that would need to be interrupted.
- The duration of the interruption.
- The annual energy that would not be served or delivered.
- The number of interruptions per year.
- The time of occurrence of the interruption (e.g., week day summer afternoon).
- The number of customers that would be interrupted.
- The composition of the load (i.e., the percent residential, commercial, industrial, and agricultural).
- Value of service or performance-based ratemaking assumptions concerning the dollar impact of a load interruption.

The above information will be documented in the ISO Transmission Plan for areas where additional transmission reinforcement is needed or justified through benefit to cost ratio determination.

VII. Interpretations of terms from NERC Reliability Standard and WECC Regional Criteria

Listed below are several ISO interpretations of the terms that are used in the NERC standards that are not already addressed by NERC.

Combined Cycle Power Plant Module: A **combined cycle** is an assembly of heat engines that work in tandem off the same source of heat, converting it into mechanical energy, which in turn usually drives electrical generators. In a combined cycle power plant (CCPP), or combined cycle gas turbine (CCGT) plant, one or more gas turbine generator(s) generates electricity and heat in the exhaust is used to make steam, which in turn drives a steam turbine to generate additional electricity.

Entity Responsible for the Reliability of the Interconnected System Performance:

In the operation of the grid, the ISO has primary responsibility for reliability. In the planning of the grid, reliability is a joint responsibility between the PTO and the ISO subject to appropriate coordination and review with the relevant local, state, regional and federal regulatory authorities.

Entity Required to Develop Load Models: The PTOs, in coordination with the utility distribution companies (UDCs) and others, develop load models.

Entity Required to Develop Load Forecast: The California Energy Commission (CEC) has the main responsibility for providing load forecast. If load forecast is not

provided by the CEC or is not detailed and/or specific enough for a certain study then the ISO, at its sole discretion, may use load forecasts developed by the PTOs in coordination with the UDCs and others.

Projected Customer Demands: The load level modeled in the studies can significantly impact the facility additions that the studies identify as necessary. For studies that address regional transmission facilities such as the design of major interties, a 1 in 5-year extreme weather load level should be assumed. For studies that are addressing local load serving concerns, the studies should assume a 1 in 10-year extreme weather load level. The more stringent requirement for local areas is necessary because fewer options exist during actual operation to mitigate performance concerns. In addition, due to diversity in load, there is more certainty in a regional load forecast than in the local area load forecast. Having a more stringent standard for local areas will help minimize the potential for interruption of end-use customers.

Planned or Controlled Interruption: Load interruptions can be either automatic or through operator action as long as the specific actions that need to be taken, including the magnitude of load interrupted, are identified and corresponding operating procedures are in place when required.

Time Allowed for Manual Readjustment: This is the amount of time required for the operator to take all actions necessary to prepare the system for the next contingency. This time should be less than 30 minutes.