
	Reliability Coordinator Procedure	Procedure No. RC0310
		Version No. 1.5
		Effective Date 5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None

Table of Contents

Purpose.....	2
1. Responsibilities.....	2
2. Scope/Applicability.....	2
3. Procedure Detail.....	2
3.1. Monitoring & Analysis Tools.....	2
3.2. Identifying SOL and IROL Exceedances.....	3
3.3. Actual Thermal Limit Exceedances.....	4
3.4. Actual Voltage Limit Exceedances.....	6
3.5. Actual Stability Limit Exceedances.....	7
3.6. RTCA Post-Contingency Thermal Exceedances.....	8
3.7. RTCA Post-Contingency Voltage Exceedances.....	10
3.8. IROL Exceedances.....	11
3.9. Insecure Operating State.....	13
3.10. Unsolved Contingencies in RTCA.....	14
3.11. Islanding Conditions.....	15
3.12. Post-Contingency Mitigation Plans.....	16
3.13. Change of RAS Status.....	16
3.14. Unscheduled Flow Relief for Qualified Paths.....	17
3.14.1. Requests for Operation of Qualified Controllable Devices (Step 2 or 3).....	17
3.14.2. Requests for Schedule Curtailments (Step 4).....	18
4. Supporting Information.....	19
Operationally Affected Parties.....	19
References.....	19
Definitions.....	20
Version History.....	23
5. Periodic Review Procedure.....	24
Review Criteria & Incorporation of Changes.....	24
Frequency.....	24
Appendix.....	24

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

Purpose

Provide guidance on mitigating System Operating Limits (SOL) and Interconnection Reliability Operating Limits (IROL) exceedances within the Reliability Coordinator (RC) Area. This procedure also outlines tools used to perform the RC function, as well as mitigation options for resolving reliability issues affecting the Bulk Electric System (BES) in a timely manner.

1. Responsibilities

- Reliability Coordinator Operator

2. Scope/Applicability

- Reliability Coordination

3. Procedure Detail


3.1. Monitoring & Analysis Tools

This section provides a brief description of the Real-time monitoring and analysis tools RC West utilizes to perform RC functions for the RC Area. These tools are used for monitoring of all BES facilities, the status of Remedial Action Schemes (RAS), and non-BES facilities that impact the BES within the RC Area. RC West monitors facilities within its RC Area and neighboring RC Areas, and makes use of analysis tools to perform Real-time Assessments in order to identify facilities approaching SOL and IROL limits; and to identify SOL and IROL exceedances within the RC West Area.¹ If any of the listed real-time applications or tools fail, the RC operator ensures Real-Time Assessments are performed in a timely manner.²

- **Energy Management System (EMS)/Supervisory Control and Data Acquisition (SCADA) System**: Provides the RC operator with real-time monitoring and visibility of the status of BES transmission and generation facilities, RAS, non-BES facilities that impact the BES, and other critical real-time parameters for the reliable operation of the BES. The EMS system also provides alarming of critical events that affect the reliability of the BES.
- **Real-time State Estimator (RTSE)**: This is an application that performs numerical analysis of the real-time network model and data to determine the system's current condition. The RTSE can typically identify bad analog telemetry, estimate non-telemetered flows and voltages and determine real-time operating limit exceedances. The RTSE runs every 5 minutes, and provides a base-case solution used by RTCA and RT-VSA applications.

¹ IRO-002-5 R5.

² See RC0520-Loss of Monitoring and Analysis Tools

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

- **Real-time Contingency Analysis (RTCA)**: This is a primary Real-time Assessment application that runs every 5 minutes and automatically performs analyses of all identified single and credible multiple Contingencies that affect the RC Area.³ The RC operator utilizes the results to identify potential post-Contingency thermal or voltage exceedances on the system and to proactively develop mitigation plans to ensure reliability.
- **Real-time Voltage-Stability Analysis (RT-VSA)**: This application runs every 5 minutes and performs voltage-stability analyses of pre-determined stability limitations on the system to determine voltage-stability limits and margins for those interfaces.
- **Real-time Dynamic Stability Analysis (RT-DSA)**: This application runs every 15 minutes and performs transient stability analyses of pre-determined stability limitations on the system to identify transient-stability limits and margins for those interfaces.
- **Plant Information (PI) System**: This is a reliability tool used to process and provide visualization of complex real-time power system information in a user-friendly format for the RC operator to process and analyze. The tool provides real-time trending of power system parameters, which enhances situational awareness.
- **Dispatcher Load Flow (DLF) and Contingency Analysis (CA) Study Tools**: These applications are used by the RC operator to manually run load flow and Contingency analysis studies. The Real-time base case solution from RTSE can be loaded into these applications to be used as a starting point to run analysis of any scenario the operator wants to study.


3.2. Identifying SOL and IROL Exceedances

SOLs and IROLs used in Real-time are based on the RC West SOL Methodology (*CAISO Procedure RC0610: SOL Methodology for the Operations Horizon*), to ensure acceptable system performance pre- and post-Contingency. Operating Plans are documented in procedures, outage cards, next day studies and current day studies, and those limits are programmed into Real-time monitoring and analysis tools to aid the RC Operator in quickly determining if an SOL or IROL is being approached or exceeded.

When an SOL or IROL exceedance is identified, the RC Operator will work with and compare results with the responsible TOP(s). In instances where there is disagreement in results between entities, the RC Operator will take a conservative approach and operate to the most limiting results⁴.

³ IRO-008-2 R4

⁴ TOP-001-3 R18 (applicable to TOP)

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	


Reliability Coordinator Actions ⁵
<ul style="list-style-type: none"> • Monitor Real-time flows, voltages and status of RAS's on BES and non-BES facilities that impact the BES using the EMS alarms, SCADA, PI and RTSE to determine any of the following <i>SOL exceedance</i> conditions: <ol style="list-style-type: none"> 1. <u>Actual Thermal Limit Exceedance</u> – Real-time flows are exceeding the normal (continuous) rating for a monitored facility. 2. <u>Actual Voltage Limit Exceedance</u> – Real-time bus voltages are outside the normal (continuous) voltage limits for a monitored facility. 3. <u>Actual Stability Exceedance</u> – Real-time flows on an interface/path are exceeding a pre-determined stability limit. • Evaluate <i>results</i> from RTCA, RT-VSA, DLF and CA Study tools to determine any of the following <i>SOL exceedance</i> conditions: <ol style="list-style-type: none"> 1. <u>Post-Contingency Thermal Exceedance</u> – Validated Contingency analysis results indicate post-Contingency flows will exceed the highest Emergency (Short-Term) Rating for a monitored facility. 2. <u>Post-Contingency Voltage Exceedance</u> – Validated Contingency analysis results indicate post-Contingency bus voltage will be outside the Emergency (Short-Term) limits. 3. <u>Insecure Operating State</u> – Single or credible multiple Contingency will result in instability, cascading or uncontrolled separation. • Evaluate <i>results</i> from EMS, PI, RTCA, RT-VSA, DLF and CA Study tools to determine any of the following <i>IROL exceedance</i> conditions: <ol style="list-style-type: none"> 1. <u>IROL Exceedance</u> - Single or credible multiple Contingency will result in exceeding a pre-determined IROL limit.

3.3. Actual Thermal Limit Exceedances

When EMS alarms, SCADA, PI and/or RTSE indicates the actual real-time flows are exceeding the Normal (continuous) Rating for a monitored facility, take the following actions:

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Confirm the condition is real by checking flows and ratings with the TOP. <ul style="list-style-type: none"> ○ Validate the quality of the solution if the indication is from RTSE. ○ Operate to the <i>most limiting</i> results, in instances where there is disagreement in results between entities.

⁵ IRO-002-5 R5

	Reliability Coordinator Procedure	Procedure No. RC0310
		Version No. 1.5
		Effective Date 5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None

Reliability Coordinator Actions

- Determine** the *mitigation time* based on the associated time duration of the rating of the monitored facility.

Example: Line X-Y has a Normal Rating of 200 MW, a 4-hour Emergency Rating of 250 MW, and a 30-minute Emergency Rating of 300 MW.

If flow on Line X-Y is 240 MW:

- Mitigation Time = 4 hours. Flow must be reduced below 200 MW within 4 hours.

If flow on Line X-Y is 280 MW:


- Mitigation Time = 30 minutes. Flow must be reduced below 200 MW within 30 minutes, unless the TOP provides a less stringent Facility Ratings methodology.

If flow on Line X-Y exceeds 300 MW:

- Mitigation Time = None. Flow must be reduced below 200 MW immediately; unless the TOP provides a less stringent Facility Ratings methodology, which allows additional mitigation time once flows have been reduced below 300 MW.

- Evaluate** the results in *RTCA* to determine the impact of Contingencies on the monitored facility. *RTCA* might indicate the need for a more stringent mitigation time.
- Notify** the *impacted entity(ies)* of the exceedance⁶, if it impacts or potentially impacts neighboring TOPs, BAs, or RCs. If necessary, initiate a conference call with the affected parties.
- Evaluate** the *effectiveness* of mitigation actions being taken by the TOP to ensure exceedance will be mitigated within the required mitigation time. Options for mitigation include:
 - o **Re-dispatching** generation,
 - o **Reconfiguring** the transmission system,
 - o **Transferring** load out of load pocket,
 - o **Returning** scheduled outages,
 - o **Curtailling** schedules,
 - o **Using** phase shifters, series devices or HVDC to re-direct flows, and
 - o **Shedding** load (*Refer to RC0410 System Emergencies, Section 3.5 Load Shedding Instructions*).

⁶ IRO-008-2- R5

	Reliability Coordinator Procedure	Procedure No. RC0310
		Version No. 1.5
		Effective Date 5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Issue an Operating Instruction including the mitigation actions needed to return the system to within limits within a specified timeframe, if the mitigation actions taken, or being taken, are not appropriate, timely or sufficient (<i>Refer to RC0410 System Emergencies, Section 3.4 Operating Instructions</i>). • Notify any <i>impacted entity(ies)</i>, as deemed necessary by the RC Operator, once the condition has been mitigated.⁷ • Log all <i>communications</i> and <i>actions</i> taken to mitigate the exceedance.


3.4. Actual Voltage Limit Exceedances

When EMS alarms, SCADA, PI and/or RTSE indicates an actual bus voltage is outside the normal (continuous) voltage limits for a monitored facility, take the following actions:

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Confirm the condition is real by checking voltage and ratings with the TOP. <ul style="list-style-type: none"> ○ Validate the quality of the solution if the indication is from RTSE. ○ Operate to the <i>most limiting</i> results, in instances where there is disagreement in results between entities. • Determine the mitigation time based on the associated time duration of the rating of the monitored facility. • Evaluate the results in <i>RTCA</i> to determine the impact of Contingencies on the monitored facility. <i>RTCA</i> might indicate the need for a more stringent mitigation time. • Notify the <i>impacted entity(ies)</i> of the exceedance⁸, if the exceedance impacts or potentially impacts neighboring TOPs, BAs, or RCs. If necessary, initiate a conference call with the affected parties. • Evaluate the <i>effectiveness</i> of mitigation actions being taken by the TOP to ensure exceedance will be mitigated within the required mitigation time. Options for mitigation include: <ul style="list-style-type: none"> ○ Switching static reactive devices such as shunt capacitors and reactors in/out of service, ○ Re-dispatching dynamic reactive resources such as synchronous condensers, static VAR compensators (SVCs), HVDC Voltage Source Converters (VSCs), STATCOMs, etc., ○ Using transformer tap changers to redirect reactive flows,

⁷ IRO-008-2- R6

⁸ IRO-008-2- R5

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

Reliability Coordinator Actions
<ul style="list-style-type: none"> ○ Issuing revised voltage schedules to synchronized generation, ○ Re-dispatching generation/pumps, ○ Reconfiguring the transmission system, ○ Returning scheduled outages, ○ Curtailling schedules, ○ Using phase shifters, series devices or HVDC to re-direct flows, and ○ Shedding load (<i>Refer to RC0410 System Emergencies, Section 3.5 Load Shedding Instructions</i>). ● Issue an Operating Instruction including the mitigation actions needed to return the system to within limits within a specified timeframe, if the mitigation actions taken, or being taken, are not appropriate, timely or sufficient (<i>Refer to RC0410 System Emergencies, Section 3.4 Operating Instructions</i>). ● Notify any <i>impacted entity(ies)</i>, as deemed necessary by the RC Operator, once the condition has been mitigated.⁹ ● Log all <i>communications</i> and <i>actions</i> taken to mitigate the exceedance.

3.5. Actual Stability Limit Exceedances


Stability limits have been established for certain interfaces/paths based on Operations Planning Studies. These limits already have built-in distribution factors that account for the effect of identified single or credible multiple Contingencies. If a stability limit is exceeded, the expectation is a contingency could cause instability on the system.

Pre-identified stability limits would typically have an associated Operating Plan, Procedure, Process, or memo.

When EMS alarms, SCADA, PI and/or RTSE indicate the flow on an interface/path is exceeding a pre-determined stability limit, take the following actions:

Reliability Coordinator Actions
<ul style="list-style-type: none"> ● Confirm the <i>stability limit</i> and flows with the TOP. <ul style="list-style-type: none"> ○ Ensure the <i>revised limits</i> are <i>properly coordinated</i> with impacted entity(ies) if the TOP provides a revised stability limit. ○ Operate to the <i>most limiting</i> results, in instances where there is disagreement in results between entities.

⁹ IRO-008-2- R6

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Determine the <i>mitigation actions</i> and <i>mitigation time</i> from available pre-determined Operating Plans, Procedures, Processes, or memos for the limit. • Notify the <i>impacted entity(ies)</i> of the exceedance,¹⁰ if it impacts or potentially impacts neighboring TOPs, BAs, or RCs. If necessary, initiate a conference call with the affected parties. • Evaluate the effectiveness of mitigation actions being taken by the TOP to ensure exceedance will be mitigated within the required mitigation time. Options for mitigation include: <ul style="list-style-type: none"> ○ Re-dispatching generation, ○ Reconfiguring the transmission system, ○ Transferring load out of area with stability concern, ○ Returning scheduled outages, ○ Curtailling schedules, ○ Using phase shifters, series devices or HVDC to redirect flows, ○ Requesting unscheduled flow (USF) mitigation for qualified paths, and ○ Shedding load (<i>Refer to RC0410 System Emergencies, Section 3.5 Load Shedding Instructions</i>). • Issue an <i>Operating Instruction</i> with the mitigation actions to take to return the system to within limits within a specified timeframe, if the mitigation actions taken, or being taken, are not appropriate, timely or sufficient (<i>Refer to RC0410 System Emergencies, Section 3.4 Operating Instructions</i>). • Notify the <i>impacted entity(ies)</i> of the exceedance and the mitigation once completed,¹¹ if it impacts or potentially impacts neighboring TOPs, BAs, or RCs. If necessary, initiate a conference call with the affected parties. • Notify any <i>impacted entity(ies)</i>, as deemed necessary by the RC Operator, once the condition has been mitigated.¹² • Log all <i>communications</i> and <i>actions</i> taken to mitigate the exceedance.


3.6. RTCA Post-Contingency Thermal Exceedances

When RTCA results indicate calculated post-Contingency flow will exceed the highest Emergency (Short-Term) Rating for a monitored facility, an SOL is being exceeded, and actions must be taken to mitigate the exceedance *pre-Contingency*.

¹⁰ IRO-008-2- R5

¹¹ IRO-008-2- R5, R6

¹² IRO-008-2- R6


	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

Reliability Coordinator Actions
--

- **Validate** the *results* and *limits* used in RTCA:
 - **Check** RTSE solution quality.
 - **Verify** if any RAS(s) is associated with the contingency and the status.
 - **Use** a DLF and CA *study* tool as needed to verify the results.
 - **Verify** the contingency definition.
 - **Request** a study by the RCOE.
- **Verify** results with the TOP and determine whether the TOP's *Real-time Assessment* indicates the same exceedance.
 - **Operate to** the *most limiting* RTCA results in instances where there is disagreement on the results.
- **Refer** to Section 3.9, if results indicate any post-Contingency *exceedance greater than 125%*.
- **Notify** the *impacted entity(ies)* of the exceedance,¹³ if it impacts or potentially impacts neighboring TOPs, BAs, or RCs. If necessary, initiate a conference call with the affected parties.
- **Evaluate** the *effectiveness* of mitigation actions being taken by the TOP. Options for mitigation include:
 - **Re-dispatching** generation,
 - **Reconfiguring** the transmission system,
 - **Transferring** load out of area,
 - **Returning** scheduled outages,
 - **Curtailling** schedules, and
 - **Using** phase shifters, series devices or HVDC to re-direct flows.
- **Require** the TOP to provide a *viable post-Contingency mitigation plan within 30 minutes*¹⁴, if the pre-contingent exceedance cannot be mitigated by implementing the primary Operating Plan, which would include actions up to and including post-contingent load shedding. (Refer to Section 02:
 - Post-Contingency Mitigation Plans).
- **Issue** an *Operating Instruction* including the mitigation actions needed to return the system to within limits within a specified timeframe if the mitigation actions taken, or being taken, are not appropriate, timely or sufficient (*Refer to RC0410 System Emergencies, Section 3.4 Operating Instructions*).

¹³ IRO-008-2- R5

¹⁴ The 30-minute requirement starts when the RC Operator requests for the plan from the TOP.

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Notify any <i>impacted entity(ies)</i>, as deemed necessary by the RC Operator, once the condition has been mitigated.¹⁵ • Log all <i>communications</i> and <i>actions</i> taken to mitigate the exceedance.


3.7. RTCA Post-Contingency Voltage Exceedances

When RTCA results indicate calculated post-Contingency bus voltage will be outside the Emergency (Short-Term) limits for a monitored facility, an SOL is being exceeded, and actions must be taken to mitigate the exceedance *pre-Contingency*.

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Validate the <i>results</i> and <i>limits</i> used in RTCA: <ul style="list-style-type: none"> ○ Check RTSE solution quality. ○ Verify if any RAS(s) is associated with the contingency and the status. ○ Use DLF and CA <i>study</i> tool as needed to verify the results. ○ Verify the Contingency definition. ○ Request a study by the RCOE. • Verify results with the TOP and determine whether the <i>TOPs Real-time Assessment</i> indicates the same exceedance. <ul style="list-style-type: none"> ○ Operate to the <i>most limiting</i> RTCA results in instances where there is disagreement on the results. • Refer to Section 3.9, if calculated post-Contingency results indicate <i>potential voltage collapse</i>. • Notify the <i>impacted entity(ies)</i> of the exceedance¹⁶, if it impacts or potentially impacts neighboring TOPs, BAs, or RCs. If necessary, initiate a conference call with the affected parties. • Evaluate the <i>effectiveness</i> of mitigation actions being taken by the TOP. Options for mitigation include: <ul style="list-style-type: none"> ○ Switching static reactive devices such as shunt capacitors and reactors in/out of service, ○ Re-dispatching dynamic reactive resources such as synchronous condensers, static VAR compensators (SVCs), HVDC Voltage Source Converters (VSCs), etc. ○ Using transformer tap changers to redirect reactive flows,

¹⁵ IRO-008-2- R6

¹⁶ IRO-008-2- R5

	Reliability Coordinator Procedure	Procedure No. RC0310
		Version No. 1.5
		Effective Date 5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None

Reliability Coordinator Actions
<ul style="list-style-type: none"> ○ Issuing revised voltage schedules to synchronized generation, ○ Re-dispatching generation/pumps, ○ Reconfiguring the transmission system, ○ Transferring load out of collapse zone, ○ Returning scheduled outages, ○ Curtailling schedules, and ○ Using phase shifters, series devices or HVDC to re-direct flows. ● Require the TOP to provide a <i>viable post-Contingency mitigation plan</i>, which would include actions up to and including post-contingent load shedding <i>within 30 minutes</i>¹⁷, if the pre-contingent exceedance cannot be mitigated by implementing the primary Operating Plan (Refer to Section 0: Post-Contingency Mitigation Plans). ● Issue an Operating Instruction including the mitigation actions needed to return the system within limits within a specified timeframe if the mitigation actions taken, or being taken, are not appropriate, timely or sufficient (<i>Refer to RC0410 System Emergencies, Section 3.4 Operating Instructions</i>). ● Notify any <i>impacted entity(ies)</i>, as deemed necessary by the RC Operator, once the condition has been mitigated.¹⁸ ● Log all <i>communications</i> and <i>actions</i> taken to mitigate the exceedance.

3.8. IROL Exceedances


For each IROL identified one or more days prior to the current day, RC West has an Operating Plan that identifies actions the RC shall take or direct others to take (up to and including load shedding) which can be implemented in time to prevent the identified IROL exceedance within IROL T_v.¹⁹ The default IROL T_v is 30 minutes, unless conditions require a shorter T_v.

When EMS alarms, SCADA, PI and/or RTSE indicate the actual Real-time flow on an interface/path is exceeding a pre-determined IROL limit; or RTCA or RT-VSA indicates a single or credible multiple Contingency will result in exceeding a pre-determined IROL limit, take the following actions:

¹⁷ The 30-minute requirement starts when the RC Operator requests for the plan from the TOP.

¹⁸ IRO-008-2- R6

¹⁹ IRO-009-2 R1

	Reliability Coordinator Procedure	Procedure No. RC0310
		Version No. 1.5
		Effective Date 5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None

Reliability Coordinator Actions


- **Validate** the *results* and *limits* used in the application if the exceedance is based on RTCA or RT-VSA results:
 - **Check** *RTSE* solution quality
 - **Verify** if any *RAS(s)* is associated with the contingency and the status
 - **Use** *DLF* and *CA study* tool as needed to verify the results
- **Confirm** the *IROL limit* and flows with the TOP if the exceedance is based on real-time flows on an IROL interface/path,
 - **Ensure** the *revised limits* are *properly coordinated* with impacted BA/TOP and the RC if the TOP provides a revised IROL limit.
 - **Operate** to the *most limiting* IROL and T_v , in instances where there is disagreement in results between entities.
- **Review** the applicable *IROL Operating Plan*, and **determine** the required *mitigation actions*.²⁰
- **Determine** (from the TOP) the amount of time needed to shed load, if required.
- **Notify** the *impacted entity(ies)* of the exceedance²¹, if it impacts or potentially impacts neighboring TOPs, BAs, or RCs. If necessary, initiate a conference call with the affected parties.
- **Evaluate** the *effectiveness* of mitigation actions being taken by the TOP to ensure exceedance will be *mitigated within 30 minutes* (IROL T_v).
- **Issue** an *Operating Instruction* without delay, if the actions being taken by the TOP will not resolve the exceedance within the 30-minute T_v .
- **Issue** an Operating Instruction, without delay, to **shed load** (within the amount of time the TOP requires to accomplish it) to ensure the exceedance is resolved within the 30-minute T_v ²², if further evaluation of the mitigation actions indicates the exceedance will not be mitigated within the 30-minute T_v (*Refer to RC0410 System Emergencies, Section 3.4 Operating Instructions*).
- **Notify** any *impacted entity(ies)* **in accordance with applicable IROL Operating Guide**.²³
- **Log** all *communications* and *actions* taken to mitigate the exceedance.

²⁰ IRO-009-2 R2

²¹ IRO-008-2- R5

²² IRO-009-2 R3

²³ IRO-008-2- R6


	Reliability Coordinator Procedure	Procedure No. RC0310
		Version No. 1.5
		Effective Date 5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None

3.9. Insecure Operating State

When RTCA, RT-DSA or RT-VSA indicates a single or credible multiple Contingency will result in *instability, cascading outages or voltage collapse*, which was not identified one or more days prior to the current day,²⁴ the system is considered to be in an insecure operating state once the condition is verified. In this scenario, although an IROL was not previously identified, the exceedance of an unidentified IROL cannot be ruled out. Therefore, System Operators should focus on communicating **the urgency to the impacted BA/TOP(s) and RC(s) and returning** the system to a secure operating state **without delay**. A return to a secure operating state should be based on an updated study and mitigating actions up to and including shedding load. An after-the-fact analysis should explore whether an IROL and/or an area specific operating guide should be established for future similar real-time conditions.

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Validate the results and limits used in the solution: <ul style="list-style-type: none"> ○ Check <i>RTSE</i> solution quality. ○ Verify if any <i>RAS(s)</i> is associated with the Contingency and the status. ○ Verify the contingency definition. ○ Request a study by the RCOE. • Run a cascading test, if RTCA indicates exceedance greater than <i>125%</i> of the <i>highest Emergency Rating</i> of a monitored facility <i>or</i> the facility's relay trip setting (if known), whichever is lower. <div style="border: 1px solid black; padding: 10px; margin-top: 10px;"> <p><u>Cascading Test</u></p> <ol style="list-style-type: none"> 1. Load the <i>RTSE</i> case into the CA study tool. 2. Take out of service the contingent element and the monitored element. 3. Run power flow study. 4. Determine if any facilities will be loaded above <i>125%</i> of the highest Emergency rating or the facility's relay trip setting (if known), whichever is lower. 5. Take out of service any facility that meets the criteria in step 4. 6. Repeat steps 3 to 5 until no facility meets the criteria in step 4, or until the solution diverges. <p>Note: <i>A diverged solution may indicate a potential voltage collapse.</i></p> </div>

²⁴ IRO-009-2 R1

	Reliability Coordinator Procedure	Procedure No. RC0310
		Version No. 1.5
		Effective Date 5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None


Reliability Coordinator Actions	
<ul style="list-style-type: none"> • Verify results with the TOP and determine whether the <i>TOPs Real-time Assessment</i> indicates the same condition. <ul style="list-style-type: none"> ○ Operate to the <i>most limiting</i> RTCA results in instances where there is disagreement on the results. • Declare an insecure operating state, via GMS without intentional delay <u>as soon as</u> instability, cascading outages, or voltage collapse indications are verified (<i>Refer to RC0310C Guidelines for Declaring Insecure Operating State</i>). If necessary, initiate a conference call with the affected party(s). • Require the TOP to start taking <i>mitigation actions</i>. The insecure operating state must be mitigated <i>within 30 minutes</i> from the time the insecure operating state was declared. • Evaluate the <i>effectiveness</i> of mitigation actions being taken by the TOP. Options for mitigation include: <ul style="list-style-type: none"> ○ Re-dispatching generation, ○ Reconfiguring the transmission system, ○ Transferring load out of the zone, ○ Returning scheduled outages, ○ Curtailling schedules, ○ Using phase shifters, series devices or HVDC to re-direct flows, ○ Requesting unscheduled flow (USF) mitigation for qualified paths, and ○ Shedding load (<i>Refer to RC West RC0410 System Emergencies, Section 3.5: Load Shedding</i>). • Issue an Operating Instruction without delay, to shed load (within the amount of time the TOP requires to accomplish it) to ensure the insecure operating state is resolved within the 30-minute timeframe, if further evaluation of the mitigation actions indicates the insecure operating state will not be mitigated within the 30-minute timeframe²⁵ (<i>Refer to RC West Operating Procedure RC0410 System Emergencies, Section 3.4 Operating Instructions</i>). • Notify impacted BA(s), TOP(s) and RC(s) via GMS once the condition has been mitigated.²⁶ • Log all <i>communications</i> and <i>actions</i> taken to mitigate the insecure operating state. 	

3.10. Unsolved Contingencies in RTCA

A Contingency that fails to converge in RTCA may be an indication of a potential voltage collapse or other infeasible operating state that might occur if the Contingency actually happened.

²⁵ IRO-009-2 R3

²⁶ IRO-008-2- R6

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

On the other hand, an unsolved Contingency might also indicate a modelling error or other data problem, which could degrade the quality of the base case. Such errors could degrade the quality of the results for all Contingencies, even those that solve successfully²⁷. If left unresolved, situational awareness of potential SOL or IROL violations is compromised until personnel can identify the cause of the unsolved Contingency²⁸.

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Request RCOE and EMS <i>Engineering support</i> to investigate and resolve the causal factors related to input data, the model or the RTCA application itself. • Run <i>study</i> of the Contingency in question using DLF and CA study tools • Verify results with the TOP and determine whether the <i>TOPs Real-time Assessment</i> indicates the same exceedance. <ul style="list-style-type: none"> ○ Operate to the <i>most limiting</i> results in instances where there is disagreement. • Assume a <i>conservative approach</i> because the post-Contingency operating state is most likely unstable or in a voltage collapse. Refer to Section 3.10: Unsolved Contingencies in RTCA • Insecure Operating State. • Log each <i>unsolved Contingency</i>, verbal discussions, related studies and <i>actions</i> taken to resolve it.


3.11. Islanding Conditions

RC West RTCA will identify islands greater than 100 MW that will result from a single or credible multiple Contingency. Contingencies creating islands are not SOLs or IROLs; however, the RC will notify the impacted TOPs, BAs and RCs for situational awareness.

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Validate the <i>islanding</i> condition in RTCA. <ul style="list-style-type: none"> ○ Verify the Contingency definition ○ Verify the topology in the model. ○ Use DLF and CA <i>study</i> tool as needed to verify the results. ○ Request a study by the RCOE. • Notify the impacted TOPs, BAs and RCs of the Contingency creating an island for situational awareness.

²⁷ IRO-018-1 R2.3.

²⁸ NATF Operator Tools & Environment – Contingency Analysis Practices

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

3.12. Post-Contingency Mitigation Plans

A TOP must provide a viable post-Contingency mitigation plan if it is unable to mitigate an SOL pre-Contingency in a timely manner, due to generation startup, ramp rate or other constraints; or if there are no automatic post-Contingency actions such as RAS/SPS that can resolve the issue. A post-Contingency mitigation plan is considered viable and acceptable by the RC when:


- The limitation in question is not an IROL, stability limit or Insecure Operating State.
- The plan can be implemented in a timely manner without adverse reliability consequences.
- The RC confirms the plan will resolve the reliability issue in a timely manner.
- All impacted BAs, TOPs and RCs agree with the plan.

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Ensure the <i>TOP</i> understands the limiting contingency and monitored facility. • Require the <i>TOP</i> to provide the <i>specifics</i> of the plan and the <i>time to implement</i>. • Ensure the plan meets the four criteria described above. • Request a study by the RCOE if needed. • Log all <i>communications</i> and the specifics of the <i>plan</i>.

3.13. Change of RAS Status

Accurate RAS monitoring is necessary to perform Real-time Assessments in order to identify facilities approaching SOL and IROL limits; and to identify SOL and IROL exceedances within the RC West Area. The applicable TOP shall notify the RC if there is a change in RAS status according to RC0130 Reporting Requirements for Real-Time Events.

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Receive notification from EMS, GMS, or phone that there has been a change in status for one or more RAS. • Verify with the <i>TOP</i> that the RAS status has changed, and the reason for the change. • Request the TOP to submit an OMS outage if the RAS is forced out of service for more than 30 minutes. • Notify the RCOE of the change in RAS status. • Notify the impacted TOPs, BAs and RCs of the RAS status change for situational awareness. • Verify that the RAS modeling is correctly reflected in RTCA.

	Reliability Coordinator Procedure	Procedure No. RC0310
		Version No. 1.5
		Effective Date 5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Request a study by the RCOE if needed. • Log all <i>communications</i> and the specifics of the change in RAS status.

3.14. Unscheduled Flow Relief for Qualified Paths

Excessive unscheduled flow on qualified WECC transmission paths can be mitigated following procedures outlined in the Western Interconnection Unscheduled Flow Mitigation Plan. When the RC operator receives a request for the operation of Qualified Controllable Devices (phase shifters) from a Qualified Path operator within the RC West footprint, RC West will assess the potential reliability impacts on the RC West Area, and coordinate the operation of these devices with **SPP West RC**.

The Qualified Path operator is responsible for initiating a request for mitigating unscheduled flow on its path. In accordance with IRO-006-WECC-2, RC West must approve or deny requests for schedule curtailments (Step 4) for unscheduled flow mitigation within 5 minutes of receiving the request²⁹. The Qualified Paths and Controllable Devices are listed in RC0310B.


3.14.1. Requests for Operation of Qualified Controllable Devices (Step 2 or 3)

RC West will assess the potential impacts of operating Qualified Controllable Devices on the RC West Area, and will coordinate with neighboring RCs to ensure that operation of the devices does not cause reliability issues anywhere within the Western Interconnection.

In accordance with the Western Interconnection Unscheduled Flow Mitigation Plan, it is expected that before invoking Step 3 or higher, the path operator has ensured that actual flow on the path is at a level greater than or equal to 95 percent of the Path's TTC, with actual flows greater than the scheduled flows by an amount of 2 percent of the TTC or 25 MW, whichever is greater.

Reliability Coordinator Actions
<ul style="list-style-type: none"> • Evaluate ACE of applicable BA(s) to determine if ACE is significantly contributing to unscheduled flow on the Qualified Path. <ul style="list-style-type: none"> ○ If ACE is contributing to unscheduled flow on the path, issue <i>Operating Instruction</i> to affected BA(s) within the RC West Area to return ACE to normal, or coordinate with neighboring RC if the BA(s) is within the neighboring RC Area. • Evaluate the <i>potential reliability impacts</i> of operating the requested Controllable Devices. <ul style="list-style-type: none"> ○ Coordinate with SPP West RC to ensure that movement of the Controllable Devices will not adversely impact or create an SOL/IROL exceedance in the SPP West RC Area or anywhere in the Western Interconnection.

²⁹ IRO-006-WECC-2 R1.

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	


Reliability Coordinator Actions
<ul style="list-style-type: none"> ○ Identify <i>outages</i> that could be impacting the Path TTC limits and in coordination with the TOP assess options to return the facilities to service, if deemed necessary. ● Determine the <i>optimal tap settings</i> for the Qualified Controllable Devices in coordination with SPP West RC (<i>Refer to RC9010 Unscheduled Flow Mitigation on Qualified Paths</i>). ● If movement of the devices will overload another Qualified Path (Competing Paths), and the RC Operator determines schedule curtailments (Step 4) can be avoided: <ul style="list-style-type: none"> ○ Initiate a <i>conference call</i> with SPP West RC and the path operators for the competing paths, if necessary. ○ Coordinate with SPP West RC to determine tap settings that will maximize relief on both paths without adverse reliability impacts, prior to operating the Qualified Controllable Devices. ○ Coordinate movement of tap changes in a gradual manner to observe flow changes from each tap change. ● Coordinate with SPP West RC to issue Operating Instructions to the operators of Qualified Controllable Devices in its area (Note: <i>phase shifter operation should be avoided during ramps unless required to mitigate a System Emergency</i>)³⁰. ● Notify all BAs and TOPs within the RC West Area via the Grid Messaging System (GMS). ● Monitor <i>system conditions</i> to ensure that operation of Qualified Controllable Devices is not resulting in unacceptable system performance. ● Log all <i>communications</i> and <i>actions</i> taken.

3.14.2. Requests for Schedule Curtailments (Step 4)

If schedule curtailments are required to mitigate unscheduled flow because the previous Steps are inadequate, the Path Operator is expected to coordinate with the RC Operator to determine the amount of relief needed, and re-issue a request each hour until relief is no longer required on the path. The RC Operator will inform **impacted RC(s)** of the MW amount of reduction approved and ensure that the approval of the MW reduction is issued prior to 30 minutes before the start of the hour for which it is to be in effect.

Reliability Coordinator Actions
<ul style="list-style-type: none"> ● Evaluate <i>ACE</i> of applicable BA(s) to determine if ACE is significantly contributing to unscheduled flow on the Qualified Path.

³⁰ Shiprock and Waterflow PSTs are Qualified Controllable Devices operated by TOPs in **SPP West RC** area.

	Reliability Coordinator Procedure	Procedure No. RC0310
		Version No. 1.5
		Effective Date 5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None

Reliability Coordinator Actions
<ul style="list-style-type: none"> ○ If ACE is contributing to unscheduled flow on the path, issue Operating Instruction to affected BA(s) within the RC West Area to return ACE to normal, or coordinate with neighboring RC if the BA(s) is within the neighboring RC Area. ● Evaluate the <i>potential reliability impacts</i> of the schedule curtailments. <ul style="list-style-type: none"> ○ Identify <i>outages</i> that could be impacting the Path TTC limits and in coordination with the TOP assess options to return the facilities to service, if deemed necessary. ● Determine the amount of <i>relief required</i> on the Qualified Path, in coordination with the path operator. ● If there is a competing request for relief from another Qualified Path (Competing Path) in the SPP West RC Area: <ul style="list-style-type: none"> ○ Initiate a conference call with SPP West RC and the path operators for the competing paths. ○ Determine the amount of relief required on the competing paths, in coordination with SPP West RC and the path operators. ● Approve the <i>request</i> for schedule curtailments prior to 30 minutes before the start of the hour for which it is to be in effect. ● Notify impacted RC(s) of the MW amount of reduction approved. ● Notify all BAs and TOPs within the RC West Area via the Grid Messaging System (GMS). ● Monitor <i>system conditions</i> to ensure that the schedule reduction is not resulting in unacceptable system performance. ● Log all <i>communications</i> and <i>actions</i> taken.

4. Supporting Information


Operationally Affected Parties

Shared with Public

References

NERC Requirements	IRO-002-6 R5; IRO-006-5 R1; IRO-006-WECC-2 R1; IRO-008-2 R4, R5, R6; IRO-009-2 R1, R2, R3; IRO-018-1 R2.3.
BA/TOP Operating Procedure	

*This document is controlled when viewed electronically.
 When downloaded or printed, this document becomes UNCONTROLLED.*


	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

Other References	RC0520 Loss of Monitoring and Analysis Tools RC0410 System Emergencies RC0610 SOL Methodology for the Operations Horizon RC9010 Unscheduled Flow Mitigation on Qualified Paths NATF Operator Tools & Environment – Contingency Analysis Practices Western Interconnection Unscheduled Flow Mitigation Plan
------------------	---


Definitions

The following terms capitalized in this Operating Procedure are in accordance with the NERC Glossary, and/or otherwise when used are as defined below:


Term	Description
Energy Management System (EMS)	An application used to perform real-time monitoring, analysis, real-time coordination and generation control. Reliability entities provide telemetered data to CAISO EMS. Generators and CAISO Market Participants receive data and control signals from CAISO EMS.
Inter-Control Center Communication Protocol (ICCP)	Provides a standard format for exchanging data between system and / or entities.
PT RTCA	Backup RTCA tool

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

Term	Description
Remedial Action Schemes (RAS)	<p>A scheme designed to detect predetermined System conditions and automatically take corrective actions that may include, but are not limited to, adjusting or tripping generation (MW and Mvar), tripping load, or reconfiguring a System(s). RAS accomplish objectives such as:</p> <ul style="list-style-type: none"> • Meet requirements identified in the NERC Reliability Standards • Maintain Bulk Electric System (BES) stability • Maintain acceptable BES voltages • Maintain acceptable BES power flows • Limit the impact of Cascading or extreme events <p>The following do not individually constitute a RAS:</p> <ul style="list-style-type: none"> • Protection Systems installed for the purpose of detecting Faults on BES Elements and isolating the faulted Elements • Schemes for automatic underfrequency load shedding (UFLS) and automatic undervoltage load shedding (UVLS) comprised of only distributed relays • Out-of-step tripping and power swing blocking • Automatic reclosing schemes • Schemes applied on an Element for non-Fault conditions, such as, but not limited to, generator loss-of-field, transformer top-oil temperature, overvoltage, or overload to protect the Element against damage by removing it from service
System Operating Limit (SOL)	<p>The value (such as MW, Mvar, amperes, frequency or volts) that satisfies the most limiting of the prescribed operating criteria for a specified system configuration to ensure operation within acceptable reliability criteria. System Operating Limits are based upon certain operating criteria. These include, but are not limited to:</p> <ul style="list-style-type: none"> • Facility Ratings (applicable pre- and post-Contingency Equipment Ratings or Facility Ratings) • Transient stability ratings (applicable pre- and post-Contingency stability limits) • Voltage stability ratings (applicable pre- and post-Contingency voltage stability) • System voltage limits (applicable pre- and post-Contingency voltage limits)

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	


Term	Description
Interconnection Reliability Operating Limit (IROL)	A System Operating Limit that, if violated, could lead to instability, uncontrolled separation, or Cascading outages that adversely impact the reliability of the Bulk Electric System.
IROL Tv	The maximum time that an Interconnection Reliability Operating Limit can be violated before the risk to the interconnection or other Reliability Coordinator Area(s) becomes greater than acceptable. Each Interconnection Reliability Operating Limit's Tv shall be less than or equal to 30 minutes.
SCADA	Supervisory Control and Data Acquisition
Reliability Coordinator (RC) Area	The collection of generation, transmission, and loads within the boundaries of the Reliability Coordinator. Its boundary coincides with one or more Balancing Authority Areas.
Normal (Continuous) Ratings	The rating as defined by the equipment owner that specifies the level of electrical loading, usually expressed in megawatts (MW) or other appropriate units that a system, facility, or element can support or withstand through the daily demand cycles without loss of equipment life.
Emergency (Short-Term) Rating	The rating as defined by the equipment owner that specifies the level of electrical loading or output, usually expressed in megawatts (MW) or Mvar or other appropriate units, that a system, facility, or element can support, produce, or withstand for a finite period. The rating assumes acceptable loss of equipment life or other physical or safety limitations for the equipment involved.
Operating Plan	A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.
Operating Procedure	A document that identifies specific steps or tasks that should be taken by one or more specific operating positions to achieve specific operating goal(s). The steps in an Operating Procedure should be followed in the order in which they are presented, and should be performed by the position(s) identified. A document that lists the specific steps for a system

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

Term	Description
	operator to take in removing a specific transmission line from service is an example of an Operating Procedure.
Operating Process	A document that identifies general steps for achieving a generic operating goal. An Operating Process includes steps with options that may be selected depending upon Real-time conditions. A guideline for controlling high voltage is an example of an Operating Process.
Real-time Assessment	An evaluation of system conditions using Real-time data to assess existing (pre-Contingency) and potential (post-Contingency) operating conditions. The assessment shall reflect applicable inputs including, but not limited to: load, generation output levels, known Protection System and Special Protection System status or degradation, Transmission outages, generator outages, Interchange, Facility Ratings, and identified phase angle and equipment limitations. (Real-time Assessment may be provided through internal systems or through third-party services.)
Contingency	The unexpected failure or outage of a system component, such as a generator, transmission line, circuit breaker, switch or other electrical element.

Version History

Version	Change	Date
1.0	Approved by Steering Committee.	9/26/18
1.1	Added section 3.13 on USF relief for qualified paths, and appendix RC0310B on list of qualified paths and controllable devices. Minor clarifications to Section 3.3, 3.6, 3.7 and 3.12. Reviewed by RTWG.	1/16/19
1.2	Due to retirement of <i>WECC Unscheduled Flow Reduction Guideline</i> document, changed references in section 3.14 to <i>Western Interconnection Unscheduled Flow Mitigation Plan</i> . Clarified example in section 3.3 on actual thermal limit exceedances. Added clarification language to section 3.9 to address insecure operating state. Added new section 3.13 for Change in RAS Status. Clarified requirement to approve/deny USF requests within 5 minutes in section 3.14.	4/08/19

	Reliability Coordinator Procedure	Procedure No.	RC0310
		Version No.	1.5
		Effective Date	5/12/2020
Mitigating SOL and IROL Exceedances		Distribution Restriction: None	

Version	Change	Date
1.3	Fixed reference errors in Sections 3.6 and 3.7. Added new appendix RC0310C Guidelines for Declaring Insecure Operating State.	05/01/19
1.4	Minor updates for 11/1, replaced all CAISO RC references to RC West. Approved by RTWG on 06/21/19.	11/01/19
1.5	Section 3.9: Removed references of RCIS. Replaced Peak RC with SPP West RC or impacted RC. Updated NERC IRO-002 reference. Clarified RC Operator notification requirements after an exceedance is mitigated in Sections 3.3 to 3.8.	5/12/20

5. Periodic Review Procedure

Review Criteria & Incorporation of Changes

There are no specific review criteria identified for this document.

Frequency

Review at least once every three years.

Appendix

RC0310A – Non-IROL Stability Limits (Restricted)

RC0310B - Qualified Paths and Controllable Devices (Restricted)

RC0310C Guidelines for Declaring Insecure Operating State (Restricted)