

4.11.9 Equipment Installation and Access Rights to SUDC Facilities

4.11.9.1 Installation of Facilities

The CAISO and the SUDC shall each have the right on reasonable notice to install or to have installed equipment (including metering equipment) or other facilities on the property of the other, to the extent that such installation is necessary for the installing party to meet its service obligations unless to do so would have a negative impact on the reliability of the service provided by the party owning the property. The CAISO and the SUDC shall enter into agreements governing the installation of such equipment or other facilities containing customary, reasonable terms and conditions.

4.11.9.2 Access to Facilities

The SUDCs shall grant, free of charge, the CAISO reasonable access to SUDC facilities for purposes of inspection, repair, maintenance, or upgrading of facilities installed by the CAISO on the SUDC's system, provided that the CAISO must provide reasonable advance notice of its intent to access SUDC facilities and opportunity for SUDC staff to be present. Such access shall not be provided unless the parties mutually agree to the date, time and purpose of each access. Agreement on the terms of the access shall not be unreasonably withheld.

4.11.9.3 Access During Emergencies

Notwithstanding any provision in this Section 4.11 the CAISO may have access, without giving prior notice, to any SUDC's equipment or other facilities during times of a System Emergency.

4.11.9.4 Access for Audit Functions

Notwithstanding any provision in this Section 4.11 the CAISO may have access, without giving prior notice, to any SUDC's equipment or other facilities where the CAISO has a reasonable basis to believe the SUDC has failed to comply with the SUDC Operating Agreement, applicable CAISO Tariff or CAISO Protocol provisions and access is required to conduct an audit to gather relevant facts.

4.12 Relationship of CAISO and Resource-Specific System Resources

The CAISO shall not accept Bids for any Resource-Specific System Resource otherwise than through a Scheduling Coordinator. The CAISO shall further not be obligated to provide Bid Cost Recovery to any Resource-Specific System Resource unless the relevant Resource-Specific System Resource owner undertakes in writing, by entering into a Resource-Specific System Resource Agreement, to comply with

all applicable provisions of this CAISO Tariff as they may be amended from time to time, including, without limitation, the applicable provisions of this Section 4.12. Except as otherwise provided in this Section 4.12, Resource-Specific System Resources shall have the same rights and obligations as other System Resources, including the ability to have Bids submitted for either full or partial output from the RSSR, provided that a Bid must be for at least the Minimum Load of the resource in order to be eligible for Bid Cost Recovery.

4.12.1 General Responsibilities

4.12.1.1 Operate Pursuant to Relevant Provisions of CAISO Tariff

Resource-Specific System Resource owners shall operate, or cause their facilities to be operated, in accordance with the relevant provisions of this CAISO Tariff, including but not limited to the following.

- (i) A Resource-Specific System Resource shall only be eligible for Bid Cost Recovery if the Resource-Specific System Resource has complied with a Start-Up Instruction or Dispatch Instruction issued by the CAISO as specified in Section 11.8.
- (ii) In order to be eligible for Bid Cost Recovery pursuant to Sections 30.4 and 30.5.2.4, a Resource-Specific System Resource owner shall ensure that its Scheduling Coordinator makes an election for Start-Up Costs and Minimum Load Costs.
- (iii) A Resource-Specific System Resource owner shall ensure that any Ancillary Services Bids submitted by its Scheduling Coordinator are submitted in accordance with Section 30.5.2.6.
- (iv) Owners of Dynamic Resource-Specific System Resources that are Resource Adequacy Resources shall comply with additional availability requirements to the extent required by Section 40.6.5.1.
- (v) Each Resource-Specific System Resource owner shall immediately inform the CAISO, through its respective Scheduling Coordinator and using the CAISO's outage management system as described in Section 9, of any change or potential change in the current status of any Resource-Specific System Resource that may affect a submitted Bid. This will include, but not be limited to, any change in status of equipment that could affect the maximum output of a Resource-Specific System Resource, the Minimum Load

of a Resource-Specific System Resource, or the ability of a Resource-Specific System Resource to provide Ancillary Services in accordance with its Bid.

- (vi) In the event that a Resource-Specific System Resource owner cannot meet its Generation schedule as specified in the Day-Ahead Schedule, or comply with a Dispatch Instruction, whether due to a Resource-Specific System Resource trip or the loss of a piece of equipment causing a reduction in capacity or output, the Resource-Specific System Resource owner shall notify the CAISO, through its Scheduling Coordinator, at once. If a Resource-Specific System Resource owner will not be able to meet a time commitment or requires the cancellation of a Resource-Specific System Resource Start-Up, it shall notify the CAISO, through its Scheduling Coordinator, at once.

4.12.1.2 Operate Pursuant to Relevant Operating Procedures

Resource-Specific System Resource owners shall operate, or cause their Resource-Specific System Resources and associated facilities to be operated, in accordance with the relevant Operating Procedures and Business Practice Manuals established by the CAISO.

4.12.2 Identification of Resource-Specific System Resources

Each Resource-Specific System Resource owner shall provide data identifying each of its Resource-Specific System Resources and such information regarding the capacity and the operating characteristics of the Resource-Specific System Resource as may be reasonably requested from time to time by the CAISO. All information provided to the CAISO regarding the operation and technical constraints in the Master File shall be accurate and actually based on physical characteristics of the resource. Pursuant to Sections 8.9 and 8.10, the CAISO may verify, inspect and test the capacity and operating characteristics of the resource provided to the CAISO.

4.12.3 Telemetry Data to Demonstrate Compliance

The Resource-Specific System Resource owner shall provide SCADA data by telemetry to the CAISO EMS at the Resource-Specific System Resource owner's expense in order to demonstrate compliance with CAISO Start-Up Instructions in order to be eligible for BCR. Telemetry data from Dynamic Resource-Specific System Resources shall be provided in accordance with the requirements of the CAISO's Dynamic Scheduling Protocol in Appendix X. For Non-Dynamic Resource-Specific System Resources,

the Resource-Specific System Resource owner shall have the option of providing the required telemetry data by transmittal directly to the CAISO EMS in accordance with the CAISO's standards for direct telemetry or by means of transmittal to the CAISO EMS through the EMS of its Host Balancing Authority Area by use of the inter-control center communications protocol (ICCP).

4.12.4 Recordkeeping

Resource-Specific System Resource owners shall provide to the CAISO such information and maintain such records as are reasonably required by the CAISO to implement the provisions of the CAISO Tariff applicable to Resource-Specific System Resources.

4.12.5 Access Rights

A Resource-Specific System Resource owner shall, at the request of the CAISO and upon reasonable notice, provide access to its facilities and records (including those relating to communications and telemetry) as necessary to permit the CAISO to perform such testing as is necessary to test the accuracy of any telemetry equipment upon which the Resource-Specific System Resource owner's performance is measured.

4.13 DRPs, RDRRs, and PDRs

4.13.1 Relationship Between CAISO and DRPs

The CAISO shall only accept Bids for Energy from Reliability Demand Response Resources, and shall only accept Bids for Energy or Ancillary Services from Proxy Demand Resources, Submissions to Self-Provide Ancillary Services from Proxy Demand Resources, or submissions of Energy Self-Schedules from Proxy Demand Resources that have provided Submissions to Self-Provide Ancillary Services, if such Reliability Demand Response Resources or Proxy Demand Resources are represented by a Demand Response Provider that has entered into a Demand Response Provider Agreement with the CAISO, has accurately provided the information required in the Demand Response System, has satisfied all Reliability Demand Response Resource or Proxy Demand Resource registration requirements, and has met standards adopted by the CAISO and published on the CAISO Website. Reliability Demand Response Resources and Proxy Demand Resources may not participate in a Distributed Energy Resource Aggregation. The CAISO shall not accept submitted Bids for Energy or Ancillary Services from a Demand Response Provider other than through a Scheduling Coordinator, which Scheduling

Coordinator may be the Demand Response Provider itself or another entity. Proxy Demand Response Resources providing Ancillary Services must submit Meter Data for the interval preceding, during, and following the Trading Interval(s) in which they were awarded Ancillary Services for the purposes of determining settlement pursuant to Section 8.10.8.

4.13.2 Applicable Requirements for RDRRs, PDRs and DRPs

A single Demand Response Provider must represent each Reliability Demand Response Resource or Proxy Demand Resource and may represent more than one (1) Reliability Demand Response Resource or Proxy Demand Resource. Each Reliability Demand Response Resource or Proxy Demand Resource that is not within a MSS must be associated with a single Load Serving Entity and a single Utility Distribution Company, and each Reliability Demand Response Resource or Proxy Demand Resource that is within a MSS must be associated with a single Load Serving Entity. A Demand Response Provider may be, but is not required to be, a Load Serving Entity or a Utility Distribution Company. Each Reliability Demand Response Resource or Proxy Demand Resource is required to be located in a single Sub-LAP. All underlying Locations of a Reliability Demand Response Resource or Proxy Demand Resource must be located in a single Sub-LAP. Each Demand Response Provider is required to satisfy registration requirements and to provide information to allow the CAISO to establish performance evaluation methodologies in accordance with Section 4.13.4 and the applicable Business Practice Manuals. Registration of a Location for participation in Reliability Demand Response Resources or Proxy Demand Resources requires the approval of the CAISO resulting from its registration process. As part of the submitted registration process, both the appropriately Demand Response Provider designated Load Serving Entity and Utility Distribution Company will have an opportunity to review the registration Location detail and provide comments with regard to its accuracy. Disputes regarding the acceptances or rejections of a registration of a Location shall be undertaken with the applicable Local Regulatory Authority and shall not be arbitrated or in any way resolved through a CAISO dispute resolution mechanism or process. A Location cannot be registered to both a Reliability Demand Response Resource and a Proxy Demand Resource for the same Trading Day.

4.13.3 Identification of RDRRs and PDRs

Each Demand Response Provider shall provide data, as described in the Business Practice Manual, identifying each of its Reliability Demand Response Resources or Proxy Demand Resources and such information regarding the capacity and the operating characteristics of the Reliability Demand Response Resource or Proxy Demand Resource as may be reasonably requested from time to time by the CAISO. All information provided to the CAISO regarding the operational and technical constraints in the Master File shall be accurate and actually based on physical characteristics of the resources.

4.13.4 Performance Evaluation Methodologies for PDRs and RDRRs

The following methodologies may be utilized to calculate Customer Load Baselines and Demand Response Energy Measurements for Proxy Demand Resources and Reliability Demand Response Resources. Proxy Demand Resources and Reliability Demand Response Resources consisting of residential End Users may elect to use the ten-in-ten methodology, metering generator output methodology, control group methodology, five-in-ten methodology, or weather matching methodology. Proxy Demand Resources and Reliability Demand Response Resources consisting of non-residential End Users may elect to use the ten-in-ten methodology, metering generator output methodology, control group methodology, or weather matching methodology. Proxy Demand Resources providing Ancillary Services must submit Meter Data for the intervals immediately preceding, during, and following the Trading Interval(s) in which the Proxy Demand Response Resources were awarded Ancillary Services. As specified in the Business Practice Manual, the CAISO will retain authority to calculate or correct Customer Load Baselines and Demand Response Energy Measurements for those resources that used the CAISO's Demand Response System, until all relevant metering, settlement, and correction windows have lapsed since the CAISO retired its ability to calculate on behalf of Scheduling Coordinators in the Demand Response System.

4.13.4.1 Ten-in-Ten Load Baseline Methodology

Scheduling Coordinators will be responsible for calculating the Customer Load Baseline for Proxy Demand Resources or Reliability Demand Response Resources using the ten-in-ten methodology as follows:

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (a) Meter Data will be collected for the Proxy Demand Resource or Reliability Demand Response Resource for calendar days preceding the Trading Day on which the Demand Response Event occurred. Where the Proxy Demand Resource or Reliability Demand Response Resource uses behind-the-meter generation to offset Demand, the Proxy Demand Resource or Reliability Demand Response Resource may elect to provide, at all times, Meter Data reflecting the total gross consumption, independent of any offsetting Energy produced by behind-the-meter generation. The calendar days for which the Meter Data will be collected will be determined by working sequentially backwards from the Trading Day under examination up to a maximum of forty-five (45) calendar days prior to the Trading Day, including only business days if the Trading Day is a business day, including only non-business days if the Trading Day is a non-business day, and excluding calendar days on which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services, except as discussed below. The collection of Meter Data for this purpose stops upon reaching the target number of calendar days, which is ten (10) calendar days if the Trading Day is a business day or four (4) calendar days if the Trading Day is a non-business day. If these targets cannot be met, a minimum of five (5) calendar days if the Trading Day is a business day or a minimum of four (4) calendar days if the Trading Day is a non-business day must be collected. If these targets cannot be met, Meter Data will be collected for the calendar days on which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services, and for which the amount of totalized load was highest during the hours when the Demand Response Services were provided in the forty-five (45) calendar days prior to the Trading Day.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (b) The Scheduling Coordinator will be responsible for calculating the simple hourly average of the collected Meter Data to determine a baseline amount of Energy provided by the Proxy Demand Resource or Reliability Demand Response Resource.
- (c) Unless otherwise requested by the Demand Response Provider and approved by the CAISO, the Scheduling Coordinator will be responsible for multiplying the amount calculated pursuant to Section 4.13.4.1(b) by a percentage equal to the ratio of (i) the average load of the Proxy Demand Resource or Reliability Demand Response Resource during the second, third, and fourth hours preceding the hour of the Trading Day on which the Proxy Demand Resource or Reliability Demand Response Resource provided the Demand Response Services during the Demand Response Event to (ii) the average load of the Proxy Demand Resource or Reliability Demand Response Resource during the same second, third, and fourth hours of the calendar days for which Meter Data has been collected pursuant to Section 4.13.4.1(a). To provide a maximum adjustment factor of twenty (20) percent, the adjusted percentage can have a maximum value of one hundred-twenty (120) percent and a minimum value of eighty (80) percent.
- (d) If the Proxy Demand Resource or Reliability Demand Response Resource elects to provide Meter Data reflecting the total gross Demand at all times, independent of any offsetting Energy, the offsetting Energy must be metered separate from Load to enable the accurate calculation of total gross consumption.

4.13.4.2 Metering Generator Output Methodology

For behind-the-meter generation registered in Proxy Demand Resources or Reliability Demand Response Resources and settling Energy Transactions pursuant to Section 11.6.2, the Generator Output Baseline will be calculated as follows:

- (a) Meter Data will be collected for the behind-the-meter generation for the same hour as the Trading Hour on calendar days preceding the Trading Day on which the Demand Response Event occurred for which the Generator Output Baseline is calculated. Meter Data will consist of Energy output of the behind-the-meter generation up to, but not including, output that represent an export of energy from that location. To determine the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

hours for which the Meter Data will be collected, the calculation will work sequentially backwards from the Trading Day under examination up to a maximum of forty-five (45) calendar days prior to the Trading Day, including only business days if the Trading Day is a business day, including only non-business days if the Trading Day is a non-business day, and excluding hours in which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) pursuant to a Bid at or above the net benefits test set forth in Section 30.6.3, or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services pursuant to a Bid at or above the net benefits test set forth in Section 30.6.3, except as discussed below. The calculation will have complete Meter Data for this purpose if and when it is able to collect Meter Data for its target number of hours the same as the Trading Hour, which target number is ten (10) hours if the Trading Day is a business day or four (4) hours if the Trading Day is a non-business day. If it is not possible to collect Meter Data for the target number of hours, the Meter Data will include a minimum of five (5) hours if the Trading Day is a business day or a minimum of four (4) hours if the Trading Day is a non-business day. If it is not possible to collect Meter Data for the minimum number of hours described above, the Generator Output Baseline will be set at zero.

- (b) The baseline amount of Energy provided by the behind-the-meter generation will be calculated on the simple hourly average of the collected Meter Data.
- (c) In calculating the Generator Output Baseline pursuant to Section 4.13.4.2(a), the Meter Data must be set to zero in any Settlement Interval in which the behind-the-meter generation is charging.
- (d) In any Settlement Interval where the behind-the-meter generation is exporting Energy (i.e., where the behind-the-meter generation Energy output exceeds its location Demand), the Meter Data will consist of the Energy output of the behind-the-meter generation up to, but not including, the output greater than its facility Demand that would

represent an export of Energy from that location.

4.13.4.3 Control Group Methodology

Scheduling Coordinators will be responsible for calculating the Customer Load Baseline for Proxy Demand Resources or Reliability Demand Response Resources using the control group methodology as follows:

- (a) Prior to any Demand Response Event, a randomized control group of End Users that are registered in the Demand Response System but not responding to CAISO dispatch as Proxy Demand Resources or Reliability Demand Response Resources must be submitted to the CAISO. But for any Demand Response Event, the control group must have nearly identical Demand patterns in aggregate as the Proxy Demand Resources or Reliability Demand Response Resources. The control group must be geographically similar to the Proxy Demand Resources or Reliability Demand Response Resources such that they experience the same weather patterns and grid conditions. The control group must consist of 150 distinct End Users or more. Prior to use of the control group baseline methodology, Scheduling Coordinators will be responsible for validating the control group pursuant to Section 4.13.4.3(c).
- (b) The control group's aggregate Demand during the same Trade Date and Trading Hour(s) as the Demand Response Event, divided by the relevant number of End Users, will constitute the Customer Load Baseline.
- (c) Scheduling Coordinators are responsible for validating that the control group accurately represents its Proxy Demand Resources or Reliability Demand Response Resources. As described in the Business Practice Manual, to validate the control group, Meter Data of the control group and the Proxy Demand Resources or Reliability Demand Response Resources from the previous seventy-five (75) days must be evaluated, excluding days where the Proxy Demand Resources or Reliability Demand Response Resources provided Demand Response Services or participated in a utility demand response program. Using the most recent days, at least twenty (20) eligible days of Meter Data must be used for validation. From these days, an average of the hourly load profile from

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

12 p.m. to 9 p.m. must be developed for the Proxy Demand Resources or Reliability Demand Response Resources and the control group by day and by hour. The average hourly Demand of the Proxy Demand Resources or Reliability Demand Response Resources is then regressed against the average hourly Demand of the control group. As described in the Business Practice Manual, the control group must statistically demonstrate (i) lack of bias and (ii) sufficient statistical precision with (iii) sufficient confidence. Control groups that fail these screens may not be used.

- (d) For Proxy Demand Resources or Reliability Demand Response Resources whose number of End Users have not changed by more than ten (10) percent in the prior month, the control group must be re-validated every other month. For Proxy Demand Resources or Reliability Demand Response Resources whose number of End Users have changed by more than ten (10) percent in the prior month, control groups must continue to be re-validated monthly.
- (e) Control group randomization, equivalence, and validation, and all Demand Response Event calculations are subject to CAISO audit for three (3) years from the date Demand Response Event. All results must be reproducible, including underlying interval data, randomization, validation, bias, confidence, precision, and analysis.

4.13.4.4 Five-in-Ten Methodology

Scheduling Coordinators will be responsible for calculating the Customer Load Baseline for Proxy Demand Resources or Reliability Demand Response Resources using the five-in-ten methodology as follows:

- (a) Meter Data for the Proxy Demand Resource or Reliability Demand Response Resource will be collected for calendar days preceding the Trading Day on which the Demand Response Event occurred for the Customer Load Baseline. Where the Proxy Demand Response or Reliability Demand Response Resource may elect to provide, at all times, Meter Data reflecting the total gross consumption, independent of any offsetting Energy produced by behind-the-meter generation. The calendar days for which the Meter Data will be collected will be determined by working sequentially backwards from the Trading

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Day under examination up to a maximum of forty-five (45) calendar days prior to the Trading Day, including only business days if the Trading Day is a business day, including only non-business days if the Trading Day is a non-business day, and excluding calendar days on which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services, except as discussed below. The collection of Meter Data for this purpose stops upon reaching the target number of calendar days, which is ten (10) calendar days if the Trading Day is a business day or five (5) calendar days if the Trading Day is a non-business day. From the target days, the five (5) business days and three (3) non-business days with the highest totalized load during the hours when the Demand Response Services were provided will be used. If these targets cannot be met, the Meter Data will instead be used for the calendar days on which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services, and for which the amount of totalized load was highest during the hours when the Demand Response Services were provided in the forty-five (45) calendar days prior to the Trading Day.

- (b) For business days, the Scheduling Coordinator will be responsible for calculating the simple hourly average of the collected Meter Data to determine a baseline amount of Energy provided by the Proxy Demand Resource or Reliability Demand Response Resource. For non-business days, the Scheduling Coordinator will be responsible for calculating a weighted average of the collected Meter Data to determine a baseline as follows: the day closest to the Demand Response Event receives a weight of fifty (50) percent, the next closest receives a weight of thirty (30) percent, and the furthest receives a weight of twenty (20) percent.

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

- (c) Unless otherwise requested by the Demand Response Provider and approved by the CAISO, the Scheduling Coordinator will be responsible for multiplying the amount calculated pursuant to Section 4.13.4.4(b) by a percentage of the ratio of:
- (i) the average Demand of Proxy Demand Resource or Reliability Demand Response Resource during (a) the period from four (4) to two (2) hours preceding the Trading Intervals, and (b) the period from two (2) to four (4) hours following the Trading Intervals on which the Proxy Demand Resource or Reliability Demand Response Resource provided Demand Response Services during the Demand Response Event to
 - (ii) the average Demand of the Proxy Demand Resource or Reliability Demand Response Resource during (a) the period from four (4) to two (2) hours preceding the Trading Intervals, and (b) the period from (2) to four (4) hours following the Trading Intervals for which Meter Data was collected pursuant to Section 4.13.4.4(a).

To provide maximum adjustment factor of 1.4, the adjusted percentage can have a maximum value of one hundred-forty (140) percent and a minimum value of seventy-one (71) percent.

- (d) If the Proxy Demand Resource or Reliability Demand Response Resource elects to provide Meter Data reflecting the total gross Demand at all times, independent of any offsetting Energy, the offsetting Energy must be separated from Load to enable the accurate calculation of total gross consumption.

4.13.4.5 Weather Matching Methodology

Scheduling Coordinators will be responsible for calculating the Customer Load Baseline for Proxy Demand Resources or Reliability Demand Response Resources using the weather matching methodology as follows:

- (a) The Scheduling Coordinator will be responsible for collecting Meter Data for the Proxy Demand Resource or Reliability Demand Response Resource for calendar days preceding the Trading Day on which the Demand Response Event occurred. Where the

California Independent System Operator Corporation
Fifth Replacement FERC Electric Tariff

Proxy Demand Response or Reliability Demand Response Resource uses behind-the-meter generation to offset Demand, the Proxy Demand Resource or Reliability Demand Response Resource may elect to provide, at all times, Meter Data reflecting the total gross consumption, independent of any offsetting Energy produced by behind-the-meter generation. The calendar days for which the Meter Data will be collected will be determined by working sequentially backwards from the Trading Day under examination up to a maximum of ninety (90) calendar days prior to the Trading Day, including only business days if the Trading Day is a business day, including only non-business days if the Trading Day is a non-business day, and excluding calendar days on which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services. As detailed in the Business Practice Manual, from the ninety (90) calendar days prior to the Trading Day, the four (4) days with the closest daily maximum temperature to the Trading Day will be used to calculate the baseline.

- (b) The Scheduling Coordinator will be responsible for calculating the simple hourly average of the collected Meter Data to determine a baseline amount of Energy provided by the Proxy Demand Resource or Reliability Demand Response Resource.
- (c) Unless otherwise requested by the Demand Response Provider and approved by the CAISO, the Scheduling Coordinator will be responsible for multiplying the amount calculated pursuant to Section 4.13.4.5(b) by a percentage equal to the ratio of:
 - (i) the average Demand of the Proxy Demand Resource or Reliability Demand Response Resource during (a) the period from four (4) to two (2) hours preceding the Trading Intervals, and (b) the period from two (2) to four (4) hours following the Trading Intervals on which the Proxy Demand Resource or Reliability Demand Response Resource provided the Demand Response Services during the Demand Response Event to

- (ii) the average Demand of the Proxy Demand Resource or Reliability Demand Response Resource during (a) the period from four (4) to two (2) hours preceding the Trading Intervals, and (b) the period from two (2) to four (4) hours following the Trading Intervals for which Meter Data was collected pursuant to Section 4.13.4.5(a).

To provide a maximum adjustment factor of 1.4, the adjusted percentage can have a maximum value of one hundred-forty (140) percent and a minimum value of seventy-one (71) percent.

- (d) If the Proxy Demand Resource or Reliability Demand Response Resource elects to provide Meter Data reflecting the total gross Demand at all times, independent of any offsetting Energy, the offsetting Energy must be metered separate from Load to enable the accurate calculation of total gross consumption.

4.13.5 Characteristics of PDRs and PDRRs

4.13.5.1 Availability to Provide Demand Response Services

Each Proxy Demand Resource and Reliability Demand Response Resource shall become available to provide Demand Response Services pursuant to the Demand Response Provider Agreement following the date on which the Demand Response Provider Agreement is executed by all parties thereto, as specified by the parties, and shall be available to provide Demand Response Services until the Demand Response Provider Agreement is terminated as set forth in the Demand Response Provider Agreement.

4.13.5.2 Size Limits for PDRs and PDRRs

4.13.5.2.1 PDRs

The minimum Load curtailment of a Proxy Demand Resource shall be no smaller than 0.1 MW. Loads may be aggregated together to achieve the 0.1 MW threshold. There is no upper limit on the maximum Load curtailment of a Proxy Demand Resource.

4.13.5.2.2 RDRRs

The minimum Load curtailment of a Reliability Demand Response Resource shall be no smaller than 0.5 MW. Loads may be aggregated together to achieve the 0.5 MW threshold. The maximum Load curtailment of a Reliability Demand Response Resource that selects the Discrete Real-Time Dispatch

Option shall be no larger than 50 MW. There is no upper limit on the maximum Load curtailment of a Reliability Demand Response Resource that selects the Marginal Real-Time Dispatch Option.

4.13.5.3 Dispatch Parameters for RDRRs

Each Reliability Demand Response Resource shall be capable of reaching its maximum Load curtailment within forty (40) minutes after it receives a Dispatch Instruction, and shall be capable of providing Demand Response Services for at least four (4) consecutive hours per Demand Response Event. Each Reliability Demand Response Resource shall have a minimum run time of no more than one (1) hour.

4.14 Relationship Between the CAISO and CBEs

Only entities that satisfy all of the requirements specified in this Section 4.14 will be certified by the CAISO to be Convergence Bidding Entities and thus be authorized by the CAISO to submit Virtual Bids. A Convergence Bidding Entity may submit Virtual Bids only through a Scheduling Coordinator, which can be either the Convergence Bidding Entity itself or another entity that is a Scheduling Coordinator. A Convergence Bidding Entity may be represented by only one Scheduling Coordinator at any given time.

4.14.1 Procedure to Become a Convergence Bidding Entity

4.14.1.1 Convergence Bidding Entity Application

To become a Convergence Bidding Entity, a Convergence Bidding Entity applicant must submit a completed written application, as provided in the applicable form posted on the CAISO Website, to the CAISO by mail or in person.

4.14.1.2 CAISO Information

The CAISO will provide the following information, in its most current form, on the CAISO Website and, upon request by a Convergence Bidding Entity applicant, the CAISO will send the requested information by electronic mail:

- (a) the Convergence Bidding Entity application form; and
- (b) the CAISO Tariff and Business Practice Manuals.

4.14.1.3 Convergence Bidding Entity Applicant Submits Application

At least sixty (60) Business Days before the date on or after which the Convergence Bidding Entity applicant proposes to start submitting Virtual Bids, the Convergence Bidding Entity applicant must return a completed application form.

4.14.1.4 Notice of Receipt

Within three (3) Business Days of receiving the application, the CAISO will send written notification to the Convergence Bidding Entity applicant that it has received the application.

4.14.1.5 CAISO Review of Application

Within ten (10) Business Days after receiving an application, the CAISO will notify the Convergence Bidding Entity applicant whether the Convergence Bidding Entity applicant has submitted all necessary information as set forth in Section 4.14.1.

4.14.1.5.1 Information Requirements

The Convergence Bidding Entity applicant must submit with its application:

- (a) the proposed date on or after which the Convergence Bidding Entity applicant proposes to start submitting Virtual Bids, which may not be less than sixty (60) Business Days after the date the application was filed, unless waived by the CAISO;
- (b) an explanation of whether the Convergence Bidding Entity applicant is a Rated or Unrated Public/Private Corporation, a Rated or Unrated Governmental Entity, a Local Publicly Owned Electric Utility, or another type of entity, and a chart, or equivalent information, depicting the Convergence Bidding Entity applicant's corporate structure, including all parent companies of the Convergence Bidding Entity applicant, all subsidiaries of the Convergence Bidding Entity applicant, and all Affiliates of the Convergence Bidding Entity applicant that meet the requirements of Section 4.14.2.1; and
- (c) the name of the Scheduling Coordinator and SCID(s) that the Convergence Bidding Entity anticipates will be used for submitting Virtual Bids on behalf of the Convergence Bidding Entity.

Additional instructions for completing the foregoing requirements will be set forth in the applicable Business Practice Manual(s) posted on the CAISO Website.

4.14.1.6 Deficient Application

In the event that the CAISO determines that the application is deficient, the CAISO will send an electronic notification of the deficiency to the Convergence Bidding Entity applicant within ten (10) Business Days of

receipt by the CAISO of the application explaining the deficiency and requesting additional information.

4.14.1.6.1 Additional Information

Once the CAISO requests additional information, the Convergence Bidding Entity applicant has five (5) Business Days, or such longer period as the CAISO may agree not to exceed five (5) additional Business Days, to provide the additional material requested by the CAISO.

4.14.1.6.2 CAISO Approval or Rejection of an Application

If the Convergence Bidding Entity applicant does not submit additional information within five (5) Business Days or the longer period referred to in Section 4.14.1.6.1, the application may be rejected by the CAISO.

4.14.1.7 CAISO Approval or Rejection of an Application

4.14.1.7.1 Approval or Rejection Notification

- (a) If the CAISO approves the application, it will send a written notification of approval. In addition, the CAISO will provide an executable Convergence Bidding Entity Agreement.
- (b) If the CAISO rejects the application, the CAISO will send an electronic notification of rejection stating one or more of the following grounds:
 - (i) incomplete information; or
 - (ii) non-compliance with any other CAISO Tariff requirements.

Upon request, the CAISO will provide guidance as to how the Convergence Bidding Entity applicant can cure the grounds for the rejection.

4.14.1.7.2 Time for Processing Application

The CAISO will make a decision whether to accept or reject the application within ten (10) Business Days of receipt of the application. If more information is requested, the CAISO will make a final decision within ten (10) Business Days of the receipt of all outstanding or additional information requested.

4.14.1.8 Convergence Bidding Entity Applicant's Response

4.14.1.8.1 Convergence Bidding Entity Applicant's Acceptance

If the CAISO accepts the application, the Convergence Bidding Entity applicant must return the partially executed Convergence Bidding Entity Agreement previously provided by the CAISO.

4.14.1.8.2 Convergence Bidding Entity Applicant's Rejection

4.14.1.8.2.1 Resubmittal

If the CAISO rejects the application, the Convergence Bidding Entity applicant may resubmit its application at any time.

4.14.1.8.2.2 Appeal

The Convergence Bidding Entity applicant may also appeal the rejection of an application by the CAISO. An appeal must be submitted within twenty (20) Business Days following the CAISO's issuance of a notification of rejection.

4.14.1.9 Final Certification

The Convergence Bidding Entity applicant will become a Convergence Bidding Entity when:

- (a) its application has been accepted;
- (b) it has entered into a Convergence Bidding Entity Agreement and any other applicable agreements with the CAISO; and
- (c) it has fulfilled all requirements of Section 4.14.1.5.1.

The CAISO will not certify a Convergence Bidding Entity applicant as a Convergence Bidding Entity until the Convergence Bidding Entity applicant has completed all the above-referenced requirements to the CAISO's satisfaction, at least ten (10) Business Days before the commencement of service.

4.14.2 Convergence Bidding Entity's Ongoing Obligations

4.14.2.1 Affiliate Disclosure Requirements

Each Convergence Bidding Entity applicant will notify the CAISO of any Affiliate that is a Market Participant, any Affiliate that participates in an organized electricity market in North America, and any guarantor of any such Affiliate. Upon request, a Convergence Bidding Entity applicant will provide the CAISO with information on each such Affiliate, including information concerning the ownership structure of such Affiliate and the business purpose of such Affiliate. These requirements will continue to apply after a Convergence Bidding Entity applicant becomes a Convergence Bidding Entity.

4.14.2.2 Obligation to Report a Change in Filed Information

Each Convergence Bidding Entity has an ongoing obligation to inform the CAISO of any changes to any of the information submitted by it to the CAISO as part of the application process, including but not limited

standards as further detailed in the CAISO's Business Practice Manual. Distributed Energy Resource Providers must make Settlement Quality Meter Data from individual Distributed Energy Resources comprising a Distributed Energy Resource Aggregation available to the CAISO upon request.

Distributed Energy Resource Providers shall provide information regarding Distributed Energy Resource Aggregation(s) with a rated capacity of 10 MW or greater or, if the Distributed Energy Resource Aggregation(s) provides Ancillary Services, through telemetry to the CAISO's EMS in accordance with the CAISO's standards for direct telemetry and consistent with the requirement for telemetry set forth in Section 7.6.1.

4.17.6 Operating Requirements

Distributed Energy Resource Aggregations will respond to CAISO Dispatch Instructions. The CAISO may dispatch a Distributed Energy Resource Aggregation to the extent the Distributed Energy Resource Aggregation bids or schedules Energy or Ancillary Services into the CAISO Markets and receives an award. The CAISO may also issue an Exceptional Dispatch Instruction for the Distributed Energy Resource Aggregation for reliability pursuant to Section 34.10. Distributed Energy Resource Aggregations shall respond to Dispatch Instructions consistent with Generation Distribution Factors for the Distributed Energy Resource Aggregation.

Each Distributed Energy Resource Provider will operate its Distributed Energy Resource Aggregation(s) in a manner consistent with limitations or operating orders established by the Utility Distribution Company or Metered Subsystem. Scheduling Coordinators for Distributed Energy Resources Providers shall submit Outages to the CAISO as necessary to reflect any distribution constraints impacting Distributed Energy Resources that comprise a Distributed Energy Resource Aggregation under its control. The CAISO shall have the authority to coordinate and approve Outage schedules for the Distributed Energy Resource Aggregation(s) listed in a Distributed Energy Resource Provider Agreement, in accordance with the provisions of Section 9.