

July 15 2019 Exceptional Dispatch CPM Designation Report**Designation Summary:**

The California ISO issued an Exceptional Dispatch Capacity Procurement Mechanism (CPM) designation to HUMBPP_1_UNITS3 for a non-system reliability need. The designation is effective July 15, 2019 for a duration of 60 days.

Duration and Cost:

RESOURCE_ID	MW	ED Code	Accepted Offer Price	Estimated CPM Cost
HUMBPP_1_UNITS3	15	Local Reliability Issue	\$6.31/kw-month	\$189,300.00

Reason for CPM:

The ISO issued an Exceptional Dispatch CPM designation to HUMBPP_1_UNITS3 to address an Exceptional Dispatch non-system Reliability Need. The Exceptional Dispatch was issued to address a potential thermal overload on a 60 kV line in the PG&E Area for the next contingency event. The designation amount reflects the minimum amount of capacity the ISO could designate to mitigate the reliability need posed by the potential thermal overload.

Prior CPM report information is available to download at:
<http://www.caiso.com/market/Pages/ReportsBulletins/Default.aspx>