



Decision on Outage & Forecasting Modifications for Eligible Intermittent Resources


Grant Rosenblum
Integration of Renewable Resources Program,
Manager

ISO Board of Governors Meeting
General Session

October 29, 2009

Requesting approval of two tariff modifications to improve renewable resource forecasting accuracy.

1. Extend applicability of forecasting data and equipment requirements to broader set of renewable resources



2. Reduce forced outage reporting threshold from 10 MW to 1 MW

The new technical requirements will be included in a Business Practice Manual.

- Physical site data, i.e., longitude/latitude, elevation
- Meteorological station location
- Data measuring capability
- Redundant power source standards
- Maintenance and calibration of equipment

Business Practice Manuals are subject to the change management process, including stakeholder input and routine reports to the Board.

Management carefully considered stakeholder concerns.

- Extension of forecast fee to all intermittent renewable resources
- Outage reporting threshold
- Grandfathering some existing resources
- Technical requirements vary depending on resource size