



California ISO  
Your Link to Power

California Independent  
System Operator

# **2008 LOCAL CAPACITY TECHNICAL ANALYSIS**

## **REPORT AND STUDY RESULTS**

~~March~~ Updated April 93, 2007

|

# Local Capacity Technical Analysis Overview and Study Results

## I. Executive Summary

This Report documents the results and recommendations of the 2008 Local Capacity Requirements (LCR) Study. The LCR sStudy assumptions, processes, and criteria for this study were discussed and recommended through the LCR Study Advisory Group (“LSAG”)<sup>1</sup>, an advisory group formed by the CAISO to assist the CAISO in its preparation for performing the 2008 LCR Study (see December 6, 2006 LSAG meeting notes at <http://www.caiso.com/1b64/1b648dea14820.pdf>). On balance, the assumptions, processes, and criteria used for the 2008 LCR Study mirror those used in the 2007 LCR Study which were adopted by CPUC in the 2007 Resource Adequacy Requirements program.

These 2008 LCR study results are provided to the CPUC for consideration in its 2008 resource adequacy requirements program. These results will also be used by the CAISO for establishing the scope of local capacity needs and for allocating appropriate costs of any necessary CAISO procurement of local capacity following implementation of its Market Redesign and Technology Upgrade (“MRTU”) project in accordance with the CAISO’s FERC-approved MRTU Tariff.<sup>2</sup> In this regard, the 2008 LCR Study also provides additional information like sub-area needs and effectiveness factors (where applicable) in order to allow LSEs to engage in more informed procurement.

Overall, the LCR need trended upward due to load growth. The two-three exceptions are (1) the Greater Bay Area, where the LCR was reduced due to the

---

<sup>1</sup> The Local capacity requirements Study Advisory Group (LSAG) is formed from a representative cross-section of stakeholders, technically qualified to assess the issues related to the study assumptions, process and criteria of the existing LCR methodology and to recommend changes, where needed that could be implemented into the 2008 LCR study.

<sup>2</sup> The CAISO, under Section 40.3 of the CAISO MRTU Tariff, has the authority to procure generation capacity to backstop LSE procurement for two basic reasons: 1) an LSE did not procure sufficient resources to meet its individual local area resource obligation and that failure results in a collective deficiency of capacity that prevents compliance with Applicable Reliability Criteria or 2) LSEs collectively satisfied their local area resource obligations, but their procurement in aggregate did not permit the CAISO to meet Applicable Reliability Criteria.

installation of the new Vaca-Dixon 500/230 kV transformer, ~~and~~ (2) the LA Basin, where the LCR increased, and (3) creation of a Big Creek/Ventura local area.

➤ **Increase in LA Basin**

The increase in LA Basin LCR arises from the fact that the 2007 LCR Study did not have the benefit of results from a then-pending SCE study evaluating the effect on the South of Lugo operational path rating of transmission upgrades that were still under construction at the time of the 2007 LCR Study. The 2008 LCR study incorporates the outcome of the SCE study and therefore reflects the current, accurate South of Lugo operational path rating. Thus, the increase in capacity needs in the LA Basin is based on differences between the manner in which the CAISO attempt to account for the unavailability and uncertainty of the study results in the 2007 LCR Study and the use of actual final results of the SCE study in the 2008 LCR Study.

At the time the 2007 LCR Study was performed, South of Lugo had a formal operational path rating of 5600 MW. However, the CAISO understood that the South of Lugo operational path rating would increase during the following year when CAISO-approved transmission upgrades were completed or finally implemented by SCE. The extent of the increase was unknown because the new South of Lugo operational path rating was under development by SCE. The new formal South of Lugo operational path rating is 6100 MW as a result of the completed upgrades.

Accordingly, at the time the 2007 LCR study was performed, the CAISO identified two potential means of addressing the uncertainty surrounding the South of Lugo operational path rating. The first option was to use the approved South of Lugo operational rating of 5600 MW. This option would have resulted in a 2007 LCR need driven by the loss of Devers-Valley 500 kV line with SONGS #3 unit out of service, while maintaining the 5600 MW South of Lugo operational path rating. Such an outcome would have been equal to last year's projected need plus the SONGS #3 units output and additional generation to keep the path bellow the 5600 MW limit (see footnote 24 in page 65 under the 2007 LCR Report) (e.g., 8843 + 1080 + 900 = 10823 MW). The second option ignored the existing 5600 MW operational path rating as obsolete and,

instead, utilized the next worst contingency in the area based on the same criteria published in page 15 of the 2007 LCR report.

The CAISO selected the second option, which resulted in a 2007 LA Basin LCR need of 8843 MW. It decided that the first option was unfair to LSEs and ratepayers not to take advantage of the upgrades simply because SCE had not yet completed its study of, and the CAISO could not validate, the new operating rating for the South of Lugo path. Thus, had the accurate data been used, the real need for 2007 should have been equal with last year's projected need plus the SONGS #3 units output (e.g., 8843 + 1080 = 9923 MW). It should be noted that the South of Lugo upgrades lowered the LCR needs by 900 MW (e.g., 10823 – 9923 = 900 MW). Finally, after SCE completed, and the CAISO approved, the new 6100 MW South of Lugo operational path rating, the CAISO reassessed LSE procurement in the LA Basin and confirmed that the combined LSE procurement exceeded the actual 9923 MW requirement for 2007.

Thus, from 2007 to 2008, there was no change in study methodology or inconsistent application of study protocols across the CAISO controlled system. In retrospect, the CAISO could have assumed or estimated an operational path rating on South of Lugo or any path for which studies are incomplete. This approach can be taken in the future if stakeholders agree that it represents a better alternative.

### ➤ **Big Creek/Ventura Local Area**

Additionally, there is a new local area in southern California designated as the Big Creek/Ventura area which has been previously described in the SCE Transmission Plan as well as in the CAISO's 2009-2011 Long-Term LCR technical analysis study (<http://www.caiso.com/18d8/18d8ce1118390.pdf>) and in the CAISO's 2007 Transmission Plan (<http://www.caiso.com/1b6b/1b6bb4d51db0.pdf>).

Below is a comparison of the 2007 vs. 2008 total LCR need:

### 2007 Local Capacity Needs

| Local Area Name         | Qualifying Capacity |              |              | 2007 LCR Need Based on Category B |            |              | 2007 LCR Need Based on Category C with operating procedure |            |              |
|-------------------------|---------------------|--------------|--------------|-----------------------------------|------------|--------------|--|------------|--------------|
|                         | QF/ Muni (MW)       | Market (MW)  | Total (MW)   | Existing Capacity Needed          | Deficiency | Total (MW)   | Existing Capacity Needed                                   | Deficiency | Total (MW)   |
| Humboldt                | 73                  | 133          | 206          | 202                               | 0          | <b>202</b>   | 202  | 0          | <b>202</b>   |
| North Coast / North Bay | 158                 | 861          | 1019         | 582                               | 0          | <b>582</b>   | 582  | 0          | <b>582</b>   |
| Sierra                  | 1072                | 776          | 1848         | 1833                              | 205        | <b>2038</b>  | 1833   | 328        | <b>2161</b>  |
| Stockton                | 314                 | 257          | 571          | 432                               | 0          | <b>432</b>   | 536  | 53         | <b>589</b>   |
| Greater Bay             | 1314                | 5231         | 6545         | 4771                              | 0          | <b>4771</b>  | 4771   | 0          | <b>4771</b>  |
| Greater Fresno          | 575                 | 2337         | 2912         | 2115                              | 0          | <b>2115</b>  | 2151   | 68         | <b>2219</b>  |
| Kern                    | 978                 | 31           | 1009         | 554                               | 0          | <b>554</b>   | 769  | 17         | <b>786</b>   |
| LA Basin                | 3510                | 7012         | 10522        | 8843                              | 0          | <b>8843</b>  | 8843   | 0          | <b>8843</b>  |
| Big Creek/ Ventura      | N/A                 | N/A          | N/A          | N/A                               | N/A        | <b>N/A</b>   | N/A  | N/A        | <b>N/A</b>   |
| San Diego               | 191                 | 2741         | 2932         | 2781                              | 0          | <b>2781</b>  | 2781   | 0          | <b>2781</b>  |
| <b>Total</b>            | <b>8185</b>         | <b>19379</b> | <b>27564</b> | <b>22113</b>                      | <b>205</b> | <b>22318</b> | <b>22468</b>   | <b>466</b> | <b>22934</b> |

### 2008 Local Capacity Needs

| Local Area Name         | Qualifying Capacity |             |            | 2008 LCR Need Based on Category B |            |                 | 2008 LCR Need Based on Category C with operating procedure |            |                 |
|-------------------------|---------------------|-------------|------------|-----------------------------------|------------|-----------------|--|------------|-----------------|
|                         | QF/ Muni (MW)       | Market (MW) | Total (MW) | Existing Capacity Needed          | Deficiency | Total (MW)      | Existing Capacity Needed                                   | Deficiency | Total (MW)      |
| Humboldt                | 45                  | 135         | 180        | 175                               | 0          | <b>175</b>      | 175  | 0          | <b>175</b>      |
| North Coast / North Bay | 262                 | 621         | 883        | 676                               | 0          | <b>676</b>      | 676  | 0          | <b>676</b>      |
| Sierra                  | 1014                | 766         | 1780       | 1780                              | 89         | <b>1869</b>     | 1780   | 312        | <b>2092</b>     |
| Stockton                | 272                 | 264         | 536        | 460                               | 15         | <b>475</b>      | 536  | 250        | <b>786</b>      |
| Greater Bay             | 1116                | 5098        | 6214       | 4688                              | 0          | <b>4688</b>     | 4688   | 0          | <b>4688</b>     |
| Greater Fresno          | 496                 | 2495        | 2991       | 2212                              | 0          | <b>2212</b>     | 2274   | 108        | <b>2382</b>     |
| Kern                    | 615                 | 31          | 646        | 259                               | 0          | <b>259</b>      | 463  | 23         | <b>486</b>      |
| LA Basin                | 3545                | 8545        | 12093      | 1050130*                          | 0          | <b>1050130*</b> | 1050130*   | 0          | <b>1050130*</b> |
| Big Creek/ Ventura      | 1463                | 3933        | 5396       | 3562                              | 0          | <b>3562</b>     | 3658   | 0          | <b>3658</b>     |
| San Diego               | 201                 | 2758        | 2959       | 2957                              | 0          | <b>2957</b>     | 2957   | 0          | <b>2957</b>     |

|              |             |              |              |  |            |  |  |            |  |
|--------------|-------------|--------------|--------------|--|------------|--|--|------------|--|
| <b>Total</b> | <b>9029</b> | <b>24646</b> | <b>33678</b> | <b><del>27269</del>2689</b><br><b><u>9</u></b> | <b>104</b> | <b><del>27373</del>27</b><br><b><u>003</u></b> | <b><del>27707</del>2733</b><br><b><u>7</u></b> | <b>693</b> | <b><del>28400</del>2</b><br><b><u>8030</u></b> |
|--------------|-------------|--------------|--------------|--|------------|--|--|------------|--|

~~\*—Potentially higher requirements combined with another area (see detail description).~~

Regarding the 2007 data the term “Qualifying Capacity” used in this report represents the “Gross Qualifying Capacity” (as of 1/12/2006) and it may be slightly higher, for certain generators, than the “Net Qualifying Capacity” as presented in the official list posted on the CAISO web site at:

<http://www.caiso.com/1796/179694f65b9f0.xls>

The difference between the terms “Qualifying Capacity” and “Net Qualifying Capacity” is that certain generators have associated plant load (pumps, lighting, controls, etc.) and thus, the “Net Qualifying Capacity” represents the output from the generator after the plant load has been netted out. This LCR study, however, incorporates the plant load into the “total load” calculation from these generators.

Regarding the 2008 data the term “Qualifying Capacity” used in this report is the same as the latest “Net Qualifying Capacity” list posted on the CAISO web site at:

<http://www.caiso.com/1796/179688b22c970.html>

Along with this report a Local Area Resource list is provided with all units that qualify to meet the 2008 LCR needs.

The first column, “Qualifying Capacity”, reflects two sets of generation. The first set is comprised of generation that would normally be expected to be on-line such as Municipal generation and Regulatory Must-take generation (state, federal, QFs, wind and nuclear units). The second set is “market” generation. The second column, “2008 LCR Requirement Based on Category B” identifies the local capacity requirements, and deficiencies that must be addressed, in order to achieve a service reliability level based on Performance Criteria- Category B. The third column, “2008 LCR Requirement Based on Category C with Operating Procedure”, sets forth the local capacity requirements, and deficiencies that must be addressed, necessary to attain a service reliability level based on Performance Criteria-Category C with operational solutions.

# Table of Contents

|  |           |
|--|-----------|
| <b>I. Executive Summary.....</b>   | <b>1</b>  |
| <b>II. Study Overview: Inputs, Outputs and Options.....</b>  | <b>9</b>  |
| <i>A. Objectives.....</i>  | <i>9</i>  |
| <i>B. Key Study Assumptions .....</i>  | <i>9</i>  |
| 1. Inputs and Methodology.....   | 9         |
| <i>C. Grid Reliability.....</i>  | <i>11</i> |
| <i>D. Application of N-1, N-1-1, and N-2 Criteria.....</i>   | <i>12</i> |
| <i>E. Performance Criteria.....</i>  | <i>13</i> |
| <i>F. The Two Options Presented In This LCR Study .....</i>  | <i>19</i> |
| 1. Option 1- Meet Performance Criteria Category B.....   | 19        |
| 2. Option 2- Meet Performance Criteria Category C and Incorporate Suitable Operational Solutions ..... | 19        |
| <b>III. Assumption Details: How the Study was Conducted .....</b>                                      | <b>20</b> |
| <i>A. System Planning Criteria.....</i>  | <i>20</i> |
| 1. Power Flow Assessment:.....   | 22        |
| 2. Post Transient Load Flow Assessment: .....  | 23        |
| 3. Stability Assessment: .....   | 23        |
| <i>B. Load Forecast.....</i>   | <i>23</i> |
| 1. System Forecast .....   | 23        |
| 2. Base Case Load Development Method.....  | 23        |
| <i>C. Power Flow Program Used in the LCR analysis.....</i>   | <i>25</i> |
| <b>IV. Locational Capacity Requirement Study Results .....</b>   | <b>26</b> |
| <i>A. Summary of Study Results.....</i>  | <i>26</i> |
| <i>B. Summary of Zonal Needs .....</i>   | <i>27</i> |
| <i>C. Summary of Results by Local Area.....</i>  | <i>29</i> |
| 1. Humboldt Area.....  | 29        |
| 2. North Coast / North Bay Area .....  | 31        |
| 3. Sierra Area .....   | 35        |
| 4. Stockton Area.....  | 43        |
| 5. Greater Bay Area .....  | 47        |
| 6. Greater Fresno Area.....  | 55        |
| 7. Kern Area.....  | 64        |
| 8. LA Basin Area .....   | 67        |
| 9. Big Creek/Ventura Area .....  | 80        |
| 10. San Diego Area.....  | 85        |



|             |   |           |
|-------------|---|-----------|
| <b>I.</b>   | <b><u>Executive Summary</u></b> .....   | <b>1</b>  |
| <b>II.</b>  | <b><u>Study Overview: Inputs, Outputs and Options</u></b> .....   | <b>5</b>  |
|             | <i>A. Objectives</i> .....  | 5         |
|             | <i>B. Key Study Assumptions</i> .....   | 5         |
|             | 1. <u>Inputs and Methodology</u> .....  | 5         |
|             | <i>C. Grid Reliability</i> .....  | 7         |
|             | <i>D. Application of N-1, N-1-1, and N-2 Criteria</i> .....   | 8         |
|             | <i>E. Performance Criteria</i> .....  | 9         |
|             | <i>F. The Two Options Presented In This LCR Study</i> .....   | 10        |
|             | 1. <u>Option 1- Meet Performance Criteria Category B</u> .....  | 11        |
|             | 2. <u>Option 2- Meet Performance Criteria Category C and Incorporate Suitable Operational Solutions</u> ..... | 11        |
| <b>III.</b> | <b><u>Assumption Details: How the Study was Conducted</u></b> .....   | <b>11</b> |
|             | <i>A. System Planning Criteria</i> .....  | 11        |
|             | 1. <u>Power Flow Assessment</u> .....   | 13        |
|             | 2. <u>Post Transient Load Flow Assessment</u> .....   | 14        |
|             | 3. <u>Stability Assessment</u> .....  | 14        |
|             | <i>B. Load Forecast</i> .....   | 14        |
|             | 1. <u>System Forecast</u> .....   | 14        |
|             | 2. <u>Base Case Load Development Method</u> .....   | 14        |
|             | <i>C. Power Flow Program Used in the LCR analysis</i> .....   | 16        |
| <b>IV.</b>  | <b><u>Locational Capacity Requirement Study Results</u></b> .....   | <b>17</b> |
|             | <i>A. Summary of Study Results</i> .....  | 17        |
|             | <i>B. Summary of Zonal Needs</i> .....  | 18        |
|             | <i>C. Summary of Results by Local Area</i> .....  | 19        |
|             | 1. <u>Humboldt Area</u> .....   | 20        |
|             | 2. <u>North Coast / North Bay Area</u> .....  | 21        |
|             | 3. <u>Sierra Area</u> .....   | 26        |
|             | 4. <u>Stockton Area</u> .....   | 34        |
|             | 5. <u>Greater Bay Area</u> .....  | 38        |
|             | 6. <u>Greater Fresno Area</u> .....   | 46        |
|             | 7. <u>Kern Area</u> .....   | 54        |
|             | 8. <u>LA Basin Area</u> .....   | 58        |
|             | 9. <u>Big Creek/Ventura Area</u> .....  | 70        |
|             | 10. <u>San Diego Area</u> .....   | 75        |

## **II. Study Overview: Inputs, Outputs and Options**

### **A. Objectives**

As was the objective of the 2006 and the 2007 LCR technical analysis studies, the intent of the 2008 LCR Study is to identify specific areas within the CAISO Controlled Grid that have limited import capability into those areas and determine the generation capacity (MW) necessary to mitigate the local reliability problems in those areas.

### **B. Key Study Assumptions**

#### **1. Inputs and Methodology**

The CAISO incorporated into its 2008 LCR study the same criteria, input assumptions and methodology that were incorporated into its 2007 LCR Study. Several new methodologies were briefly discussed in the LSAG. The group concluded that there was no time to introduce a new methodology change in time to complete the 2008 studies. The discussion of new methodologies is continuing in LSAG. The original 2007 LCR study criteria, input assumptions and methodology were majority agreed to by interested parties at the CPUC directed meet and confer session held at the CAISO on February 17, 2006. These same input assumptions and methodology align with the criteria that was subsequently discussed and agreed to by the LCR Study Advisory Group (“LSAG”) (see December 6, 2006 LSAG meeting notes found at <http://www.caiso.com/1b64/1b648dea14820.pdf>).

The following table sets forth a summary of the approved inputs and methodology that have been used in the previous 2007 LCR Study as well as this 2008 LCR Study:

**Summary Table of Inputs and Methodology Used in this LCR Study:**

| <b>Issue:</b>   | <b>HOW INCORPORATED INTO THIS LCR STUDY:</b>  |
|---|---|
| <u>Input Assumptions:</u>   |   |
| <ul style="list-style-type: none"> <li>• Transmission System Configuration</li> </ul>   | The existing transmission system has been modeled, including all projects operational on or before June 1, of the study year and all other feasible operational solutions brought forth by the PTOs and as agreed to by the CAISO.  |
| <ul style="list-style-type: none"> <li>• Generation Modeled</li> </ul>  | The existing generation resources has been modeled and also includes all projects that will be on-line and commercial on or before June 1, of the study year  |
| <ul style="list-style-type: none"> <li>• Load Forecast</li> </ul>   | Uses a 1-in-10 year summer peak load forecast   |
| <u>Methodology:</u>   |   |
| <ul style="list-style-type: none"> <li>• <b><u>Maximize Import Capability</u></b></li> </ul>  | Import capability into the load pocket has been maximized, thus minimizing the generation required in the load pocket to meet applicable reliability requirements.  |
| <ul style="list-style-type: none"> <li>• <b><u>QF/Nuclear/State/Federal Units</u></b></li> </ul>  | Regulatory Must-take and similarly situated units like QF/Nuclear/State/Federal resources have been modeled on-line at qualifying capacity output values for purposes of this LCR Study.  |
| <ul style="list-style-type: none"> <li>• <b><u>Maintaining Path Flows</u></b></li> </ul>  | Path flows have been maintained below all established path ratings into the load pockets, including the 500 kV. For clarification, given the existing transmission system configuration, the only 500 kV path that flows directly into a load pocket and will, therefore, be considered in this LCR Study is the South of Lugo transfer path flowing into the LA Basin.   |
| <u>Performance Criteria:</u>  |   |
| <ul style="list-style-type: none"> <li>• <b><u>Performance Level B &amp; C, including incorporation of PTO operational solutions</u></b></li> </ul> | This LCR Study is being published based on Performance Level B and Performance Level C criterion, yielding the low and high range LCR scenarios. In addition, the CAISO will incorporate all new projects and other feasible and CAISO-approved operational solutions brought forth by the PTOs that can be operational on or before June 1, of the study year. Any such solutions that can reduce the need for procurement to meet the Performance Level C criteria will be incorporated into the LCR Study. |
| <u>Load Pocket:</u>   |   |
| <ul style="list-style-type: none"> <li>• <b><u>Fixed Boundary, including limited reference to published effectiveness factors</u></b></li> </ul>    | This LCR Study has been produced based on load pockets defined by a fixed boundary. The CAISO only publishes effectiveness factors where they are useful in facilitating procurement where excess capacity exists within a load pocket.   |

Further details regarding the 2008 LCR Study methodology and assumptions are provided in Section III, below.

### **C. Grid Reliability**

Service reliability builds from grid reliability because grid reliability is reflected in the planning standards of the Western Electricity Coordinating Council (“WECC”) that incorporate standards set by the North American Electric Reliability Council (“NERC”) (collectively “NERC Planning Standards”). The NERC Planning Standards apply to the interconnected electric system in the United States and are intended to address the reality that within an integrated network, whatever one control area does can affect the reliability of other control areas. Consistent with the mandatory nature of the NERC Planning Standards, the CAISO is under a statutory obligation to ensure efficient use and reliable operation of the transmission grid consistent with achievement of the NERC Planning Standards.<sup>3</sup> The CAISO is further under an obligation, pursuant to its FERC-approved Transmission Control Agreement, to secure compliance with all “Applicable Reliability Criteria.” Applicable Reliability Criteria consists of the NERC Planning Standards as well as reliability criteria adopted by the CAISO, in consultation with the CAISO’s Participating Transmission Owners (“PTOs”), which affect a PTO’s individual system.

The NERC Planning Standards define reliability on interconnected electric systems using the terms “adequacy” and “security.” “Adequacy” is the ability of the electric systems to supply the aggregate electrical demand and energy requirements of their customers at all times, taking into account physical characteristics of the transmission system such as transmission ratings and scheduled and reasonably expected unscheduled outages of system elements. “Security” is the ability of the electric systems to withstand sudden disturbances such as electric short circuits or unanticipated loss of system elements. The NERC Planning Standards are organized by Performance Categories. For instance, certain categories require that the grid operator not only ensure grid integrity is maintained under certain adverse system conditions, e.g., security, but also that all customers continue to receive electric supply

---

<sup>3</sup> Pub. Utilities Code § 345

to meet demand, e.g., adequacy. In that case, grid reliability and service reliability would overlap. But there are other levels of performance where security can be maintained without ensuring adequacy.

#### **D. Application of N-1, N-1-1, and N-2 Criteria**

The CAISO will maintain the system in a safe operating mode at all times. This obligation translates into respecting the Applicable Reliability Criteria at all times, for example during normal operating conditions (N-0) the CAISO must protect for all single contingencies (N-1) and common mode (N-2) double line outages. Also, after a single contingency, the CAISO must re-adjust the system to support the loss of the next most stringent contingency. This is referred to as the N-1-1 condition.

Upon the completion of the 2006 and 2007 LCR studies, the CAISO came under considerable scrutiny on how the N-1, N-1-1, and N-2 criteria were applied in these studies. Some argued that the CAISO had not applied these criteria correctly, and as a result, erroneous results had been presented. The CAISO has always, as it did then and as it does now, argued that its application of these criteria were correct, and as such, the results presented in the 2006 and 2007 LCR reports correctly represented the LCR need in the identified load pockets.

However, as a result of recommendations from stakeholders, the CAISO formed the LCR Study Advisory Group to assist the CAISO in its preparation for performing the 2008 LCR Study. The LSAG was formed in late 2006 and immediately undertook a review of several key LCR issues, where the clarification of the N-1, N-1-1, and N-2 criteria was considered. While LSAG is still completing the documentation of its work, of significant importance to the CAISO is the unanimous agreement among LSAG members that its application of the N-1, N-1-1, and N-2 criteria in the 2007 LCR study was done correctly. Given this conclusion, the application of these criteria in the 2008 LCR Study will be consistent with the 2007 LCR Study. The criteria used in both the 2007 and 2008 studies conform in nearly all respects to NERC reliability standards that will become mandatory by July 1, 2007 with penalty sanctions as approved by FERC. LSAG members and stakeholders noted that the terminology N-1-1 is not included in NERC reliability standards and can create confusion. The N-1-1 vs N-2 terminology was

introduced only as a mere temporal differentiation between two existing NERC Category C events. N-1-1 represents NERC Category C3 (“category B contingency, manual system adjustment, followed by another category B contingency”). The N-2 represents NERC Category C5 (“any two circuits of a multiple circuit tower line”) as well as WECC-S2 (for 500 kV only) (“any two circuits in the same right-of-way”) with no manual system adjustment between the two contingencies.

LSAG discussion on these criteria clearly illustrated that a detailed discussion/explanation of these criteria and how they should be applied in all “going forward” LCR Studies was needed. LSAG is currently preparing this discussion/explanation in the documentation of their work. Once completed, this documentation will be distributed to the Stakeholders.

## **E. Performance Criteria**

As set forth on the Summary Table of Inputs and Methodology, this LCR Report is based on NERC Performance Level B and Performance Level C criterion. The NERC Standards refer mainly to thermal overloads however the CAISO will also test the electric system in regards to the dynamic and reactive margin compliance with the existing WECC standards for the same NERC performance levels. These Performance Levels can be described as follows:

### **a. Performance Criteria- Category B**

Category B describes the system performance that is expected immediately following the loss of a single transmission element, such as a transmission circuit, a generator, or a transformer.

Category B system performance requires that all thermal and voltage limits must be within their “Applicable Rating,” which, in this case, are the emergency ratings as generally determined by the PTO or facility owner. Applicable Rating includes a temporal element such that emergency ratings can only be maintained for certain duration. Under this category, load cannot be shed in order to assure the Applicable

Ratings are met however there is no guarantee that facilities are returned to within normal ratings or to a state where it is safe to continue to operate the system in a reliable manner such that the next element out will not cause a violation of the applicable ratings and criteria.

**b. Performance Criteria- Category C**

The NERC Standards require system operators to “look forward” to make sure they safely prepare for the “next” N-1 following the loss of the “first” N-1 (stay within Applicable Ratings after the “next” N-1). This is commonly referred to as N-1-1. Because it is assumed that some time exists between the “first” and “next” element losses, operating personnel may make any reasonable and feasible adjustments to the system to prepare for the loss of the second element, including, operating procedures, dispatching generation, moving load from one substation to another to reduce equipment loading, dispatching operating personnel to specific station locations to manually adjust load from the substation site, or installing a “Special Protection Scheme” that would remove pre-identified load from service upon the loss of the “next” element.<sup>4</sup> All Category C requirements in this report refer to situations when in real time (N-0) or after the first contingency (N-1) the system requires additional readjustment in order to prepare for the next worst contingency. In this time frame load drop is not allowed per existing planning criteria.

Generally, Category C describes system performance that is expected following the loss of two or more system elements. This loss of two elements is generally expected to happen simultaneously, referred to as N-2. It should be noted that once the “next” element is lost after the first contingency, as discussed above under the Performance Criteria B, N-1-1 scenario, the event is effectively a Category C. As noted


---

<sup>4</sup> A Special Protection Scheme is typically proposed as an operational solution that does not require additional generation and permits operators to effectively prepare for the next event as well as ensure security should the next event occur. However, these systems have their own risks, which limit the extent to which they could be deployed as a solution for grid reliability augmentation. While they provide the value of protecting against the next event without the need for pre-contingency load shedding, they add points of potential failure to the transmission network. This increases the potential for load interruptions because sometimes these systems will operate when not required and other times they will not operate when needed.

above, depending on system design and expected system impacts, the **planned and controlled** interruption of supply to customers (load shedding), the removal from service of certain generators and curtailment of exports may be utilized to maintain grid “security.”

**c. CAISO Statutory Obligation Regarding Safe Operation**

The CAISO will maintain the system in a safe operating mode at all times. This obligation translates into respecting the Applicable Criteria at all times, for example during normal operating conditions **A (N-0)** the CAISO must protect for all single contingencies **B (N-1)** and common mode **C5 (N-2)** double line outages. As a further example after a single contingency the CAISO must readjust the system in order to be able to support the loss of the next most stringent contingency **C3 (N-1-1)**.





## **Definition of Terms**

### **Applicable Rating:**

This represents the equipment rating that will be used under certain contingency conditions.

Normal rating is to be used under normal conditions.

Long-term emergency ratings, if available, will be used in all emergency conditions as long as “system readjustment” is provided in the amount of time given (specific to each element) to reduce the flow to within the normal ratings. If not available normal rating is to be used.

Short-term emergency ratings, if available, can be used as long as “system readjustment” is provided in the “short-time” available in order to reduce the flow to within the long-term emergency ratings where the element can be kept for another length of time (specific to each element) before the flow needs to be reduced the below the normal ratings. If not available long-term emergency rating should be used.

Temperature-adjusted ratings shall not be used because this is a year-ahead study not a real-time tool, as such the worst-case scenario must be covered. In case temperature-adjusted ratings are the only ratings available then the minimum rating (highest temperature) given the study conditions shall be used.

CAISO Transmission Register is the only official keeper of all existing ratings mentioned above.

Ratings for future projects provided by PTO and agree upon by the CAISO shall be used.

Other short-term ratings not included in the CAISO Transmission Register may be used as long as they are engineered, studied and enforced through clear operating procedures that can be followed by real-time operators.

Path Ratings need to be maintained in order for these studies to comply with the Minimum Operating Reliability Criteria and assure that proper capacity is available in order to operate the system in real-time.

## **System Readjustment:**

This represents the actions taken by operators in order to bring the system within a safe operating zone after any given contingency in the system.

Actions that can be taken as system readjustment after a single contingency (Category B):

1. System configuration change – based on validated and approved operating procedures
2. Generation re-dispatch
  - a. Decrease generation (up to 1150 MW) – limit given by single contingency SPS as part of the CAISO Grid Planning standards (ISO G4)
  - b. Increase generation – this generation will become part of the LCR need

Actions, which shall not be taken as system readjustment after a single contingency (Category B):

1. Load drop – based on the intent of the CAISO/WECC and NERC criteria for category B contingencies.

This is one of the most controversial aspects of the interpretation of the existing NERC criteria because the footnote mentions that load drop can be done after a category B event in certain local areas in order to comply. However, the main body of the criteria spells out that **no dropping of load** should be done following a single contingency. All stakeholders and the CAISO agree that no **involuntary interruption of load** should be done immediately after a single contingency. **Further, the CAISO and LSAG now appear to agree on the viability of dropping load** as part of the system readjustment period – in order to protect for the next most limiting contingency. **After a single contingency, it is understood that the system is in a Category B condition and the system should be planned based on the body of the criteria with no shedding of load regardless of whether it is done immediately or in 15-30 minute after the original contingency.** Category C conditions only arrive after the second contingency has

happened; at that point in time, shedding load is allowed in a planned and controlled manner.

A robust California transmission system should be planned based on the main body of the criteria not the footnote regarding Category B contingencies. Therefore, if there are available resources in the area, they should be used first (and included in the LCR requirement) before resorting to involuntary load curtailment. The footnote can be used as a last resort for criteria compliance issues only if there are no resources available in the area.

This interpretation tends to guarantee that dropping of load is done only as a last resort for Category B conditions, if no other resource measures are available and it is in line with existing operating practices. Doing otherwise could institutionalize the dropping of load as the preferred way of planning the transmission system under Category B conditions and, as a consequence, it may seriously increase the exposure to outages by changing the manner in which the system is operated.

#### **Time allowed for manual readjustment:**

This is the amount of time required for the operator to take all actions necessary to prepare the system for the next contingency. This time should be less than 30 minutes, based on the CAISO Grid Planning criteria.

This is a somewhat controversial aspect of the interpretation of existing criteria. This item is very specific in the CAISO grid planning criteria. However, some will argue that 30 minutes only allows generation re-dispatch and automated switching where remote control is possible. If remote capability does not exist, a person needs to be dispatched in the field to do switching and 30 minutes does not allow sufficient time. If approved, an exemption from the existing time requirements may be given for small local areas with very limited exposure and impact, clearly described in operating procedures, and only until remote controlled switching equipment can be installed.

#### **Planned load drop:**

Is achieved when the most limiting equipment has short-term emergency ratings AND the operators have an operating procedure that clearly describes the actions that need to be taken in order to shed load.

**Controlled load drop:**

Is achieved with the use of a Special Protection Scheme.

**Special Protection Scheme:**

All known SPS shall all be used. New SPS needs to be verified and approved by the CAISO and needs to comply with the new SPS guideline described in the CAISO Grid Planning Standards.

**F. The Two Options Presented In This LCR Study**

This LCR study sets forth different solution “options” with varying ranges of potential service reliability consistent with CAISO’s Applicable Reliability Criteria:

**1. Option 1- Meet Performance Criteria Category B**

Option 1 is a service reliability level that reflects generation capacity that must be available to comply with reliability standards immediately after a NERC Category B given that load cannot be removed to meet this performance standard under Applicable Reliability Criteria. However, this capacity amount implicitly relies on load interruption as the **only means** of meeting any Applicable Reliability Criteria that is beyond the loss of a single transmission element (N-1). These situations will likely require substantial load interruptions in order to maintain system continuity and alleviate equipment overloads including load interruptions prior to the actual occurrence of the second contingency.<sup>5</sup>

**2. Option 2- Meet Performance Criteria Category C and Incorporate Suitable Operational Solutions**

---

<sup>5</sup> This potential for pre-contingency load shedding also occurs because real time operators must prepare for the loss of a common mode N-2 at all times.

Option 2 is a service reliability level that reflects generation capacity that is needed to readjust the system to prepare for the loss of a second transmission element (N-1-1) using generation capacity *after* considering all reasonable and feasible operating solutions (involving customer load interruption) developed and approved by the CAISO, in consultation with the PTOs. Under this option, there is no expected load interruption to end-use customers under normal or single contingency conditions as the CAISO operators prepare for the second contingency. However, the customer load will be interrupted in the event the second contingency occurs.

This Option 2 is the local capacity level that the CAISO needs in order to reliably operate the grid per NERC, WECC and CAISO standards. As such the CAISO is proposing that the CPUC adopt it through its RA proceedings.

### **III. Assumption Details: How the Study was Conducted**

#### **A. System Planning Criteria**

The following table provides a comparison of system planning criteria, based on the NERC performance standards, used in the study:

**Table 4: Criteria Comparison**

| Contingency Component(s)   | ISO Grid Planning Criteria   | Existing RMR Criteria                  | Locational Capacity Criteria  |
|--|--|--|---|
| <b><u>A – No Contingencies</u></b>   | X  | X                                      | X   |
| <b><u>B – Loss of a single element</u></b><br>1. Generator (G-1)<br>2. Transmission Circuit (L-1)<br>3. Transformer (T-1)<br>4. Single Pole (dc) Line<br>5. G-1 system readjusted L-1  | <br>X<br>X<br>X<br>X   | <br>X<br>X<br>X <sup>2</sup><br>X<br>X | <br>X <sup>1</sup><br>X <sup>1</sup><br>X <sup>1,2</sup><br>X <sup>1</sup><br>X |
| <b><u>C – Loss of two or more elements</u></b><br>1. Bus Section<br>2. Breaker (failure or internal fault)<br>3. L-1 system readjusted G-1<br>3. G-1 system readjusted T-1 or T-1 system readjusted G-1<br>3. L-1 system readjusted T-1 or T-1 system readjusted L-1<br>3. G-1 system readjusted G-1<br>3. L-1 system readjusted L-1<br>3. T-1 system readjusted T-1<br>4. Bipolar (dc) Line<br>5. Two circuits (Common Mode) L-2<br>6. SLG fault (stuck breaker or protection failure) for G-1<br>7. SLG fault (stuck breaker or protection failure) for L-1<br>8. SLG fault (stuck breaker or protection failure) for T-1<br>9. SLG fault (stuck breaker or protection failure) for Bus section<br>WECC-S3. Two generators (Common Mode) G-2 | <br>X<br>X<br>X<br>X<br>X<br>X<br>X<br>X<br>X<br>X<br>X<br>X<br>X<br>X<br>X <sup>3</sup> |  | <br><br>X<br>X<br>X<br>X<br>X<br><br>X<br>X<br><br>X                            |
| <b><u>D – Extreme event – loss of two or more elements</u></b><br>Any B1-4 system readjusted (Common Mode) L-2<br>All other extreme combinations D1-14.  | <br>X <sup>4</sup><br>X <sup>4</sup>   |  | <br>X <sup>3</sup>  |
| 1 System must be able to readjust to a safe operating zone in order to be able to support the loss of the next contingency.<br>2 A thermal or voltage criterion violation resulting from a transformer outage may not be cause for a local area reliability requirement if the violation is considered marginal (e.g. acceptable loss of facility life or low voltage), otherwise, such a violation will necessitate creation of a requirement.<br>3 Evaluate for risks and consequence, per NERC standards. No voltage collapse or dynamic instability allowed.<br>4 Evaluate for risks and consequence, per NERC standards.  |  |  |   |

A significant number of simulations were run to determine the most critical contingencies within each Local Capacity Area. Using power flow, post-transient load flow, and stability assessment tools, the system performance results of all the contingencies that were studied were measured against the system performance requirements defined by the criteria shown in Table 4. Where the specific system performance requirements were not met, generation was adjusted such that the minimum amount of generation required to meet the criteria was determined in the Local Capacity Area. The following describes how the criteria were tested for the specific type of analysis performed.

**1. Power Flow Assessment:**

| <u>Contingencies</u>              | <u>Thermal Criteria</u> <sup>3</sup> | <u>Voltage Criteria</u> <sup>4</sup> |
|-----------------------------------|--------------------------------------|--------------------------------------|
| Generating unit <sup>1, 6</sup>   | Applicable Rating                    | Applicable Rating                    |
| Transmission line <sup>1, 6</sup> | Applicable Rating                    | Applicable Rating                    |
| Transformer <sup>1, 6</sup>       | Applicable Rating <sup>5</sup>       | Applicable Rating <sup>5</sup>       |
| (G-1)(L-1) <sup>2, 6</sup>        | Applicable Rating                    | Applicable Rating                    |
| Overlapping <sup>6, 7</sup>       | Applicable Rating                    | Applicable Rating                    |

- <sup>1</sup> All single contingency outages (i.e. generating unit, transmission line or transformer) will be simulated on Participating Transmission Owners' local area systems.
- <sup>2</sup> Key generating unit out, system readjusted, followed by a line outage. This overlapping outage is considered a single contingency within the ISO Grid Planning Criteria. Therefore, load dropping for an overlapping G-1, L-1 scenario is not permitted.
- <sup>3</sup> Applicable Rating – Based on ISO Transmission Register or facility upgrade plans including established Path ratings.
- <sup>4</sup> Applicable Rating – ISO Grid Planning Criteria or facility owner criteria as appropriate including established Path ratings.
- <sup>5</sup> A thermal or voltage criterion violation resulting from a transformer outage may not be cause for a local area reliability requirement if the violation is considered marginal (e.g. acceptable loss of facility life or low voltage), otherwise, such a violation will necessitate creation of a requirement.
- <sup>6</sup> Following the first contingency (N-1), the generation must be sufficient to allow the operators to bring the system back to within acceptable (normal) operating range (voltage and loading) and/or appropriate OTC following the studied outage conditions.
- <sup>7</sup> During normal operation or following the first contingency (N-1), the generation must be sufficient to allow the operators to prepare for the next worst N-1 or common mode N-2 without pre-contingency interruptible or firm load shedding. SPS/RAS/Safety Nets may be utilized to satisfy the criteria after the second N-1

or common mode N-2 except if the problem is of a thermal nature such that short-term ratings could be utilized to provide the operators time to shed either interruptible or firm load. T-2s (two transformer bank outages) would be excluded from the criteria.

## **2. Post Transient Load Flow Assessment:**

Contingencies  
**Selected**<sup>1</sup>

Reactive Margin Criteria<sup>2</sup>  
**Applicable Rating**

- <sup>1</sup> If power flow results indicate significant low voltages for a given power flow contingency, simulate that outage using the post transient load flow program. The post-transient assessment will develop appropriate Q/V and/or P/V curves.
- <sup>2</sup> Applicable Rating – positive margin based on the higher of imports or load increase by 5% for N-1 contingencies, and 2.5% for N-2 contingencies.

## **3. Stability Assessment:**

Contingencies  
**Selected**<sup>1</sup>

Stability Criteria<sup>2</sup>  
**Applicable Rating**

- <sup>1</sup> Base on historical information, engineering judgment and/or if power flow or post transient study results indicate significant low voltages or marginal reactive margin for a given contingency.
- <sup>2</sup> Applicable Rating – ISO Grid Planning Criteria or facility owner criteria as appropriate.

## **B. Load Forecast**

### **1. System Forecast**

The California Energy Commission (CEC) derives the load forecast at the system as well as PTO levels. This relevant CEC forecast is then distributed across the entire system, down to the local area, division and substation level. PTO's use an econometric equation to forecast the system load. The predominant parameters affecting the system load are (1) number of households, (2) economic activity (gross metropolitan products, GMP), (3) temperature and (4) increased energy efficiency and distributed generation programs.

### **2. Base Case Load Development Method**



The method used to develop the base case loads is a melding process that extracts, adjusts and modifies the information from the system, distribution and municipal utility forecasts. The melding process consists of two parts: Part 1 deals with the PTO load and Part 2 deals with the municipal utility load. There may be small differences between the methodologies used by each PTO to disaggregate the CEC load forecast to their level of local area as well as bar-bus model; please refer to each PTO expansion plan for additional details.

#### **a. PTO Loads in Base Case**

The methods used to determine the PTO loads are for the most part similar. One part of the method deals with the determination of the division loads that would meet the requirements of 1-in-5 or 1-in-10 system or area base cases and the other part deals with the allocation of the division load to the transmission buses.

##### **i. Determination of division loads**

The annual division load is determined by summing the previous year division load and the current division load growth. Thus the key steps are the determination of the initial year division load and the annual load growth. The initial year for the base case development method is based heavily on recorded data. The division load growth in the system base case is determined in two steps. First, the total PTO load growth for the year is determined, as the product of the PTO load and the load growth rate from the system load forecast. Then this total PTO load growth is allocated to the division, based on the relative magnitude of the load growths projected for the divisions by the distribution planners. For example the 1-in-10 area base case, the division load growth determined for the system base case is adjusted to the 1-in-10 temperature using the load temperature relation determined from the latest peak load and temperature data of the division.

##### **ii. Allocation of division load to transmission bus level**

Since the base case loads are modeled at the various transmission buses, the division loads developed would need to be allocated to those buses. The allocation

process is different depending on the load types. For the most part each PTO's classifies its loads into four types: conforming, non-conforming, self-generation and generation-plant loads. Since the non-conforming and self-generation loads are assumed to not vary with temperature, their magnitude would be the same in the system or area base cases of the same year. The remaining load (the total division load developed above, less the quantity of non-conforming and self-generation load) is the conforming load. The remaining load would be allocated to the transmission buses based on the relative magnitude of the distribution forecast. The summation of all base case loads usually is higher than the load forecast because some load like self-generation and generation-plant are load behind the meter and they need to be modeled in the base cases, however for the most part metered or aggregated data with telemetry is used to come up with the load forecast.

#### **b. Municipal Loads in Base Case**

The municipal utility forecasts that have been provided to the CEC and PTOs for the purposes of their base cases were also used for this study.

#### **C. Power Flow Program Used in the LCR analysis**

The LCR technical studies were conducted using General Electric's Power System Load Flow (GE PSLF) program version 15.2. This GE PSLF program is available directly from GE or through the Western System Electricity Council (WECC) to any member.

To complete the local area component of this study, the starting base case was adjusted to reflect the latest generation and transmission projects as well as the one-in-ten-year peak load forecast for each local area as provided to the ISO by the Participating Transmission Owners ("PTOs").

Electronic contingency files provided by the PTOs were utilized to perform the numerous contingencies required to identify the LCR needs. These contingency files include remedial action and special protection schemes that are expected to be in operation during the year of study. An CAISO created EPCL (a GE programming language contained within the GE PSLF package) routine was used to run the

combination of contingencies; however, other routines are available from WECC with the GE PSFL package or can be developed by third parties to identify the most limiting combination of contingencies requiring the highest amount of generation within the local area to maintain power flows within applicable ratings.

#### **IV. Locational Capacity Requirement Study Results**

##### **A. Summary of Study Results**

The LCR results reflect two sets of generation. The first set is comprised of generation that would normally be expected to be on-line such as Municipal generation and Regulatory Must-take generation (state, federal, QFs and nuclear units). The second set is “market” generation. Within this overview, LCR is defined as the amount of generating capacity that is needed within a Local Capacity Area to reliably serve the load located within this area. The results of the CAISO’s analysis are summarized in the Executive Summary Tables.

**Table 5: 2007 Local Capacity Needs vs. Peak Load and Local Area Generation**

|                       | <b>2007<br/>Total LCR<br/>(MW)</b> | <b>Peak Load<br/>(1 in10)<br/>(MW)</b> | <b>2007 LCR<br/>as % of<br/>Peak Load</b> | <b>Total Dependable<br/>Local Area<br/>Generation (MW)</b> | <b>2007 LCR as %<br/>of Total Area<br/>Generation</b> |
|-----------------------|------------------------------------|--|---|--|---|
| Humboldt              | 202                                | 197                                    | 103%                                      | 206  | 98%   |
| North Coast/North Bay | 582                                | 1,513                                  | 38%                                       | 1,019  | 57%   |
| Sierra                | 2,161                              | 1,841                                  | 117%                                      | 1,848  | 117%**  |
| Stockton              | 589                                | 1,267                                  | 46%                                       | 571  | 103%**  |
| Greater Bay           | 4,771                              | 9,633                                  | 50%                                       | 6,545  | 73%   |
| Greater Fresno        | 2,219                              | 3,154                                  | 70%                                       | 2,912  | 76%**   |
| Kern                  | 786                                | 1,209                                  | 65%                                       | 1,009  | 78%**   |
| LA Basin              | 8,843                              | 19,325                                 | 46%                                       | 10,522   | 84%   |
| Big Creek/Ventura     | N/A                                | N/A                                    | N/A                                       | N/A  | N/A   |
| San Diego             | 2,781                              | 4,742                                  | 59%                                       | 2,932  | 95%   |
| <b>Total</b>          | <b>22,934</b>                      | <b>42,881*</b>                         | <b>53%*</b>                               | <b>27,471</b>  | <b>83%</b>  |

**Table 6: 2008 Local Capacity Needs vs. Peak Load and Local Area Generation**

|                       | <b>2008<br/>Total LCR<br/>(MW)</b> | <b>Peak Load<br/>(1 in10)<br/>(MW)</b> | <b>2008 LCR<br/>as % of<br/>Peak Load</b> | <b>Total Dependable<br/>Local Area<br/>Generation (MW)</b> | <b>2008 LCR as %<br/>of Total Area<br/>Generation</b> |
|-----------------------|------------------------------------|--|---|--|---|
| Humboldt              | 175                                | 199                                    | 88%                                       | 180  | 97%   |
| North Coast/North Bay | 676                                | 1495                                   | 45%                                       | 883  | 77%   |
| Sierra                | 2092                               | 2091                                   | 100%                                      | 1780   | 118%**  |
| Stockton              | 786                                | 1333                                   | 59%                                       | 536  | 147%**  |
| Greater Bay           | 4688                               | 9870                                   | 47%                                       | 6214   | 75%   |
| Greater Fresno        | 2382                               | 3260                                   | 73%                                       | 2991   | 80%**   |
| Kern                  | 486                                | 1324                                   | 37%                                       | 646  | 75%**   |
| LA Basin              | <del>40500</del> 101<br>30         | 19648                                  | <del>5352</del> %                         | 12093  | <del>8784</del> %                                     |
| Big Creek/Ventura     | 3658                               | 4911                                   | 74%                                       | 5396   | 68%   |
| San Diego             | 2957                               | 4916                                   | 60%                                       | 2959   | 100%  |
| <b>Total</b>          | <b>28,400</b> 30                   | <b>49,047*</b>                         | <b>5857%*</b>                             | <b>33,678</b>  | <b>8483%</b>  |

\* Value shown only illustrative, since each local area peaks at a different time.

\*\* Generation deficient LCA (or with sub-area that are deficient) – deficiency included in LCR. Generator deficient area implies that in order to comply with the criteria, at summer peak, load must be shed immediately after the first contingency.

Tables 5 and 6 shows how much of the local area load is dependent on local generation and how much local generation needs to be available in order to reliably (see LCR criteria) serve the load in those Local Capacity Areas. These tables also indicate where new transmission projects, new generation additions or demand side management programs would be most useful in order to reduce the dependency on existing, generally older and less efficient local area generation.

## **B. Summary of Zonal Needs**

The CAISO, PG&E, SDG&E, SCE and TURN ~~is-are~~ proposing an alternative method for determining zonal needs that is currently under discussion at the CPUC as part of the RA Phase 2, Track 1 issues. Based on the existing import allocation methodology, the only major 500 kV constraint not accounted for is path 26 (Midway-Vincent). ***The recently proposed method under review could allocate capacity on path 26 similar to the way imports are proposed to be allocated to LSEs.*** Thus as

a consequence from a high level, and without further refinement at this juncture, the total minimum resources needs (based on the latest CEC load forecast) in each the two relevant zones, SP26 and NP26 is:

| Zone                  | Load Forecast (MW) | 15% reserves (MW) | (-) Allocated imports (MW) | (-) <del>Maximum Allocated</del> Path 26 Flow (MW) | Total Zonal Resource Need (MW) |
|-----------------------|--------------------|-------------------|----------------------------|--|--------------------------------|
| <b>SP26</b>           | 28,778             | 4,318             | -8,598                     | <del>-3,7503,430</del>                             | <b>20,75821,078</b>            |
| <b>NP26=NP15+ZP26</b> | 26,220             | 3,933             | -4,101                     | <del>-3,2502,583</del>                             | <b>22,80223,469</b>            |

Where:

Load Forecast is the most recent 1 in 2 CEC forecast for year 2008.

Reserve Margin is the minimum CPUC approved planning reserve margin of 15%.

Allocated Imports are the actual 2007 numbers that are not expected to change much by 2008 because there are no additional transmission additions to the grid between now and summer of 2008.

~~Allocated Maximum Path 26 flow The CAISO determines the amount of Path 26 transfer capacity available for RA counting purposes after accounting for (1) Existing Transmission Contracts (ETCs) that serve load outside the CAISO control area<sup>6</sup> and (2) loop flow<sup>7</sup> from the maximum path 26 rating of 4000 MW (North-to-South) and 3000 MW (South-to-North). represents the path rating (N to S for SP 26 transfers and S to N for NP 26 transfers) adjusted for the inherent loop flow across WECC interconnected system (estimated here at 250 MW). An additional derate of P26 transfer capability may be necessary to accommodate legacy transmission contracts.~~

The SP 26 load forecast, import allocation and zonal results refer to the CAISO control area only. The NP 26 load forecast, import allocation and zonal results include the load associated with embedded control areas within the CAISO footprint. This is

<sup>6</sup> ~~The transfer capability on Path 26 must be derated to accommodate ETCs on Path 26 that are used to serve load outside of the CAISO control area. These particular ETCs represent physical transmission capacity that cannot be allocated to LSEs within the CAISO control area.~~

<sup>7</sup> ~~“Loop flow” is a phenomenon common to large electric power systems like the Western Electricity Coordinating Council. Power is scheduled to flow point-to-point on a Day-ahead and Hour-ahead basis through the CAISO. However, electric grid physics prevails and the actual power flow in real-time will differ from the pre-arranged scheduled flows. Loop flow is real, physical energy and it uses part of the available transfer capability on a path. If not accommodated, loop flow will cause overloading of lines which can jeopardize the security and reliability of the grid.~~

done in order to be consistent with the import allocation methodology which also considers that same load embedded in other control areas within the CAISO footprint.

All resources that are counted as part of the Local Area Capacity Requirements fully count toward the Zonal Need. The local areas of San Diego, LA Basin and Big Creek/Ventura are all situated in SP26 and the remaining local areas are in NP26.

### C. Summary of Results by Local Area

Each local area's overall requirement is determined by also achieving each sub-area requirement. Because these areas are a part of the interconnected electric system, the total for each local area is not simply a summation of the sub-area needs. For example, some sub-areas may overlap and therefore the same units may count for meeting the needs in both sub-areas.

#### 1. Humboldt Area

##### Area Definition

The transmission tie lines into the area include:

- 1) Bridgeville-Cottonwood 115 kV line #1
- 2) Humboldt-Trinity 115 kV line #1
- 3) Willits-Garberville 60 kV line #1
- 4) Trinity-Maple Creek 60 kV line #1

The substations that delineate the Humboldt Area are:

- 1) Bridgeville is in Cottonwood and Low Gap are out
- 2) Humboldt is in Trinity is out
- 3) Willits and Kekawaka are out Garberville is in
- 4) Trinity and Ridge Cabin are out Maple Creek is in

Total 2008 busload within the defined area: 194 MW with 5 MW of losses resulting in total load + losses of 199 MW.

Total units and qualifying capacity available in this area:

| MKT/SCHED RESOURCE ID | BUS # | BUS NAME | kV   | NQC   | UNIT ID | NQC Comments | CAISO Tag  |
|-----------------------|-------|----------|------|-------|---------|--------------|------------|
| FAIRHV_6_UNIT         | 31150 | FAIRHAVN | 13.8 | 12.58 | 1       |              | QF/Selfgen |
| HUMBPP_1_MOBLE2       | 31154 | HUMBOLDT | 13.2 | 15.00 | 2       |              | Market     |

|                 |       |          |      |       |   |                          |            |
|-----------------|-------|----------|------|-------|---|--------------------------|------------|
| HUMBPP_1_MOBLE3 | 31154 | HUMBOLDT | 13.2 | 15.00 | 1 |                          | Market     |
| HUMBPP_7_UNIT 1 | 31170 | HMBOLDT1 | 13.8 | 52.00 | 1 |                          | Market     |
| HUMBPP_7_UNIT 2 | 31172 | HMBOLDT2 | 13.8 | 53.00 | 1 |                          | Market     |
| KEKAWK_6_UNIT   | 31166 | KEKAWAK  | 9.1  | 0.00  | 1 |                          | QF/Selfgen |
| LAPAC_6_UNIT    | 31158 | LP SAMOA | 12.5 | 12.00 | 1 | No NQC - historical data | QF/Selfgen |
| PACLUM_6_UNIT   | 31152 | PAC.LUMB | 13.8 | 10.33 | 1 |                          | QF/Selfgen |
| PACLUM_6_UNIT   | 31152 | PAC.LUMB | 13.8 | 10.33 | 2 |                          | QF/Selfgen |
| ULTPBL_6_UNIT 1 | 31156 | ULTRAPWR | 12.5 | 0.00  | 1 | No NQC - historical data | Market     |

### **Critical Contingency Analysis Summary**

#### **Humboldt overall:**

The most critical contingency for the Humboldt area is the outage of the Bridgeville-Cottonwood 115 kV line over-lapping with an outage of one Humboldt Bay Power Plant. The local area limitation is low voltage and reactive power margin. This contingency establishes a Local Capacity **Requirement-Need** of 175 MW in 2008 (includes 45 MW of QF/Selfgen generation) as the minimum capacity necessary for reliable load serving capability within this area.

#### **Effectiveness factors:**

All units within this area have the same effectiveness factor. Units outside of this area are not effective.

#### **Humboldt Overall Requirements:**

| <b>2008</b>          | QF/Selfgen (MW) | Muni (MW) | Market (MW) | Max. Qualifying Capacity (MW) |
|----------------------|-----------------|-----------|-------------|-------------------------------|
| Available generation | 45              | 0         | 135         | 180                           |

| <b>2008</b>                        | Existing Generation Capacity Needed (MW) | Deficiency (MW) | Total MW Requirement |
|------------------------------------|--|-----------------|----------------------|
| Category B (Single) <sup>8</sup>   | 175                                      | 0               | 175                  |
| Category C (Multiple) <sup>9</sup> | 175                                      | 0               | 175                  |

<sup>8</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>9</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

## 2. North Coast / North Bay Area

### Area Definition

The North Coast/North Bay Area is composed of three sub-areas and the generation requirements within them.

The transmission tie facilities coming into the North Coast/North Bay area are:

- 1) Cortina-Mendocino 115 kV Line
- 2) Cortina-Eagle Rock 115 kV Line
- 3) Willits-Garberville 60 kV line #1
- 4) Vaca Dixon-Lakeville 230 kV line #1
- 5) Tulucay-Vaca Dixon 230 kV line #1
- 6) Lakeville-Sobrante 230 kV line #1
- 7) Ignacio-Sobrante 230 kV line #1

The substations that delineate the North Coast/North Bay area are:

- 1) Cortina is out Mendocino and Indian Valley are in
- 2) Cortina is out Eagle Rock, Highlands and Homestake are in
- 3) Willits and Kekawaka are in Garberville is out
- 4) Vaca Dixon is out Lakeville is in
- 5) Tulucay is in Vaca Dixon is out
- 6) Lakeville is in Sobrante is out
- 7) Ignacio is in Sobrante and Crocket are out

Total 2008 busload within the defined area: 1437 MW with 58 MW of losses resulting in total load + losses of 1495 MW.

Total units and qualifying capacity available in this area are shown in the following table:

| MKT/SCHED RESOURCE ID | BUS # | BUS NAME | kV   | NQC   | UNIT ID | LCR SUB-AREA NAME                        | NQC Comments | CAISO Tag  |
|-----------------------|-------|----------|------|-------|---------|--|--------------|------------|
| ADLIN_1_UNIT 1        | 31435 | GEO.ENGY | 9.1  | 6.80  | 1       | Eagle Rock, Eagle Rock-Fulton, Lakeville |              | QF/Selfgen |
| ADLIN_1_UNIT 2        | 31435 | GEO.ENGY | 9.1  | 7.01  | 2       | Eagle Rock, Eagle Rock-Fulton, Lakeville |              | QF/Selfgen |
| GEYS11_7_UNIT11       | 31412 | GEYSER11 | 13.8 | 60.00 | 1       | Eagle Rock, Eagle Rock-Fulton, Lakeville |              | Market     |
| GYS5X6_7_UNITS        | 31406 | GEYSR5-6 | 13.8 | 36.00 | 1       | Eagle Rock, Eagle Rock-Fulton, Lakeville |              | Market     |
| GYS5X6_7_UNITS        | 31406 | GEYSR5-6 | 13.8 | 36.00 | 2       | Eagle Rock, Eagle Rock-Fulton, Lakeville |              | Market     |



|                 |       |          |      |       |   |  |                                   |            |
|-----------------|-------|----------|------|-------|---|--|-----------------------------------|------------|
| GYS7X8_7_UNITS  | 31408 | GEYSER78 | 13.8 | 31.00 | 1 | Eagle Rock, Eagle Rock-Fulton, Lakeville |                                   | Market     |
| GYS7X8_7_UNITS  | 31408 | GEYSER78 | 13.8 | 31.00 | 2 | Eagle Rock, Eagle Rock-Fulton, Lakeville |                                   | Market     |
| INDVLY_1_UNITS  | 31436 | INDIAN V | 9.1  | 1.79  | 1 | Eagle Rock, Eagle Rock-Fulton, Lakeville |                                   | QF/Selfgen |
| POTTER_6_UNITS  | 31433 | POTTRVLY | 2.4  | 4.70  | 1 | Eagle Rock, Eagle Rock-Fulton, Lakeville |                                   | Market     |
| POTTER_6_UNITS  | 31433 | POTTRVLY | 2.4  | 2.25  | 3 | Eagle Rock, Eagle Rock-Fulton, Lakeville |                                   | Market     |
| POTTER_6_UNITS  | 31433 | POTTRVLY | 2.4  | 2.25  | 4 | Eagle Rock, Eagle Rock-Fulton, Lakeville |                                   | Market     |
| BEARCN_2_UNIT 1 | 31402 | BEAR CAN | 13.8 | 7.41  | 1 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | QF/Selfgen |
| BEARCN_2_UNIT 2 | 31402 | BEAR CAN | 13.8 | 7.37  | 2 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | QF/Selfgen |
| GEYS12_7_UNIT12 | 31414 | GEYSER12 | 13.8 | 41.00 | 1 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | Market     |
| GEYS14_7_UNIT14 | 31418 | GEYSER14 | 13.8 | 63.00 | 1 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | Market     |
| GEYS16_7_UNIT16 | 31420 | GEYSER16 | 13.8 | 75.00 | 1 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | Market     |
| GEYS17_7_UNIT17 | 31422 | GEYSER17 | 13.8 | 51.00 | 1 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | Market     |
| MONTPH_7_UNITS  | 32700 | MONTICLO | 9.1  | 2.50  | 1 | Fulton, Eagle Rock-Fulton, Lakeville     | Monthly NQC - used August for LCR | QF/Selfgen |
| MONTPH_7_UNITS  | 32700 | MONTICLO | 9.1  | 2.50  | 2 | Fulton, Eagle Rock-Fulton, Lakeville     | Monthly NQC - used August for LCR | QF/Selfgen |
| MONTPH_7_UNITS  | 32700 | MONTICLO | 9.1  | 0.59  | 3 | Fulton, Eagle Rock-Fulton, Lakeville     | Monthly NQC - used August for LCR | QF/Selfgen |
| NCPA_7_GP2UN3   | 38110 | NCPA2GY1 | 13.8 | 31.00 | 1 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | MUNI       |
| NCPA_7_GP2UN4   | 38112 | NCPA2GY2 | 13.8 | 30.00 | 1 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | MUNI       |
| SNMALF_6_UNITS  | 31446 | SONMA LF | 9.1  | 7.70  | 1 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | QF/Selfgen |
| WDFRDF_2_UNITS  | 31404 | WEST FOR | 13.8 | 12.07 | 1 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | QF/Selfgen |
| WDFRDF_2_UNITS  | 31404 | WEST FOR | 13.8 | 12.07 | 2 | Fulton, Eagle Rock-Fulton, Lakeville     |                                   | QF/Selfgen |
|                 | 31421 | BOTTLERK | 13.8 | 0.00  | 1 | Fulton, Eagle Rock-Fulton, Lakeville     | No NQC - historical data          | Market     |
| GEYS13_7_UNIT13 | 31416 | GEYSER13 | 13.8 | 70.00 | 1 | Lakeville                                |                                   | Market     |
| GEYS18_7_UNIT18 | 31424 | GEYSER18 | 13.8 | 40.00 | 1 | Lakeville                                |                                   | Market     |
| GEYS20_7_UNIT20 | 31426 | GEYSER20 | 13.8 | 40.00 | 1 | Lakeville                                |                                   | Market     |
| NCPA_7_GP1UN1   | 38106 | NCPA1GY1 | 13.8 | 34.25 | 1 | Lakeville                                |                                   | MUNI       |
| NCPA_7_GP1UN2   | 38108 | NCPA1GY2 | 13.8 | 32.25 | 1 | Lakeville                                |                                   | MUNI       |
| SANTFG_7_UNITS  | 31400 | SANTA FE | 13.8 | 33.21 | 1 | Lakeville                                |                                   | QF/Selfgen |
| SANTFG_7_UNITS  | 31400 | SANTA FE | 13.8 | 33.20 | 2 | Lakeville                                |                                   | QF/Selfgen |
| SMUDGO_7_UNIT 1 | 31430 | SMUDGEO1 | 13.8 | 38.00 | 1 | Lakeville                                |                                   | Market     |

## **Critical Contingency Analysis Summary**

### **Eagle Rock Sub-area**

The most critical overlapping contingency is the outage of the Eagle Rock-Silverado-Fulton 115 kV line and the Cortina #4 230/115 kV bank. The sub-area area limitation is thermal overloading of Fulton-Hopland 60 kV. This limiting contingency establishes a Local Capacity **Requirement-Need** of 215 MW in 2008 (includes 16 MW of QF generation) as the minimum capacity necessary for reliable load serving capability within this sub-area.

#### **Effectiveness factors:**

The units within the Eagle-Rock pocket have the same effectiveness to the above-mentioned constraint. Units outside this area are not effective.

### **Fulton Sub-area**

The most critical overlapping contingency is the outage of the Fulton-Ignacio 230 kV line #1 and the Fulton-Lakeville 230 kV line #1. The sub-area area limitation is thermal overloading of Sonoma-Pueblo 115 kV line #1. This limiting contingency establishes a Local Capacity **Requirement-Need** of 366 MW (includes 68 MW of QF generation) as the minimum capacity necessary for reliable load serving capability within this sub-area. All of the units required to meet the Eagle Rock pocket count towards the Fulton total requirement.

#### **Effectiveness factors:**

The following table has units that are at least 5% effective to the above-mentioned constraint.

| Gen Bus | Gen Name | Gen ID | Eff Fctr (%) |
|---------|----------|--------|--------------|
| 38112   | NCPA2GY2 | 1      | 25           |
| 38110   | NCPA2GY1 | 1      | 25           |
| 31422   | GEYSER17 | 1      | 25           |
| 31421   | BOTTLERK | 1      | 25           |
| 31420   | GEYSER16 | 1      | 25           |
| 31418   | GEYSER14 | 1      | 25           |

|       |          |   |    |
|-------|----------|---|----|
| 31414 | GEYSER12 | 1 | 25 |
| 31404 | WEST FOR | 2 | 25 |
| 31404 | WEST FOR | 1 | 25 |
| 31402 | BEAR CAN | 1 | 25 |
| 31402 | BEAR CAN | 2 | 25 |
| 31435 | GEO.ENGY | 1 | 15 |
| 31435 | GEO.ENGY | 2 | 15 |
| 31412 | GEYSER11 | 1 | 15 |
| 31408 | GEYSER78 | 1 | 15 |
| 31408 | GEYSER78 | 2 | 15 |
| 31406 | GEYSR5-6 | 1 | 15 |
| 31406 | GEYSR5-6 | 2 | 15 |

**Lakeville Sub-area**

The 2008 most limiting contingency is the outage of Vaca Dixon-Lakeville 230 kV line with DEC power plant out of service. The sub-area limitation is thermal overloading of the Vaca Dixon-Tulucay 230 kV. This limiting contingency establishes a Local Capacity Requirement Need of 676 MW (includes 134 MW of QF generation). The LCR requirement for Eagle Rock and Fulton sub-area can be counted toward fulfilling the requirement of Lakeville sub-area.

**Effectiveness factors:**

The following table has units within the North Coast/North Bay area at least 5% effective to the above-mentioned constraint.

| Gen Bus | Gen Name | Gen ID | Eff Fctr (%) |
|---------|----------|--------|--------------|
| 31400   | SANTA FE | 2      | 37           |
| 31430   | SMUDGE01 | 1      | 37           |
| 31400   | SANTA FE | 1      | 37           |
| 31416   | GEYSER13 | 1      | 37           |
| 31424   | GEYSER18 | 1      | 37           |
| 31426   | GEYSER20 | 1      | 37           |
| 38106   | NCPA1GY1 | 1      | 37           |
| 38108   | NCPA1GY2 | 1      | 37           |
| 31421   | BOTTLERK | 1      | 35           |
| 31404   | WEST FOR | 2      | 35           |
| 31402   | BEAR CAN | 1      | 35           |
| 31402   | BEAR CAN | 2      | 35           |
| 31404   | WEST FOR | 1      | 35           |
| 31414   | GEYSER12 | 1      | 35           |
| 31418   | GEYSER14 | 1      | 35           |
| 31420   | GEYSER16 | 1      | 35           |

|       |          |   |    |
|-------|----------|---|----|
| 31422 | GEYSER17 | 1 | 35 |
| 38110 | NCPA2GY1 | 1 | 35 |
| 38112 | NCPA2GY2 | 1 | 35 |
| 31406 | GEYSR5-6 | 1 | 19 |
| 31406 | GEYSR5-6 | 2 | 19 |
| 31408 | GEYSER78 | 1 | 19 |
| 31408 | GEYSER78 | 2 | 19 |
| 31412 | GEYSER11 | 1 | 19 |
| 31435 | GEO.ENGY | 1 | 19 |
| 31435 | GEO.ENGY | 2 | 19 |

**North Coast/North Bay Overall Requirements:**

| <b>2008</b>          | QF/Seflgen (MW) | Muni (MW) | Market (MW) | Max. Qualifying Capacity (MW) |
|----------------------|-----------------|-----------|-------------|-------------------------------|
| Available generation | 134             | 128       | 621         | 883                           |

| <b>2008</b>                         | Existing Generation Capacity Needed (MW) | Deficiency (MW) | Total MW Requirement |
|-------------------------------------|--|-----------------|----------------------|
| Category B (Single) <sup>10</sup>   | 676                                      | 0               | 676                  |
| Category C (Multiple) <sup>11</sup> | 676                                      | 0               | 676                  |

**3. Sierra Area**

**Area Definition**

The transmission tie lines into the Sierra Area are:

- 1) Table Mountain-Rio Oso 230 kV line
- 2) Table Mountain-Palermo 230 kV line
- 3) Table Mt-Pease 60 kV line
- 4) Caribou-Palermo 115 kV line
- 5) Drum-Summit 115 kV line #1
- 6) Drum-Summit 115 kV line #2
- 7) Spaulding-Summit 60 kV line
- 8) Brighton-Bellota 230 kV line
- 9) Rio Oso-Lockeford 230 kV line
- 10) Gold Hill-Eight Mile Road 230 kV line
- 11) Gold Hill-Lodi Stig 230 kV line

<sup>10</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>11</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

12) Gold Hill-Lake 230 kV line

The substations that delineate the Sierra Area are:

- 1) Table Mountain is out Rio Oso is in
- 2) Table Mountain is out Palermo is in
- 3) Table Mt is out Pease is in
- 4) Caribou is out Palermo is in
- 5) Drum is in Summit is out
- 6) Drum is in Summit is out
- 7) Spaulding is in Summit is out
- 8) Brighton is in Bellota is out
- 9) Rio Oso is in Lockeford is out
- 10) Gold Hill is in Eight Mile is out
- 11) Gold Hill is in Lodi Stig is out
- 12) Gold Hill is in Lake is out

Total 2008 busload within the defined area: 1983 MW with 108 MW of losses resulting in total load + losses of 2091 MW.

Total units and qualifying capacity available in this area:

| MKT/SCHED RESOURCE ID | BUS # | BUS NAME | kV   | NQC   | UNIT ID | LCR SUB-AREA NAME                                       | NQC Comments                      | CAISO Tag   |
|-----------------------|-------|----------|------|-------|---------|---|-----------------------------------|-------------|
| BOGUE_1_UNITA1        | 32451 | FREC     | 13.8 | 45.00 | 1       | Drum-Rio Oso, South of Palermo, South of Table Mountain |                                   | Market      |
| GRNLF1_1_UNITS        | 32490 | GRNLEAF1 | 13.8 | 7.54  | 1       | Drum-Rio Oso, South of Palermo, South of Table Mountain |                                   | QF/Self gen |
| GRNLF1_1_UNITS        | 32490 | GRNLEAF1 | 13.8 | 38.52 | 2       | Drum-Rio Oso, South of Palermo, South of Table Mountain |                                   | QF/Self gen |
| CAMPFW_7_FARWS<br>T   | 32470 | CMP.FARW | 9.1  | 6.50  | 1       | South of Table Mountain                                 | No NQC - historical data          | MUNI        |
| NAROW2_2_UNIT         | 32468 | NARROWS2 | 9.1  | 34.88 | 1       | South of Table Mountain                                 | Monthly NQC - used August for LCR | MUNI        |
| BIOMAS_1_UNIT 1       | 32156 | WOODLAND | 9.1  | 18.53 | 1       | Drum-Rio Oso, South of Palermo, South of Table Mountain |                                   | QF/Self gen |
| BOWMN_6_UNIT          | 32480 | BOWMAN   | 9.1  | 1.15  | 1       | Drum-Rio Oso, South of Palermo, South of Table Mountain |                                   | MUNI        |
| DEERCRCR_6_UNIT 1     | 32474 | DEER CRK | 9.1  | 5.70  | 1       | Drum-Rio Oso, South of Palermo, South of Table Mountain |                                   | Market      |
| DRUM_7_PL1X2          | 32504 | DRUM 1-2 | 6.6  | 13.00 | 1       | Drum-Rio Oso, South of Palermo, South of Table Mountain |                                   | Market      |
| DRUM_7_PL1X2          | 32504 | DRUM 1-2 | 6.6  | 13.00 | 2       | Drum-Rio Oso, South of Palermo, South of Table Mountain |                                   | Market      |

|                     |       |          |      |       |   |   |                                   |             |
|---------------------|-------|----------|------|-------|---|---|-----------------------------------|-------------|
| DRUM_7_PL3X4        | 32506 | DRUM 3-4 | 6.6  | 14.00 | 1 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | Market      |
| DRUM_7_PL3X4        | 32506 | DRUM 3-4 | 6.6  | 14.00 | 2 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | Market      |
| DRUM_7_UNIT 5       | 32454 | DRUM 5   | 13.8 | 49.50 | 1 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | Market      |
| DUTCH1_7_UNIT 1     | 32464 | DTCHFLT1 | 11   | 22.00 | 1 | Drum-Rio Oso, South of Rio Oso, South of Palermo, South of Table Mountain         |                                   | Market      |
| DUTCH2_7_UNIT 1     | 32502 | DTCHFLT2 | 6.9  | 26.00 | 1 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | MUNI        |
| HAYPRS_6_QFUNTS     | 32488 | HAYPRES+ | 9.1  | 0.68  | 1 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | QF/Self gen |
| HAYPRS_6_QFUNTS     | 32488 | HAYPRES+ | 9.1  | 0.68  | 2 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | QF/Self gen |
| NA                  | 32162 | RIV.DLTA | 9.11 | 3.10  | 1 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | QF/Self gen |
| OXBOW_6_DRUM        | 32484 | OXBOW F  | 9.1  | 6.00  | 1 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | MUNI        |
| ROLLIN_6_UNIT       | 32476 | ROLLINSF | 9.1  | 11.70 | 1 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | MUNI        |
| SPAULD_6_UNIT 3     | 32472 | SPAULDG  | 9.1  | 5.80  | 3 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           |                                   | Market      |
| SPAULD_6_UNIT12     | 32472 | SPAULDG  | 9.1  | 4.78  | 1 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           | Monthly NQC - used August for LCR | Market      |
| SPAULD_6_UNIT12     | 32472 | SPAULDG  | 9.1  | 4.78  | 2 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           | Monthly NQC - used August for LCR | Market      |
| UCDAVS_1_UNIT       | 32166 | UC DAVIS | 9.1  | 3.50  | 1 | Drum-Rio Oso, South of Palermo, South of Table Mountain                           | No NQC - historical data          | QF/Self gen |
| FORBST_7_UNIT 1     | 31814 | FORBSTWN | 11.5 | 39.00 | 1 | Drum-Rio Oso, South of Table Mountain   |                                   | MUNI        |
| NA                  | 31862 | DEADWOOD | 9.1  | 2.00  | 1 | Drum-Rio Oso, South of Table Mountain   | No NQC - historical data          | MUNI        |
| SLYCRK_1_UNIT 1     | 31832 | SLY.CR.  | 9.1  | 13.00 | 1 | Drum-Rio Oso, South of Table Mountain   |                                   | MUNI        |
| WDLEAF_7_UNIT 1     | 31794 | WOODLEAF | 13.8 | 55.00 | 1 | Drum-Rio Oso, South of Table Mountain   |                                   | MUNI        |
| GRNLF1_1_UNIT 1     | 32496 | YCEC     | 13.8 | 46.00 | 1 | Pease, Drum-Rio Oso, South of Table Mountain                                      |                                   | Market      |
| GRNLF2_1_UNIT       | 32492 | GRNLEAF2 | 13.8 | 45.79 | 1 | Pease, Drum-Rio Oso, South of Table Mountain                                      |                                   | QF/Self gen |
| YUBACT_1_SUNSW<br>T | 32494 | YUBA CTY | 9.1  | 49.50 | 1 | Pease, Drum-Rio Oso, South of Table Mountain                                      |                                   | QF/Self gen |
| HALSEY_6_UNIT       | 32478 | HALSEY F | 9.1  | 11.00 | 1 | Placer, Drum-Rio Oso, South of Rio Oso, South of Palermo, South of Table Mountain |                                   | Market      |
| WISE_1_UNIT 1       | 32512 | WISE     | 12   | 9.20  | 1 | Placer, Drum-Rio Oso,   | Monthly NQC -                     | Market      |

|                 |       |          |      |        |   |   |   |                     |  |
|-----------------|-------|----------|------|--------|---|---|---|---------------------|--|
|                 |       |          |      |        |   |   | South of Rio Oso, South of Palermo, South of Table Mountain | used August for LCR |  |
| WISE_1_UNIT 2   | 32512 | WISE     | 12   | 2.79   | 1 | Placer, Drum-Rio Oso, South of Rio Oso, South of Palermo, South of Table Mountain | Monthly NQC - used August for LCR                           | Market              |  |
| NWCSTL_7_UNIT 1 | 32460 | NEWCSTLE | 13.2 | 1.30   | 1 | Placer, Drum-Rio Oso, South of Rio Oso, South of Palermo, South of Table Mountain | Monthly NQC - used August for LCR                           | Market              |  |
| ELDORO_7_UNIT 1 | 32513 | ELDRADO1 | 21.6 | 11.00  | 1 | Placer, Drum-Rio Oso, South of Rio Oso, South of Palermo, South of Table Mountain |   | Market              |  |
| ELDORO_7_UNIT 2 | 32514 | ELDRADO2 | 21.6 | 11.00  | 1 | Placer, Drum-Rio Oso, South of Rio Oso, South of Palermo, South of Table Mountain |   | Market              |  |
| PLACVL_1_CHILIB | 32510 | CHILIBAR | 4.2  | 7.00   | 1 | Placerville, South of Rio Oso, South of Table Mountain                            |   | Market              |  |
| BELDEN_7_UNIT 1 | 31784 | BELDEN   | 13.8 | 115.00 | 1 | South of Palermo, South of Table Mountain   |   | Market              |  |
| BUCKCK_7_PL1X2  | 31820 | BCKS CRK | 11   | 29.00  | 1 | South of Palermo, South of Table Mountain   |   | Market              |  |
| BUCKCK_7_PL1X2  | 31820 | BCKS CRK | 11   | 29.00  | 2 | South of Palermo, South of Table Mountain   |   | Market              |  |
| CRESTA_7_PL1X2  | 31812 | CRESTA   | 11.5 | 35.00  | 1 | South of Palermo, South of Table Mountain   |   | Market              |  |
| CRESTA_7_PL1X2  | 31812 | CRESTA   | 11.5 | 35.00  | 2 | South of Palermo, South of Table Mountain   |   | Market              |  |
| POEPH_7_UNIT 1  | 31790 | POE 1    | 13.8 | 60.00  | 1 | South of Palermo, South of Table Mountain   |   | Market              |  |
| POEPH_7_UNIT 2  | 31792 | POE 2    | 13.8 | 60.00  | 1 | South of Palermo, South of Table Mountain   |   | Market              |  |
| RCKCRK_7_UNIT 1 | 31786 | ROCK CK1 | 13.8 | 56.00  | 1 | South of Palermo, South of Table Mountain   |   | Market              |  |
| RCKCRK_7_UNIT 2 | 31788 | ROCK CK2 | 13.8 | 56.00  | 1 | South of Palermo, South of Table Mountain   |   | Market              |  |
| CHICPK_7_UNIT 1 | 32462 | CHI.PARK | 11.5 | 38.00  | 1 | Drum-Rio Oso, South of Rio Oso, South of Palermo, South of Table Mountain         |   | MUNI                |  |
| FMEADO_7_UNIT   | 32508 | FRNCH MD | 4.2  | 16.01  | 1 | South of Rio Oso, South of Palermo, South of Table Mountain                       | Monthly NQC - used August for LCR                           | MUNI                |  |
| HELLHL_6_UNIT   | 32486 | HELLHOLE | 9.1  | 0.50   | 1 | South of Rio Oso, South of Palermo, South of Table Mountain                       | No NQC - historical data                                    | MUNI                |  |
| MIDFRK_7_UNIT 1 | 32456 | MIDLFORK | 13.8 | 63.40  | 1 | South of Rio Oso, South of Palermo, South of Table Mountain                       | No NQC - historical data                                    | MUNI                |  |
| MIDFRK_7_UNIT 2 | 32456 | MIDLFORK | 13.8 | 63.40  | 2 | South of Rio Oso, South of Palermo, South of Table Mountain                       | No NQC - historical data                                    | MUNI                |  |
| RALSTN_7_UNIT 1 | 32458 | RALSTON  | 13.8 | 86.00  | 1 | South of Rio Oso, South of Palermo, South of Table Mountain                       | No NQC - historical data                                    | MUNI                |  |
| SPI LI_2_UNIT 1 | 32498 | SPILINCF | 12.5 | 4.19   | 1 | Drum-Rio Oso, South of Palermo, South of Rio Oso, South of Table                  |   | QF/Self gen         |  |

| Unit ID         | Capacity (MW) | Unit Name | Rating | Value  | Count | Location  | Notes                             | Generation Type |
|-----------------|---------------|-----------|--------|--------|-------|---|-----------------------------------|-----------------|
| ULTRCK_2_UNIT   | 32500         | ULTR RCK  | 9.1    | 19.64  | 1     | Mountain<br>Drum-Rio Oso, South of Palermo, South of Rio Oso, South of Table Mountain |                                   | QF/Self gen     |
| COLGAT_7_UNIT 1 | 32450         | COLGATE1  | 13.8   | 165.80 | 1     | South of Table Mountain   |                                   | MUNI            |
| COLGAT_7_UNIT 2 | 32452         | COLGATE2  | 13.8   | 161.68 | 1     | South of Table Mountain   | Monthly NQC - used August for LCR | MUNI            |
| KELYRG_6_UNIT   | 31834         | KELLYRDG  | 9.1    | 10.00  | 1     | Drum-Rio Oso, South of Table Mountain   |                                   | MUNI            |
| NAROW1_2_UNIT   | 32466         | NARROWS1  | 9.1    | 0.01   | 1     | South of Table Mountain   | Monthly NQC - used August for LCR | Market          |
| OROVIL_6_UNIT   | 31888         | OROVILLE  | 9.1    | 6.08   | 1     | Drum-Rio Oso, South of Table Mountain   |                                   | QF/Self gen     |
| PACORO_6_UNIT   | 31890         | PO POWER  | 9.1    | 8.20   | 1     | Drum-Rio Oso, South of Table Mountain   |                                   | QF/Self gen     |
| PACORO_6_UNIT   | 31890         | PO POWER  | 9.1    | 8.20   | 2     | Drum-Rio Oso, South of Table Mountain   |                                   | QF/Self gen     |

### **Critical Contingency Analysis Summary**

#### **South of Table Mountain Sub-area**

The most critical contingency is the loss of the Table Mountain-Rio Oso 230 kV line with one of the Colgate Units out of service. The area limitation is thermal overloading of the Table Mt-Palermo 230 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 1780 MW (includes 214 MW of QF and 800 MW of Muni generation) in 2008 as the minimum capacity necessary for reliable load serving capability within this pocket.

#### **Effectiveness factors:**

All units within this area are needed therefore no effectiveness factor is required.

**No sub-area analysis is required. It is done here for planning purposes only.**

#### **Colgate Sub-area**

No requirements due to the addition of the Atlantic-Lincoln 115 kV upgrade project.

#### **Pease Sub-area**



The most critical contingency is the loss of the Palermo-East Nicolaus 115 kV line with Yuba City Cogen unit out of service. The area limitation is thermal overloading of the Palermo-Pease 115 kV line. This limiting contingency establishes a Local Capacity **Requirement Need** of 145 MW (includes 96 MW of QF generation and 3 MW of deficiency) in 2008 as the minimum capacity necessary for reliable load serving capability within this pocket. It is assumed that Oliverhurst is normally served from Palermo-Bogue 115 kV line and not from Pease-Rio Oso 115 kV line.

**Effectiveness factors:**

All units within this area (Greenleaf #2, Yuba City and Yuba City EC) are needed therefore no effectiveness factor is required.

***Bogue Sub-area***

No requirements due to the addition of the South of Palermo 115 kV reconductoring project.

***South of Palermo Sub-area***

The most critical contingency is the loss of the Double Circuit Tower Line Table Mountain-Rio Oso and Colgate-Rio Oso 230 kV lines. The area limitation is thermal overloading of the Pease-Rio Oso 115 kV line. This limiting contingency establishes a Local Capacity **Requirement Need** of 1275 MW (includes 475 MW of QF and Muni generation as well as 75 MW of deficiency) in 2008 as the minimum capacity necessary for reliable load serving capability within this pocket. It is assumed that Oliverhurst is normally served from Palermo-Bogue 115 kV line and not from Pease-Rio Oso 115 kV line.

The single most critical contingency is the loss of the Palermo-East Nicolaus 115 kV line with Belden unit out of service. The area limitation is thermal overloading of the Pease-Rio Oso 115 kV line. This limiting contingency establishes a Local Capacity **Requirement Need** of 1140 MW (includes 475 MW of QF and Muni generation) in 2008.

It is assumed that Oliverhurst is normally served from Palermo-Bogue 115 kV line and not from Pease-Rio Oso 115 kV line.

**Effectiveness factors:**

All units within this area are needed therefore no effectiveness factor is required.

***Placerville Sub-area***

The most critical contingency is the loss of the Gold Hill-Clarksville 115 kV line followed by loss of the Gold Hill-Missouri Flat #2 115 kV line. The area limitation is thermal overloading of the Gold Hill-Missouri Flat #1 115 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 95 MW (includes 0 MW of QF and Muni generation as well as 66 MW of deficiency) in 2008 as the minimum capacity necessary for reliable load serving capability within this pocket.

The single most critical contingency is the loss of the Gold Hill-Clarksville 115 kV line with one of the El Dorado units out of service. The area limitation is thermal overloading of the Gold Hill-Missouri Flat #1 115 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 21 MW (includes 0 MW of QF and Muni generation) in 2008.

**Effectiveness factors:**

All units within this area (El Dorado units 1&2 and Chili Bar) are needed therefore no effectiveness factor is required.

***Placer Sub-area***

The most critical contingency is the loss of the Drum-Higgins 115 kV line followed by loss of the Gold Hill-Placer #2 115 kV line. The area limitation is thermal overloading of the Gold Hill-Placer #1 115 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 148 MW (includes 0 MW of QF and Muni generation as well as 124 MW of deficiency) in 2008 as the minimum capacity necessary for reliable load serving capability within this pocket.

The single most critical contingency is the loss of the Drum-Higgins 115 kV line with the Halsey unit out of service. The area limitation is thermal overloading of the Gold Hill-Placer #1 115 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 51 MW (includes 0 MW of QF and Muni generation as well as 27 MW of deficiency) in 2008.

**Effectiveness factors:**

All units within this area (Wise units 1&2, Newcastle and Halsey) are needed therefore no effectiveness factor is required.

***Drum-Rio Oso Sub-area***

The most critical contingency is the loss of the Rio Oso #2 230/115 transformer followed by loss of the Rio Oso-Brighton 230 kV line. The area limitation is thermal overloading of the Rio Oso #1 230/115 kV transformer. This limiting contingency establishes a Local Capacity Requirement Need of 831 MW (includes 411 MW of QF and Muni generation as well as 177 MW of deficiency) in 2008 as the minimum capacity necessary for reliable load serving capability within this pocket.

The single most critical contingency is the loss of the Rio Oso #2 230/115 transformer. The area limitation is thermal overloading of the Rio Oso #1 230/115 kV transformer. This limiting contingency establishes a Local Capacity Requirement Need of 651 MW in 2008 (includes 411 MW of QF and Muni generation).

**Effectiveness factors:**

All units within this area are needed for the most limiting contingency therefore no effectiveness factor is required.

***South of Rio Oso Sub-area***

The most critical contingency is the loss of the Rio Oso-Gold Hill 230 line followed by loss of the Gold Hill-Ralston 230 kV line or vice versa. The area limitation is thermal overloading of the Rio Oso-Atlantic 230 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 584 MW (includes 310 MW of QF and Muni

generation as well as 197 MW of deficiency) in 2008 as the minimum capacity necessary for reliable load serving capability within this pocket.

The single most critical contingency is the loss of the Rio Oso-Gold Hill 230 line with the Ralston unit out of service. The area limitation is thermal overloading of the Rio Oso-Atlantic 230 kV line. This limiting contingency establishes a Local Capacity **Requirement Need** of 441 MW (includes 310 MW of QF and Muni generation as well as 72 MW of deficiency) in 2008.

**Effectiveness factors:**

All units within this area are needed for the most limiting contingency therefore no effectiveness factor is required.

**Sierra Overall Requirements:**

| 2008                 | QF (MW) | Muni (MW) | Market (MW) | Max. Qualifying Capacity (MW) |
|----------------------|---------|-----------|-------------|-------------------------------|
| Available generation | 214     | 800       | 766         | 1780                          |

| 2008                                | Existing Generation Capacity Needed (MW) | Deficiency (MW) | Total MW Requirement |
|-------------------------------------|--|-----------------|----------------------|
| Category B (Single) <sup>12</sup>   | 1780                                     | 89              | 1869                 |
| Category C (Multiple) <sup>13</sup> | 1780                                     | 312             | 2092                 |

**4. Stockton Area**

**Area Definition**

The transmission facilities that establish the boundary of the Tesla-Bellota Sub-area are:

- 1) Bellota 230/115 kV Transformer #1
- 2) Bellota 230/115 kV Transformer #2
- 3) Tesla-Tracy 115 kV Line
- 4) Tesla-Salado 115 kV Line

<sup>12</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>13</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

- 5) Tesla-Salado-Manteca 115 kV line
- 6) Tesla-Shulte 115 kV Line
- 7) Tesla-Kasson-Manteca 115 kV Line

The substations that delineate the Tesla-Bellota Sub-area are:

- 1) Bellota 230 kV is out Bellota 115 kV is in
- 2) Bellota 230 kV is out Bellota 115 kV is in
- 3) Tesla is out Tracy is in
- 4) Tesla is out Salado is in
- 5) Tesla is out Salado and Manteca are in
- 6) Tesla is out Shulte is in
- 7) Tesla is out Kasson and Manteca are in

The transmission facilities that establish the boundary of the Lockeford Sub-area are:

- 1) Lockeford-Industrial 60 kV line
- 2) Lockeford-Lodi #1 60 kV line
- 3) Lockeford-Lodi #2 60 kV line
- 4) Lockeford-Lodi #3 60 kV line

The substations that delineate the Lockeford Sub-area are:

- 1) Lockeford is out Industrial is in
- 2) Lockeford is out Lodi is in
- 3) Lockeford is out Lodi is in
- 4) Lockeford is out Lodi is in

The transmission facilities that establish the boundary of the Stagg Sub-area are:

- 1) Tesla – Stagg 230 kV Line
- 2) Tesla – Eight Mile Road 230 kV Line
- 3) Gold Hill – Eight Mile Road 230 kV Line
- 4) Gold Hill - Lodi Stigg 230 kV Line

The substations that delineate the Stagg Sub-area is:

- 1) Tesla is out Stagg is in
- 2) Tesla is out Eight Mile Road is in
- 3) Gold Hill is out Eight Mile Road is in
- 4) Gold Hill is out Lodi Stigg is in

Total 2008 busload within the defined area: 1306 MW with 27 MW of losses resulting in total load + losses of 1333 MW.

Total units and qualifying capacity available in this area:

| <b>MKT/SCHED<br/>RESOURCE ID</b> | <b>BUS<br/>#</b> | <b>BUS NAME</b> | <b>kV</b> | <b>NQC</b> | <b>UNI<br/>T ID</b> | <b>LCR SUB-<br/>AREA<br/>NAME</b> | <b>NQC Comments</b>      | <b>CAISO Tag</b> |
|----------------------------------|------------------|-----------------|-----------|------------|---------------------|-----------------------------------|--------------------------|------------------|
| LODI25_2_UNIT 1                  | 38120            | LODI25CT        | 9.11      | 25.00      | 1                   | Lockeford                         | No NQC - historical data | MUNI             |

|                 |       |          |      |       |   |              |                                   |            |
|-----------------|-------|----------|------|-------|---|--------------|-----------------------------------|------------|
| NA              | 33830 | GEN.MILL | 9.11 | 2.50  | 1 | Lockeford    | No NQC - historical data          | QF/Selfgen |
| STIGCT_2_LODI   | 38114 | Stig CC  | 13.8 | 49.50 | 1 | Stagg        |                                   | MUNI       |
| BEARDS_7_UNIT 1 | 34074 | BEARDSLY | 6.9  | 8.36  | 1 | TeslaBellota | Monthly NQC - used August for LCR | MUNI       |
| CAMCHE_1_PL1X3  | 33850 | CAMANCHE | 4.2  | 3.50  | 1 | TeslaBellota | No NQC - historical data          | MUNI       |
| CAMCHE_1_PL1X3  | 33850 | CAMANCHE | 4.2  | 3.50  | 2 | TeslaBellota | No NQC - historical data          | MUNI       |
| CAMCHE_1_PL1X3  | 33850 | CAMANCHE | 4.2  | 3.50  | 3 | TeslaBellota | No NQC - historical data          | MUNI       |
| DONNLS_7_UNIT   | 34058 | DONNELLS | 13.8 | 72.00 | 1 | TeslaBellota | Monthly NQC - used August for LCR | MUNI       |
| SCHLTE_1_UNITA1 | 33805 | GWFTRCY1 | 13.8 | 83.56 | 1 | TeslaBellota |                                   | Market     |
| SCHLTE_1_UNITA2 | 33807 | GWFTRCY2 | 13.8 | 82.88 | 1 | TeslaBellota |                                   | Market     |
| SNDBAR_7_UNIT 1 | 34060 | SANDBAR  | 13.8 | 8.54  | 1 | TeslaBellota |                                   | MUNI       |
| SPIFBD_1_PL1X2  | 33917 | FBERBORD | 115  | 3.20  | 1 | TeslaBellota | No NQC - historical data          | QF/Selfgen |
| SPRGAP_1_UNIT 1 | 34078 | SPRNG GP | 6    | 6.70  | 1 | TeslaBellota |                                   | Market     |
| STANIS_7_UNIT 1 | 34062 | STANISLS | 13.8 | 91.00 | 1 | TeslaBellota |                                   | Market     |
| STNRES_1_UNIT   | 34056 | STNSLSRP | 13.8 | 16.33 | 1 | TeslaBellota |                                   | QF/Selfgen |
| STOKCG_1_UNIT 1 | 33814 | CPC STCN | 12.5 | 45.33 | 1 | TeslaBellota |                                   | QF/Selfgen |
| TULLCK_7_UNITS  | 34076 | TULLOCH  | 6.9  | 8.23  | 1 | TeslaBellota | Monthly NQC - used August for LCR | MUNI       |
| TULLCK_7_UNITS  | 34076 | TULLOCH  | 6.9  | 8.24  | 2 | TeslaBellota | Monthly NQC - used August for LCR | MUNI       |
| ULTPCH_1_UNIT 1 | 34050 | CH.STN.  | 13.8 | 14.62 | 1 | TeslaBellota |                                   | QF/Selfgen |

## **Critical Contingency Analysis Summary**

### ***Stockton overall***

The requirement for this area is driven by the sum of requirements for the Tesla-Bellota, Lockeford, and Stagg Sub-areas.

### ***Tesla-Bellota Sub-area***

The critical contingency for the Tesla-Bellota pocket is the loss of Tesla-Tracy 115 kV and Tesla-Kasson-Manteca 115 kV. The area limitation is thermal overloading of the Manteca-Ingram Creek section of Tesla-Salado-Manteca 115 kV line above its emergency rating. This limiting contingency establishes a Local Capacity **Requirement Need** of 565 MW (includes 195 MW of QF and Muni generation as well as 105 MW of deficiency) in 2008 as the minimum capacity necessary for reliable load serving capability within this area.

The single most critical contingency for the Tesla-Bellota pocket is the loss of Tesla-Kasson-Manteca 115 kV line and the loss of the Stanislaus unit #1. The area limitation is thermal overloading of the Manteca-Ingram Creek section of Tesla-Salado-Manteca 115 kV line above its emergency rating. This single contingency establishes a Local

Capacity Requirement Need of 475 MW (includes 195 MW of QF and Muni generation as well as 15 MW of deficiency) in 2008.

**Effectiveness factors:**

All units within this sub-area are needed for the most limiting contingency therefore no effectiveness factor is required.

***Lockeford Sub-area***

The critical contingency for the Lockeford area is the loss of Lockeford-Industrial 60 kV circuit and Lockeford-Lodi #2 60 kV circuit. The area limitation is thermal overloading of the Lockeford-Lodi Jct. section of the Lockeford-Lodi #3 60 kV circuit. This limiting contingency establishes a Local Capacity Requirement Need of 72 MW (including 28 MW of QF and Muni as well as a deficiency of 45 MW) in 2008 as the minimum capacity necessary for reliable load serving capability within this area.

**Effectiveness factors:**

All units within this sub-area are needed therefore no effectiveness factor is required.

***Stagg Sub-area***

The outage of the Tesla-Stagg 230 kV line and Tesla-Eight Mile 230 kV line causes low voltages at Stagg, Eight Mile Road and Lodi Stig 230 kV busses. Post-contingency steady-state voltages at these three busses are less than 0.90 pu. Lodi Stig generating unit is needed to support voltage at these three 230 kV busses. This limiting contingency establishes a Local Capacity Requirement Need of 150 MW (includes 50 MW of Muni generation as well as 100 MW of deficiency) in 2008 as the minimum capacity necessary for reliable load serving capability within this area.

**Effectiveness factors:**

The only unit within this sub-area is needed therefore no effectiveness factor is required.

### **Stockton Overall Requirements:**

| <b>2008</b>          | QF<br>(MW) | Muni<br>(MW) | Market<br>(MW) | Max. Qualifying<br>Capacity (MW) |
|----------------------|------------|--------------|----------------|----------------------------------|
| Available generation | 82         | 190          | 264            | 536                              |

| <b>2008</b>                         | Existing Generation<br>Capacity Needed (MW) | Deficiency<br>(MW) | Total MW<br>Requirement |
|-------------------------------------|---|--------------------|-------------------------|
| Category B (Single) <sup>14</sup>   | 460   | 15                 | 475                     |
| Category C (Multiple) <sup>15</sup> | 536   | 250                | 786                     |

## **5. Greater Bay Area**

### **Area Definition**

The transmission tie lines into the Greater Bay Area are:

- 1) Lakeville-Sobrante 230 kV
- 2) Ignacio-Sobrante 230 kV
- 3) Parkway-Moraga 230 kV
- 4) Bahia-Moraga 230 kV
- 5) Lambie SW Sta-Vaca Dixon 230 kV
- 6) Peabody-Contra Costa P.P. 230 kV
- 7) Tesla-Kelso 230 kV
- 8) Tesla-Delta Switching Yard 230 kV
- 9) Tesla-Pittsburg #1 230 kV
- 10) Tesla-Pittsburg #2 230 kV
- 11) Tesla-Newark #1 230 kV
- 12) Tesla-Newark #2 230 kV
- 13) Tesla-Ravenswood 230 kV
- 14) Tesla-Metcalf 500 kV
- 15) Moss Landing-Metcalf 500 kV
- 16) Moss Landing-Metcalf #1 230 kV
- 17) Moss Landing-Metcalf #2 230 kV
- 18) Oakdale TID-Newark #1 115 kV
- 19) Oakdale TID-Newark #2 115 kV

The substations that delineate the Greater Bay Area are:

- 1) Lakeville is out Sobrante is in
- 2) Ignacio is out Sobrante is in

---

<sup>14</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>15</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.



- 3) Parkway is out Moraga is in
- 4) Bahia is out Moraga is in
- 5) Lambie SW Sta is in Vaca Dixon is out
- 6) Peabody is out Contra Costa P.P. is in
- 7) Tesla is out Kelso is in
- 8) Tesla is out Delta Switching Yard is in
- 9) Tesla is out Pittsburg is in
- 10) Tesla is out Pittsburg is in
- 11) Tesla is out Newark is in
- 12) Tesla is out Newark is in
- 13) Tesla is out Ravenswood is in
- 14) Tesla is out Metcalf is in
- 15) Moss Landing is out Metcalf is in
- 16) Moss Landing is out Metcalf is in
- 17) Moss Landing is out Metcalf is in
- 18) Oakdale TID is out Newark is in
- 19) Oakdale TID is out Newark is in

Total 2008 busload within the defined area: 9601 MW with 268 MW of losses resulting in total load + losses of 9870 MW.

Total units and qualifying capacity available in this area:

| MKT/SCHED RESOURCE ID | BUS # | BUS NAME  | KV    | NQC    | UNI T ID | LCR SUB-AREA NAME | NQC Comments                      | CAISO Tag  |
|-----------------------|-------|-----------|-------|--------|----------|-------------------|-----------------------------------|------------|
| GILROY_1_UNIT         | 35850 | GLRY COG  | 13.8  | 66.00  | 1        | Llagas            |                                   | Market     |
| GILROY_1_UNIT         | 35850 | GLRY COG  | 13.8  | 34.00  | 2        | Llagas            |                                   | Market     |
| GILRPP_1_PL1X2        | 35851 | GROYPKR1  | 13.8  | 45.00  | 1        | Llagas            |                                   | Market     |
| GILRPP_1_PL1X2        | 35852 | GROYPKR2  | 13.8  | 45.00  | 1        | Llagas            |                                   | Market     |
| GILRPP_1_PL3X4        | 35853 | GROYPKR3  | 13.8  | 45.00  | 1        | Llagas            |                                   | Market     |
| BRDSLD_2_HIWIND       | 32172 | HIGHWINDS | 34.5  | 78.64  | 1        | None              | Monthly NQC - used August for LCR | Wind       |
| BRDSLD_2_SHILO1       | 32176 | SHILOH    | 34.5  | 16.41  | 1        | None              | Monthly NQC - used August for LCR | Wind       |
| CARDCG_1_UNITS        | 33463 | CARDINAL  | 12.47 | 26.91  | 1        | None              |                                   | QF/Selfgen |
| CARDCG_1_UNITS        | 33463 | CARDINAL  | 12.47 | 26.91  | 2        | None              |                                   | QF/Selfgen |
| COCOPP_7_UNIT 6       | 33116 | C.COS 6   | 18    | 337.00 | 1        | None              |                                   | Market     |
| COCOPP_7_UNIT 7       | 33117 | C.COS 7   | 18    | 337.00 | 1        | None              |                                   | Market     |
| FLOWD2_2_UNIT 1       | 35318 | FLOWDPTR  | 9.11  | 5.52   | 1        | None              | Monthly NQC - used August for LCR | Wind       |
| GAYCRZ_1_UNIT 1       | 33145 | CROWN.Z.  | 13.8  | 40.00  | 1        | None              | No NQC - historical data          | QF/Selfgen |
| GAYCRZ_1_UNIT 1       | 33145 | CROWN.Z.  | 13.8  | 5.40   | 2        | None              | No NQC - historical data          | QF/Selfgen |
| GRZZLY_1_BERKLY       | 32740 | HILLSIDE  | 115   | 26.73  | 1        | None              |                                   | QF/Selfgen |
| LFC 51_2_UNIT 1       | 35310 | LFC FIN+  | 9.11  | 4.93   | 1        | None              | Monthly NQC - used August for LCR | Wind       |
| LMBEPK_2_UNITA1       | 32173 | LAMBGT1   | 13.8  | 47.00  | 1        | None              |                                   | Market     |

|                  |       |              |      |        |   |           |                                   |            |
|------------------|-------|--------------|------|--------|---|-----------|-----------------------------------|------------|
| LMBEPK_2_UNITA2  | 32174 | GOOSEHGT     | 13.8 | 46.00  | 2 | None      |                                   | Market     |
| LMBEPK_2_UNITA3  | 32175 | CREEDGT1     | 13.8 | 47.00  | 3 | None      |                                   | Market     |
| RVRVIEW_1_UNITA1 | 33178 | RVEC_GEN     | 13.8 | 46.00  | 1 | None      |                                   | Market     |
| SEAWST_6_LAPOS   | 35312 | SEAWESTF     | 9.11 | 1.83   | 1 | None      | Monthly NQC - used August for LCR | Wind       |
| SRINTL_6_UNIT    | 33468 | SRI INTL     | 9.11 | 1.07   | 1 | None      |                                   | QF/Selfgen |
| STAUFF_1_UNIT    | 33139 | STAUFER      | 9.11 | 0.06   | 1 | None      |                                   | QF/Selfgen |
| USWND1_2_UNITS   | 33838 | USWP_#3      | 9.11 | 9.52   | 1 | None      | Monthly NQC - used August for LCR | Wind       |
| USWNR_2_SMUD     | 32169 | SOLANOWP     | 21   | 12.40  | 1 | None      | No NQC - historical data          | Wind       |
| USWNR_2_UNITS    | 32168 | USWINDPW     | 9.11 | 13.13  | 1 | None      | Monthly NQC - used August for LCR | Wind       |
| USWPFK_6_FRICK   | 35320 | USW FRIC     | 12   | 0.92   | 1 | None      | Monthly NQC - used August for LCR | Wind       |
| USWPFK_6_FRICK   | 35320 | USW FRIC     | 12   | 0.93   | 2 | None      | Monthly NQC - used August for LCR | Wind       |
| WNDMAS_2_UNIT 1  | 33170 | WINDMSTR     | 9.11 | 2.10   | 1 | None      | Monthly NQC - used August for LCR | Wind       |
| ZOND_6_UNIT      | 35316 | ZOND SYS     | 9.11 | 3.75   | 1 | None      | Monthly NQC - used August for LCR | Wind       |
| ALMEGT_1_UNIT 1  | 38118 | ALMDACT1     | 13.8 | 23.80  | 1 | Oakland   |                                   | MUNI       |
| ALMEGT_1_UNIT 2  | 38119 | ALMDACT2     | 13.8 | 24.00  | 1 | Oakland   |                                   | MUNI       |
| OAK C_7_UNIT 1   | 32901 | OAKLND 1     | 13.8 | 55.00  | 1 | Oakland   |                                   | Market     |
| OAK C_7_UNIT 2   | 32902 | OAKLND 2     | 13.8 | 55.00  | 1 | Oakland   |                                   | Market     |
| OAK C_7_UNIT 3   | 32903 | OAKLND 3     | 13.8 | 55.00  | 1 | Oakland   |                                   | Market     |
| CROKET_7_UNIT    | 32900 | CRCKTCOG     | 18   | 240.00 | 1 | Pittsburg |                                   | QF/Selfgen |
| DELTA_2_PL1X4    | 33108 | DEC CTG1     | 18   | 181.13 | 1 | Pittsburg |                                   | Market     |
| DELTA_2_PL1X4    | 33109 | DEC CTG2     | 18   | 181.13 | 1 | Pittsburg |                                   | Market     |
| DELTA_2_PL1X4    | 33110 | DEC CTG3     | 18   | 181.13 | 1 | Pittsburg |                                   | Market     |
| DELTA_2_PL1X4    | 33107 | DEC STG1     | 24   | 269.61 | 1 | Pittsburg |                                   | Market     |
| DOWCHM_1_UNITS   | 33161 | DOWCHEM<br>1 | 13.8 | 10.30  | 1 | Pittsburg |                                   | QF/Selfgen |
| DOWCHM_1_UNITS   | 33162 | DOWCHEM<br>2 | 13.8 | 13.63  | 1 | Pittsburg |                                   | QF/Selfgen |
| DOWCHM_1_UNITS   | 33163 | DOWCHEM<br>3 | 13.8 | 13.63  | 1 | Pittsburg |                                   | QF/Selfgen |
| GWFPW1_6_UNIT    | 33131 | GWFP #1      | 9.11 | 19.00  | 1 | Pittsburg |                                   | QF/Selfgen |

|                 |       |          |       |        |   |               |                          |            |
|-----------------|-------|----------|-------|--------|---|---------------|--------------------------|------------|
| GWFPW2_1_UNIT 1 | 33132 | GWF #2   | 13.8  | 18.81  | 1 | Pittsburg     |                          | QF/Selfgen |
| GWFPW3_1_UNIT 1 | 33133 | GWF #3   | 13.8  | 19.16  | 1 | Pittsburg     |                          | QF/Selfgen |
| GWFPW4_6_UNIT 1 | 33134 | GWF #4   | 13.8  | 19.19  | 1 | Pittsburg     |                          | QF/Selfgen |
| GWFPW5_6_UNIT 1 | 33135 | GWF #5   | 13.8  | 18.83  | 1 | Pittsburg     |                          | QF/Selfgen |
| IMHOFF_1_UNIT 1 | 33136 | CCCSD    | 12.47 | 4.40   | 1 | Pittsburg     | No NQC - historical data | QF/Selfgen |
| LMEC_1_PL1X3    | 33112 | LMECCT1  | 18    | 164.37 | 1 | Pittsburg     |                          | Market     |
| LMEC_1_PL1X3    | 33111 | LMECCT2  | 18    | 164.37 | 1 | Pittsburg     |                          | Market     |
| LMEC_1_PL1X3    | 33113 | LMECST1  | 18    | 231.26 | 1 | Pittsburg     |                          | Market     |
| PITTSP_7_UNIT 5 | 33105 | PTSB 5   | 18    | 312.00 | 1 | Pittsburg     |                          | Market     |
| PITTSP_7_UNIT 6 | 33106 | PTSB 6   | 18    | 317.00 | 1 | Pittsburg     |                          | Market     |
| PITTSP_7_UNIT 7 | 30000 | PTSB 7   | 20    | 682.00 | 1 | Pittsburg     |                          | Market     |
| SHELRF_1_UNITS  | 33141 | SHELL 1  | 12.47 | 20.00  | 1 | Pittsburg     | No NQC - historical data | QF/Selfgen |
| SHELRF_1_UNITS  | 33142 | SHELL 2  | 12.47 | 40.00  | 1 | Pittsburg     | No NQC - historical data | QF/Selfgen |
| SHELRF_1_UNITS  | 33143 | SHELL 3  | 12.47 | 40.00  | 1 | Pittsburg     | No NQC - historical data | QF/Selfgen |
| STOILS_1_UNITS  | 32921 | CHEVGEN1 | 13.8  | 0.42   | 1 | Pittsburg     |                          | QF/Selfgen |
| STOILS_1_UNITS  | 32922 | CHEVGEN2 | 13.8  | 0.41   | 1 | Pittsburg     |                          | QF/Selfgen |
| TIDWTR_2_UNITS  | 33151 | FOSTER W | 12.47 | 6.30   | 1 | Pittsburg     |                          | QF/Selfgen |
| TIDWTR_2_UNITS  | 33151 | FOSTER W | 12.47 | 6.29   | 2 | Pittsburg     |                          | QF/Selfgen |
| TIDWTR_2_UNITS  | 33151 | FOSTER W | 12.47 | 6.29   | 3 | Pittsburg     |                          | QF/Selfgen |
| UNCHEM_1_UNIT   | 32920 | UNION CH | 9.11  | 20.00  | 1 | Pittsburg     |                          | QF/Selfgen |
| UNOCAL_1_UNITS  | 32910 | UNOCAL   | 12    | 0.70   | 1 | Pittsburg     |                          | QF/Selfgen |
| UNOCAL_1_UNITS  | 32910 | UNOCAL   | 12    | 0.69   | 2 | Pittsburg     |                          | QF/Selfgen |
| UNOCAL_1_UNITS  | 32910 | UNOCAL   | 12    | 0.69   | 3 | Pittsburg     |                          | QF/Selfgen |
| POTRPP_7_UNIT 3 | 33252 | POTRERO3 | 20    | 206.00 | 1 | San Francisco |                          | Market     |
| POTRPP_7_UNIT 4 | 33253 | POTRERO4 | 13.8  | 52.00  | 1 | San Francisco |                          | Market     |
| POTRPP_7_UNIT 5 | 33254 | POTRERO5 | 13.8  | 52.00  | 1 | San Francisco |                          | Market     |
| POTRPP_7_UNIT 6 | 33255 | POTRERO6 | 13.8  | 52.00  | 1 | San Francisco |                          | Market     |
| UNTDQF_7_UNITS  | 33466 | UNTED CO | 9.11  | 26.93  | 1 | San Francisco |                          | QF/Selfgen |
| CALPIN_1_AGNEW  | 35860 | OLS-AGNE | 9.11  | 27.94  | 1 | San Jose      |                          | QF/Selfgen |
| CONTAN_1_UNIT   | 36856 | CSC_CCA  | 13.8  | 16.15  | 1 | San Jose      |                          | QF/Selfgen |

|                     |       |          |      |        |   |          |                                   |            |
|---------------------|-------|----------|------|--------|---|----------|-----------------------------------|------------|
| CSCCOG_1_UNIT 1     | 36854 | CSC COG. | 12   | 3.00   | 1 | San Jose |                                   | MUNI       |
| CSCCOG_1_UNIT 1     | 36854 | CSC COG. | 12   | 3.00   | 2 | San Jose |                                   | MUNI       |
| CSCGNR_1_UNIT 1     | 36858 | CSC_GNR1 | 13.8 | 21.30  | 1 | San Jose | Monthly NQC - used August for LCR | MUNI       |
| CSCGNR_1_UNIT 2     | 36895 | CSC_GNR2 | 13.8 | 21.30  | 2 | San Jose | Monthly NQC - used August for LCR | MUNI       |
| DUANE_1_PL1X3       | 36863 | DVRPPCT1 | 13.8 | 49.27  | 1 | San Jose |                                   | MUNI       |
| DUANE_1_PL1X3       | 36864 | DVRPPCT2 | 13.8 | 49.27  | 1 | San Jose |                                   | MUNI       |
| DUANE_1_PL1X3       | 36865 | DVRPPSTA | 13.8 | 49.26  | 1 | San Jose |                                   | MUNI       |
| IBMCTL_1_UNIT 1     | 35637 | IBM-CTLE | 115  | 0.00   | 1 | San Jose | No NQC - historical data          | Market     |
| LECEF_1_UNITS       | 35854 | LECEFGT1 | 13.8 | 46.50  | 1 | San Jose |                                   | Market     |
| LECEF_1_UNITS       | 35855 | LECEFGT2 | 13.8 | 46.50  | 1 | San Jose |                                   | Market     |
| LECEF_1_UNITS       | 35856 | LECEFGT3 | 13.8 | 46.50  | 1 | San Jose |                                   | Market     |
| LECEF_1_UNITS       | 35857 | LECEFGT4 | 13.8 | 46.50  | 1 | San Jose |                                   | Market     |
| MARKHM_1_CATLS<br>T | 35863 | CATALYST | 9.11 | 0.00   | 1 | San Jose |                                   | QF/Selfgen |
| METEC_2_PL1X3       | 35881 | MEC CTG1 | 18   | 185.68 | 1 | San Jose |                                   | Market     |
| METEC_2_PL1X3       | 35882 | MEC CTG2 | 18   | 185.68 | 1 | San Jose |                                   | Market     |
| METEC_2_PL1X3       | 35883 | MEC STG1 | 18   | 221.79 | 1 | San Jose |                                   | Market     |
| ZANKER_1_UNIT 1     | 35861 | SJ-SCL W | 9.11 | 2.50   | 1 | San Jose | No NQC - historical data          | QF/Selfgen |
| ZANKER_1_UNIT 2     | 35861 | SJ-SCL W | 9.11 | 2.50   | 2 | San Jose | No NQC - historical data          | QF/Selfgen |
| NA                  | 33469 | P0527    | 4.16 | 1.90   | 1 | None     | No NQC - Pmax                     | Market     |
| NA                  | 33469 | P0527    | 4.16 | 1.90   | 2 | None     | No NQC - Pmax                     | Market     |
| NA                  | 33469 | P0527    | 4.16 | 1.90   | 3 | None     | No NQC - Pmax                     | Market     |
| NA                  | 33469 | P0527    | 4.16 | 1.90   | 4 | None     | No NQC - Pmax                     | Market     |
| NA                  | 33469 | P0527    | 4.16 | 1.90   | 5 | None     | No NQC - Pmax                     | Market     |
| NA                  | 33469 | P0527    | 4.16 | 1.90   | 6 | None     | No NQC - Pmax                     | Market     |
| NA                  | 33469 | P0527    | 4.16 | 1.90   | 7 | None     | No NQC - Pmax                     | Market     |

## **Critical Contingency Analysis Summary**

### **San Francisco Sub-area**

Per the CAISO Revised Action Plan for SF, Potrero units #3 and all three CTs (360 MW) will continue to be required until completion of the plan as it is presently described.

The most critical contingency is an outage of H-P #1 and H-P #3. The area limitation is thermal overloading of A-H-W #2 115kV Cable. This limiting contingency establishes a Local Capacity Requirement Need of 360 MW (includes 0 MW of QF and Muni

generation) as the minimum capacity necessary for reliable load serving capability within this area in 2008.

**Effectiveness factors:**

All units within this area are needed therefore no effectiveness factor is required.

***Oakland Sub-area***

For 2008 the most critical contingency is an outage of the D-L 115 kV cable (with one of the Oakland CT's off-line). The area limitation is thermal overloading of the C-X #2 115 kV cable. This limiting contingency establishes a Local Capacity Requirement Need of 105 MW in 2008 (includes 48 MW of Muni generation) as the minimum capacity necessary for reliable load serving capability within this area.

**Effectiveness factors:**

All units within this area have the same effectiveness factor. Units outside of this area are not effective.

***Llagas Sub-area***

The most critical contingency is an outage between Metcalf D and Morgan Hill 115 kV (with one of the Gilroy Peaker off-line). The area limitation is thermal overloading of the Metcalf-Llagas 115 kV line. As documented within a CAISO Operating Procedure, this limitation is dependent on power flowing in the direction from Metcalf to Llagas/Morgan Hill. This limiting contingency establishes a Local Capacity Requirement Need of 112 MW in 2008 (includes 0 MW of QF and Muni generation) as the minimum capacity necessary for reliable load serving capability within this area.

Effectiveness factors:

All units within this area have the same effectiveness factor. Units outside of this area are not effective.

***San Jose Sub-area***

Due to existing SPS and future reconductoring this area has no requirements.

**Pittsburg Sub-area**

The most critical contingency is an outage of the Pittsburg-Tesla #1 or #2 230 kV line (with Delta Energy Center off-line). The sub-area area limitation is thermal overloading of the parallel Pittsburg-Tesla 230 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 2123 MW in 2008 (including 519 MW of QF generation) as the minimum capacity necessary for reliable load serving capability within this area.

**Effectiveness factors:**

The following table has units within the Bay Area that are at least 5% effective to the above-mentioned constraint.

| Gen Bus | Gen Name | Gen ID | Eff Fctr (%) |
|---------|----------|--------|--------------|
| 33840   | FLOWD3-6 | 1      | 86           |
| 33840   | FLOWD3-6 | 2      | 86           |
| 33840   | FLOWD3-6 | 3      | 86           |
| 33840   | FLOWD3-6 | 4      | 86           |
| 33171   | TRSVQ+NW | 2      | 26           |
| 33171   | TRSVQ+NW | 1      | 26           |
| 33105   | PTSB 5   | 1      | 26           |
| 33106   | PTSB 6   | 1      | 26           |
| 30000   | PTSB 7   | 1      | 26           |
| 33110   | DEC CTG3 | 1      | 25           |
| 33109   | DEC CTG2 | 1      | 25           |
| 33108   | DEC CTG1 | 1      | 25           |
| 33107   | DEC STG1 | 1      | 25           |
| 33113   | LMECST1  | 1      | 24           |
| 33112   | LMECCT1  | 1      | 24           |
| 33111   | LMECCT2  | 1      | 24           |
| 33132   | GWF #2   | 1      | 24           |
| 33161   | DOWCHEM1 | 1      | 24           |
| 33162   | DOWCHEM2 | 1      | 24           |
| 33163   | DOWCHEM3 | 1      | 24           |
| 33151   | FOSTER W | 1      | 23           |
| 33151   | FOSTER W | 2      | 23           |
| 33151   | FOSTER W | 3      | 23           |
| 33141   | SHELL 1  | 1      | 21           |
| 33143   | SHELL 3  | 1      | 21           |
| 33142   | SHELL 2  | 1      | 21           |
| 32900   | CRCKTCOG | 1      | 19           |
| 32910   | UNOCAL   | 1      | 19           |

|       |          |   |    |
|-------|----------|---|----|
| 32910 | UNOCAL   | 2 | 19 |
| 32910 | UNOCAL   | 3 | 19 |
| 32920 | UNION CH | 1 | 19 |
| 32922 | ChevGen2 | 1 | 18 |
| 32921 | ChevGen1 | 1 | 18 |
| 32740 | HILLSIDE | 1 | 18 |
| 33135 | GWF #5   | 1 | 18 |
| 38119 | ALMDACT2 | 1 | 16 |
| 32903 | OAKLND 3 | 1 | 16 |
| 32902 | OAKLND 2 | 1 | 16 |
| 32901 | OAKLND 1 | 1 | 16 |
| 38118 | ALMDACT1 | 1 | 16 |
| 30464 | EXXON_BH | 1 | 9  |
| 33252 | POTRERO3 | 1 | 7  |
| 33253 | POTRERO4 | 1 | 7  |
| 33254 | POTRERO5 | 1 | 7  |
| 33255 | POTRERO6 | 1 | 7  |
| 33466 | UNTED CO | 1 | 7  |
| 35312 | SEAWESTF | 1 | 7  |
| 35316 | ZOND SYS | 1 | 7  |
| 35320 | USW FRIC | 1 | 7  |
| 32176 | SHILOH   | 1 | 5  |
| 36865 | DVRPPSTA | 1 | 5  |
| 36864 | DVRPPCT2 | 1 | 5  |
| 36863 | DVRPPCT1 | 1 | 5  |
| 33178 | RVEC_GEN | 1 | 5  |
| 32175 | CREEDGT1 | 3 | 5  |
| 32174 | GOOSEHGT | 2 | 5  |
| 32173 | LAMBGT1  | 1 | 5  |
| 32172 | HIGHWNDS | 1 | 5  |
| 33134 | GWF #4   | 1 | 5  |
| 33116 | C.COS 6  | 1 | 5  |
| 33117 | C.COS 7  | 1 | 5  |
| 33133 | GWF #3   | 1 | 5  |
| 33145 | CROWN.Z. | 1 | 5  |
| 33145 | CROWN.Z. | 2 | 5  |
| 33131 | GWF #1   | 1 | 5  |
| 36856 | CSC_CCA  | 1 | 5  |
| 33463 | CARDINAL | 1 | 5  |
| 33463 | CARDINAL | 2 | 5  |
| 32168 | USWINDPW | 1 | 5  |
| 32168 | USWINDPW | 2 | 5  |
| 33838 | USWP_#3  | 1 | 5  |

**Bay Area overall**

The most critical contingency is the loss of the Tesla-Metcalf 500 kV followed by Delta Energy Center or vice versa. The area limitation is reactive margin within the Bay Area as well as thermal overload of the Tesla #6 500/230 transformer. This limiting contingency establishes a Local Capacity Requirement Need of 4688 MW in 2008 (includes 722 MW of QF, 150 MW of Wind and 244 MW of Muni generation) as the minimum capacity necessary for reliable load serving capability within this area. (The transformer bank requirement only includes units in the Greater Bay Area, assuming all effective units in Stockton are at their historical output levels and not included in the requirement total.)

**Effectiveness factors:**

For most helpful procurement information please read procedure T-133Z effectiveness factors – Bay Area at:

<http://www.caiso.com/docs/2004/11/01/2004110116234011719.pdf>

**Bay Area Overall Requirements:**

| 2008                 | Wind (MW) | QF/Selfgen (MW) | Muni (MW) | Market (MW) | Max. Qualifying Capacity (MW) |
|----------------------|-----------|-----------------|-----------|-------------|-------------------------------|
| Available generation | 150       | 722             | 244       | 5098        | 6214                          |

| 2008                                | Existing Generation Capacity Needed (MW) | Deficiency (MW) | Total MW Requirement |
|-------------------------------------|--|-----------------|----------------------|
| Category B (Single) <sup>16</sup>   | 4688                                     | 0               | 4688                 |
| Category C (Multiple) <sup>17</sup> | 4688                                     | 0               | 4688                 |

**6. Greater Fresno Area**

**Area Definition**

The transmission facilities coming into the Greater Fresno area are:

- 1) Gates-Henrietta Tap 1 230 kV Line

<sup>16</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>17</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.



- 2) Gates-Henrietta Tap 2 230 kV Line
- 3) Gates #1 230/115 kV Transformer Bank
- 4) Los Banos #3 230/70 kV Transformer Bank
- 5) Los Banos #4 230/70 kV Transformer Bank
- 6) Panoche-Gates #1 230 kV Line
- 7) Panoche-Gates #2 230 kV Line
- 8) Panoche-Coburn 230 kV Line
- 9) Panoche-Moss Landing 230 kV Line
- 10) Panoche-Los Banos #1 230 kV Line
- 11) Panoche-Los Banos #2 230 kV Line
- 12) Panoche-Dos Amigos 230 kV Line
- 13) Warnerville-Wilson 230 kV Line
- 14) Wilson-Melones 230 kV Line
- 15) Midway-Semitropic-Smyrna 115kV Line
- 16) Coalinga #1-San Miguel 70 kV Line

The substations that delineate the Greater Fresno area are:

- 1) Gates is out Henrietta is in
- 2) Gates is out Henrietta is in
- 3) Gates 230 kV is out Gates 115 kV is in
- 4) Los Banos 230 kV is out Los Banos 70 kV is in
- 5) Los Banos 230 kV is out Los Banos 70 kV is in
- 6) Panoche is in Gates is out
- 7) Panoche is in Gates is out
- 8) Panoche is in Coburn is out
- 9) Panoche is in Moss Landing is out
- 10) Panoche is in Los Banos is out
- 11) Panoche is in Los Banos is out
- 12) Panoche is in Dos Amigos is out
- 13) Warnerville is out Wilson is in
- 14) Wilson is in Melones is out
- 15) Midway and Semitropic are out Smyrna is in
- 16) Coalinga is in San Miguel is out

2008 total busload within the defined area is 3149 MW with 111 MW of losses resulting in a total (load plus losses) of 3260 MW.

Total units and qualifying capacity available in this area:

| <b>MKT/SCHED<br/>RESOURCE ID</b> | <b>BUS<br/>#</b> | <b>BUS NAME</b> | <b>kV</b> | <b>NQC</b> | <b>UNI<br/>T ID</b> | <b>LCR SUB-AREA<br/>NAME</b> | <b>NQC Comments</b> | <b>CAISO Tag</b> |
|----------------------------------|------------------|-----------------|-----------|------------|---------------------|------------------------------|---------------------|------------------|
| PINFLT_7_UNITS                   | 38720            | PINEFLAT        | 13.8      | 75.00      | 3                   | Wilson, Herndon              |                     | MUNI             |
| PINFLT_7_UNITS                   | 38720            | PINEFLAT        | 13.8      | 75.00      | 2                   | Wilson, Herndon              |                     | MUNI             |
| PINFLT_7_UNITS                   | 38720            | PINEFLAT        | 13.8      | 75.00      | 1                   | Wilson, Herndon              |                     | MUNI             |
| GWFPWR_6_UNIT                    | 34650            | GWFPWR.         | 9.11      | 23.87      | 1                   | Wilson, Henrietta            |                     | QF/Selfgen       |
| HENRTA_6_UNITA1                  | 34539            | GWFTGT1         | 13.8      | 45.33      | 1                   | Wilson, Henrietta            |                     | Market           |

|                 |       |           |      |        |   |                   |                                   |            |
|-----------------|-------|-----------|------|--------|---|-------------------|-----------------------------------|------------|
| HENRTA_6_UNITA2 | 34541 | GWF_GT2   | 13.8 | 45.23  | 1 | Wilson, Henrietta |                                   | Market     |
| AGRICO_6_PL3N5  | 34608 | AGRICO    | 13.8 | 21.00  | 3 | Wilson, Herndon   |                                   | Market     |
| AGRICO_7_UNIT   | 34608 | AGRICO    | 13.8 | 42.62  | 2 | Wilson, Herndon   |                                   | Market     |
| AGRICO_7_UNIT   | 34608 | AGRICO    | 13.8 | 7.38   | 4 | Wilson, Herndon   |                                   | Market     |
| BALCHS_7_UNIT 1 | 34624 | BALCH     | 13.2 | 34.00  | 1 | Wilson, Herndon   |                                   | Market     |
| BALCHS_7_UNIT 2 | 34612 | BLCH      | 13.8 | 52.50  | 1 | Wilson, Herndon   |                                   | Market     |
| BALCHS_7_UNIT 3 | 34614 | BLCH      | 13.8 | 52.50  | 1 | Wilson, Herndon   |                                   | Market     |
| CAPMAD_1_UNIT 1 | 34179 | MADERA_G  | 13.8 | 19.70  | 1 | Wilson            |                                   | Market     |
| CHEVCO_6_UNIT 1 | 34652 | CHV.COAL  | 9.11 | 9.76   | 1 | Wilson            |                                   | QF/Selfgen |
| CHEVCO_6_UNIT 2 | 34652 | CHV.COAL  | 9.11 | 1.25   | 2 | Wilson            |                                   | QF/Selfgen |
| CHWCHL_1_UNIT   | 34301 | CHOWCOGN  | 13.8 | 48.00  | 1 | Wilson, Herndon   |                                   | Market     |
| COLGA1_6_SHELLW | 34654 | COLNEAGN  | 9.11 | 35.44  | 1 | Wilson            |                                   | QF/Selfgen |
| CRNEVL_6_SJQN 2 | 34631 | SJ2GEN    | 9.11 | 3.20   | 1 | Wilson            |                                   | Market     |
| CRNEVL_6_SJQN 3 | 34633 | SJ3GEN    | 9.11 | 4.20   | 1 | Wilson            |                                   | Market     |
| DINUBA_6_UNIT   | 34648 | DINUBA E  | 13.8 | 9.89   | 1 | Wilson, Herndon   |                                   | Market     |
| FRIANT_6_UNITS  | 34636 | FRIANTDM  | 6.6  | 8.49   | 2 | Wilson            |                                   | QF/Selfgen |
| FRIANT_6_UNITS  | 34636 | FRIANTDM  | 6.6  | 4.53   | 3 | Wilson            |                                   | QF/Selfgen |
| FRIANT_6_UNITS  | 34636 | FRIANTDM  | 6.6  | 1.20   | 4 | Wilson            |                                   | QF/Selfgen |
| GATES_6_UNIT    | 34553 | WHD_GAT2  | 13.8 | 49.00  | 1 | Wilson            | No NQC - historical data          | Market     |
| GWFPWR_1_UNITS  | 34431 | GWF_HEP1  | 13.8 | 84.40  | 1 | Wilson, Herndon   |                                   | Market     |
| GWFPWR_1_UNITS  | 34433 | GWF_HEP2  | 13.8 | 84.40  | 1 | Wilson, Herndon   |                                   | Market     |
| HAASPH_7_PL1X2  | 34610 | HAAS      | 13.8 | 68.15  | 1 | Wilson, Herndon   | Monthly NQC - used August for LCR | Market     |
| HAASPH_7_PL1X2  | 34610 | HAAS      | 13.8 | 68.15  | 2 | Wilson, Herndon   | Monthly NQC - used August for LCR | Market     |
| KERKH1_7_UNIT 1 | 34344 | KERCKHOF  | 6.6  | 13.00  | 1 | Wilson, Herndon   |                                   | Market     |
| KERKH1_7_UNIT 2 | 34344 | KERCKHOF  | 6.6  | 8.50   | 2 | Wilson, Herndon   |                                   | Market     |
| KERKH1_7_UNIT 3 | 34344 | KERCKHOF  | 6.6  | 12.80  | 3 | Wilson, Herndon   |                                   | Market     |
| KERKH2_7_UNIT 1 | 34308 | KERCKHOF  | 13.8 | 153.90 | 1 | Wilson, Herndon   |                                   | Market     |
| KINGCO_1_KINGBR | 34642 | KINGSBUR  | 9.11 | 28.81  | 1 | Wilson, Herndon   |                                   | QF/Selfgen |
| KINGRV_7_UNIT 1 | 34616 | KINGSRIV  | 13.8 | 51.20  | 1 | Wilson, Herndon   |                                   | Market     |
| MALAGA_1_PL1X2  | 34671 | KRCDPCT1  | 13.8 | 96.00  | 1 | Wilson, Herndon   |                                   | Market     |
| MALAGA_1_PL1X2  | 34672 | KRCDPCT2  | 13.8 | 96.00  | 1 | Wilson, Herndon   |                                   | Market     |
| MENBIO_6_UNIT   | 34334 | BIO PWR   | 9.11 | 19.69  | 1 | Wilson            |                                   | QF/Selfgen |
| NA              | 34485 | FRESNOW W | 12.5 | 9.00   | 1 | Wilson            | No NQC - historical data          | QF/Selfgen |
| ONLLPP_6_UNITS  | 34316 | ONEILPMP  | 9.11 | 0.50   | 1 | Wilson            | No NQC - historical data          | MUNI       |

|                    |       |          |      |        |   |                 |                                   |            |
|--------------------|-------|----------|------|--------|---|-----------------|-----------------------------------|------------|
| PNOCHE_1_UNITA1    | 34186 | DG_PAN1  | 13.8 | 42.78  | 1 | Wilson          |                                   | Market     |
| PNOCHE_1_UNITB1    | 34142 | WHD_PAN2 | 13.8 | 49.00  | 1 | Wilson, Herndon | No NQC - historical data          | Market     |
| ULTPFR_1_UNIT 1    | 34640 | ULTR.PWR | 9.11 | 20.26  | 1 | Wilson, Herndon |                                   | QF/Selfgen |
| WISHON_6_UNITS     | 34658 | WISHON   | 2.3  | 4.60   | 1 | Wilson          |                                   | Market     |
| WISHON_6_UNITS     | 34658 | WISHON   | 2.3  | 4.60   | 2 | Wilson          |                                   | Market     |
| WISHON_6_UNITS     | 34658 | WISHON   | 2.3  | 4.60   | 3 | Wilson          |                                   | Market     |
| WISHON_6_UNITS     | 34658 | WISHON   | 2.3  | 4.60   | 4 | Wilson          |                                   | Market     |
| WISHON_6_UNITS     | 34658 | WISHON   | 2.3  | 0.00   | 5 | Wilson          |                                   | Market     |
| HELMPG_7_UNIT 1    | 34600 | HELMS    | 18   | 404.00 | 1 | Wilson          |                                   | Market     |
| HELMPG_7_UNIT 2    | 34602 | HELMS    | 18   | 404.00 | 2 | Wilson          |                                   | Market     |
| HELMPG_7_UNIT 3    | 34604 | HELMS    | 18   | 404.00 | 3 | Wilson          |                                   | Market     |
| INTTRB_6_UNIT      | 34342 | INT.TURB | 9.11 | 3.99   | 1 | Wilson          | Monthly NQC - used August for LCR | QF/Selfgen |
| SGREGY_6_SANG<br>R | 34646 | SANGERCO | 9.11 | 31.03  | 1 | Wilson          |                                   | QF/Selfgen |
| EXCHEC_7_UNIT 1    | 34306 | EXCHQUER | 13.8 | 61.77  | 1 | Wilson          | Monthly NQC - used August for LCR | MUNI       |
| JRWOOD_1_UNIT 1    | 34332 | JRWCOGEN | 9.11 | 6.31   | 1 | Wilson, Merced  |                                   | QF/Selfgen |
| MCSWAN_6_UNITS     | 34320 | MCSWAIN  | 9.11 | 5.04   | 1 | Wilson          | Monthly NQC - used August for LCR | MUNI       |
| MERCFL_6_UNIT      | 34322 | MERCEDFL | 9.11 | 2.20   | 1 | Wilson          | Monthly NQC - used August for LCR | Market     |

## **Critical Contingency Analysis Summary**

### **Wilson Sub-area**

The Wilson sub-area largely defines the Fresno area import constraints. The main constrained spot is located at Wanerville-Wilson-Gregg 230 kV transmission corridor. Other constrained spots are located at the Gates-McCall, Gates-Gregg, Panoche-McCall and Panoche-Gregg 230 kV transmission corridors.

The most critical contingency is the loss of the Melones - Wilson 230 kV line followed by the loss of the Gates-Gregg 230 kV line, which could thermally overload the Warnerville - Wilson 230 kV line and the Gates-McCall 230 kV line. This limiting contingency establishes a Local Capacity **Requirement Need** of 1563 MW (which includes 292 MW of Muni generation and 204 MW of QF generation) in 2008 as the minimum generation capacity necessary for reliable load serving capability within this area.

The most critical single contingency is the loss of the Melones - Wilson 230 kV line overlapped with one of the Helms units out of service. This contingency would thermally overload the Warnerville - Wilson 230 kV line and possibly also the Gates-McCall 230 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 1505 MW (which includes 292 MW of Muni generation and 204 MW of QF generation) in 2008.

**Effectiveness factors:**

The following table has units within Fresno that are at least 5% effective to the constraint on the Warnerville – Wilson 230 kV line.

| Gen Bus | Gen Name | Gen ID | Eff Fctr (%) |
|---------|----------|--------|--------------|
| 34332   | JRWCOGEN | 1      | 43           |
| 34322   | MERCEDFL | 1      | 36           |
| 34320   | MCSWAIN  | 1      | 36           |
| 34301   | CHOWCOGN | 1      | 35           |
| 34306   | EXCHQUER | 1      | 34           |
| 34658   | WISHON   | 1      | 32           |
| 34658   | WISHON   | 2      | 32           |
| 34658   | WISHON   | 3      | 32           |
| 34658   | WISHON   | 4      | 32           |
| 34631   | SJ2GEN   | 1      | 32           |
| 34633   | SJ2GEN   | 1      | 32           |
| 34636   | FRIANTDM | 2      | 31           |
| 34636   | FRIANTDM | 3      | 31           |
| 34636   | FRIANTDM | 4      | 31           |
| 34600   | HELMS 1  | 1      | 31           |
| 34602   | HELMS 2  | 1      | 31           |
| 34604   | HELMS 3  | 1      | 31           |
| 34344   | KERCKHOF | 1      | 29           |
| 34344   | KERCKHOF | 2      | 29           |
| 34344   | KERCKHOF | 3      | 29           |
| 34308   | KERCKHOF | 1      | 29           |
| 34485   | FRESNOWW | 1      | 27           |
| 34648   | DINUBA E | 1      | 26           |
| 34616   | KINGSRIV | 1      | 25           |
| 34624   | BALCH 1  | 1      | 25           |
| 34671   | KRCDPCT1 | 1      | 24           |
| 34672   | KRCDPCT2 | 1      | 24           |
| 34640   | ULTR.PWR | 1      | 23           |
| 34646   | SANGERCO | 1      | 23           |
| 34179   | MADERA_G | 1      | 23           |
| 34642   | KINGSBUR | 1      | 21           |

|       |          |   |    |
|-------|----------|---|----|
| 38720 | PINE FLT | 1 | 21 |
| 38720 | PINE FLT | 2 | 21 |
| 38720 | PINE FLT | 3 | 21 |
| 34610 | HAAS     | 1 | 21 |
| 34610 | HAAS     | 2 | 21 |
| 34612 | BLCH 2-2 | 1 | 20 |
| 34614 | BLCH 2-3 | 1 | 20 |
| 34433 | GWF_HEP2 | 1 | 19 |
| 34431 | GWF_HEP1 | 1 | 19 |
| 34334 | BIO PWR  | 1 | 15 |
| 34608 | AGRICO   | 2 | 14 |
| 34608 | AGRICO   | 3 | 14 |
| 34608 | AGRICO   | 4 | 14 |
| 34539 | GWF_GT1  | 1 | 14 |
| 34541 | GWF_GT2  | 1 | 14 |
| 34650 | GWF-PWR. | 1 | 14 |
| 34186 | DG_PAN1  | 1 | 12 |
| 34142 | WHD_PAN2 | 1 | 12 |
| 34652 | CHV.COAL | 1 | 9  |
| 34652 | CHV.COAL | 2 | 9  |
| 34553 | WHD_GAT2 | 1 | 9  |
| 34654 | COLNGAGN | 1 | 9  |
| 34342 | INT.TURB | 1 | 7  |
| 34316 | ONEILPMP | 1 | 6  |

The following table has units within Fresno that are at least 5% effective to the constraint on the Gates – McCall 230 kV line.

| Gen Bus | Gen Name | Gen ID | Eff Fctr (%) |
|---------|----------|--------|--------------|
| 34610   | HAAS     | 1      | 34           |
| 34610   | HAAS     | 2      | 34           |
| 34612   | BLCH 2-2 | 1      | 34           |
| 34614   | BLCH 2-3 | 1      | 34           |
| 38720   | PINE FLT | 1      | 34           |
| 38720   | PINE FLT | 2      | 34           |
| 38720   | PINE FLT | 3      | 34           |
| 34539   | GWF_GT1  | 1      | 32           |
| 34541   | GWF_GT2  | 1      | 32           |
| 34433   | GWF_HEP2 | 1      | 32           |
| 34431   | GWF_HEP1 | 1      | 32           |
| 34642   | KINGSBUR | 1      | 32           |
| 34650   | GWF-PWR. | 1      | 32           |
| 34640   | ULTR.PWR | 1      | 30           |
| 34671   | KRCDPCT1 | 1      | 30           |
| 34672   | KRCDPCT2 | 1      | 30           |
| 34648   | DINUBA E | 1      | 30           |
| 34616   | KINGSRIV | 1      | 29           |

|       |          |   |    |
|-------|----------|---|----|
| 34646 | SANGERCO | 1 | 28 |
| 34624 | BALCH 1  | 1 | 28 |
| 34344 | KERCKHOF | 1 | 24 |
| 34344 | KERCKHOF | 2 | 24 |
| 34344 | KERCKHOF | 3 | 24 |
| 34308 | KERCKHOF | 1 | 24 |
| 34636 | FRIANTDM | 2 | 18 |
| 34636 | FRIANTDM | 3 | 18 |
| 34636 | FRIANTDM | 4 | 18 |
| 34658 | WISHON   | 1 | 17 |
| 34658 | WISHON   | 2 | 17 |
| 34658 | WISHON   | 3 | 17 |
| 34658 | WISHON   | 4 | 17 |
| 34631 | SJ2GEN   | 1 | 16 |
| 34633 | SJ2GEN   | 1 | 16 |
| 34301 | CHOWCOGN | 1 | 15 |
| 34485 | FRESNOWW | 1 | 13 |
| 34600 | HELMS 1  | 1 | 13 |
| 34602 | HELMS 2  | 1 | 13 |
| 34604 | HELMS 3  | 1 | 13 |
| 34608 | AGRICO   | 2 | 12 |
| 34608 | AGRICO   | 3 | 12 |
| 34608 | AGRICO   | 4 | 12 |
| 34332 | JRWCOGEN | 1 | 11 |
| 34322 | MERCEDFL | 1 | 10 |
| 34320 | MCSWAIN  | 1 | 10 |
| 34306 | EXCHQUER | 1 | 10 |
| 34179 | MADERA_G | 1 | 8  |
| 34334 | BIO PWR  | 1 | 7  |

### ***Herndon Sub-area***

The most critical contingency is the loss of the Herndon 230/115 kV bank 1 overlapped with Kerckhoff II generator out of service. This contingency could thermally overload the parallel Herndon 230/115 kV bank 2. This limiting contingency establishes a Local Capacity **Requirement Need** of 847 MW (which includes 49 MW of QF generation and 225 MW of Muni generation) in 2008 as the minimum generation capacity necessary for reliable load serving capability within this area.

The most critical single contingency for the Herndon sub-area is the loss of the Herndon 230/115 kV bank 1, which could thermally overload the parallel Herndon 230/115 kV bank 2. This limiting contingency establishes a Local Capacity **Requirement Need** of

639 MW (which includes 49 MW of QF generation and 225 MW of Muni generation) in 2008.

**Effectiveness factors:**

The following table has units within Fresno area that are relatively effective to the above-mentioned constraint. All units in Fresno not listed or units outside of this area have smaller effectiveness factors.

| Gen Bus | Gen Name | Gen ID | Eff Fctr (%) |
|---------|----------|--------|--------------|
| 34308   | KERCKHOF | 1      | 34           |
| 34344   | KERCKHOF | 1      | 33           |
| 34344   | KERCKHOF | 2      | 33           |
| 34344   | KERCKHOF | 3      | 33           |
| 34624   | BALCH 1  | 1      | 31           |
| 34646   | SANGERCO | 1      | 29           |
| 34672   | KRCDPCT2 | 1      | 29           |
| 34671   | KRCDPCT1 | 1      | 29           |
| 34640   | ULTR.PWR | 1      | 29           |
| 34616   | KINGSRIV | 1      | 28           |
| 34648   | DINUBA E | 1      | 26           |
| 34642   | KINGSBUR | 1      | 23           |
| 38720   | PINE FLT | 1      | 21           |
| 38720   | PINE FLT | 2      | 21           |
| 38720   | PINE FLT | 3      | 21           |
| 34610   | HAAS     | 1      | 21           |
| 34610   | HAAS     | 2      | 21           |
| 34612   | BLCH 2-2 | 1      | 20           |
| 34614   | BLCH 2-3 | 1      | 20           |
| 34433   | GWF_HEP2 | 1      | 12           |
| 34431   | GWF_HEP1 | 1      | 12           |
| 34301   | CHOWCOGN | 1      | 9            |
| 34608   | AGRICO   | 2      | 6            |
| 34608   | AGRICO   | 3      | 6            |
| 34608   | AGRICO   | 4      | 6            |
| 34332   | JRWCOGEN | 1      | -8           |
| 34485   | FRESNOWW | 1      | -15          |
| 34600   | HELMS 1  | 1      | -16          |
| 34602   | HELMS 2  | 1      | -16          |
| 34604   | HELMS 3  | 1      | -16          |

**McCall Sub-area**

No requirements because of the McCall 230/115kV #1 transformer bank replacement by May 2008.

**Henrietta Sub-area**

The most critical contingency is the loss of Henrietta 230/70 kV transformer bank #4 followed by the loss of the Henrietta-GWF Henrietta 70 kV line. This contingency could thermally overload the Henrietta 230/70 kV transformer bank #2. This limiting contingency establishes a Local Capacity Requirement Need of 141 MW in 2008 (which includes 24 MW of QF generation and 27 MW of deficiency) as the minimum generation capacity necessary for reliable load serving capability within this area.

The most critical single contingency is the loss of Henrietta 230/70 kV transformer bank #4. This contingency could thermally overload the Henrietta 230/70 kV transformer bank #2. This limiting contingency establishes a Local Capacity Requirement Need of 32 MW in 2008 (which includes 24 MW of QF generation).

**Effectiveness factors:**

All units within this sub-area have the same effectiveness factor. Units outside of this sub-area are not effective.

**Merced Sub-area**

The most critical contingencies is the double line outage of the Wilson – Atwater 115 kV #1 and #2 lines, which could thermally overload the Wilson – Merced 115 kV #1 and #2 lines. This limiting contingency establishes a Local Capacity Requirement Need of 87 MW (which includes 6 MW of QF generation and 81 MW of area deficiency) as the minimum generation capacity necessary for reliable load serving capability within this area.

**Effectiveness factors:**

The only unit in this sub-area JRWCOGEN is needed therefore no effectiveness factor is required.

**Fresno Area Overall Requirements:**

|             |            |      |        |                 |
|-------------|------------|------|--------|-----------------|
| <b>2008</b> | QF/Selfgen | Muni | Market | Max. Qualifying |
|-------------|------------|------|--------|-----------------|



|                      |      |      |      |               |
|----------------------|------|------|------|---------------|
|                      | (MW) | (MW) | (MW) | Capacity (MW) |
| Available generation | 204  | 292  | 2495 | 2991          |

| <b>2008</b>                         | Existing Generation Capacity Needed (MW) | Deficiency (MW) | Total MW Requirement |
|-------------------------------------|--|-----------------|----------------------|
| Category B (Single) <sup>18</sup>   | 2212                                     | 0               | 2212                 |
| Category C (Multiple) <sup>19</sup> | 2274                                     | 108             | 2382                 |

## 7. Kern Area

### Area Definition

The transmission facilities coming into the Kern PP sub-area are:

- 1) Wheeler Ridge-Lamont 115 kV line
- 2) Kern PP 230/115 kV Bank # 3 & 3A
- 3) Kern PP 230/115 kV Bank # 4
- 4) Kern PP 230/115 kV Bank # 5
- 5) Midway 230/115 Bank # 1
- 6) Midway 230/115 Bank # 2 & 2a
- 7) Midway 230/115 Bank #3
- 8) Temblor – San Luis Obispo 115 kV line

The substations that delineate the Kern-PP sub-area are:

- 1) Wheeler Ridge is out Lamont is in
- 2) Kern PP 230 kV is out Kern PP 115 kV is in
- 3) Kern PP 230 kV is out Kern PP 115 kV is in
- 4) Kern PP 230 kV is out Kern PP 115 kV is in
- 5) Midway 230 kV is out Midway 115 kV is in
- 6) Midway 230 kV is out Midway 115 kV is in
- 7) Midway 230 kV is out Midway 115 kV is in
- 8) Temblor is in San Luis Obispo is out

The transmission facilities coming into the Weedpatch sub-area are:

- 1) Wheeler Ridge-Tejon 60 kV line
- 2) Wheeler Ridge-Weedpatch 60 kV line
- 3) Wheeler Ridge-San Bernard 60 kV line

The substations that delineate the Weedpatch sub-area are:

- 1) Wheeler Ridge is out Tejon is in

<sup>18</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>19</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

- 2) Wheeler Ridge is out Weedpach is in
- 3) Wheeler Ridge is out San Bernard is in

2008 total busload within the defined area: 1308 MW with 16 MW of losses resulting in a total (load plus losses) of 1324 MW.

Total units and qualifying capacity available in this Kern area:

| <b>MKT/SCHED<br/>RESOURCE ID</b> | <b>BUS<br/>#</b> | <b>BUS NAME</b> | <b>kV</b> | <b>NQC</b> | <b>UNI<br/>T ID</b> | <b>LCR SUB-AREA<br/>NAME</b> | <b>NQC Comments</b> | <b>CAISO Tag</b> |
|----------------------------------|------------------|-----------------|-----------|------------|---------------------|------------------------------|---------------------|------------------|
| BDGRCK_1_UNITS                   | 35029            | BADGERCK        | 9.11      | 42.67      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| BEARMT_1_UNIT                    | 35066            | PSE-BEAR        | 9.11      | 39.91      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| CHALK_1_UNIT                     | 35038            | CHLKCLF+        | 9.11      | 41.56      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| CHEVCD_6_UNIT                    | 35052            | CHEV.USA        | 9.11      | 0.73       | 1                   | Kern PP                      |                     | QF/Selfgen       |
| CHEVCY_1_UNIT                    | 35032            | CHV-CYMR        | 9.11      | 7.74       | 1                   | Kern PP                      |                     | QF/Selfgen       |
| DEXZEL_1_UNIT                    | 35024            | DEXEL +         | 9.11      | 29.32      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| DISCOV_1_CHEVRN                  | 35062            | DISCOVERY       | 9.11      | 5.45       | 1                   | Kern PP                      |                     | QF/Selfgen       |
| DOUBLC_1_UNITS                   | 35023            | DOUBLE C        | 9.11      | 46.81      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| FRITO_1_LAY                      | 35048            | FRITOLAY        | 9.11      | 0.09       | 1                   | Kern PP                      |                     | QF/Selfgen       |
| KERNFT_1_UNITS                   | 35026            | KERNFRNT        | 9.11      | 45.00      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| KERNRG_1_UNITS                   | 35040            | KERNRDGE        | 9.11      | 0.47       | 1                   | Kern PP                      |                     | QF/Selfgen       |
| KERNRG_1_UNITS                   | 35040            | KERNRDGE        | 9.11      | 0.48       | 2                   | Kern PP                      |                     | QF/Selfgen       |
| LIVOAK_1_UNIT 1                  | 35058            | PSE-LVOK        | 9.11      | 39.67      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| MIDSET_1_UNIT 1                  | 35044            | TX MIDST        | 9.11      | 33.75      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| MIDSUN_1_UNITA1                  | 35034            | MIDSUN +        | 9.11      | 22.00      | 1                   | Kern PP                      |                     | Market           |
| MKTRCK_1_UNIT 1                  | 35060            | PSEMCKIT        | 9.11      | 42.99      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| MTNPOS_1_UNIT                    | 35036            | MT POSO         | 9.11      | 50.61      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| NAVY35_1_UNITS                   | 35064            | NAVY 35R        | 9.11      | 0.00       | 1                   | Kern PP                      |                     | QF/Selfgen       |
| NAVY35_1_UNITS                   | 35064            | NAVY 35R        | 9.11      | 0.00       | 2                   | Kern PP                      |                     | QF/Selfgen       |
| OILDAL_1_UNIT 1                  | 35028            | OILDALE         | 9.11      | 35.39      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| SIERRA_1_UNITS                   | 35027            | HISIERRA        | 9.11      | 45.58      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| TANHIL_6_SOLART                  | 35050            | SLR-TANN        | 9.11      | 9.78       | 1                   | Kern PP                      |                     | QF/Selfgen       |
| TXNMID_1_UNIT 2                  | 34783            | TEXCO_NM        | 9.11      | 0.00       | 1                   | Kern PP                      |                     | QF/Selfgen       |
| TXNMID_1_UNIT 2                  | 34783            | TEXCO_NM        | 9.11      | 0.00       | 2                   | Kern PP                      |                     | QF/Selfgen       |
| ULTOGL_1_POSO                    | 35035            | ULTR PWR        | 9.11      | 30.87      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| UNVRSY_1_UNIT 1                  | 35037            | UNIVRSTY        | 9.11      | 30.64      | 1                   | Kern PP                      |                     | QF/Selfgen       |
| VEDDER_1_SEKER<br>N              | 35046            | SEKR            | 9.11      | 20.46      | 1                   | Kern PP                      |                     | QF/Selfgen       |

|                 |       |          |      |      |   |           |                                      |            |
|-----------------|-------|----------|------|------|---|-----------|--------------------------------------|------------|
| N/A             | 35056 | TX-LOSTH | 4.16 | 9.00 | 1 | Kern PP   | No NQC - historical data             | QF/Selfgen |
| KRNCNY_6_UNIT   | 35018 | KERNCNYN | 9.11 | 9.22 | 1 | Weedpatch | Monthly NQC - used<br>August for LCR | Market     |
| RIOBRV_6_UNIT 1 | 35020 | RIOBRAVO | 9.11 | 6.15 | 1 | Weedpatch |                                      | QF/Selfgen |

**Critical Contingency Analysis Summary**

**Kern PP Sub-area**

The most critical contingency is the outage of the Kern PP #5 230/115 kV transformer bank followed by the Kern PP – Kern Front 115 kV line, which could thermally overload the parallel Kern PP 230/115 kV Bank 3 and Bank 3a. This limiting contingency establishes a Local Capacity Requirement Need of 448 MW in 2008 (includes 609 MW of QF generation) as the minimum generation capacity necessary for reliable load serving capability within this area.

The most critical single contingency is the loss of Kern PP #5 230/115 kV transformer bank, which could thermally overload the parallel Kern PP 230/115 kV Bank 3 and Bank 3a. This limiting contingency establishes a Local Capacity Requirement Need of 259 MW in 2008 (includes 609 MW of QF generation) as the minimum generation capacity necessary for reliable load serving capability within this area.

**Effectiveness factors:**

The following table shows units that are at least 5% effective to the above-mentioned constraint.

| Gen Bus | Gen Name  | Gen ID | Eff Fctr (%) |
|---------|-----------|--------|--------------|
| 35066   | PSE-BEAR  | 1      | 21           |
| 35027   | HISIERRA  | 1      | 21           |
| 35029   | BADGERCK  | 1      | 21           |
| 35023   | DOUBLE C  | 1      | 21           |
| 35058   | PSE-LVOK  | 1      | 21           |
| 35026   | KERNFRNT  | 1      | 21           |
| 35028   | OILDALE   | 1      | 21           |
| 35046   | SEKR      | 1      | 21           |
| 25062   | DISCOVERY | 1      | 21           |
| 35036   | MT POSO   | 1      | 15           |
| 35035   | ULTR PWR  | 1      | 14           |
| 35052   | CHEV.USA  | 1      | 5            |

## Weedpatch Sub-area

The most critical contingency is the loss of the Wheeler Ridge – San Bernard 70 kV line followed by the Wheeler Ridge – Tejon 70 kV line, which could thermally overload the Wheeler Ridge – Weedpatch 70 kV line and cause low voltage problem at the local 70 kV transmission system. This limiting contingency establishes a Local Capacity **Requirement Need** of 38 MW in 2008 (includes 6 MW of QF generation and 23 MW of area deficiency) as the minimum generation capacity necessary for reliable load serving capability within this area.

### Effectiveness factors:

All units within this sub-area are needed therefore no effectiveness factor is required.

### Kern Area Overall Requirements:

| 2008                 | QF/Selfgen (MW) | Market (MW) | Max. Qualifying Capacity (MW) |
|----------------------|-----------------|-------------|-------------------------------|
| Available generation | 615             | 31          | 646                           |

| 2008                                | Existing Generation Capacity Needed (MW) | Deficiency (MW) | Total MW Requirement |
|-------------------------------------|--|-----------------|----------------------|
| Category B (Single) <sup>20</sup>   | 259                                      | 0               | 259                  |
| Category C (Multiple) <sup>21</sup> | 463                                      | 23              | 486                  |

## 8. LA Basin Area

### Area Definition

The transmission tie lines into the LA Basin Area are:

- 1) San Onofre - San Luis Rey #1, #2, & #3 230 kV Lines

---

<sup>20</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>21</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

- 2) San Onofre - Talega #1 & #2 230 kV Lines
- 3) Lugo - Mira Loma #1, #2 & #3 500 kV Lines
- 4) Sylmar - Eagle Rock 230 kV Line
- 5) Sylmar - Gould 230 kV Line
- 6) Vincent - Mesa Cal 230 kV Line
- 7) Antelope - Mesa Cal 230 kV Line
- 8) Vincent - Rio Hondo #1 & #2 230 kV Lines
- 9) Eagle Rock - Pardee 230 kV Line
- 10) Devers - Palo Verde 500 kV Line
- 11) Devers – Harquahala 500 kV Line
- 12) Mirage - Coachelv 230 kV Line
- 13) Mirage - Ramon 230 kV Line
- 14) Mirage - Julian Hinds 230 kV Line

These sub-stations form the boundary surrounding the LA Basin area:

- 1) San Onofre is in San Luis Rey is out
- 2) San Onofre is in Talega is out
- 3) Mira Loma is in Lugo is out
- 4) Eagle Rock is in Sylmar is out
- 5) Gould is in Sylmar is out
- 6) Mesa Cal is in Vincent is out
- 7) Mesa Cal is in Antelope is out
- 8) Rio Hondo is in Vincent is out
- 9) Eagle Rock is in Pardee is out
- 10) Devers is in Palo Verde is out
- 11) Devers is in Harquahala is out
- 12) Mirage is in Coachelv is out
- 13) Mirage is in Ramon is out
- 14) Mirage is in Julian Hinds is out

Total 2008 busload within the defined area is 19,409 MW with 226 MW of losses and 22.5MW pumps resulting in total load + losses + pumps of 19,648 MW.

Total units and qualifying capacity available in the LA Basin area:

| <b>MKT/SCHED RESOURCE ID</b> | <b>BUS #</b> | <b>BUS NAME</b> | <b>KV</b> | <b>NQC</b> | <b>UNI T ID</b> | <b>LCR SUB-AREA NAME</b> | <b>NQC Comments</b>               | <b>CAISO Tag</b> |
|------------------------------|--------------|-----------------|-----------|------------|-----------------|--------------------------|-----------------------------------|------------------|
| CABZON_1_WINDA1              | 28280        | CABAZON         | 33        | 10.86      | 1               | Eastern                  | Monthly NQC - used August for LCR | Wind             |
| CHINO_2_QF                   | 24024        | CHINO           | 66        | 12.09      | 1               | Eastern                  |                                   | QF/Selfgen       |
| CHINO_6_SMPPAP               | 24140        | SIMPSON         | 13.8      | 40.06      | 1               | Eastern                  |                                   | QF/Selfgen       |
| CORONS_6_CLRWTR              | 24210        | MIRALOMA        | 66        | 14.00      | 1               | Eastern                  |                                   | MUNI             |
| CORONS_6_CLRWTR              | 24210        | MIRALOMA        | 66        | 14.00      | 2               | Eastern                  |                                   | MUNI             |
| DEVERS_1_QF                  | 24815        | GARNET          | 115       | 64.02      | 1               | Eastern                  | Monthly NQC - used August for LCR | QF/Selfgen       |
| DVLCYN_1_UNITS               | 25648        | DVLCYN1G        | 13.8      | 50.74      | 1               | Eastern                  |                                   | MUNI             |

|                 |       |          |      |        |   |         |                          |            |
|-----------------|-------|----------|------|--------|---|---------|--------------------------|------------|
| DVLCYN_1_UNITS  | 25649 | DVLCYN2G | 13.8 | 50.74  | 2 | Eastern |                          | MUNI       |
| DVLCYN_1_UNITS  | 25603 | DVLCYN3G | 13.8 | 67.66  | 3 | Eastern |                          | MUNI       |
| DVLCYN_1_UNITS  | 25604 | DVLCYN4G | 13.8 | 67.66  | 4 | Eastern |                          | MUNI       |
| ETIWND_2_QF     | 24055 | ETIWANDA | 66   | 17.76  | 2 | Eastern |                          | QF/Selfgen |
| ETIWND_6_MWDETI | 24055 | ETIWANDA | 66   | 18.55  | 1 | Eastern |                          | Market     |
| ETIWND_6_MWDETI | 25422 | ETI MWDG | 13.8 | 18.55  | 1 | Eastern |                          | Market     |
| ETIWND_7_UNIT 3 | 24052 | MTNVIST3 | 18   | 320.00 | 3 | Eastern |                          | Market     |
| ETIWND_7_UNIT 4 | 24053 | MTNVIST4 | 18   | 320.00 | 4 | Eastern |                          | Market     |
| INDIGO_1_UNIT 1 | 28190 | WINTECX2 | 13.8 | 42.00  | 1 | Eastern |                          | Market     |
| INDIGO_1_UNIT 2 | 28191 | WINTECX1 | 13.8 | 42.00  | 1 | Eastern |                          | Market     |
| INDIGO_1_UNIT 3 | 28180 | WINTECX8 | 13.8 | 42.00  | 1 | Eastern |                          | Market     |
| INLAND_6_UNIT   | 24071 | INLAND   | 13.8 | 30.00  | 1 | Eastern | No NQC - historical data | QF/Selfgen |
| MIRLOM_6_DELGEN | 24030 | DELGEN   | 13.8 | 39.59  | 1 | Eastern |                          | QF/Selfgen |
| NA              | 24111 | PADUA    | 66   | 0.00   | 1 | Eastern |                          | QF/Selfgen |
| NA              | 24214 | SANBRDNO | 66   | 0.00   | 1 | Eastern |                          | QF/Selfgen |
| NA              | 24214 | SANBRDNO | 66   | 0.00   | 2 | Eastern |                          | QF/Selfgen |
| NA              | 24826 | INDIGO   | 115  | 0.00   | 1 | Eastern |                          | QF/Selfgen |
| NA              | 25632 | TERAWND  | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 25633 | CAPWIND  | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| BUCKWD_Y_WINTCV | 25634 | BUCKWIND | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 25635 | ALTWIND  | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 25636 | RENWIND  | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 25637 | TRANWIND | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 25639 | SEAWIND  | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 25640 | PANAERO  | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 25645 | VENWIND  | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 25646 | SANWIND  | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 28020 | WINTECX6 | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 28060 | SEAWEST  | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 28060 | SEAWEST  | 115  | 0.00   | 2 | Eastern |                          | Wind       |
| WHTWTR_1_WINDA1 | 28061 | WHITEWTR | 33   | 0.00   | 1 | Eastern |                          | Wind       |
| NA              | 28260 | ALTAMSA4 | 115  | 0.00   | 1 | Eastern |                          | Wind       |
| PADUA_6_QF      | 24111 | PADUA    | 66   | 7.25   | 2 | Eastern |                          | QF/Selfgen |
| SBERDO_2_PSP3   | 24921 | MNTV-CT1 | 18   | 129.71 | 1 | Eastern |                          | Market     |
| SBERDO_2_PSP3   | 24922 | MNTV-CT2 | 18   | 129.71 | 1 | Eastern |                          | Market     |
| SBERDO_2_PSP3   | 24923 | MNTV-ST1 | 18   | 225.07 | 1 | Eastern |                          | Market     |
| SBERDO_2_PSP4   | 24924 | MNTV-CT3 | 18   | 129.71 | 1 | Eastern |                          | Market     |
| SBERDO_2_PSP4   | 24925 | MNTV-CT4 | 18   | 129.71 | 1 | Eastern |                          | Market     |
| SBERDO_2_PSP4   | 24926 | MNTV-ST2 | 18   | 225.07 | 1 | Eastern |                          | Market     |
| VALLEY_2_QF     | 24160 | VALLEYSC | 115  | 6.73   | 1 | Eastern |                          | QF/Selfgen |
| VALLEY_7_UNITA1 | 24229 | VALLEY-S | 115  | 1.94   | 1 | Eastern |                          | QF/Selfgen |
| VISTA_6_QF      | 24902 | VSTA     | 66   | 0.08   | 1 | Eastern |                          | QF/Selfgen |
| VISTA_6_QF      | 24902 | VSTA     | 66   | 0.08   | 2 | Eastern |                          | QF/Selfgen |
| NA              | 24242 | RERC1G   | 13.8 | 48.00  | 1 | Eastern | No NQC - Pmax            | Market     |
| NA              | 24243 | RERC2G   | 13.8 | 48.00  | 1 | Eastern | No NQC - Pmax            | Market     |
| NA              | 24244 | SPRINGEN | 13.8 | 44.00  | 1 | Eastern | No NQC - Pmax            | Market     |
| NA              | 28041 | TOT037C1 | 19.5 | 405.00 | 1 | Eastern | No NQC - Pmax            | Market     |
| NA              | 28042 | TOT037C2 | 19.5 | 405.00 | 2 | Eastern | No NQC - Pmax            | Market     |
| ALAMIT_7_UNIT 1 | 24001 | ALAMT1 G | 18   | 174.56 | 1 | Western |                          | Market     |
| ALAMIT_7_UNIT 2 | 24002 | ALAMT2 G | 18   | 175.00 | 2 | Western |                          | Market     |
| ALAMIT_7_UNIT 3 | 24003 | ALAMT3 G | 18   | 332.18 | 3 | Western |                          | Market     |
| ALAMIT_7_UNIT 4 | 24004 | ALAMT4 G | 18   | 335.67 | 4 | Western |                          | Market     |
| ALAMIT_7_UNIT 5 | 24005 | ALAMT5 G | 20   | 497.97 | 5 | Western |                          | Market     |
| ALAMIT_7_UNIT 6 | 24161 | ALAMT6 G | 20   | 495.00 | 6 | Western |                          | Market     |
| ANAHM_7_CT      | 25203 | ANAHEIMG | 13.8 | 46.00  | 1 | Western |                          | MUNI       |

|                  |       |          |      |          |    |                |                          |            |
|------------------|-------|----------|------|----------|----|----------------|--------------------------|------------|
| ARCOGN_2_UNITS   | 24018 | BRIGEN   | 13.8 | 35.00    | 1  | Western, Barre | No NQC - historical data | Market     |
| ARCOGN_2_UNITS   | 24011 | ARCO 1G  | 13.8 | 62.63    | 1  | Western, Barre |                          | QF/Selfgen |
| ARCOGN_2_UNITS   | 24012 | ARCO 2G  | 13.8 | 62.63    | 2  | Western, Barre |                          | QF/Selfgen |
| ARCOGN_2_UNITS   | 24013 | ARCO 3G  | 13.8 | 62.63    | 3  | Western, Barre |                          | QF/Selfgen |
| ARCOGN_2_UNITS   | 24014 | ARCO 4G  | 13.8 | 62.63    | 4  | Western, Barre |                          | QF/Selfgen |
| ARCOGN_2_UNITS   | 24163 | ARCO 5G  | 13.8 | 31.31    | 5  | Western, Barre |                          | QF/Selfgen |
| ARCOGN_2_UNITS   | 24164 | ARCO 6G  | 13.8 | 31.31    | 6  | Western, Barre |                          | QF/Selfgen |
| BRDWAY_7_UNIT 3  | 28007 | BRODWYSC | 13.8 | 65.00    | 1  | Western, Barre |                          | MUNI       |
| CENTER_2_QF      | 24203 | CENTER S | 66   | 25.27    | 1  | Western        |                          | QF/Selfgen |
| CHEVMN_2_UNITS   | 24022 | CHEVGEN1 | 13.8 | 0.91     | 1  | Western, Barre |                          | QF/Selfgen |
| CHEVMN_2_UNITS   | 24023 | CHEVGEN2 | 13.8 | 0.92     | 2  | Western, Barre |                          | QF/Selfgen |
| CHINO_6_CIMGEN   | 24026 | CIMGEN   | 13.8 | 25.65    | 1  | Western        |                          | QF/Selfgen |
| ELLIS_2_QF       | 24197 | ELLIS    | 66   | 0.13     | 1  | Western        |                          | QF/Selfgen |
| ELSEGN_7_UNIT 3  | 24047 | ELSEG3 G | 18   | 335.00   | 3  | Western, Barre |                          | Market     |
| ELSEGN_7_UNIT 4  | 24048 | ELSEG4 G | 18   | 335.00   | 4  | Western, Barre |                          | Market     |
| GLNARM_7_UNIT 1  | 28005 | PASADNA1 | 13.8 | 22.30    | 1  | Western, Barre |                          | MUNI       |
| GLNARM_7_UNIT 2  | 28006 | PASADNA2 | 13.8 | 22.30    | 1  | Western, Barre |                          | MUNI       |
| GLNARM_7_UNIT 3  | 28005 | PASADNA1 | 13.8 | 44.83    | 1  | Western, Barre |                          | MUNI       |
| GLNARM_7_UNIT 4  | 28006 | PASADNA2 | 13.8 | 42.42    | 1  | Western, Barre |                          | MUNI       |
| HARBGN_7_UNITS   | 24062 | HARBOR G | 13.8 | 76.27    | 1  | Western, Barre |                          | Market     |
| HARBGN_7_UNITS   | 24062 | HARBOR G | 13.8 | 11.86    | 2  | Western, Barre |                          | Market     |
| HARBGN_7_UNITS   | 25510 | HARBORG4 | 4.16 | 11.86    | 3  | Western, Barre |                          | Market     |
| HINSON_6_CARBGN  | 24020 | CARBOGEN | 13.8 | 29.00    | 1  | Western, Barre |                          | Market     |
| HINSON_6_QF      | 24064 | HINSON   | 66   | 0.00     | 1  | Western, Barre | No NQC - historical data | QF/Selfgen |
| HINSON_6_SERRGN  | 24139 | SERRFGEN | 13.8 | 25.90    | 1  | Western, Barre |                          | QF/Selfgen |
| HNTGBH_7_UNIT 1  | 24066 | HUNT1 G  | 13.8 | 225.80   | 1  | Western, Barre |                          | Market     |
| HNTGBH_7_UNIT 2  | 24067 | HUNT2 G  | 13.8 | 225.80   | 2  | Western, Barre |                          | Market     |
| HNTGBH_7_Unit 3  | 24167 | HUNT3 G  | 13.8 | 225.00   | 3  | Western, Barre |                          | Market     |
| HNTGBH_7_Unit 4  | 24168 | HUNT4 G  | 13.8 | 227.00   | 4  | Western, Barre |                          | Market     |
| LAFRES_6_QF      | 24073 | LA FRESA | 66   | 5.38     | 1  | Western        |                          | QF/Selfgen |
| LAGBEL_6_QF      | 24075 | LAGUBELL | 66   | 10.85    | 1  | Western        |                          | QF/Selfgen |
| LGHTHP_6_ICEGEN  | 24070 | ICEGEN   | 13.8 | 44.67    | 1  | Western, Barre |                          | QF/Selfgen |
| LGHTHP_6_QF      | 24083 | LITEHIPE | 66   | 0.43     | 1  | Western        |                          | QF/Selfgen |
| MESAS_2_QF       | 24209 | MESA CAL | 66   | 1.47     | 1  | Western        |                          | QF/Selfgen |
| MOBGEN_6_UNIT 1  | 24094 | MOBGEN   | 13.8 | 45.00    | 1  | Western, Barre | No NQC - historical data | QF/Selfgen |
| NA               | 24027 | COLDGEN  | 13.8 | 0.00     | 1  | Western, Barre | No NQC - historical data | Market     |
| NA               | 24028 | DELAMO   | 66   | 0.00     | 1  | Western        |                          | QF/Selfgen |
| NA               | 24060 | GROWGEN  | 13.8 | 0.00     | 1  | Western, Barre | No NQC - historical data | Market     |
| NA               | 24208 | LCIENEGA | 66   | 0.00     | 1  | Western        |                          | QF/Selfgen |
| OLINDA_2_QF      | 24211 | OLINDA   | 66   | 4.75     | 1  | Western        |                          | QF/Selfgen |
| PULPGN_6_UNIT    | 24120 | PULPGEN  | 13.8 | 35.00    | 1  | Western, Barre | No NQC - historical data | Market     |
| REDOND_7_UNIT 5  | 24121 | REDON5 G | 18   | 178.87   | 5  | Western, Barre |                          | Market     |
| REDOND_7_UNIT 6  | 24122 | REDON6 G | 18   | 175.00   | 6  | Western, Barre |                          | Market     |
| REDOND_7_UNIT 7  | 24123 | REDON7 G | 20   | 493.24   | 7  | Western, Barre |                          | Market     |
| REDOND_7_UNIT 8  | 24124 | REDON8 G | 20   | 495.90   | 8  | Western, Barre |                          | Market     |
| RHONDO_2_QF      | 24213 | RIOHONDO | 66   | 1.50     | 1  | Western        |                          | QF/Selfgen |
| SANTGO_6_COYOTE  | 24133 | SANTIAGO | 66   | 9.99     | 1  | Western, Barre |                          | Market     |
| SONGS_7_UNIT 2   | 24129 | S.ONOFR2 | 22   | 1,122.00 | 2  | Western        |                          | Nuclear    |
| SONGS_7_UNIT 3   | 24130 | S.ONOFR3 | 22   | 1,124.00 | 3  | Western        |                          | Nuclear    |
| WALNUT_6_HILLGEN | 24063 | HILLGEN  | 13.8 | 46.97    | 1  | Western        |                          | QF/Selfgen |
| WALNUT_6_QF      | 24157 | WALNUT   | 66   | 7.49     | 1  | Western        |                          | QF/Selfgen |
| NA               | 24239 | MALBRG1G | 13.8 | 43.00    | C1 | Western, Barre | No NQC - Pmax            | Market     |
| NA               | 24240 | MALBRG2G | 13.8 | 43.00    | C2 | Western, Barre | No NQC - Pmax            | Market     |
| NA               | 24241 | MALBRG3G | 13.8 | 50.00    | S3 | Western, Barre | No NQC - Pmax            | Market     |
| NA               | 24078 | LBEACH1G | 13.8 | 63.00    | 1  | Western, Barre | No NQC - Pmax            | Market     |

|    |       |          |      |       |   |                |               |        |
|----|-------|----------|------|-------|---|----------------|---------------|--------|
| NA | 24170 | LBEACH2G | 13.8 | 56.50 | 2 | Western, Barre | No NQC - Pmax | Market |
| NA | 24171 | LBEACH3G | 13.8 | 56.50 | 3 | Western, Barre | No NQC - Pmax | Market |
| NA | 24172 | LBEACH4G | 13.8 | 56.50 | 4 | Western, Barre | No NQC - Pmax | Market |
| NA | 24173 | LBEACH5G | 13.8 | 56.50 | 5 | Western, Barre | No NQC - Pmax | Market |
| NA | 24174 | LBEACH6G | 13.8 | 56.50 | 6 | Western, Barre | No NQC - Pmax | Market |
| NA | 24079 | LBEACH7G | 13.8 | 63.00 | 7 | Western, Barre | No NQC - Pmax | Market |
| NA | 24080 | LBEACH8G | 13.8 | 82.50 | 8 | Western, Barre | No NQC - Pmax | Market |
| NA | 24081 | LBEACH9G | 13.8 | 63.00 | 9 | Western, Barre | No NQC - Pmax | Market |

Units in yellow can not be found on the base case provided by SCE.

### **Critical Contingency Analysis Summary**

#### **LA Basin Overall:**

The most critical contingency for LA Basin is the loss of one Songs unit followed by Paloverde-Devers 500 kV line, which could exceed the approved 6100 MW rating for the South of Lugo path. This limiting contingency establishes a Local Capacity Requirement Need of 10,500-130 MW in 2008 (includes 780 MW of QF, 11 MW of Wind, 508 MW of Muni and 2246 MW of Nuclear generation) as the minimum generation capacity necessary for reliable load serving capability within this area. The extra 370 MW reduction versus the March 9 report was achieved by generation redispatch after the reduction in series compensation for the El Dorado-Lugo 500 kV line from 70% to 35% and also the insertion of the series capacitors on the Imperial Valley-Miguel 500 kV line both available as part of the system readjustment between the two contingencies.

#### **Effectiveness factors:**

The following table has units that have at least 5% effectiveness to the above-mentioned South of Lugo constraint within the LA Basin area:

| Gen Bus | Gen Name | Gen ID | MW Eff. Fctr. (%) |
|---------|----------|--------|-------------------|
| 24052   | MTNVIST3 | 3      | 21                |
| 24053   | MTNVIST4 | 4      | 21                |
| 28041   | TOT037C1 | 1      | 21                |
| 28042   | TOT037C2 | 2      | 21                |
| 24905   | RVCANAL1 | 1      | 20                |
| 24906   | RVCANAL2 | 2      | 20                |
| 24907   | RVCANAL3 | 3      | 20                |
| 24908   | RVCANAL4 | 4      | 20                |



|       |          |    |    |
|-------|----------|----|----|
| 24071 | INLAND   | 1  | 20 |
| 25422 | ETI MWDG | 1  | 20 |
| 24921 | MNTV-CT1 | 1  | 20 |
| 24922 | MNTV-CT2 | 1  | 20 |
| 24923 | MNTV-ST1 | 1  | 20 |
| 24924 | MNTV-CT3 | 1  | 20 |
| 24925 | MNTV-CT4 | 1  | 20 |
| 24926 | MNTV-ST2 | 1  | 20 |
| 25632 | TERAWND  | QF | 20 |
| 28021 | WINTEC6  | 1  | 20 |
| 25634 | BUCKWND  | QF | 20 |
| 25635 | ALTWIND  | Q1 | 20 |
| 25635 | ALTWIND  | Q2 | 20 |
| 25637 | TRANWND  | QF | 20 |
| 25639 | SEAWIND  | QF | 20 |
| 25640 | PANAERO  | QF | 20 |
| 25645 | VENWIND  | EU | 20 |
| 25645 | VENWIND  | Q2 | 20 |
| 25645 | VENWIND  | Q1 | 20 |
| 25646 | SANWIND  | Q2 | 20 |
| 24815 | GARNET   | QF | 20 |
| 24815 | GARNET   | W3 | 20 |
| 24815 | GARNET   | W2 | 20 |
| 28023 | WINTEC4  | 1  | 20 |
| 28060 | SEAWEST  | S1 | 20 |
| 28060 | SEAWEST  | S3 | 20 |
| 28060 | SEAWEST  | S2 | 20 |
| 28061 | WHITEWTR | 1  | 20 |
| 28260 | ALTAMSA4 | 1  | 20 |
| 28280 | CABAZON  | 1  | 20 |
| 24242 | RERC1G   | 1  | 20 |
| 24243 | RERC2G   | 1  | 20 |
| 24244 | SPRINGEN | 1  | 20 |
| 24026 | CIMGEN   | 1  | 19 |
| 24030 | DELGEN   | 1  | 19 |
| 25648 | DVLCYN1G | 1  | 19 |
| 25649 | DVLCYN2G | 2  | 19 |
| 25603 | DVLCYN3G | 3  | 19 |
| 25604 | DVLCYN4G | 4  | 19 |
| 24140 | SIMPSON  | 1  | 19 |
| 25633 | CAPWIND  | QF | 19 |
| 28190 | WINTECX2 | 1  | 19 |
| 28191 | WINTECX1 | 1  | 19 |
| 28180 | WINTEC8  | 1  | 19 |
| 25203 | ANAHEIMG | 1  | 18 |
| 24066 | HUNT1 G  | 1  | 15 |
| 24067 | HUNT2 G  | 2  | 15 |
| 24167 | HUNT3 G  | 3  | 15 |
| 24168 | HUNT4 G  | 4  | 15 |
| 24129 | S.ONOFR2 | 2  | 15 |

|       |          |    |    |
|-------|----------|----|----|
| 24130 | S.ONOFR3 | 3  | 15 |
| 24133 | SANTIAGO | 1  | 15 |
| 24001 | ALAMT1 G | 1  | 14 |
| 24002 | ALAMT2 G | 2  | 14 |
| 24003 | ALAMT3 G | 3  | 14 |
| 24004 | ALAMT4 G | 4  | 14 |
| 24005 | ALAMT5 G | 5  | 14 |
| 24161 | ALAMT6 G | 6  | 14 |
| 24162 | ALAMT7 G | 7  | 14 |
| 24063 | HILLGEN  | 1  | 14 |
| 24018 | BRIGEN   | 1  | 12 |
| 24011 | ARCO 1G  | 1  | 11 |
| 24012 | ARCO 2G  | 2  | 11 |
| 24013 | ARCO 3G  | 3  | 11 |
| 24014 | ARCO 4G  | 4  | 11 |
| 24163 | ARCO 5G  | 5  | 11 |
| 24164 | ARCO 6G  | 6  | 11 |
| 24020 | CARBOGEN | 1  | 11 |
| 24064 | HINSON   | 1  | 11 |
| 24070 | ICEGEN   | 1  | 11 |
| 24078 | LBEACH1G | 1  | 11 |
| 24170 | LBEACH2G | 2  | 11 |
| 24171 | LBEACH3G | 3  | 11 |
| 24172 | LBEACH4G | 4  | 11 |
| 24173 | LBEACH5G | 5  | 11 |
| 24174 | LBEACH6G | 6  | 11 |
| 24079 | LBEACH7G | 7  | 11 |
| 24080 | LBEACH8G | 8  | 11 |
| 24081 | LBEACH9G | 9  | 11 |
| 24139 | SERRFGEN | 1  | 11 |
| 24062 | HARBOR G | 1  | 11 |
| 25510 | HARBORG4 | LP | 11 |
| 24062 | HARBOR G | HP | 11 |
| 24022 | CHEVGEN1 | 1  | 10 |
| 24023 | CHEVGEN2 | 2  | 10 |
| 24047 | ELSEG3 G | 3  | 10 |
| 24048 | ELSEG4 G | 4  | 10 |
| 24094 | MOBGEN   | 1  | 10 |
| 24121 | REDON5 G | 5  | 10 |
| 24122 | REDON6 G | 6  | 10 |
| 24123 | REDON7 G | 7  | 10 |
| 24124 | REDON8 G | 8  | 10 |
| 24241 | MALBRG3G | S3 | 9  |
| 24240 | MALBRG2G | C2 | 9  |
| 24239 | MALBRG1G | C1 | 9  |
| 24027 | COLDGEN  | 1  | 9  |
| 24060 | GROWGEN  | 1  | 9  |
| 24120 | PULPGEN  | 1  | 9  |
| 28005 | PASADNA1 | 1  | 7  |
| 28006 | PASADNA2 | 1  | 7  |

**Barre Sub-Area:**

The most critical contingency for Barre sub-area within the LA Basin is the loss of the one of Huntington units followed by double line outage of Songs-Santiago 230kV lines, which ~~would thermally overload the Ellis-Barre 230kV line~~ could result in voltage collapse. This limiting contingency establishes a ~~local~~ Local eCapacity requirement Need of 3,229-100 MW (including 431 MW of QF and 197 MW of Muni generation) in 2008.

Also another critical contingency for the Barre sub-area is the double line outage of Songs-Santiago 230kV lines, which could thermally overload the Ellis-Barre 230 kV line.

**Effectiveness factors:**

The following table has units that have at least 5% effectiveness to the above-mentioned thermal constraint:

| Gen Bus | Gen Name | Gen ID | MW Eff. Fctr. (%) |
|---------|----------|--------|-------------------|
| 24066   | HUNT1 G  | 1      | 63                |
| 24067   | HUNT2 G  | 2      | 63                |
| 24167   | HUNT3 G  | 3      | 63                |
| 24168   | HUNT4 G  | 4      | 63                |
| 24133   | SANTIAGO | 1      | 63                |
| 24018   | BRIGEN   | 1      | 17                |
| 24241   | MALBRG3G | S3     | 10                |
| 24240   | MALBRG2G | C2     | 10                |
| 24239   | MALBRG1G | C1     | 10                |
| 24027   | COLDGEN  | 1      | 10                |
| 24060   | GROWGEN  | 1      | 10                |
| 24120   | PULPGEN  | 1      | 10                |
| 24020   | CARBOGEN | 1      | 9                 |
| 24064   | HINSON   | 1      | 9                 |
| 24078   | LBEACH1G | 1      | 9                 |
| 24170   | LBEACH2G | 2      | 9                 |
| 24171   | LBEACH3G | 3      | 9                 |
| 24172   | LBEACH4G | 4      | 9                 |
| 24080   | LBEACH8G | 8      | 9                 |
| 24081   | LBEACH9G | 9      | 9                 |
| 24139   | SERRFGEN | 1      | 9                 |
| 24011   | ARCO 1G  | 1      | 8                 |
| 24012   | ARCO 2G  | 2      | 8                 |
| 24013   | ARCO 3G  | 3      | 8                 |
| 24014   | ARCO 4G  | 4      | 8                 |
| 24163   | ARCO 5G  | 5      | 8                 |

|       |          |    |   |
|-------|----------|----|---|
| 24164 | ARCO 6G  | 6  | 8 |
| 24022 | CHEVGEN1 | 1  | 8 |
| 24023 | CHEVGEN2 | 2  | 8 |
| 24173 | LBEACH5G | 5  | 8 |
| 24174 | LBEACH6G | 6  | 8 |
| 24079 | LBEACH7G | 7  | 8 |
| 24094 | MOBGEN   | 1  | 8 |
| 24062 | HARBOR G | 1  | 8 |
| 25510 | HARBORG4 | LP | 8 |
| 24062 | HARBOR G | HP | 8 |
| 28005 | PASADNA1 | 1  | 8 |
| 28006 | PASADNA2 | 1  | 8 |
| 28007 | BRODWYSC | 1  | 8 |
| 24047 | ELSEG3 G | 3  | 7 |
| 24048 | ELSEG4 G | 4  | 7 |
| 24121 | REDON5 G | 5  | 7 |
| 24122 | REDON6 G | 6  | 7 |
| 24123 | REDON7 G | 7  | 7 |
| 24124 | REDON8 G | 8  | 7 |
| 24070 | ICEGEN   | 1  | 5 |

**LA Basin Available Capacity:**

| <b>2008</b>          | QF/Wind<br>(MW) | Muni<br>(MW) | Nuclear<br>(MW) | Market<br>(MW) | Max. Qualifying<br>Capacity (MW) |
|----------------------|-----------------|--------------|-----------------|----------------|----------------------------------|
| Available generation | 791             | 508          | 2246            | 8548           | 12093                            |

| <b>2008</b>                         | Existing Generation<br>Capacity Needed (MW) | Deficiency<br>(MW) | Total MW<br>Needed |
|-------------------------------------|---|--------------------|--------------------|
| Category B (Single) <sup>22</sup>   | 10,500130                                   | 0                  | 10,500130          |
| Category C (Multiple) <sup>23</sup> | 10,500130                                   | 0                  | 10,500130          |

**LA Basin & North of Lugo Overall Requirements:**

Total units and base case Pmax for units in the North of Lugo sub-area:

| BUS-NO | NAME     | ID | Pmax | Sub-area      |
|--------|----------|----|------|---------------|
| 28000  | HIDEDST1 | 1  | 300  | North of Lugo |
| 28001  | HIDEDCT3 | 1  | 170  | North of Lugo |
| 28002  | HIDEDCT2 | 1  | 170  | North of Lugo |

<sup>22</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>23</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

|       |                   |    |             |               |
|-------|-------------------|----|-------------|---------------|
| 28003 | HIDEDCT1          | 1  | 170         | North of Lugo |
| 24703 | BLM E7G           | 7  | 20          | North of Lugo |
| 24704 | BLM E8G           | 8  | 20          | North of Lugo |
| 24705 | BLM W9G           | 9  | 20          | North of Lugo |
| 24708 | BORAX I           | 1  | 47          | North of Lugo |
| 24709 | BSPHYD26          | 26 | 13          | North of Lugo |
| 24710 | BSPHYD34          | 34 | 15          | North of Lugo |
| 24711 | CALGEN1G          | 1  | 30          | North of Lugo |
| 24712 | CALGEN2G          | 2  | 25          | North of Lugo |
| 24713 | CALGEN3G          | 3  | 25          | North of Lugo |
| 24714 | ALTA 1G           | 1  | 60          | North of Lugo |
| 24715 | ALTA 2G           | 2  | 80          | North of Lugo |
| 24718 | ALTA31GT          | 31 | 65          | North of Lugo |
| 24719 | ALTA 3ST          | 3  | 105         | North of Lugo |
| 24720 | ALTA41GT          | 41 | 65          | North of Lugo |
| 24721 | ALTA 4ST          | 4  | 105         | North of Lugo |
| 24726 | CSA DIAB          | 1  | 30          | North of Lugo |
| 24732 | KERRGEN           | 1  | 3           | North of Lugo |
| 24733 | KERRMGEE          | 1  | 55          | North of Lugo |
| 24734 | ALTA32GT          | 32 | 65          | North of Lugo |
| 24735 | ALTA42GT          | 42 | 65          | North of Lugo |
| 24737 | LUZ8 G            | 8  | 80          | North of Lugo |
| 24738 | LUZ9 G            | 9  | 80          | North of Lugo |
| 24740 | MC GEN            | 1  | 105         | North of Lugo |
| 24742 | MOGEN G           | 1  | 60          | North of Lugo |
| 24744 | NAVYII4G          | 4  | 25          | North of Lugo |
| 24745 | NAVYII5G          | 5  | 25          | North of Lugo |
| 24746 | NAVYII6G          | 6  | 25          | North of Lugo |
| 24747 | OXBOW G1          | 1  | 50          | North of Lugo |
| 24751 | SEGS 1G           | 1  | 20          | North of Lugo |
| 24752 | SEGS 2G           | 2  | 30          | North of Lugo |
| 24754 | SUNGEN3G          | 3  | 34          | North of Lugo |
| 24755 | SUNGEN4G          | 4  | 34          | North of Lugo |
| 24756 | SUNGEN5G          | 5  | 34          | North of Lugo |
| 24757 | SUNGEN6G          | 6  | 35          | North of Lugo |
| 24758 | SUNGEN7G          | 7  | 35          | North of Lugo |
| 24783 | RUSH              | 1  | 30          | North of Lugo |
| 24784 | POOLUWD           | 1  | 30          | North of Lugo |
|       | <b>Total 2008</b> |    | <b>2455</b> |               |

### **Critical Contingency Analysis Summary**

#### ***LA Basin & North of Lugo overall:***

The most critical contingency within the LA Basin & North of Lugo area is the loss of the Paloverde-Devers 500 kV line followed by the loss of the Eldorado-Lugo 500kV line,

which could thermally overload the Victorville-Lugo 500 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 11,750 MW combines capacity in the LA Basin & North of Lugo in 2008 as the minimum generation capacity necessary for reliable load serving capability within this combined area.

The most critical single contingency within the LA Basin & North of Lugo is the loss of the Eldorado-Lugo 500kV line, followed by the loss of Songs unit #3, which could thermally overload the Victorville-Lugo 500 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 10,330 MW combines capacity in the LA Basin & North of Lugo in 2008.

### **Effectiveness factors:**

The following table has units that have at least 5% effectiveness to the above-mentioned Victorville-Lugo constraint within the LA Basin & North of Lugo area:

| Gen Bus | Gen Name | Gen ID | MW Eff. Fctr. (%) |
|---------|----------|--------|-------------------|
| 28000   | HIDEDST1 | 1      | 31                |
| 28001   | HIDEDCT3 | 1      | 31                |
| 28002   | HIDEDCT2 | 1      | 31                |
| 28003   | HIDEDCT1 | 1      | 31                |
| 24737   | LUZ8 G   | 8      | 30                |
| 24738   | LUZ9 G   | 9      | 30                |
| 24721   | ALTA 4ST | 4      | 30                |
| 24703   | BLM E7G  | 7      | 29                |
| 24704   | BLM E8G  | 8      | 29                |
| 24705   | BLM W9G  | 9      | 29                |
| 24708   | BORAX I  | 1      | 29                |
| 24742   | MOGEN G  | 1      | 29                |
| 24744   | NAVYII4G | 4      | 29                |
| 24745   | NAVYII5G | 5      | 29                |
| 24746   | NAVYII6G | 6      | 29                |
| 24718   | ALTA31GT | 31     | 29                |
| 24734   | ALTA32GT | 32     | 29                |
| 24719   | ALTA 3ST | 3      | 29                |
| 24720   | ALTA41GT | 41     | 29                |
| 24735   | ALTA42GT | 42     | 29                |
| 24754   | SUNGEN3G | 3      | 28                |
| 24755   | SUNGEN4G | 4      | 28                |
| 24756   | SUNGEN5G | 5      | 28                |
| 24757   | SUNGEN6G | 6      | 28                |
| 24758   | SUNGEN7G | 7      | 28                |
| 24714   | ALTA 1G  | 1      | 26                |
| 24715   | ALTA 2G  | 2      | 26                |
| 24751   | SEGS 1G  | 1      | 26                |

|       |          |    |    |
|-------|----------|----|----|
| 24752 | SEGS 2G  | 2  | 26 |
| 28041 | TOT037C1 | 1  | 26 |
| 28042 | TOT037C2 | 2  | 26 |
| 24905 | RVCANAL1 | 1  | 25 |
| 24906 | RVCANAL2 | 2  | 25 |
| 24907 | RVCANAL3 | 3  | 25 |
| 24908 | RVCANAL4 | 4  | 25 |
| 24921 | MNTV-CT1 | 1  | 25 |
| 24922 | MNTV-CT2 | 1  | 25 |
| 24923 | MNTV-ST1 | 1  | 25 |
| 24924 | MNTV-CT3 | 1  | 25 |
| 24925 | MNTV-CT4 | 1  | 25 |
| 24926 | MNTV-ST2 | 1  | 25 |
| 24242 | RERC1G   | 1  | 25 |
| 24243 | RERC2G   | 1  | 25 |
| 24244 | SPRINGEN | 1  | 25 |
| 24026 | CIMGEN   | 1  | 24 |
| 24030 | DELGEN   | 1  | 24 |
| 25648 | DVLCYN1G | 1  | 24 |
| 25649 | DVLCYN2G | 2  | 24 |
| 25603 | DVLCYN3G | 3  | 24 |
| 25604 | DVLCYN4G | 4  | 24 |
| 24052 | MTNVIST3 | 3  | 24 |
| 24053 | MTNVIST4 | 4  | 24 |
| 24071 | INLAND   | 1  | 24 |
| 24140 | SIMPSON  | 1  | 24 |
| 25422 | ETI MWDG | 1  | 24 |
| 25632 | TERAWND  | QF | 24 |
| 25633 | CAPWIND  | QF | 24 |
| 28021 | WINTEC6  | 1  | 24 |
| 25634 | BUCKWND  | QF | 24 |
| 25635 | ALTWIND  | Q1 | 24 |
| 25635 | ALTWIND  | Q2 | 24 |
| 25637 | TRANWND  | QF | 24 |
| 25639 | SEAWIND  | QF | 24 |
| 25640 | PANAERO  | QF | 24 |
| 25645 | VENWIND  | EU | 24 |
| 25645 | VENWIND  | Q2 | 24 |
| 25645 | VENWIND  | Q1 | 24 |
| 25646 | SANWIND  | Q2 | 24 |
| 28190 | WINTECX2 | 1  | 24 |
| 28191 | WINTECX1 | 1  | 24 |
| 28180 | WINTEC8  | 1  | 24 |
| 24815 | GARNET   | QF | 24 |
| 24815 | GARNET   | W3 | 24 |
| 24815 | GARNET   | W2 | 24 |
| 28023 | WINTEC4  | 1  | 24 |
| 28060 | SEAWEST  | S1 | 24 |
| 28060 | SEAWEST  | S3 | 24 |
| 28060 | SEAWEST  | S2 | 24 |

|       |          |    |    |
|-------|----------|----|----|
| 28061 | WHITEWTR | 1  | 24 |
| 28260 | ALTAMSA4 | 1  | 24 |
| 28280 | CABAZON  | 1  | 24 |
| 25203 | ANAHEIMG | 1  | 23 |
| 24711 | CALGEN1G | 1  | 20 |
| 24712 | CALGEN2G | 2  | 20 |
| 24713 | CALGEN3G | 3  | 20 |
| 24066 | HUNT1 G  | 1  | 19 |
| 24067 | HUNT2 G  | 2  | 19 |
| 24167 | HUNT3 G  | 3  | 19 |
| 24168 | HUNT4 G  | 4  | 19 |
| 24129 | S.ONOFR2 | 2  | 19 |
| 24130 | S.ONOFR3 | 3  | 19 |
| 24133 | SANTIAGO | 1  | 19 |
| 24001 | ALAMT1 G | 1  | 18 |
| 24002 | ALAMT2 G | 2  | 18 |
| 24003 | ALAMT3 G | 3  | 18 |
| 24004 | ALAMT4 G | 4  | 18 |
| 24005 | ALAMT5 G | 5  | 18 |
| 24161 | ALAMT6 G | 6  | 18 |
| 24162 | ALAMT7 G | 7  | 18 |
| 24740 | MC GEN   | 1  | 18 |
| 25618 | PEARBMBP | 5  | 18 |
| 25618 | PEARBMBP | 6  | 18 |
| 25619 | PEARBMCP | 7  | 18 |
| 25619 | PEARBMCP | 8  | 18 |
| 24136 | SEAWEST  | 1  | 18 |
| 24733 | KERRMGEE | 1  | 18 |
| 24063 | HILLGEN  | 1  | 17 |
| 25617 | PEARBMAP | 1  | 17 |
| 25617 | PEARBMAP | 2  | 17 |
| 25620 | PEARBMDP | 9  | 17 |
| 24011 | ARCO 1G  | 1  | 15 |
| 24012 | ARCO 2G  | 2  | 15 |
| 24013 | ARCO 3G  | 3  | 15 |
| 24014 | ARCO 4G  | 4  | 15 |
| 24163 | ARCO 5G  | 5  | 15 |
| 24164 | ARCO 6G  | 6  | 15 |
| 24018 | BRIGEN   | 1  | 15 |
| 24070 | ICEGEN   | 1  | 15 |
| 24173 | LBEACH5G | 5  | 15 |
| 24174 | LBEACH6G | 6  | 15 |
| 24079 | LBEACH7G | 7  | 15 |
| 24062 | HARBOR G | 1  | 15 |
| 25510 | HARBORG4 | LP | 15 |
| 24062 | HARBOR G | HP | 15 |
| 24710 | BSPHYD34 | 34 | 14 |
| 24020 | CARBOGEN | 1  | 14 |
| 24022 | CHEVGEN1 | 1  | 14 |
| 24023 | CHEVGEN2 | 2  | 14 |



|       |          |    |    |
|-------|----------|----|----|
| 24726 | CSA DIAB | 1  | 14 |
| 24047 | ELSEG3 G | 3  | 14 |
| 24048 | ELSEG4 G | 4  | 14 |
| 24064 | HINSON   | 1  | 14 |
| 24078 | LBEACH1G | 1  | 14 |
| 24170 | LBEACH2G | 2  | 14 |
| 24171 | LBEACH3G | 3  | 14 |
| 24172 | LBEACH4G | 4  | 14 |
| 24080 | LBEACH8G | 8  | 14 |
| 24081 | LBEACH9G | 9  | 14 |
| 24094 | MOBGEN   | 1  | 14 |
| 24121 | REDON5 G | 5  | 14 |
| 24122 | REDON6 G | 6  | 14 |
| 24123 | REDON7 G | 7  | 14 |
| 24124 | REDON8 G | 8  | 14 |
| 24139 | SERRFGEN | 1  | 14 |
| 24784 | POOLUWD  | 1  | 13 |
| 24241 | MALBRG3G | S3 | 11 |
| 24240 | MALBRG2G | C2 | 11 |
| 24239 | MALBRG1G | C1 | 11 |
| 24027 | COLDGEN  | 1  | 11 |
| 24060 | GROWGEN  | 1  | 11 |
| 24120 | PULPGEN  | 1  | 11 |

## 9. Big Creek/Ventura Area

### **Area Definition**

The transmission tie lines into the Big Creek/Ventura Area are:

- 1) Vincent-Antelope 230 kV Line
- 2) Mesa-Antelope 230 kV Line
- 3) Sylmar-Pardee #1 230 kV Line
- 4) Sylmar-Pardee #2 230 kV Line
- 5) Eagle Rock-Pardee #1 230 kV Line
- 6) Vincent-Pardee 230 kV Line
- 7) Vincent-Santa Clara 230 kV Line

These sub-stations form the boundary surrounding the Big Creek/Ventura area:

- 1) Vincent is out Antelope is in
- 2) Mesa is out Antelope is in
- 3) Sylmar is out Pardee is in
- 4) Sylmar is out Pardee is in
- 5) Eagle Rock is out Pardee is in
- 6) Vincent is out Pardee is in

7) Vincent is out Santa Clara is in

Total 2008 busload within the defined area is 4,435 MW with 156 MW of losses and 420 MW of pumps resulting in total load + losses + pumps of 4,911 MW.

Total units and qualifying capacity available in the Big Creek/Ventura area:

| MKT/SCHED RESOURCE ID | BUS # | BUS NAME | kV   | NQC    | UNIT ID | LCR SUB-AREA NAME | NQC Comments | CAISO Tag  |
|-----------------------|-------|----------|------|--------|---------|-------------------|--------------|------------|
| ALAMO_6_UNIT          | 25653 | ALAMO SC | 13.8 | 18     | 1       | Big Creek         |              | Market     |
| ANTLPE_2_QF           | 24457 | ARBWIND  | 66   | 21.8   | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 28506 | BREEZE1  | 12   | 4.5    | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 28507 | BREEZE2  | 12   | 8      | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 24460 | DUTCHWND | 66   | 14     | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 24458 | ENCANWND | 66   | 112.9  | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 24459 | FLOWIND  | 66   | 40.8   | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 28501 | MIDWIND  | 12   | 18     | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 24465 | MORWIND  | 66   | 56     | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 28503 | NORTHWND | 12   | 19.4   | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 24491 | OAKWIND  | 66   | 18     | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 28502 | SOUTHWND | 12   | 6.6    | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 28504 | ZONDWND1 | 12   | 13.2   | 1       | Big Creek         |              | Wind       |
| ANTLPE_2_QF           | 28505 | ZONDWND2 | 12   | 12.8   | 1       | Big Creek         |              | Wind       |
| APPGEN_6_UNIT 1       | 24009 | APPGEN1G | 13.8 | 60.5   | 1       | Big Creek         |              | Market     |
| APPGEN_6_UNIT 1       | 24010 | APPGEN2G | 13.8 | 60.5   | 2       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24314 | B CRK 4  | 11.5 | 48.96  | 41      | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24314 | B CRK 4  | 11.5 | 49.15  | 42      | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24315 | B CRK 8  | 13.8 | 23.70  | 81      | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24315 | B CRK 8  | 13.8 | 42.74  | 82      | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24306 | B CRK1-1 | 7.2  | 19.33  | 1       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24306 | B CRK1-1 | 7.2  | 20.98  | 2       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24307 | B CRK1-2 | 13.8 | 20.98  | 3       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24307 | B CRK1-2 | 13.8 | 30.31  | 4       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24308 | B CRK2-1 | 13.8 | 49.35  | 1       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24308 | B CRK2-1 | 13.8 | 50.51  | 2       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24309 | B CRK2-2 | 7.2  | 18.17  | 3       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24309 | B CRK2-2 | 7.2  | 19.14  | 4       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24310 | B CRK2-3 | 7.2  | 16.51  | 5       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24310 | B CRK2-3 | 7.2  | 17.97  | 6       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24311 | B CRK3-1 | 13.8 | 34.00  | 1       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24311 | B CRK3-1 | 13.8 | 34.00  | 2       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24312 | B CRK3-2 | 13.8 | 34.00  | 3       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24312 | B CRK3-2 | 13.8 | 39.83  | 4       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24313 | B CRK3-3 | 13.8 | 37.89  | 5       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24319 | EASTWOOD | 13.8 | 201.09 | 1       | Big Creek         |              | Market     |
| BIGCRK_2_PROJCT       | 24317 | MAMOTH1G | 13.8 | 90.83  | 1       | Big Creek         |              | QF/Selfgen |
| BIGCRK_2_PROJCT       | 24318 | MAMOTH2G | 13.8 | 90.83  | 2       | Big Creek         |              | QF/Selfgen |
| BIGCRK_2_PROJCT       | 24323 | PORTAL   | 4.8  | 9.33   | 1       | Big Creek         |              | Market     |
| GOLETA_6_ELLWOD       | 28004 | ELLWOOD  | 13.8 | 54     | 1       | Big Creek         |              | Market     |
| KERRGN_1_UNIT 1       | 24437 | KERNRVR  | 66   | 23.5   | 1       | Big Creek         |              | Market     |
| LEBECS_2_UNITS        | 28051 | PSTRIAG1 | 18   | 157.6  | G1      | Big Creek         |              | Market     |

|                 |       |          |      |        |    |           |                          |            |
|-----------------|-------|----------|------|--------|----|-----------|--------------------------|------------|
| LEBECS_2_UNITS  | 28052 | PSTRIAG2 | 18   | 157.6  | G2 | Big Creek |                          | Market     |
| LEBECS_2_UNITS  | 28054 | PSTRIAG3 | 18   | 157.6  | G3 | Big Creek |                          | Market     |
| LEBECS_2_UNITS  | 28053 | PSTRIAS1 | 18   | 162.2  | S1 | Big Creek |                          | Market     |
| LEBECS_2_UNITS  | 28055 | PSTRIAS2 | 18   | 78.8   | S2 | Big Creek |                          | Market     |
| MONLTH_6_BOREL  | 24456 | BOREL    | 66   | 9.24   | 1  | Big Creek |                          | QF/Selfgen |
| NA              | 24422 | PALMDALE | 66   | 1      | 1  | Big Creek | No NQC - historical data | Market     |
| OMAR_2_UNITS    | 24102 | OMAR 1G  | 13.8 | 69.44  | 1  | Big Creek |                          | QF/Selfgen |
| OMAR_2_UNITS    | 24103 | OMAR 2G  | 13.8 | 69.44  | 2  | Big Creek |                          | QF/Selfgen |
| OMAR_2_UNITS    | 24104 | OMAR 3G  | 13.8 | 69.44  | 3  | Big Creek |                          | QF/Selfgen |
| OMAR_2_UNITS    | 24105 | OMAR 4G  | 13.8 | 69.44  | 4  | Big Creek |                          | QF/Selfgen |
| PANDOL_6_UNIT 1 | 24113 | PANDOL   | 13.8 | 27.5   | 1  | Big Creek | No NQC - historical data | QF/Selfgen |
| PANDOL_6_UNIT 2 | 24113 | PANDOL   | 13.8 | 22.4   | 2  | Big Creek | No NQC - historical data | QF/Selfgen |
| SNCLRA_6_PROCGN | 24119 | PROCGEN  | 13.8 | 55.62  | 1  | Big Creek | No NQC - historical data | Market     |
| SYCAMR_2_UNITS  | 24143 | SYCCYN1G | 13.8 | 76.5   | 1  | Big Creek |                          | QF/Selfgen |
| SYCAMR_2_UNITS  | 24144 | SYCCYN2G | 13.8 | 76.3   | 2  | Big Creek |                          | QF/Selfgen |
| SYCAMR_2_UNITS  | 24145 | SYCCYN3G | 13.8 | 76.3   | 3  | Big Creek |                          | QF/Selfgen |
| SYCAMR_2_UNITS  | 24146 | SYCCYN4G | 13.8 | 76.3   | 4  | Big Creek |                          | QF/Selfgen |
| TENGEN_6_UNIT_1 | 24148 | TENNGEN1 | 13.8 | 24.2   | 1  | Big Creek | No NQC - historical data | QF/Selfgen |
| TENGEN_6_UNIT_2 | 24149 | TENNGEN2 | 13.8 | 17.5   | 2  | Big Creek | No NQC - historical data | QF/Selfgen |
| VESTAL_6_ULTRGN | 24150 | ULTRAGEN | 13.8 | 34.92  | 1  | Big Creek |                          | QF/Selfgen |
| WARNE_2_UNIT    | 25651 | WARNE1   | 13.8 | 19.5   | 1  | Big Creek |                          | Market     |
| WARNE_2_UNIT    | 25652 | WARNE2   | 13.8 | 19.5   | 1  | Big Creek |                          | Market     |
| NA              | 24436 | GOLDTOWN | 66   | 13     | 1  | Big Creek |                          | Market     |
| NA              | 28008 | LAKEGEN  | 13.8 | 11     | 1  | Big Creek |                          | QF/Selfgen |
| NA              | 24118 | PITCHGEN | 13.8 | 30     | 1  | Big Creek |                          | QF/Selfgen |
| NA              | 24152 | VESTAL   | 66   | 50     | 1  | Big Creek |                          | QF/Selfgen |
| MNDALY_7_UNIT 1 | 24089 | MANDLY1G | 13.8 | 215    | 1  | Ventura   |                          | Market     |
| MNDALY_7_UNIT 2 | 24090 | MANDLY2G | 13.8 | 215.29 | 2  | Ventura   |                          | Market     |
| MNDALY_7_UNIT 3 | 24222 | MANDLY3G | 16   | 130    | 3  | Ventura   |                          | Market     |
| ORMOND_7_UNIT 1 | 24107 | ORMOND1G | 26   | 741.27 | 1  | Ventura   |                          | Market     |
| ORMOND_7_UNIT 2 | 24108 | ORMOND2G | 26   | 775    | 2  | Ventura   |                          | Market     |
| SNCLRA_6_OXGEN  | 24110 | OXGEN    | 13.8 | 48.5   | 1  | Ventura   |                          | QF/Selfgen |
| SNCLRA_6_WILLMT | 24159 | WILLAMET | 13.8 | 27.81  | 1  | Ventura   | No NQC - historical data | QF/Selfgen |
| NA              | 24127 | S.CLARA  | 66   | 49     | 1  | Ventura   |                          | QF/Selfgen |

## **Critical Contingency Analysis Summary**

### **Big Creek/Ventura overall:**

The most critical contingency is the loss of the Lugo-Victorville 500 kV followed by Sylmar-Pardee #1 or #2 230 kV line, which could thermally overload the remaining Sylmar-Pardee #1 or #2 230 kV line. This limiting contingency establishes a Local Capacity **Requirement Need** of 3658 MW in 2008 (includes 1117 MW of QF and 346

MW of Wind generation) as the minimum generation capacity necessary for reliable load serving capability within this area.

The single most critical contingency is the loss of Sylmar-Pardee #1 (or # 2) line followed by Ormond Beach Unit # 1 or #2, which could thermally overload the remaining Sylmar-Pardee #1 or #2 230 kV line. This limiting contingency establishes a Local Capacity Requirement Need of 3562 MW in 2008 (includes 1117 MW of QF and 346 MW of Wind generation).

**Effectiveness factors:**

The following table has units that have at least 5% effectiveness to the above-mentioned constraint within the Big Creek/Ventura area:

| Gen Bus | Gen Name | Gen ID | MW Eff. Fctr. (%) |
|---------|----------|--------|-------------------|
| 24009   | APPGEN1G | 1      | 29                |
| 24010   | APPGEN2G | 2      | 29                |
| 24107   | ORMOND1G | 1      | 29                |
| 24108   | ORMOND2G | 2      | 29                |
| 24118   | PITCHGEN | 1      | 28                |
| 24148   | TENNGEN1 | 1      | 28                |
| 24149   | TENNGEN2 | 2      | 28                |
| 24089   | MANDLY1G | 1      | 27                |
| 24090   | MANDLY2G | 2      | 27                |
| 24110   | OXGEN    | 1      | 27                |
| 24119   | PROCGEN  | 1      | 27                |
| 24159   | WILLAMET | 1      | 27                |
| 25651   | WARNE1   | 1      | 27                |
| 25652   | WARNE2   | 1      | 27                |
| 28004   | ELLWOOD  | 1      | 27                |
| 28051   | PSTRIAG1 | G1     | 26                |
| 25606   | EDMON2AP | 2      | 26                |
| 25607   | EDMON3AP | 3      | 26                |
| 25607   | EDMON3AP | 4      | 26                |
| 25608   | EDMON4AP | 5      | 26                |
| 25608   | EDMON4AP | 6      | 26                |
| 25609   | EDMON5AP | 7      | 26                |
| 25609   | EDMON5AP | 8      | 26                |
| 25610   | EDMON6AP | 9      | 26                |
| 25610   | EDMON6AP | 10     | 26                |
| 25611   | EDMON7AP | 11     | 26                |
| 25611   | EDMON7AP | 12     | 26                |
| 25612   | EDMON8AP | 13     | 26                |
| 25612   | EDMON8AP | 14     | 26                |
| 28054   | PSTRIAG3 | G3     | 25                |
| 25615   | OSO B P  | 7      | 25                |

|       |          |    |    |
|-------|----------|----|----|
| 25615 | OSO B P  | 8  | 25 |
| 24127 | S.CLARA  | 1  | 25 |
| 28055 | PSTRIAS2 | S2 | 24 |
| 28053 | PSTRIAS1 | S1 | 24 |
| 28052 | PSTRIAG2 | G2 | 24 |
| 25605 | EDMON1AP | 1  | 24 |
| 24143 | SYCCYN1G | 1  | 24 |
| 24144 | SYCCYN2G | 2  | 24 |
| 24145 | SYCCYN3G | 3  | 24 |
| 24146 | SYCCYN4G | 4  | 24 |
| 24102 | OMAR 1G  | 1  | 23 |
| 24103 | OMAR 2G  | 2  | 23 |
| 24104 | OMAR 3G  | 3  | 23 |
| 24105 | OMAR 4G  | 4  | 23 |
| 25614 | OSO A P  | 1  | 23 |
| 25614 | OSO A P  | 2  | 23 |
| 25653 | ALAMO SC | 1  | 23 |
| 24222 | MANDLY3G | 3  | 20 |
| 28008 | LAKEGEN  | 1  | 20 |
| 24150 | ULTRAGEN | 1  | 20 |
| 24152 | VESTAL   | 1  | 20 |
| 24319 | EASTWOOD | 1  | 20 |
| 24306 | B CRK1-1 | 1  | 20 |
| 24306 | B CRK1-1 | 2  | 20 |
| 24307 | B CRK1-2 | 3  | 20 |
| 24307 | B CRK1-2 | 4  | 20 |
| 24308 | B CRK2-1 | 1  | 20 |
| 24308 | B CRK2-1 | 2  | 20 |
| 24309 | B CRK2-2 | 3  | 20 |
| 24309 | B CRK2-2 | 4  | 20 |
| 24310 | B CRK2-3 | 5  | 20 |
| 24310 | B CRK2-3 | 6  | 20 |
| 24311 | B CRK3-1 | 1  | 20 |
| 24311 | B CRK3-1 | 2  | 20 |
| 24312 | B CRK3-2 | 3  | 20 |
| 24312 | B CRK3-2 | 4  | 20 |
| 24313 | B CRK3-3 | 5  | 20 |
| 24314 | B CRK 4  | 41 | 20 |
| 24314 | B CRK 4  | 42 | 20 |
| 24315 | B CRK 8  | 81 | 20 |
| 24315 | B CRK 8  | 82 | 20 |
| 24317 | MAMOTH1G | 1  | 20 |
| 24318 | MAMOTH2G | 2  | 20 |
| 24113 | PANDOL   | 1  | 19 |
| 24113 | PANDOL   | 2  | 19 |
| 24437 | KERNRVR  | 1  | 18 |
| 24459 | FLOWIND  | 1  | 14 |
| 24436 | GOLDTOWN | 1  | 14 |
| 28501 | MIDWIND  | 1  | 14 |
| 24457 | ARBWIND  | 1  | 13 |

|       |          |   |    |
|-------|----------|---|----|
| 24456 | BOREL    | 1 | 12 |
| 24458 | ENCANWND | 1 | 12 |
| 24460 | DUTCHWND | 1 | 12 |
| 24465 | MORWIND  | 1 | 12 |
| 28503 | NORTHWND | 1 | 12 |
| 28504 | ZONDWND1 | 1 | 12 |
| 28505 | ZONDWND2 | 1 | 12 |
| 25618 | PEARBMBP | 5 | 6  |
| 25618 | PEARBMBP | 6 | 6  |
| 25619 | PEARBMCP | 7 | 6  |
| 25619 | PEARBMCP | 8 | 6  |
| 25617 | PEARBMAP | 1 | 5  |
| 25617 | PEARBMAP | 2 | 5  |
| 25620 | PEARBMDP | 9 | 5  |
| 24136 | SEAWEST  | 1 | 5  |

**Big Creek Overall Requirements:**

| <b>2008</b>          | QF<br>(MW) | Wind<br>(MW) | Market<br>(MW) | Max. Qualifying<br>Capacity (MW) |
|----------------------|------------|--------------|----------------|----------------------------------|
| Available generation | 1117       | 346          | 3933           | 5396                             |

| <b>2008</b>                         | Existing Generation<br>Capacity Needed (MW) | Deficiency<br>(MW) | Total MW<br>Requirement |
|-------------------------------------|---|--------------------|-------------------------|
| Category B (Single) <sup>24</sup>   | 3562  | 0                  | 3562                    |
| Category C (Multiple) <sup>25</sup> | 3658  | 0                  | 3658                    |

**10. San Diego Area**

**Area Definition**

The transmission tie lines forming a boundary around San Diego include:

- 1) Imperial Valley – Miguel 500 kV Line
- 2) Miguel – Tijuana 230 kV Line
- 3) San Onofre - San Luis Rey #1 230 kV Line
- 4) San Onofre - San Luis Rey #2 230 kV Line
- 5) San Onofre - San Luis Rey #3 230 kV Line
- 6) San Onofre – Talega #1 230 kV Line
- 7) San Onofre – Talega #2 230 kV Line

<sup>24</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>25</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

The substations that delineate the San Diego Area are:

- 1) Imperial Valley is out Miguel is in
- 2) Miguel is in Tijuana is out
- 3) San Onofre is out San Luis Rey is in
- 4) San Onofre is out San Luis Rey is in
- 5) San Onofre is out San Luis Rey is in
- 6) San Onofre is out Talega is in
- 7) San Onofre is out Talega is in

Total 2008 busload within the defined area: 4799 MW with 117 MW of losses resulting in total load + losses of 4916 MW.

Total units and qualifying capacity available in this area:

| <b>MKT/SCHED<br/>RESOURCE ID</b> | <b>BUS #</b> | <b>BUS NAME</b> | <b>KV</b> | <b>NQC</b> | <b>UNIT ID</b> | <b>NQC Comments</b>                  | <b>CAISO Tag</b> |
|----------------------------------|--------------|-----------------|-----------|------------|----------------|--------------------------------------|------------------|
| BORDER_6_UNITA1                  | 22149        | CALPK_BD        | 13.8      | 43.80      | 1              |                                      | Market           |
| CBRILLO_6_PLSTP1                 | 22092        | CABRILLO        | 69        | 3.50       | 1              |                                      | QF/Selfgen       |
| CHILLS_1_SYCLFL                  | 22120        | CARLTNHS        | 138       | 1.00       | 1              |                                      | QF/Selfgen       |
| CHILLS_7_UNITA1                  | 22120        | CARLTNHS        | 138       | 2.50       | 2              |                                      | QF/Selfgen       |
| CPSTNO_7_PRMADS                  | 22112        | CAPISTRANO      | 138       | 4.10       | 1              |                                      | QF/Selfgen       |
| CRSTWD_6_KUMYAY                  | 22915        | KUMEYAAY        | 34.5      | 8.32       | 1              | Monthly NQC - used<br>August for LCR | Wind             |
| DIVSON_6_NSQF                    | 22172        | DIVISION        | 69        | 47.00      | 1              |                                      | QF/Selfgen       |
| EGATE_7_NOCITY                   | 22204        | EASTGATE        | 69        | 1.00       | 1              |                                      | QF/Selfgen       |
| ELCAJN_6_UNITA1                  | 22150        | CALPK_EC        | 13.8      | 42.20      | 1              |                                      | Market           |
| ELCAJN_7_GT1                     | 22212        | ELCAJNGT        | 12.5      | 13.00      | 1              |                                      | Market           |
| ENCINA_7_EA1                     | 22233        | ENCINA 1        | 14.4      | 106.00     | 1              |                                      | Market           |
| ENCINA_7_EA2                     | 22234        | ENCINA 2        | 14.4      | 103.00     | 1              |                                      | Market           |
| ENCINA_7_EA3                     | 22236        | ENCINA 3        | 14.4      | 109.00     | 1              |                                      | Market           |
| ENCINA_7_EA4                     | 22240        | ENCINA 4        | 22        | 299.00     | 1              |                                      | Market           |
| ENCINA_7_EA5                     | 22244        | ENCINA 5        | 24        | 329.00     | 1              |                                      | Market           |
| ENCINA_7_GT1                     | 22248        | ENCINAGT        | 12.5      | 14.00      | 1              |                                      | Market           |
| ESCND0_6_PL1X2                   | 22257        | MMC_ES          | 13.8      | 35.50      | 1              |                                      | Market           |
| ESCND0_6_UNITB1                  | 22153        | CALPK_ES        | 13.8      | 45.50      | 1              |                                      | Market           |
| ESCO_6_GLMQF                     | 22332        | GOALLINE        | 69        | 50.00      | 1              |                                      | QF/Selfgen       |
| KEARNY_7_KY1                     | 22377        | KEARNGT1        | 12.5      | 15.00      | 1              |                                      | Market           |
| KEARNY_7_KY2                     | 22373        | KEARN2AB        | 12.5      | 14.00      | 2              |                                      | Market           |
| KEARNY_7_KY2                     | 22373        | KEARN2AB        | 12.5      | 14.00      | 1              |                                      | Market           |
| KEARNY_7_KY2                     | 22374        | KEARN2CD        | 12.5      | 14.00      | 1              |                                      | Market           |
| KEARNY_7_KY2                     | 22374        | KEARN2CD        | 12.5      | 13.00      | 2              |                                      | Market           |
| KEARNY_7_KY3                     | 22375        | KEARN3AB        | 12.5      | 15.00      | 2              |                                      | Market           |
| KEARNY_7_KY3                     | 22375        | KEARN3AB        | 12.5      | 14.00      | 1              |                                      | Market           |
| KEARNY_7_KY3                     | 22376        | KEARN3CD        | 12.5      | 14.00      | 1              |                                      | Market           |
| KEARNY_7_KY3                     | 22376        | KEARN3CD        | 12.5      | 14.00      | 2              |                                      | Market           |
| KYCORA_7_UNIT 1                  | 22384        | KYOCERA         | 69        | 0.00       | 1              |                                      | QF/Selfgen       |
| LARKSP_6_UNIT 1                  | 22074        | LRKSPBD1        | 13.8      | 46.00      | 1              |                                      | Market           |
| LARKSP_6_UNIT 2                  | 22075        | LRKSPBD2        | 13.8      | 46.00      | 1              |                                      | Market           |
| MRGT_6_MMAREF                    | 22486        | MFE_MR1         | 13.8      | 46.60      | 1              |                                      | Market           |
| MRGT_7_UNITS                     | 22488        | MIRAMRGT        | 12.5      | 17.00      | 1              |                                      | Market           |
| MRGT_7_UNITS                     | 22488        | MIRAMRGT        | 12.5      | 16.00      | 2              |                                      | Market           |
| MSHGTS_6_MMARLF                  | 22448        | MESAHGTS        | 69        | 2.70       | 1              |                                      | QF/Selfgen       |
| NIMTG_6_NIQF                     | 22576        | NOISLMTR        | 69        | 35.10      | 1              |                                      | QF/Selfgen       |
| OTAY_6_PL1X2                     | 22617        | MMC_OY          | 13.8      | 35.50      | 1              |                                      | Market           |
| OTAY_6_UNITB1                    | 22604        | OTAY            | 69        | 2.90       | 1              |                                      | QF/Selfgen       |

|                 |       |          |      |        |   |                          |            |
|-----------------|-------|----------|------|--------|---|--------------------------|------------|
| PALOMR_2_PL1X3  | 22262 | PENCT1   | 18   | 155.42 | 1 |                          | Market     |
| PALOMR_2_PL1X3  | 22263 | PENCT2   | 18   | 155.42 | 1 |                          | Market     |
| PALOMR_2_PL1X3  | 22265 | PENST    | 18   | 230.63 | 1 |                          | Market     |
| PTLOMA_6_NTCCGN | 22660 | POINTLMA | 69   | 2.40   | 2 |                          | QF/Selfgen |
| PTLOMA_6_NTCQF  | 22660 | POINTLMA | 69   | 21.90  | 1 |                          | QF/Selfgen |
| SAMPSN_6_KELCO1 | 22704 | SAMPSON  | 12.5 | 14.10  | 1 |                          | QF/Selfgen |
| SMRCOS_6_UNIT 1 | 22724 | SANMRCOS | 69   | 1.10   | 1 |                          | QF/Selfgen |
| SOBAY_7_GT1     | 22776 | SOUTHBGT | 12.5 | 13.00  | 1 |                          | Market     |
| SOBAY_7_SY1     | 22780 | SOUTHBY1 | 15   | 145.00 | 1 |                          | Market     |
| SOBAY_7_SY2     | 22784 | SOUTHBY2 | 15   | 149.00 | 1 |                          | Market     |
| SOBAY_7_SY3     | 22788 | SOUTHBY3 | 20   | 174.00 | 1 |                          | Market     |
| SOBAY_7_SY4     | 22792 | SOUTHBY4 | 20   | 221.00 | 1 |                          | Market     |
| MSSION_2_QF     | 22532 | MURRAY   | 69   | 0.20   | 1 | No NQC - historical data | QF/Selfgen |
| MSSION_2_QF     | 22680 | R.SNTAFE | 69   | 0.80   | 1 | No NQC - historical data | QF/Selfgen |
| MSSION_2_QF     | 22496 | MISSION  | 69   | 2.10   | 1 |                          | QF/Selfgen |
| MSSION_2_QF     | 22760 | SHADOWR  | 138  | 0.10   | 1 | No NQC - historical data | QF/Selfgen |
| MSSION_2_QF     | 22008 | ASH      | 69   | 0.90   | 1 | No NQC - historical data | QF/Selfgen |
| NA              | 22625 | LKHODG1  | 13.8 | 20.00  | 1 | No NQC - Pmax            | Market     |
| NA              | 22626 | LKHODG2  | 13.8 | 20.00  | 2 | No NQC - Pmax            | Market     |

### **Critical Contingency Analysis Summary**

#### **San Diego overall:**

In 2008 the most limiting contingency in the San Diego area is described by the outage of the 500 kV Southwest Power Link (SWPL) between Imperial Valley and Miguel Substations over-lapping with an outage of the Palomar Combined-Cycle Power plant (541 MW) while staying within the South of San Onofre (WECC Path 44) non-simultaneous import capability rating of 2,500 MW. This limiting contingency establishes a Local Capacity **Requirement Need** of 2957 MW in 2008 (includes 193 MW of QF generation and 8 MW of Wind) as the minimum generation capacity necessary for reliable load serving capability within this area.

#### **Effectiveness factors:**

All units within this area have the same effectiveness factor. Units outside of this area are not effective.

#### **San Diego Overall Requirements:**

|             |    |      |        |                 |
|-------------|----|------|--------|-----------------|
| <b>2008</b> | QF | Wind | Market | Max. Qualifying |
|-------------|----|------|--------|-----------------|



|                      |      |      |      |               |
|----------------------|------|------|------|---------------|
|                      | (MW) | (MW) | (MW) | Capacity (MW) |
| Available generation | 193  | 8    | 2758 | 2959          |

| <b>2008</b>                         | Existing Generation<br>Capacity Needed (MW) | Deficiency<br>(MW) | Total MW<br>Requirement |
|-------------------------------------|---|--------------------|-------------------------|
| Category B (Single) <sup>26</sup>   | 2957  | 0                  | 2957                    |
| Category C (Multiple) <sup>27</sup> | 2957  | 0                  | 2957                    |

---

<sup>26</sup> A single contingency means that the system will be able to survive the loss of a single element, however the operators will not have any means (other than load drop) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.

<sup>27</sup> Multiple contingencies means that the system will be able to survive the loss of a single element, and the operators will have enough generation (other operating procedures) in order to bring the system within a safe operating zone and get prepared for the next contingency as required by MORC.